




# Federal Emergency Management Agency

Washington, D.C. 20472

MAY - 8 1986

MEMORANDUM FOR: Edward L. Jordan  
Director, Division of Emergency Preparedness  
and Engineering Response  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission

FROM:   
Richard W. Krimm  
Assistant Associate Director  
Office of Natural and Technological Hazards Programs

SUBJECT: Wolf Creek Remedial Exercise

Attached is a copy of a memorandum from Federal Emergency Management Agency (FEMA) Region VII on the results of a remedial exercise conducted on April 3, 1986, to evaluate corrective actions taken to resolve a deficiency observed at the November 20, 1985, exercise at the Wolf Creek Generating Station, Coffee County, Kansas. The remedial exercise was held at the Garnett City Reception/Relocation Center to demonstrate revised radiological monitoring procedures. Prior to the exercise, training had been carried out.

Although the performance of the procedures was adequate at the exercise, the procedures are currently undergoing a formal review by the Region VII Regional Assistance Committee. The results of the review will be made available to you as soon as we receive and analyze them.

If you have any questions, please feel free to contact me or Robert S. Wilkerson, Chief, Technological Hazards Division, at 646-2861.

Attachment  
As Stated

8605140041 860508  
PDR ADOCK 05000482  
F PDR

50-482

1E35



# Federal Emergency Management Agency

Region VII 911 Walnut Street Kansas City, Missouri 64106

MAY 5 1986

SL-NT  
D.

MEMORANDUM FOR: *Sam* Samuel Speck, Associate Director  
State & Local Programs & Support Directorate

FROM: *John P. Coleman* John P. Coleman, Acting Regional Director, FEMA-Region VII

SUBJECT: Wolf Creek Generating Station - Remedial Exercise Conducted  
April 3, 1986, at the Garnett City Reception/Relocation  
Center

As a result of the deficiency identified during the November 20, 1985, exercise of the Wolf Creek Generating Station, a remedial exercise was conducted April 3, 1986, at the Garnett City Reception/Relocation Center. Corrective actions consisted of preparing detailed procedures for monitoring and decontamination, providing training in monitoring concepts and procedures, and having prospective monitors demonstrate their response capabilities.

These requirements were adequately completed. Written procedures for monitoring and decontamination were provided. Monitors received appropriate training in both monitoring and decontamination concepts. Subsequently, these functions and procedures were adequately demonstrated. Two teams were utilized; each monitoring three individuals. Procedures for disposition of contaminated articles were also demonstrated. Decontamination of evacuees, equipment and vehicles was not actually demonstrated. However, the procedures for performing this function were thoroughly discussed.

The written procedures for monitoring and decontamination, provided at the exercise, will be reviewed by the appropriate Regional Assistance Committee (RAC) member for appropriateness. This deficiency will be closed when this review is completed and the written procedures are determined to be adequate. RAC comments are due in this office May 15, 1986.

If you have any questions, please contact Richard Leonard at FTS-758-2161.

SL-5-34