

OPERATING DATA REPORT
Report Number: 173

DOCKET NO.: 50-482
UNIT NAME: Wolf Creek Generating Station
DATE: August 2, 1999
COMPLETED BY: K. A. Harris
TELEPHONE: 316-364-4038

REPORT MONTH: July, 1999

| | | |
|----|--|------|
| 1. | Design Electrical Rating (MWe - Net): | 1170 |
| 2. | Maximum Dependable Capacity (MWe - Net): | 1170 |

| | This Month | YTD | Cumulative | |
|----|---------------------------------------|---------|------------|-------------|
| 3. | Number of Hours Reactor Critical: | 744.0 | 4,233.4 | 102,088.5 |
| 4. | Number of Hours Generator On-Line: | 744.0 | 4,199.3 | 101,074.3 |
| 5. | Unit Reserve Shutdown Hcurs: | 0.0 | 0.0 | 339.8 |
| 6. | Net Electrical Energy Generated (MWH) | 873,677 | 4,869,113 | 113,342,005 |

UNIT SHUTDOWN AND POWER REDUCTIONS

DOCKET NO.: 50-482
 UNIT NAME: Wolf Creek Generating Station
 DATE: August 2, 1999
 COMPLETED BY: K. A. Harris
 TELEPHONE: 316-364-4038

| No | Date | Type F: FORCED S: SCHEDULED | DURATION (Hours) | REASON (1) | METHOD OF SHUTTING DOWN THE REACTOR (2) | CORRECTIVE ACTIONS/COMMENTS |
|-----|------|-----------------------------------|---------------------|---------------|---|-----------------------------|
| N/A | N/A | N/A | N/A | N/A | N/A | N/A |

SUMMARY: The unit operated at or near 100% power, Mode 1, from July 1 through July 31, 1999.

- 1) REASON: A: EQUIPMENT FAILURE (EXPLAIN) E: OPERATOR TRAINING AND LICENSE EXAMINATION (2) METHOD: 1. MANUAL
 B: MAINTENANCE OR TEST F: ADMINISTRATIVE 2. MANUAL SCRAM
 C: REFUELING G: OPERATIONAL ERROR (EXPLAIN) 3. AUTOMATIC SCRAM
 D: REGULATORY RESTRICTION H: OTHER (EXPLAIN) 4. CONTINUATION
 5. OTHER