

- 2 -


According to the licensee, the argon tanks were among a shipment of 12 tanks received from a supplier and specified as containing hydrogen. The argon tanks were identical in appearance and fittings to the rest of the tanks, although a small label correctly identified the contents as argon.


The licensee is investigating the source of the leakage from the waste gas treatment system and reviewing the procedures for hydrogen use to preclude a recurrence of this event.


There was local news media interest in the event.

The State of Wisconsin was informed of the Unusual Event classification.

Region III (Chicago) was notified of this event 6:30 p.m. (CDT), September 26, 1986, by the Headquarters Duty Officer. This information is current as of 9 a.m. (CDT), September 29, 1986.

CONTACT: 
I. N. Jackiw
FTS 388-5697


M. Schumacher
FTS 388-5514


W. G. Guldmond
FTS 388-5574