

SAFEGUARDS INFORMATION

U. S. NUCLEAR REGULATORY COMMISSION

REGION II

Docket No: 50-302
License No: DPR-72

Report No: 50-302/97-10

Licensee: Florida Power Corporation

Facility: Crystal River Nuclear Station Unit 3

Location: 15760 West Power Line Street
Crystal River, FL 34428-6708

Dates: August 4-6, 1997

Inspector: L. Stratton, Safeguards Inspector

Approved by: Caudle A. Julian, Acting Chief
Special Inspection Branch
Division of Reactor Safety

Document transmitted herewith
contains sensitive unclassified
information. When separated from
enclosure(s) this document is decontrolled.

SAFEGUARDS INFORMATION

9709040187 970827
PDR ADOCK 05000302
G PDR

SAFEGUARDS INFORMATION

EXECUTIVE SUMMARY

Crystal River Unit 3
NRC Inspection Report 50-302/97-10

This routine, announced inspection was conducted in the area of plant support by a regional safeguards inspector and selected personnel from the Office of Nuclear Reactor Regulation. The specific area evaluated was the Physical Security Program for Power Reactors.

- Licensee access control equipment was satisfactory and met the requirements specified in the Physical Security Plan.
- The licensee's intrusion detection system/capability had minor deficiencies with respect to two zones. An Inspector Followup Item was opened to further review the system during future inspections.
- A violation was identified in that deficiencies in the licensee's assessment capability of the protected area were noted.
- Questionable licensee response capabilities were noted. An Operational Safeguards Review Evaluation is planned to be conducted in 1998.

SAFEGUARDS INFORMATION

Document transmitted herewith
contains sensitive unclassified
information. When separated from
enclosure(s) this document is declassified.