

Georgia Power Company
333 Piedmont Avenue
Atlanta, Georgia 30308
Telephone 404 526-7020

Mailing Address:
Post Office Box 4545
Atlanta, Georgia 30302



Georgia Power

the southern electric system

J. T. Beckham, Jr.
Vice President and General Manager
Nuclear Generation

SL-1325
0763C

October 2, 1986

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II - Suite 2900
101 Marietta Street, NW
Atlanta, Georgia 30323

REFERENCE:
RII: JNG
50-321/50-366
I&E Bulletin
85-03

ATTENTION: Dr. J. Nelson Grace

Gentlemen:

Georgia Power Company (GPC) in previous conversations with NRC Region II personnel obtained NRC permission to submit this report after the original October 1, 1986, due date. As of the date of this report, GPC has completed the initial actions required by NRC Inspection and Enforcement Bulletin 85-03, "Motor-Operated Valve Common Mode Failure During Plant Transients Due to Improper Switch Settings", for Plant Hatch Units 1 and 2. The bulletin requires GPC to develop and implement programs for Plant Hatch to ensure that certain valve operator switches in the High Pressure Coolant Injection (HPCI) and Rector Core Isolation Cooling (RCIC) systems are properly selected, set, and maintained.

The bulletin further requires:

1. Review and document the design basis for the operation of each valve. This documentation should include the maximum differential pressure expected during both opening and closing the valve for both normal and abnormal events to the extent that these valve operations and events are included in the existing approved design basis.
2. Using the results from the above, establish the correct switch settings. This shall include a program to review and revise, as necessary, the methods for selecting and setting all switches for each valve operation.

8610090442 861002
PDR ADOCK 05000321
Q PDR

IEH
11

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II - Suite 2900
October 2, 1986
Page Two

3. Individual valve settings shall be changed, as appropriate, to those established above. Whether the valve setting is changed or not, the valve will be demonstrated to be operable by testing the valve at the maximum differential pressure determined in item 1 above with the exception that testing motor operated valves under conditions simulating a break in the line containing the valve is not required. Otherwise, justification should be provided for any cases where testing with the maximum differential pressure cannot practicably be performed. This justification should include the alternative to maximum differential pressure testing which will be used to verify the correct settings. Each valve shall be stroke tested, to the extent practical, to verify that the settings defined in item 2 have been properly implemented even if testing with differential pressure cannot be performed.
4. Prepare or revise procedures to ensure that correct switch settings are determined and maintained throughout the life of the plant. Ensure that applicable industry recommendations are considered in the preparation of these procedures.
5. Submit a written report to the NRC that: 1) reports the results of item 1, and 2) contains the program to accomplish items 2 through 4 including a schedule for completion of these items.

Georgia Power Company participated in the Boiling Water Reactor Owners Group (BWROG) subcommittee that addressed the subject bulletin. The BWROG subcommittee obtained the assistance of the General Electric Company (GE), who provided and developed data and methodology to support plant-specific calculations of the maximum differential pressures requested by action item (a) of the bulletin. The actions included the following specific items:

1. Identify the BWR system valves that are generically subject to the I.E. Bulletin requirements.
2. Identify the conditions within the approved design basis, under which each of the affected valves is subject to the maximum differential pressure.

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II - Suite 2900
October 2, 1986
Page Three

3. Develop a generic methodology in determining the maximum fluid differential pressure across the affected valves.
4. Recommend generic guidelines for valve testing.

The results of the GE research is documented in GE report NEDC 31322 "BWR Owners Group Report on the Operational Design Basis of Selected Safety Related Motor Operated Valves", dated September 1986. A copy of this report was forwarded to the NRC on September 2, 1986. This report was used to address item (a) of I.E. Bulletin 85-03.

The technical information in NEDC 31322, and additional information provided by GE, were used by Georgia Power Company's Architect/Engineer (AE), Southern Company Services, to calculate the maximum expected differential pressures across the identified valves. Enclosures 1 and 2 provide the results of these calculations for the Plant Hatch Unit 1 HPCI and RCIC systems, respectively. Similarly, Enclosures 3 and 4 pertain to Plant Hatch Unit 2. These enclosures contain the following information:

1. Drawings which show the valves analyzed as part of the I.E. Bulletin 85-03 effort.

The valves were chosen based on the previously referenced GE document. The drawings show:

- a. Plant specific Master Parts List (MPL) numbers for valves and pumps.
 - b. A table that relates the MPL to the part description.
 - c. Process fluid flow direction.
 - d. That all listed valves on the drawings are subject to full differential pressure test requirements unless otherwise designated.
2. Documentation packages for the HPCI and RCIC systems of both Unit 1 and Unit 2. There is a total of four packages (Enclosures 1-4).

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II - Suite 2900
October 2, 1986
Page Four

Each package generally includes: 1) introduction, 2) criteria and assumptions, 3) summary of conclusions, 4) listed references, 5) definition of terms, 6) derivation of values, 7) body of calculations, and 8) computer printouts.

The documentation packages have summary tables of the results of the calculations for each valve addressed by the bulletin. The summary tables provide a quick overview, for each system of each unit, of the valves that are subject to the bulletin's requirements. The tables contain the following information:

- a. Valve MPL number.
- b. Valve description.
- c. Valve function.
- d. Indication if the valve has a safety related function on opening or closing.
- e. The governing formula used to calculate the differential pressure for the valve.
- f. An indication of when the maximum pressure occurs, either upon opening or closing of the valve.
- g. An indication of where the maximum pressure occurs, either upstream or downstream of the valve.
- h. The maximum anticipated differential pressure.
- i. An indication if the valve has a safety related function.

The information in the tables is supported by the additional information in the body of the design packages.

A schedule for responding to the remaining I.E. Bulletin 85-03 requirements is also provided as Enclosure 5.


Based on the above information, Georgia Power Company believes it has satisfied the requirements to provide a written report showing the results of item 1 of the Bulletin and to provide a program to accomplish the remaining bulletin requirements including time frames.

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II - Suite 2900
October 2, 1986
Page Five


J. T. Beckham, Jr. states that he is Vice President of Georgia Power Company and is authorized to execute this oath on behalf of Georgia Power Company, and that to the best of his knowledge and belief the facts set forth in this letter are true.

GEORGIA POWER COMPANY

By:


J. T. Beckham, Jr.

Sworn to and subscribed before me this 2nd day of October, 1986.



Notary Public

Notary Public, Clayton County, Georgia
My Commission Expires Dec. 12, 1991

LGB/lc


Enclosure


c: Georgia Power Company
Mr. J. P. O'Reilly
Mr. H. C. Nix, Jr.
GO-NORMS

U. S. Nuclear Regulatory Commission
Dr. J. N. Grace, Regional Administrator
Mr. P. Holmes-Ray, Sr. Resident
Inspector - Hatch
Document Control Desk

0763C

ENCLOSURE 1





* THESE VALVES HAVE NO SAFETY ACTION ON OPEN/CLOSE AND THEREFORE DO NOT REQUIRE DP TESTING.

REVISION DATE REVISION DATE

Southern Company Services, Inc.

EDWIN L. HATCH NUCLEAR PLANT UNIT NO. 1
HPCI SYSTEM FLOW DIAGRAM
MOV DIFFERENTIAL PRESSURE STUDY

DESIGNED DRAWN BY CHECKED

SCALE PROJECT ID DRAWING NUMBER REV


D DRAW 3

8610090442-01

TI
APERTURE
CARD

Also Available On
Aperture Card

Calculation Cover Sheet

Southern Company Services 

Project E.I. HATCH NUCLEAR PLANT UNIT 1		Calculation Number SNH-86-015
Objective Calculate DP for HPCI Motor Operated Valves		Discipline Mechanical
Subject/Title Unit 1 HPCI Motor Operated Valve Differential Pressure Calculation		SDS Number

Design Engineer's Signature <i>L B Watkins</i>	Date 9-20-86	Last Page Number 61
---	-----------------	------------------------

Contents

Topics	Page	Topics	Page
Introduction	1	Definition of Terms	7
Summary of Conclusions	3	Definition of Valves	9
Criteria and Assumptions	2		
Listed References	5		
Body of Calculations	9		
(Computer Printout)	55		

Record of Revisions

Rev. No.	Description	Originator Date	Reviewer Date	Proj. Engr. Date
0	APPROVED	<i>LBM</i> 9-20-86	<i>WMB</i> 9/21/86	<i>ACM</i> 9/24/86

Notes

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>Lawson Wilson</i>	Date 09/19/86
Subject/Title Unit 1 HPCI Motor Operated Valve	Reviewed By <i>W. T. Barr</i>	Date 9/20/86
Differential Pressure Calculation	Calculation Number SNH-86-015	Sheet 1 of 61

INTRODUCTION

The Nuclear Regulatory Commission (NRC) IE Bulletin 85-03 (Motor Operated Valve Common Mode Failure) requested that owners of light water reactors develop and implement a program to ensure that torque switch settings on safety related motor-operated valves on high pressure systems are selected, set and maintained correctly to accomodate the maximum differential pressures expected on these valves during both normal and abnormal events within the design basis. The objective of this calculation is to determine the maximum Differential Pressure across each of the affected Unit 1 HPCI Motor Operated Valves.

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>GP Haskins</i>	Date 9-20-86
Subject/Title Unit 1 HPCI Motor Operated Valve	Reviewed By <i>A.D. McNeil</i>	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-015	Sheet 2 of 61

CRITERIA

- 1) The criteria, assumptions and formulas given in the General Electric "BWR Owner's Group Report on the Operational Design Basis of Selected Safety-Related Motor-Operated Valves," DRF-E12-00100-75, are assumed to be correct.

ASSUMPTIONS

- 1) PC is assumed to equal PLOC. The terms are defined as follows:
 - * PLOC is the maximum wet well LOCA pressure.
 - * PC is the maximum wetwell LOCA pressure which the valve is required to operate against.
- 2) In the PVEL calculation, it is assumed that the time required for a sound wave to travel to and return from an atmospheric vessel is infinity. Thus, the related term in the PVEL equation is equal to zero.
- 3) Disc and Port diameters are assumed to be equal. Equal diameters for disc and port yield higher rate of change therefore higher DV and is therefore more conservative.
- 4) The Formula for calculating area of the gate valve available for flow is approximated from a known geometric relationship and is off by a small percentage, however, the overall effect is negligible.
- 5) In the PVEL calculation, it is assumed that where a small line tees into a much larger line (i.e. Larger being two times or greater in diameter) the boundary for the small line ends at the line intersection.

00431

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>L. B. H. [Signature]</i>	Date 9/29/86
Subject/Title Unit 1 HPCI Motor Operated Valve	Reviewed By <i>W. T. Barr</i>	Date 9/29/86
Differential Pressure Calculation	Calculation Number SNH-86-015	Sheet 3 of 61

SUMMARY OF CONCLUSIONS

The following page is a summary table of the results for each HPCI Motor Operated Valve in the Scope of NRC IEB 85-03.

The first column titled "MPL Number" gives the MPL number of the valve.

The second column titled "Valve Description" is the description of the valve given in the equipment location index (ELI).

The third column titled "Valve Function" is the function of the valve as stated in the General Electric "BWR Owners' Group Report on the Operational Design Basis of Selected Safety-Related Motor-Operated Valves."

The fourth column titled "Safety" indicates if the valve has any safety-related action.

The fifth column titled "DP Calculation Formula" gives the formula used to calculate the maximum differential pressure.

The sixth column titled "Maximum DP" indicates whether the maximum DP occurs upstream or downstream of the valve.

The seventh column titled "Max DP ON" indicates whether the maximum DP is calculated for opening or closing.

The eighth column titled "DP (PSID)" gives the calculated maximum DP in psid.

The ninth column titled "Safety On" gives the safety action of the valve.

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT UNIT 1

PREPARED BY:

JB Hughes

UNIT 1 HPCI MOTOR OPERATED VALVE

REVIEWED BY:

C. Sorenson

DIFFERENTIAL PRESSURE CALCULATION

CALCULATION No. SNH-86-015

DATE 09/21/86

DATE 09/21/86

SHEET 4 OF 61

SUMMARY TABLE 09/21/86

MPL NUMBER	VALVE DESCRIPTION	VALVE FUNCTION	SAFETY	DP CALCULATION FORMULA	MAXIMUM DP UPSTREAM	MAX DP ON OPEN	DP (PSID) 1080	SAFETY ON OPEN
1E41-F001	TURBINE STEAM SUPPLY VALVE	HPCI TURBINE STEAM ADMISSION VALVE	YES	DP=PRSS	UPSTREAM	OPEN	1080	OPEN
1E41-F002	STEAM SUPPLY INBOARD ISOL VALVE	HPCI STEAM LINE ISOLATION VALVE	YES	DP=PRSS	UPSTREAM	CLOSE	1080	CLOSE
1E41-F003	STEAM SUPPLY OUTBD ISOL VALVE	HPCI STEAM LINE ISOLATION VALVE	YES	DP=PRSS	UPSTREAM	CLOSE	1080	CLOSE
1E41-F004	PUMP SUCT FRM COND STOR TANK	HPCI CST SUCTION VALVE	YES	DP=PELD+PV+PVEL1	UPSTREAM	CLOSE	29.594	CLOSE
1E41-F006	HPCI PUMP INBD DISCH VALVE	HPCI INJECTION/ISOLATION VALVE	YES	DP=PSOH-PISD-PEL	UPSTREAM	OPEN	1403.81	OPEN/CLOSE
1E41-F006	HPCI PUMP INBD DISCH VALVE	HPCI INJECTION/ISOLATION VALVE	YES	DP=PSOH-PISD-PEL+PVEL2	UPSTREAM	CLOSE	1411.886	OPEN/CLOSE
1E41-F007	HPCI PUMP OUTBD DISCH VALVE	HPCI INJECTION VALVE TEST VALVE	NO	NO SAFETY ACTION	N/A	N/A	N/A	NONE
1E41-F008	TEST BYPASS VALVE TO COND STOR	HPCI CST TEST RETURN VALVE	NO	NO SAFETY ACTION	N/A	N/A	N/A	NONE
1E41-F011	REDUNDANT SHUTOFF W/F008	HPCI CST TEST RETURN VALVE	NO	NO SAFETY ACTION	N/A	N/A	N/A	NONE
1E41-F012	PHP MIN FLO BYP TO SUPP POOL	HPCI PUMP MIN FLO BYP ISOL VALVE	YES	DP=PSOH+PELM	UPSTREAM	OPEN	2289.37	OPEN/CLOSE
1E41-F012	PHP MIN FLO BYP TO SUPP POOL	HPCI PUMP MIN FLO BYP ISOL VALVE	YES	DP=PMF+PELM+PVEL3	UPSTREAM	CLOSE	2289.911	OPEN/CLOSE
1E41-F041	PHP SUCT FROM SUPP POOL	HPCI SUPP POOL SUCT ISOL VALVE	YES	DP=PRV-PELS	DOWNSTREAM	OPEN	95.72	OPEN/CLOSE
1E41-F041	PHP SUCT FROM SUPP POOL	HPCI SUPP POOL SUCT ISOL VALVE	YES	DP=PLOC+PLOW1	UPSTREAM	CLOSE	35.93	OPEN/CLOSE
1E41-F042	PHP SUCT FROM SUPP POOL	HPCI SUPP POOL SUCT ISOL VALVE	YES	DP=PRV-PELS	DOWNSTREAM	OPEN	95.72	OPEN/CLOSE
1E41-F042	PHP SUCT FROM SUPP POOL	HPCI SUPP POOL SUCT ISOL VALVE	YES	DP=PLOC+PLOW1	UPSTREAM	CLOSE	35.93	OPEN/CLOSE
1E41-F059	COOLING WATER SUPPLY VALVE	HPCI TURBINE ACCES COOLING WTR VLV	YES	DP=PC+PLOW2	UPSTREAM	OPEN	36.94	OPEN/CLOSE
1E41-F059	COOLING WATER SUPPLY VALVE	HPCI TURBINE ACCES COOLING WTR VLV	YES	DP=PC+PLOW2+PVEL4	UPSTREAM	CLOSE	37.857	OPEN/CLOSE
1E41-F104	GATE VALVE 2 IN MD	HPCI VAC BREAKER LINE ISOL VALVE	YES	DP=PC+PATM	UPSTREAM	CLOSE	30.5	CLOSE
1E41-F111	GATE VALVE 2 IN MD	HPCI VAC BREAKER LINE ISOL VALVE	YES	DP=PC+PATM	UPSTREAM	CLOSE	30.5	CLOSE

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>L.B. Hester</i>	Date 9-20-86
Subject/Title Unit 1 HPCI Motor Operated Valve	Reviewed By <i>W.T. Barr</i>	Date 4/20/86
Differential Pressure Calculation	Calculation Number SNH-86-015	Sheet 5 of 61

UNIT 1
HPCI MOV CALCULATIONS
REFERENCES

1. A-11000 REV. N/A UNIT 1 PIPE SPECIFICATION
2. A-16360 REV. N/A SHT 2 & SHT 25 MOV DATA SHEETS
3. A-16368 REV. N/A SHT 1 MOV DATA SHEETS
4. A-16397 REV. 12 INSTRUMENT SETPOINT INDEX
5. H-11038 REV. 15 P & ID DEMINERALIZED WATER
6. H-16081 REV. 4 FEEDWATER PIPING INSIDE DRYWELL ELEVATION 130'-0"
& ABOVE
7. H-16134 REV. 19 HPCI STEAM TURBINE DRAINAGE PIPING
8. H-16332 REV. 19 HPCI SYSTEM P & ID SHEET 1
9. H-16333 REV. 17 HPCI SYSTEM P & ID SHEET 2
10. S-00010 REV. 0 KELLOGG ISOMETRIC DWG. B21-11
11. S-00079 REV. 0 KELLOGG ISOMETRIC DWG. E41-1
12. S-00081 REV. 0 KELLOGG ISOMETRIC DWG. E41-3
13. S-00086 REV. 0 KELLOGG ISOMETRIC DWG. E41-8
14. S-01388 REV. 0 KELLOGG ISOMETRIC DWG. E41-F6
15. S-01390 REV. 0 KELLOGG ISOMETRIC DWG. E41-F6B
16. S-01441 REV. 0 KELLOGG ISOMETRIC DWG. E41-F61
17. S-11417 REV. B. 18" L 900 WE MANUAL OPERATED 900 LB GATE VALVE
18. S-11423 REV. F 14" L 900 WEOS PRESSURE SEAL GATE, CRANE
19. S-14482 REV. A 16" L 150 WEOS GATE VALVE WITH FLEX DISC, CRANE
20. S-15290 REV. H GENERAL PLAN DRYWELL AND TORUS LAYOUT
21. S-16122 REV. 0 PROCESS DIAGRAM HPCI SYSTEM

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>H. B. Harkins</i>	Date <i>9-20-86</i>
Subject/Title Unit 1 HPCI Motor Operated Valve	Reviewed By <i>W. T. Barn</i>	Date <i>9/20/86</i>
Differential Pressure Calculation	Calculation Number SNH-86-015	Sheet <i>6 of 61</i>

UNIT 1
HPCI MOV CALCULATIONS
REFERENCES CONT'D

22. S-16788 REV. C BYRON JACKSON PUMP MANUAL, PUMP CURVE T-31749
23. S-17514 REV. O 4" PRESSURE SEAL GLOBE VALVE, VELAN
24. S-18471 REV. C 4" PRESSURE SEAL GLOBE VALVE, VELAN
25. S-18627 REV. D 2" 1500 LB MOTOR OPERATED GLOBE VALVE, VELAN
26. S-18835 REV. C MODEL LCT-20 SERIES RELIEF VALVE
27. SX-11471 REV. O 16" L-150 WEOS GATE VALVE, CRANE
28. SX-14320 REV. O BOM FOR CRANE VALVE MPL NO. E41-F004
29. ~~S-~~ S-14482 REV. A 16" L-150 WEOS GATE VALVE, CRANE
30. UNIT NO. 1 TECHNICAL SPECIFICATIONS AMENDMENT 128
31. UNIT NO. 2 FSAR TABLE 6.2-5 SHT. 2 NOTE 7
32. SCS MECHANICAL ENGINEERING STANDARDS REV. 1
33. BWR OWNERS GROUP REPORT ON THE OPERATIONAL DESIGN BASIS OF SELECTED SAFETY RELATED MOTOR OPERATED VALVES, DRF-E12-00100-75, AUGUST 1986.
34. NEDO DOCUMENT 24570 REV. 2 FIGURE H1 4.1.2-1
35. CRANE TECHNICAL PAPER NO. 410, 18TH PRINTING
36. ENGINEERS COMPANION 1966 PAGE 13
37. TELECOPY FROM DAN HORASOWYCH OF YARWAY TO JACK ROBYN ON 9-11-86
38. TELECOPY FROM PAUL COUTINHO OF VELAN TO JACK ROBYN ON 9-18-86
39. ENGINEERING FORMULAS 4TH EDITION, PAGE B3

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: *Quinn C. Gibson* DATE 09/19/86
UNIT 1 HPCI MOTOR OPER VALVE Reviewed By: *W.T. Barr* DATE 09/20/86
DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-015 SHEET 7 OF 61.

DEFINITION OF TERMS 09/18/86

TERMDEFINITION OF TERM

DP

VALVE MAXIMUM EXPECTED OPERATING DIFFERENTIAL
PRESSURE

PSOH

DIFFERENTIAL PRESSURE DEVELOPED BY SYSTEM MAIN
PUMPS AT ZERO FLOW RATE. FOR STEAM TURBINE DRIVEN
PUMPS, USE MAXIMUM NORMAL TURBINE SPEED

PEL

MINIMUM HYDROSTATIC PRESSURE DIFFERENCE BETWEEN
SUCTION AND DISCHARGE DUE TO ELEVATION.
(DISCHARGE ELEVATION IS HIGHER THAN SUCTION)

PISO

LOW REACTOR PRESSURE AT WHICH STEAM SUPPLY LINES
AUTOMATICALLY ISOLATE

PELM

MAXIMUM HYDROSTATIC PRESSURE DIFFERENCE BETWEEN
SUCTION AND DISCHARGE SOURCE DUE TO ELEVATION

PRSS

REACTOR PRESSURE CORRESPONDING TO THE SPRING
SETPOINT OF THE REACTOR SAFETY RELIEF VALVE WITH
THE LOWEST NOMINAL SPRING SETPOINT

PELD

HYDROSTATIC PRESSURE DIFFERENCE BETWEEN CST AND
SUPPRESSION POOL ASSUMING THE CST TO BE FULL AND
THE SUPPRESSION POOL WATER LEVEL AT ITS MAXIMUM
ALLOWABLE NORMAL LEVEL

PMF

DIFFERENTIAL PRESSURE DEVELOPED BY THE SYSTEM MAIN
PUMPS AT A FLOW RATE EQUAL TO THE REQUIRED MINIMUM
BYPASS FLOW RATE. FOR STEAM DRIVEN PUMPS USE
MAXIMUM NORMAL TURBINE SPEED

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1

Prepared By: *Dawn Chilton*

DATE 09/17/86

UNIT 1 HPCI MOTOR OPER VALVE

Reviewed By: *W.T. Ban*

DATE 09/20/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-015

SHEET 8 OF 61

DEFINITION OF TERMS09/18/86TERMDEFINITION OF TERM

PV

VELOCITY HEAD IN THE SUPPRESSION POOL SUCTION LINE

AT THE LOCATION WHERE THE CST LINE CONNECTS TO IT

PRV

SYSTEM SUCTION RELIEF VALVE ACTUATION SET PRESSURE

PELS

HYDROSTATIC PRESSURE DIFFERENCE BETWEEN THE

MINIMUM SUPPRESSION POOL WATER LEVEL AND THE

LOCATION OF THE RELIEF VALVE ON THE PUMP SUCTION

LINE

PLOC

LOCA WETWELL PRESSURE WHEN THE SYSTEM IS ISOLATED

PLOM

HYDROSTATIC PRESSURE UPSTREAM OF THE VALVE DUE

TO MAXIMUM LOCA SUPPRESSION POOL WATER LEVEL

PC

MAXIMUM LOCA WETWELL PRESSURE WHEN SYSTEM IS

REQUIRED TO OPERATE

PATM

ATMOSPHERIC PRESSURE

PVEL

DIFFERENTIAL PRESSURE ASSOCIATED WITH VALVE

CLOSURE DUE TO FLUID VELOCITY CHANGES (I.E., WATER

HAMMER TYPE PRESSURE INCREASE) INSIDE THE PIPE

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1	Prepared By: <i>J.B. H. [Signature]</i>	DATE 09/19/86
UNIT 1 HPCI MOTOR OPER VALVE	Reviewed By: <i>W.T. Ban</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-015	SHEET 9 OF 101.
DERIVATION OF VALUES		09/19/86

TERM	PRESSURE (PSIG)	DERIVATION OF TERM
PSOH	2260	FROM S-16788 REV.C, BYRON JACKSON PUMP MANUAL, PUMP CURVE T-31749 @ A TURBINE SPEED OF 4000 RPM.
PEL	6.19	THE ELEVATION OF THE FEEDWATER PIPING NOZZLE AT THE REACTOR IS GIVEN AS 183' 9 1/2" IN H-16081 REV.4. THE MAXIMUM WATER LEVEL IN THE CST IS GIVEN AS 169' 6" IN H-11038 REV.15. THUS THE DIFFERENCE IN ELEVATION IS: $183' 9 \frac{1}{2}" - 169' 6" = 14' 3 \frac{1}{2}"$ $= 14.29 \text{ FT H}_2\text{O}.$ AND THE HYDROSTATIC PRESSURE IS $14.29 \text{ FT.H}_2\text{O} \times 0.432781 \text{ PSIG/FT.H}_2\text{O} = 6.19 \text{ PSIG}$
PISO	850	FROM A-16397 REV. 12. INSTRUMENT SETPOINT INDEX. USE THE MSL ISOLATION SET POINT AS GIVEN FOR INSTRUMENTS B21-N015 A-D.
PELM	29.37	THE CST IS AT ITS MAXIMUM WATER LEVEL AND THE SUPPRESSION POOL

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1	Prepared By: <i>J.B. Hahn</i>	DATE 09/19/86
UNIT 1 HPCI MOTOR OPER VALVE	Reviewed By: <i>W.T. Barr</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-015	SHEET 10 OF 61
DERIVATION OF VALUES		09/19/86

TERM	PRESSURE (PSIG)	DERIVATION OF TERM
------	-----------------	--------------------

PELM		<p>IS AT ITS MINIMUM WATER LEVEL WHEN</p> <p>THE MINIMUM FLOW BYPASS VALVE IS</p> <p>REQUIRED TO OPERATE.</p> <p>THE MAXIMUM WATER LEVEL IN THE CST</p> <p>IS GIVEN AS 169' 6" IN H-11038 REV. 15.</p> <p>THE MINIMUM WATER LEVEL IN THE</p> <p>SUPPRESSION POOL IS GIVEN AS 12' 2"</p> <p>IN THE UNIT 1 TECHNICAL SPECIFICATION</p> <p>SECTION 3.7. AMENDMENT NO. 128.</p> <p>THE INSIDE BOTTOM ELEVATION OF THE</p> <p>SUPPRESSION POOL IS GIVEN AS 89' 5 3/4",</p> <p>DERIVED FROM 103' 6 1/4" - 14' 0 1/2",</p> <p>IN S-15290 REV.H.</p> <p>THE ELEVATION OF THE SUPPRESSION POOL</p> <p>AT MINIMUM WATER LEVEL IS THE INSIDE BOTTOM</p> <p>ELEVATION PLUS THE MINIMUM WATER LEVEL:</p> <p>$89' 5 \frac{3}{4}" + 12' 2" = 101' 7 \frac{3}{4}"$</p> <p>THE HEAD DIFFERENCE IS THEN:</p> <p>$169' 6" - 101' 7 \frac{3}{4}" = 67' 10 \frac{1}{4}"$</p> <p>$= 67.85 \text{ FT H}_2\text{O}$</p> <p>THUS THE HYDROSTATIC PRESSURE IS:</p>
------	--	---

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1	Prepared By: <i>J.B. Harkins</i>	DATE 09/19/86
UNIT 1 HPCI MOTOR OPER VALVE	Reviewed By: <i>W.T. Ban</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-015	SHEET 11 OF 61
DERIVATION OF VALUES		09/19/86

TERM	PRESSURE (PSIG)	DERIVATION OF TERM
------	-----------------	--------------------

PELM		67.85 FT H2O x 0.432781 PSIG/FT H2O = 29.37 PSIG
------	--	---

PRSS	1080	FROM UNIT 1 TECHNICAL SPECIFICATION SECTION 2.2 AMENDMENT NO. 128.
------	------	---

PELD	29.22	THE MAXIMUM WATER LEVEL IN THE CST IS GIVEN AS 169' 6" IN H-11038 REV. 15. THE MAXIMUM WATER LEVEL IN THE SUPPRESSION POOL IS 12' 6" FROM UNIT 1 TECHNICAL SPECIFICATION SECTION 3.7 AMENDMENT NO. 128. THE INSIDE BOTTOM ELEVATION OF THE SUPPRESSION POOL IS 89' 5 3/4", DERIVED FROM 103' 6 1/4" - 14' 0 1/2", IN S-15290 REV. H. THE ELEVATION OF THE SUPPRESSION POOL MAXIMUM WATER LEVEL IS THE INSIDE BOTTOM ELEVATION PLUS THE MAXIMUM WATER LEVEL: 89' 5 3/4" + 12' 6" = 101' 11 3/4" THE HEAD DIFFERENCE IS THEN:
------	-------	---

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1	Prepared By: <i>J.B. Harkin</i>	DATE 09/19/86
UNIT 1 HPCI MOTOR OPER VALVE	Reviewed By: <i>W.T. Bar</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-015	SHEET 12 OF 61.
DERIVATION OF VALUES		09/19/86

TERM	PRESSURE (PSIG)	DERIVATION OF TERM
------	-----------------	--------------------

PELD		$169' 6'' - 101' 11 \frac{3}{4}'' = 67' 6 \frac{1}{4}''$ $= 67.52 \text{ FT. H}_2\text{O}$
------	--	---

THUS THE HYDROSTATIC PRESSURE IS:

 $67.52 \text{ FT H}_2\text{O} \times 0.432781 \text{ PSIG/FT H}_2\text{O}$
 $= 29.22 \text{ PSIG}$

PMF	2255
-----	------

FROM S-16788 REV. C., BYRON JACKSON PUMP
MANUAL, PUMP CURVE T-31749 AT A MINIMUM FLOW
BYPASS RATE OF 450 GPM, S-16122 REV. 0
PROCESS DIAGRAM HPCI SYSTEM, AND 4000 RPM
TURBINE SPEED.

PV	0.374
----	-------

THE HPCI SYSTEM RATED FLOW IS GIVEN
AS 4250 GPM IN THE UNIT 1 TECHNICAL
SPECIFICATION SECTION 4.5.D.1.b AMENDMENT
NO. 128.
THE INSIDE DIAMETER OF THE SUPPRESSION POOL
SUCTION LINE IS 15.250" GIVEN IN H-16332
REV. 19, A-11000 UNIT 1 PIPE SPECIFICATION
AND THE CRANE TECHNICAL PAPER NO. 410,
18TH PRINTING.

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1

Prepared By: *J.B. Harkin*

DATE 09/20/86

UNIT 1 HPCI MOTOR OPER VALVE

Reviewed By: *W.T. Ban*

DATE 09/21/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-015

SHEET 13 OF 61

DERIVATION OF VALUES

09/20/86

TERM	PRESSURE (PSIG)	DERIVATION OF TERM
PV		<p>THE VELOCITY HEAD IS EQUAL TO:</p> $(V)^2 / 2(gc) \text{ WHERE:}$ <p>gc IS GRAVITATIONAL CONSTANT</p> $= 32.2 \text{ FT/ (SEC)}^2$ $PI = 3.1416 \quad (\text{dimensionless})$ $V = Q/A$ $V = (4250 \times 0.13368) \times (144/60) /$ $[PI \times ((15.250)^2)/4]$ $= 7.46 \text{ FT/SEC}$ <p>THUS VELOCITY HEAD IS:</p> $(7.46)^2 / 2(32.2) = 0.865 \text{ FT H}_2\text{O}$ <p>AND VELOCITY HEAD PRESSURE IS:</p> $0.865 \text{ FT H}_2\text{O} \times 0.432781 \text{ PSIG/FT H}_2\text{O}$ $= 0.374 \text{ PSIG}$
PRV	100	<p>FROM S-18835 REV. C MODEL LCT-20 SERIES RELIEF VALVE.</p>
PELS	4.28	<p>THE MINIMUM SUPPRESSION POOL ELEVATION WAS DETERMINED TO BE 101' 7 3/4" IN THE CALCULATION FOR PELM ABOVE.</p>

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: *J.B. Hickin* DATE 09/20/86UNIT 1 HPCI MOTOR OPER VALVE Reviewed By: *A.T. Ban* DATE 09/21/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-015 SHEET 14 OF 61 .

DERIVATION OF VALUES 09/20/86

<u>TERM</u>	<u>PRESSURE (PSIG)</u>	<u>DERIVATION OF TERM</u>
-------------	------------------------	---------------------------

PELS

THE ELEVATION FOR THE SUCTION RELIEF VALVE

E41-F020 IS GIVEN AS 91' 9" ON S-01441

REV. 0.

THUS THE HYDROSTATIC HEAD IS:

 $101' 7 \frac{3}{4}" - 91' 9" = 9' 10 \frac{3}{4}"$ $= 9.90 \text{ FT H2O}$

AND THE HYDROSTATIC PRESSURE IS:

 $9.90 \text{ FT.} \times 0.432781 \text{ PSIG/FT H2O} = 4.28 \text{ PSIG}$

PLOC 30.5

PLOC=PC. THE ECCS OPERATION MAY REQUIRE

THE CLOSURE OF THE SUPPRESSION POOL

ISOLATION VALVES TO PROVIDE PRIMARY

CONTAINMENT ISOLATION FOR EXTREME LOCA

CONDITIONS FOLLOWING UTILIZATION OF THE

WETWELL INVENTORY.

PLOM1 5.43

THE MAXIMUM LOCA SUPPRESSION POOL WATER LEVEL

IS 102' 7 1/2" GIVEN IN S-15290 REV. H.

THE CENTERLINE ELEVATION OF VALVES E41-F041

AND E41-F042 IS 90' 1" FROM S-00081

REV. 0.

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1	Prepared By: <i>J.B. Hickman</i>	DATE 09/19/86
UNIT 1 HPCI MOTOR OPER VALVE	Reviewed By: <i>W.T. Barr</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-015	SHEET 15 OF 41
DERIVATION OF VALUES		09/19/86

TERM	PRESSURE (PSIG)	DERIVATION OF TERM
------	-----------------	--------------------

PLOM1

THE HEAD DIFFERENCE IS:

$$102' 7 \frac{1}{2}" - 90' 1" = 12' 6 \frac{1}{2}"$$

$$= 12.54 \text{ FT H}_2\text{O}.$$

THUS THE HYDROSTATIC PRESSURE IS:

$$12.54 \text{ FT H}_2\text{O} \times 0.432781 \text{ PSIG/FT H}_2\text{O}$$

$$= 5.43 \text{ PSIG}$$

PLOM2 6.44

THE MAXIMUM LOCA SUPPRESSION POOL WATER

LEVEL IS 102' 7 1/2" GIVEN IN S-15290 REV. H.

THE CENTERLINE ELEVATION OF VALVE E51-F059

IS 87' 9" FROM H-16134 REV. 19.

THE HEAD DIFFERENCE IS:

$$102' 7 \frac{1}{2}" - 87' 9" = 14' 10 \frac{1}{2}"$$

$$= 14.88 \text{ FT H}_2\text{O}$$

THUS THE HYDROSTATIC PRESSURE IS:

$$14.88 \text{ FT H}_2\text{O} \times 0.432781 \text{ PSIG/FT H}_2\text{O} = 6.44 \text{ PSIG}$$

PC 30.5

FROM NEDO DOCUMENT 24570 REV. 2 FIGURE

H1 4.1.2-1

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1	Prepared By: <i>AB. [Signature]</i>	DATE 09/19/86
UNIT 1 HPCI MOTOR OPER VALVE	Reviewed By: <i>C. [Signature]</i>	DATE 09/21/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-015	SHEET 16 OF 61
DERIVATION OF VALUES		09/19/86

TERM	PRESSURE (PSIG)	DERIVATION OF TERM
------	-----------------	--------------------

PATM	0	NORMAL ATMOSPHERIC PRESSURE = 14.696 PSIA PSIG = PSIA - 14.696 = 0
------	---	---

PVEL1	0	<p>KELLOGG ISOMETRIC DRAWINGS S-00086 REV. 0, AND S-00081 REV. 0 SHOW THAT THE UPSTREAM PIPING IS CONNECTED TO THE CONDENSATE STORAGE TANK.</p> <p>IT IS ASSUMED THAT ANY WATER HAMMER EFFECTS IN THE UPSTREAM PIPING WOULD BE DISSIPATED WITHIN THE CST VOLUME AND PRODUCE NO RESULTANT PRESSURE RISE ON THE VALVE.</p> <p>THE REFERENCED DRAWINGS ALSO SHOW THAT THE DOWNSTREAM PIPING IS INTERCONNECTED WITH THE SUPPRESSION POOL SUCTION LINE. IT IS ASSUMED THE HPCI PUMP IS OPERATING TO DRAW A SUCTION FROM THE SUPPRESSION POOL WHEN 1E41-F004 BEGINS TO CLOSE. THEREFORE NO DOWNSTREAM FLUID DECELERATION WILL RESULT. IT MAY BE CONCLUDED THAT NO INCREASE IN PRESSURE RESULTS BECAUSE OF WATER HAMMER.</p> <p>CONSIDERING THE ABOVE FACTS VALVE 1E41-F004</p>
-------	---	--

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: *L.B. Hankins* DATE 09/21/86UNIT 1 HPCI MOTOR OPER VALVE Reviewed By: *C. Spencer* DATE 09/21/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-015 SHEET 17 OF 61.

DERIVATION OF VALUES 09/21/86TERM PRESSURE (PSIG) DERIVATION OF TERM

PVEL1 CAN BE CONSIDERED TO HAVE NO WATER HAMMER
PRESSURE INCREASE.

PVEL2 8.076 DIFFERENTIAL PRESSURE ACROSS THE VALVE DUE
TO WATER HAMMER FOR 1E41-F006;
THE VALUE FOR PVEL2 IS CALCULATED BY COMPUTER. A
DERIVATION FOR PVEL AND THE GATE VALVE
AREA VS PERCENT OPEN CURVE USED IN THE CALCULATION
ARE FOUND ATTACHED. THE FOLLOWING DATA IS USED IN
THE CALCULATION TO DERIVE PVEL2:

SYSTEM VELOCITY UPSTREAM (V_{su}) AND SYSTEM VELOCITY
DOWNSTREAM (V_{sd}), WHERE:

- . FLOWRATE = 4250 GPM FROM S-16122 REV. 0.
- . AREA OF 14" SCH 80 PIPE = 122.72 IN SQ
- . AREA OF 14" SCH 100 PIPE = 115.49 IN SQ
- . FROM CRANE TECHNICAL PAPER NO. 410

THEN:

$$V_{su} = (4250 \text{ GPM} \times 0.321) / 122.72 \text{ IN SQ}$$
$$= 11.12 \text{ FT/SEC}$$

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1	Prepared By: <i>JBH</i>	DATE 09/21/86
UNIT 1 HPCI MOTOR OPER VALVE	Reviewed By: <i>C. K. K.</i>	DATE 09/21/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-015	SHEET 18 OF 61
DERIVATION OF VALUES		09/21/86

<u>TERM</u>	<u>PRESSURE (PSIG)</u>	<u>DERIVATION OF TERM</u>
-------------	------------------------	---------------------------

PVEL2

Vsd = (4250 GPM x 0.321) / 115.49 IN SQ

= 11.81 FT/SEC

CLOSURE TIME = 20 SEC FROM A-16360 SH 2

VALVE THROAT DIAMETER

DIAM VALVE = 12.25" FROM S-11423 REV. F

LENGTH UPSTREAM (LU) AND DOWNSTREAM (LD)

LU = 244.14 FT FROM S-00079 REV. A

LD = 155.95 FT FROM S-00079 REV. A

S-00010 REV. 0, H-16081 REV. 4,

S-11417 REV. B AND SCS MECHANICAL ENG

STANDARDS REV. 1.

PVEL2 = 8.076 FROM COMPUTER PRINTOUT

PVEL3 5.541

DIFFERENTIAL PRESSURE ACROSS THE VALVE DUE TO
WATER HAMMER FOR 1E41-F012;

THE VALUE FOR PVEL3 IS CALCULATED BY COMPUTER.

A DERIVATION FOR PVEL AND THE GLOBE VALVE

CV VS PERCENT OPEN CURVE USED IN THE CALCULATION

ARE FOUND ATTACHED. THE FOLLOWING DATA IS USED

IN THE CALCULATION TO DERIVE PVEL3:

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: *J.B. Heline* DATE 09/21/86UNIT 1 HPCI MOTOR OPER VALVE Reviewed By: *C. Korman* DATE 09/21/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-015 SHEET 19 OF 61.

DERIVATION OF VALUES 09/21/86

TERM	PRESSURE (PSIG)	DERIVATION OF TERM
------	-----------------	--------------------

PVEL3

SYSTEM VELOCITY UPSTREAM (V_{su}) AND SYSTEM
VELOCITY DOWNSTREAM (V_{sd}) WHERE:

- . FLOWRATE = 450 GPM FROM S-16122 REV. 0
- . AREA OF 4" SCH 80 PIPE = 11.5 IN SQ
- . AREA OF 4" SCH 40 PIPE = 12.73 IN SQ
- . FROM CRANE TECHNICAL PAPER No. 410

THEN:

- . $V_{su} = (450 \text{ GPM} \times 0.321) / 11.5 \text{ IN SQ}$
- . $= 12.561 \text{ FT/SEC}$
- . $V_{sd} = (450 \text{ GPM} \times 0.321) / 12.73 \text{ IN SQ}$
- . $= 11.347 \text{ FT/SEC}$

CLOSURE TIME = 10 SEC FROM A-16360 SH 25

VALVE THROAT DIAMETER

- . DIAM VALVE = 2.5" PER
- . TELECOPY TO JACK ROBYN OF SCS
- . FROM PAUL COUTINHO OF VELAN ON 9/18/86.

LENGTH UPSTREAM (LU) AND LENGTH DOWNSTREAM (LD)

- . LU = 61.05 FT FROM S-00079 REV. A
- . LD = 38.958 FT FROM S-00079 REV. A
- . FOR LD IT IS ASSUMED THAT THE WATER HAMMER

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: *L. B. Malone* DATE 09/21/86UNIT 1 HPCI MOTOR OPER VALVE Reviewed By: *C. J. Jerns* DATE 09/21/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-015 SHEET 20 OF 61

DERIVATION OF VALUES 09/21/86

<u>TERM</u>	<u>PRESSURE (PSIG)</u>	<u>DERIVATION OF TERM</u>
-------------	------------------------	---------------------------

PVEL3		. BOUNDARY ENDS AT THE TIE IN TO THE . RHR TEST LINE.
-------	--	--

PVEL3 = 5.541 FROM COMPUTER PRINTOUT

PVEL4	0.917	
-------	-------	--

DIFFERENTIAL PRESSURE ACROSS THE VALVE DUE TO
WATER HAMMER FOR 1E41-F059.

THE VALUE FOR PVEL4 IS CALCULATED BY COMPUTER.

A DERIVATION FOR PVEL AND THE GLOBE VALVE

CV VS PERCENT OPEN CURVE USED IN THE CALCULATION

ARE FOUND ATTACHED. THE FOLLOWING DATA IS USED

IN THE CALCULATION TO DERIVE PVEL4:

. SYSTEM VELOCITY UPSTREAM (V_{su}) AND SYSTEM
VELOCITY DOWNSTREAM (V_{sd}) WHERE:

. FLOWRATE = 70 GPM FROM S-16122 REV. 0

. AREA OF 2" SCH 80 PIPE = 2.953 IN SQ

. FROM CRANE TECHNICAL PAPER No. 410

THEN:

. $V_{su} = (70 \text{ GPM} \times 0.321) / 2.953 \text{ IN SQ}$

. = 7.601 FT/SEC

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: FBH DATE 09/21/86UNIT 1 HPCI MOTOR OPER VALVE Reviewed By: C. C. C. DATE 09/21/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-015 SHEET 21 OF 61 .

DERIVATION OF VALUES 09/21/86

<u>TERM</u>	<u>PRESSURE (PSIG)</u>	<u>DERIVATION OF TERM</u>
		.
PVEL4		. Vsd=Vsu
		CLOSURE TIME = 10 SEC FROM A-16368 SH 1
		.
		. PER STD. STROKE TIME HNP2
		. FSAR TABLE 6.2-5 SH 2 NOTE 7
		VALVE THROAT DIAMETER
		. DIAM VALVE = 1 3/4" FROM S-18627 REV. C
		LENGTH UPSTREAM (LU) AND LENGTH DOWNSTREAM (LD)
		. LU = 25.0 FT FROM S-01388 REV. 0
		. LD = 31.42 FT FROM S-01388 REV.0 AND S-01390
		. REV.0
		PVEL4 = 0.917 FROM COMPUTER PRINTOUT

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>ED Jackson</i>	Date 9-19-86
Subject/Title Unit 1 HPCI Motor Operated Valve	Reviewed By <i>A. S. Kirk</i>	Date 9-20-86
Differential Pressure Calculation	Calculation Number SNH-86-015	Sheet 22 of 61

DETERMINE THE PRESSURE INCREASE DUE TO THE RAPID
DECELERATION OF FLUID CAUSED BY THE MOVEMENT
OF A PROCESS GATE OR GLOBE VALVE

ASSUMPTIONS

- 1) Valve openings result in no waterhammer effects. The differential pressure across a valve during opening is decreased by an increase in fluid velocity. The maximum actuator loading takes place before the valve lift occurs.
- 2) Steam valve closure results in only minor or no waterhammer effect. The compressible nature of the fluid medium coupled with maximum anticipated velocity changes make the pressure addition insignificant.
- 3) Area of flow through a gate valve is a direct and linear relation to system velocity.
- 4) The percentage of valve opening is a direct relation to opening time.
- 5) It is assumed that flowing pressure does not drop below the fluids vapor pressure.

The pressure increase due to sudden deceleration of fluid may be expressed as:


$$P_{VEL} = P_1 + P_2$$

Where P_1 is the upstream pressure change, and P_2 is the downstream pressure change.

The respective values for P_1 and P_2 may be calculated as follows:

$$P_1, P_2 = \frac{\rho C \Delta V_{MAX}}{144 \text{ g}}$$

Design Calculations

Southern Company Services 

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>H.B. Harkins</i>	Date 9-19-86
Subject/Title Unit 1 HPCI Motor Operated Valve	Reviewed By <i>A.S. Kirk</i>	Date 9-20-86
Differential Pressure Calculation	Calculation Number SNH-86-015	Sheet 23 of 61

Where: ρ is the fluid density

C is the speed of sound through the fluid

ΔV_{MAX} is the maximum system fluid differential velocity

144 is a conversion factor

and g is the Gravitational Constant



The fluid ΔV is assumed to be a direct relation to flow area, as shown in the gate valve area - percent open curves, and is a direct relation to Cv, as shown on the globe valve Cv - percent open curves.

The valve Δt is a direct relation to Δ percentage open.


Therefore:

$$\frac{\Delta A}{\Delta \% \text{ Open}} \approx \frac{\Delta C_v}{\Delta \% \text{ Open}} \approx \frac{\Delta V}{\Delta t}$$

Having plotted a velocity relation against a time relation the region of highest differential velocity is examined.



Design Calculations

Southern Company Services 

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>T.B. H. H. H.</i>	Date 9-19-86
Subject/Title Unit 1 HPCI Motor Operated Valve	Reviewed By <i>A.S. Kirk</i>	Date 9-20-86
Differential Pressure Calculation	Calculation Number SNH-86-015	Sheet 24 of 61

Incremental time is Defined As:

$$\Delta t = t_2 - t_1 = \frac{2L}{c}$$

Where the term $2L/C$ is the time require for a pressure wave to travel down a pipe's flow length and rebound to it's source valve.

Knowing the equation of the curve, the maximum ΔV for Δt (ie; greatest slope) is calculated and entered into the pressure equations.

The procedure is once again performed for the down stream side of the valve and added as follows to produce PVEL

$$PVEL = P1 + P2$$

Reference: BWROG REPORT APP. B


0082d

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>C. Sorenson</i>	Date 9-19-86
Subject/Title Unit 1 HPCI Motor Operated Valve	Reviewed By <i>H. D. McCall</i>	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-015	Sheet 25 of 61

RELATIONSHIP OF THE GATE VALVE FLOW AREA TO THE
PERCENTAGE OPENING OF A TYPICAL GATE VALVE

It is assumed that the diameter of the gate is equal to the port diameter of the valve since the difference in diameters is insignificantly small.


THE FLOW AREA OF THE VALVE MAY BE DETERMINED BY SUBTRACTING THE AREA OF THE GATE OCCLUDING THE TOTAL PORT AREA.



A = Area

$$A_{\text{Flow}} = A_{\text{Port}} - A_{\text{Gate}}$$

THE AREA OF THE PORT IS CALCULATED USING THE CIRCULAR SEGMENT CALCULATION



$$A_{\text{SEG}} = h/6s (3h^2 + 4s^2)$$


WITH h = RISE = RADIUS
AND s = CHORD = DIAMETER

THE AREA OF THE PORT IS EQUAL TO TWICE ASEG



$$A_{\text{PORT}} = 2A_{\text{SEG}} = R/6D (3R^{**2} + 4D^{**2})$$

Design Calculations

Southern Company Services 

Project	E.I. Hatch Nuclear Plant Unit 1	Prepared By	<i>C. Scriver</i>	Date	9.19.86
Subject/Title	Unit 1 HPCI Motor Operated Valve	Reviewed By	<i>A.D. McHugh</i>	Date	9/21/86
	Differential Pressure Calculation	Calculation Number	SNH-86-015	Sheet	26 of 61

THE OCCLUDING AREA OF THE GATE IS FOUND BY USING THE AREA OF A CIRCULAR SEGMENT CALCULATION.



$$ASEG = h/6s (3h^2 + 4s^2)$$


$$r = h/2 + s^2/8h$$

TRANSFORMING THE LATER EQUATION

$$s = (8h (r - (h/2)))^{1/2}$$

WHICH COMBINED WITH THE ASEG CALCULATION MAY BE READILY SOLVED.

THE AREA OCCLUDED IS EQUAL TO TWICE ASEG.



$$AGATE = 2 ASEG.$$


THUS THE AREA OF FLOW THROUGH THE VALVE IS CALCULATED AS:

$$A_{Flow} = A_{PORT} - A_{GATE}$$




AFlow

Design Calculations

Southern Company Services 

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>C. Lorenson</i>	Date 9.19.86
Subject/Title Unit 1 HPCI Motor Operated Valve	Reviewed By <i>A.D. McNeil</i>	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-015	Sheet 27 of 61

A GRAPHIC PRESENTATION OF THE TYPICAL FLOW AREA VS. PERCENT VALVE OPENING IS GIVEN AS FOLLOWS.



REFERENCE: ENGINEERING FORMULAS 4th EDITION, PAGE B3.

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>C. Lorenson</i>	Date 9-19-86
Subject/Title Unit 1 HPCI Motor Operated Valve	Reviewed By <i>A. S. Kirk</i>	Date 9-19-86
Differential Pressure Calculation	Calculation Number SNH-86-015	Sheet 28 of 61

NUMERICAL RELATIONSHIP BETWEEN A GRAPHICAL PRESENTATION
OF MANUFACTURER'S 2" GLOBE VALVE OPENING
VS. MANUFACTURER'S CV DATA

Given a curve of 0-100 % opening (see attached), It is Desired to numerically relate the first 60% of opening to CV.

The First 60% of opening is a linear function thus, the curve may be equated using linear regression of the point-slope form.

$$y - y_1 = m(x - x_1)$$

Using the points (0,0) and (50,40)

$$40 - 0 = m(50 - 0)$$

Solving for m

$$m = 40/50 = 0.8$$

The equation of a line is given as:


$$y = mx$$

Hence, the equation relating cv with percent opening is:

$$CV = 0.8 (\text{percentage opening})$$

FOR ALL OPENINGS LESS THAN 60%.

Reference: THE ENGINEER'S COMPANION 1966 PG. 13.



BAH
8/13/65

PERCENT VALVE OPENING

100

- 20 -

60

No

20

—

Author's address: Department of Computer Science, University of Illinois at Chicago, 620 S. Morgan St., Chicago, IL 60607, USA.
E-mail: shankar@cs.uic.edu

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>T. B. Harkins</i>	Date <i>9-19-86</i>
Subject/Title Unit 1 HPCI Motor Operated Valve	Reviewed By <i>A. S. Kirk</i>	Date <i>9-19-86</i>
Differential Pressure Calculation	Calculation Number SNH-86-015	Sheet <i>30 of 61</i>

NUMERICAL RELATIONSHIP BETWEEN A GRAPHICAL PRESENTATION
OF MANUFACTURER'S 4" GLOBE VALVE OPENING
VS. MANUFACTURER'S CV DATA

Given a curve of 0-100 % opening (see attached), It is Desired to numerically relate the first 45% of opening to CV.

The First 45% of opening is a linear function thus, the curve may be equated using linear regression of the point-slope form.

$$y - y_1 = m(x - x_1)$$

Using the points (10,15) and (30,49)

$$49 - 15 = m(30 - 10)$$

Solving for m

$$m = 34/20 = 1.7$$

The equation of a line is given as:

$$y = mx$$

Hence, the equation relating cv with percent opening is:

$$CV = 1.7 (\text{percentage opening})$$

FOR ALL OPENINGS LESS THAN 49%.

Reference: THE ENGINEER'S COMPANION 1966 PG. 13.

TELECOPY MESSAGE - MR. JACK ROBYN
TELECOPY NO.: 205-868-5143
FROM: RAUL COUTINHO - SEPT. 18/86

C_v - PERCENTAGE OF MAX.

GENERIC CURVE
 C_v VERSUS LIFT

OLD STYLE GLOBE
VALVES (FORGED)

CURVE NO.: 001

PERCENTAGE OF LIFT

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1&2 Prepared By: *L.B. Perkins* DATE 09/21/86MOTOR OPERATED VALVE Reviewed By: *C. Green* DATE 09/21/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-015 SHEET 32 OF 61.

GATE VALVE PVEL CALCULATION

MPL NUMBER	1E41-F006
VALVE DIAMETER (INCHES)	12.25
CLOSING TIME (SECONDS)	20
UPSTREAM PIPE LENGTH (FT)	244.14
DOWNSTREAM PIPE LENGTH (FT)	155.95
UPSTREAM SYSTEM VEL (FT/SEC)	11.12
DOWNSTREAM SYSTEM VEL (FT/SEC)	11.81
delta TIME UPSTREAM (SECONDS)	0.12207
delta TIME DWNSTREAM (SECONDS)	0.077975
TIME UPSTREAM 1 (SECONDS)	19.87793
TIME UPSTREAM 2 (SECONDS)	20
TIME DOWNSTREAM 1 (SECONDS)	19.922025
TIME DOWNSTREAM 2 (SECONDS)	20
RISE UPSTREAM 1	6.0876161
RISE UPSTREAM 2	6.125
RISE DOWNSTREAM 1	6.1011202
RISE DOWNSTREAM 2	6.125
CHORD UPSTREAM 1	12.249772
CHORD UPSTREAM 2	12.25
CHORD DOWNSTREAM 1	12.249907
CHORD DOWNSTREAM 2	12.25
MAX AREA (IN SQ)	118.79948
AREA FLOW UPSTREAM 1	0.9534862
AREA FLOW UPSTREAM 2	0
AREA FLOW DOWNSTREAM 1	0.6091957
AREA FLOW DOWNSTREAM 2	0
a/Au1	0.0080901
a/Au2	0
a/Ad1	0.0051689
a/Ad2	0
VELOCITY UPSTREAM 1 (FT/SEC)	0.0899616
VELOCITY UPSTREAM 2 (FT/SEC)	0
VELOCITY DOWNSTREAM 1 (FT/SEC)	0.0610442
VELOCITY DOWNSTREAM 2 (FT/SEC)	0
delta VEL UPSTREAM (FT/SEC)	0.0899616
delta VEL DOWNSTREAM (FT/SEC)	0.0610442
Pvu UPSTREAM PRESSURE (PSIG)	4.8112999
Pvd DOWNSTREAM PRESSURE (PSIG)	3.2647504

Pvel (PSIG) 8.0760503

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1&2 Prepared By: *ZB Hudson* DATE 09/19/86
 MOTOR OPERATED VALVE Reviewed By: *D. Wilson* DATE 09/30/86
 DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-015 SHEET 33 OF 61 .

FOUR INCH GLOBE VALVE PVEL CALCULATIONS

MPL NUMBER	1E41-F012
VALVE DIAMETER (INCHES)	2.5
CLOSING TIME (SECONDS)	10
UPSTREAM PIPE LENGTH (FT)	61.05
DOWNSTREAM PIPE LENGTH (FT)	38.958
UPSTREAM SYSTEM VEL (FT/SEC)	12.561
DOWNSTREAM SYSTEM VEL (FT/SEC)	11.347
delta TIME UPSTREAM (SECONDS)	0.030525
delta TIME DWNSTREAM (SECONDS)	0.019479
TIME UPSTREAM 1 (SECONDS)	5
TIME UPSTREAM 2 (SECONDS)	5.030525
TIME DOWNSTREAM 1 (SECONDS)	5
TIME DOWNSTREAM 2 (SECONDS)	5.019479
% OPEN UPSTREAM 1	50
% OPEN UPSTREAM 2	50.30525
% OPEN DOWNSTREAM 1	50
% OPEN DOWNSTREAM 2	50.19479
% CV UPSTREAM 1	85.7
% CV UPSTREAM 2	86.223198
% CV DOWNSTREAM 1	85.7
% CV DOWNSTREAM 2	86.03387
delta VEL UPSTREAM (FT/SEC)	0.065719
delta VEL DOWNSTREAM (FT/SEC)	0.0378842
Pvu UPSTREAM (PSIG)	3.5147627
Pvd DOWNSTREAM (PSIG)	2.0261138
Pvel3(PSIG)	5.5428764

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1&2

Prepared By: *J.B. Harkins*

DATE 09/19/86

MOTOR OPERATED VALVE

Reviewed By: *D. Wilcox*

DATE 09/30/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-015

SHEET 34 OF 61.

TWO INCH GLOBE VALVE PVEL CALCULATIONS

MPL NUMBER	1E41-F059
VALVE DIAMETER (INCHES)	1.75
CLOSING TIME (SECONDS)	10
UPSTREAM PIPE LENGTH (FT)	25
DOWNSTREAM PIPE LENGTH (FT)	31.42
UPSTREAM SYSTEM VEL (FT/SEC)	7.601
DOWNSTREAM SYSTEM VEL (FT/SEC)	7.601
delta TIME UPSTREAM (SECONDS)	0.0125
delta TIME DWNSTREAM (SECONDS)	0.01571
TIME UPSTREAM 1 (SECONDS)	5
TIME UPSTREAM 2 (SECONDS)	5.0125
TIME DOWNSTREAM 1 (SECONDS)	5
TIME DOWNSTREAM 2 (SECONDS)	5.01571
% OPEN UPSTREAM 1	50
% OPEN UPSTREAM 2	50.125
% OPEN DOWNSTREAM 1	50
% OPEN DOWNSTREAM 2	50.1571
% CV UPSTREAM 1	40
% CV UPSTREAM 2	40.1
% CV DOWNSTREAM 1	40
% CV DOWNSTREAM 2	40.12568
delta VEL UPSTREAM (FT/SEC)	0.007601
delta VEL DOWNSTREAM (FT/SEC)	0.0095529
Pvu UPSTREAM (PSIG)	0.4065145
Pvd DOWNSTREAM (PSIG)	0.5109074

Pvel4(PSIG)

0.9174219

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: *A. B. Harkins* DATE 09/20/86UNIT 1 HPCI MOTOR OPER VALVE Reviewed By: *W. T. Bass* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-015 SHEET 35 OF 61.

DIFFERENTIAL PRESSURE CALCULATION 09/19/86MPL NUMBER

1E41-F001

VALVE DESCRIPTION

TURBINE STEAM SUPPLY VALVE

VALVE FUNCTION

HPCI TURBINE STEAM ADMISSION VALVE

SAFETY ACTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PRSS

MAXIMUM DP ON OPEN OR CLOSE

OPEN

MAXIMUM DP UPSTREAM/DOWNSTREAM

UPSTREAM

SAFETY ACTION ON OPEN/CLOSE

OPEN

VALUES USED:

PRSS = 1080

DP (PSID)

1080

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1	Prepared By: <i>J.B. Hyslop</i>	DATE 09/20/86
UNIT 1 HPCI MOTOR OPER VALVE	Reviewed By: <i>D. Z. Barr</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-015	SHEET 36 OF 61 .

DIFFERENTIAL PRESSURE CALCULATION 09/19/86

<u>MPL NUMBER</u>	1E41-F002
<u>VALVE DESCRIPTION</u>	STEAM SUPPLY INBOARD ISOL VALVE
<u>VALVE FUNCTION</u>	HPCI STEAM LINE ISOLATION VALVE
<u>SAFETY ACTION (YES/NO)</u>	YES
<u>DP CALCULATION FORMULA</u>	DP=PRSS
<u>MAXIMUM DP ON OPEN OR CLOSE</u>	CLOSE
<u>MAXIMUM DP UPSTREAM/DOWNSTREAM</u>	UPSTREAM
<u>SAFETY ACTION ON OPEN/CLOSE</u>	CLOSE
<u>VALUES USED:</u>	
PRSS	= 1080

<u>DP (PSID)</u>	1080
------------------	------

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1	Prepared By: <i>J.B. Harker</i>	DATE 09/20/86
UNIT 1 HPCI MOTOR OPER VALVE	Reviewed By: <i>W.T. Barr</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-015	SHEET 37 OF 61 .

DIFFERENTIAL PRESSURE CALCULATION 09/19/86

<u>MPL NUMBER</u>	1E41-F003
<u>VALVE DESCRIPTION</u>	STEAM SUPPLY OUTBD ISOL VALVE
<u>VALVE FUNCTION</u>	HPCI STEAM LINE ISOLATION VALVE
<u>SAFETY ACTION (YES/NO)</u>	YES
<u>DP CALCULATION FORMULA</u>	DP=PRSS
<u>MAXIMUM DP ON OPEN OR CLOSE</u>	CLOSE
<u>MAXIMUM DP UPSTREAM/DOWNSTREAM</u>	UPSTREAM
<u>SAFETY ACTION ON OPEN/CLOSE</u>	CLOSE
<u>VALUES USED:</u>	

PRSS = 1080

<u>DP (PSID)</u>	1080
------------------	------

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: *ZB Hylton* DATE 09/20/86UNIT 1 HPCI MOTOR OPER VALVE Reviewed By: *W.T. Ban* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-015 SHEET 38 OF 61.

DIFFERENTIAL PRESSURE CALCULATION 09/19/86MPL NUMBER

1E41-F004

VALVE DESCRIPTION

PUMP SUCT FRM COND STOR TANK

VALVE FUNCTION

HPCI CST SUCTION VALVE

SAFETY ACTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PELD+PV+PVEL1

MAXIMUM DP ON OPEN OR CLOSE

CLOSE

MAXIMUM DP UPSTREAM/DOWNSTREAM

UPSTREAM

SAFETY ACTION ON OPEN/CLOSE

CLOSE

VALUES USED:

PELD = 29.22

PV = 0.374

PVEL1 = 0

DP (PSID)

29.594

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: LB Harkins DATE 09/20/86UNIT 1 HPCI MOTOR OPER VALVE Reviewed By: W. T. Barr DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-015 SHEET 37 OF 61.

DIFFERENTIAL PRESSURE CALCULATION 09/19/86

<u>MPL NUMBER</u>	1E41-F006
<u>VALVE DESCRIPTION</u>	HPCI PUMP INBD DISCH VALVE
<u>VALVE FUNCTION</u>	HPCI INJECTION/ISOLATION VALVE
<u>SAFETY ACTION (YES/NO)</u>	YES
<u>DP CALCULATION FORMULA</u>	DP=PSOH-PISO-PEL
<u>MAXIMUM DP ON OPEN OR CLOSE</u>	OPEN
<u>MAXIMUM DP UPSTREAM/DOWNSTREAM</u>	UPSTREAM
<u>SAFETY ACTION ON OPEN/CLOSE</u>	OPEN/CLOSE
<u>VALUES USED:</u>	

PSOH	=	2260
PISO	=	850
PEL	=	6.19

<u>DP (PSID)</u>	1403.81
------------------	---------

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1	Prepared By: <i>JB Hinkle</i>	DATE 09/21/86
UNIT 1 HPCI MOTOR OPER VALVE	Reviewed By: <i>Chen</i>	DATE 09/21/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-015	SHEET 40 OF 61.

DIFFERENTIAL PRESSURE CALCULATION 09/21/86

<u>MPL NUMBER</u>	1E41-F006
<u>VALVE DESCRIPTION</u>	HPCI PUMP INBD DISCH VALVE
<u>VALVE FUNCTION</u>	HPCI INJECTION/ISOLATION VALVE
<u>SAFETY ACTION (YES/NO)</u>	YES
<u>DP CALCULATION FORMULA</u>	DP=PSOH-PISO-PEL+PVEL2
<u>MAXIMUM DP ON OPEN OR CLOSE</u>	CLOSE
<u>MAXIMUM DP UPSTREAM/DOWNSTREAM</u>	UPSTREAM
<u>SAFETY ACTION ON OPEN/CLOSE</u>	OPEN/CLOSE
<u>VALUES USED:</u>	
PSOH	= 2260
PISO	= 850
PEL	= 6.19
PVEL2	= 8.076
<u>DP (PSID)</u>	1411.886

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1

Prepared By: *J.B. Hudson*

DATE 09/20/86

UNIT 1 HPCI MOTOR OPER VALVE

Reviewed By: *W.T. Barn*

DATE 09/20/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-015

SHEET 41 OF 61.

DIFFERENTIAL PRESSURE CALCULATION09/19/86MPL NUMBER

1E41-F006

VALVE DESCRIPTION

HPCI PUMP INBD DISCH VALVE

VALVE FUNCTION

HPCI INJECTION/ISOLATION VALVE

SAFETY ACTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PSOH-PISO-PEL+PVEL2

MAXIMUM DP ON OPEN OR CLOSE

CLOSE

MAXIMUM DP UPSTREAM/DOWNSTREAM

UPSTREAM

SAFETY ACTION ON OPEN/CLOSE

OPEN/CLOSE

VALUES USED:

PSOH	=	2260
PISO	=	850
PEL	=	6.19
PVEL2	=	8.377

DP (PSID)

1412.187

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: T.B. Haskins DATE 09/20/86UNIT 1 HPCI MOTOR OPER VALVE Reviewed By: W.T. Barr DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-015 SHEET 42 OF 61.

DIFFERENTIAL PRESSURE CALCULATION 09/19/86

<u>MPL NUMBER</u>	1E41-F007
<u>VALVE DESCRIPTION</u>	HPCI PUMP OUTBD DISCH VALVE
<u>VALVE FUNCTION</u>	HPCI INJECTION VALVE TEST VALVE
<u>SAFETY ACTION (YES/NO)</u>	NO
<u>DP CALCULATION FORMULA</u>	NO SAFETY ACTION
<u>MAXIMUM DP ON OPEN OR CLOSE</u>	N/A
<u>MAXIMUM DP UPSTREAM/DOWNSTREAM</u>	N/A
<u>SAFETY ACTION ON OPEN/CLOSE</u>	NONE
<u>VALUES USED:</u>	

<u>DP (PSID)</u>	N/A
------------------	-----

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1	Prepared By: <i>J.B. Harkin</i>	DATE 09/20/86
UNIT 1 HPCI MOTOR OPER VALVE	Reviewed By: <i>W.T. Bass</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-015	SHEET 43 OF 61
DIFFERENTIAL PRESSURE CALCULATION		09/19/86

<u>MPL NUMBER</u>	1E41-F008
<u>VALVE DESCRIPTION</u>	TEST BYPASS VALVE TO COND STOR
<u>VALVE FUNCTION</u>	HPCI CST TEST RETURN VALVE
<u>SAFETY ACTION (YES/NO)</u>	NO
<u>DP CALCULATION FORMULA</u>	NO SAFETY ACTION
<u>MAXIMUM DP ON OPEN OR CLOSE</u>	N/A
<u>MAXIMUM DP UPSTREAM/DOWNSTREAM</u>	N/A
<u>SAFETY ACTION ON OPEN/CLOSE</u>	NONE
<u>VALUES USED:</u>	

<u>DP (PSID)</u>	N/A
------------------	-----

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1	Prepared By: <i>L.B. Hatcher</i>	DATE 09/20/86
UNIT 1 HPCI MOTOR OPER VALVE	Reviewed By: <i>W.T. Bass</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-015	SHEET 44 OF 61.

DIFFERENTIAL PRESSURE CALCULATION 09/19/86

<u>MPL NUMBER</u>	1E41-F011
<u>VALVE DESCRIPTION</u>	REDUNDANT SHUTOFF W/F008
<u>VALVE FUNCTION</u>	HPCI CST TEST RETURN VALVE
<u>SAFETY ACTION (YES/NO)</u>	NO
<u>DP CALCULATION FORMULA</u>	NO SAFETY ACTION
<u>MAXIMUM DP ON OPEN OR CLOSE</u>	N/A
<u>MAXIMUM DP UPSTREAM/DOWNSTREAM</u>	N/A
<u>SAFETY ACTION ON OPEN/CLOSE</u>	NONE
<u>VALUES USED:</u>	

<u>DP (PSID)</u>	N/A
------------------	-----

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: *J.B. Hatcher* DATE 09/26/86UNIT 1 HPCI MOTOR OPER VALVE Reviewed By: *W.T. Bass* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-015 SHEET 45 OF 61.

DIFFERENTIAL PRESSURE CALCULATION 09/19/86MPL NUMBER

1E41-F012

VALVE DESCRIPTION

PMP MIN FLO BYP TO SUPP POOL

VALVE FUNCTION

HPCI PUMP MIN FLO BYP ISOL VALVE

SAFETY ACTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PSOH+PELM

MAXIMUM DP ON OPEN OR CLOSE

OPEN

MAXIMUM DP UPSTREAM/DOWNSTREAM

UPSTREAM

SAFETY ACTION ON OPEN/CLOSE

OPEN/CLOSE

VALUES USED:

PSOH = 2260
PELM = 29.37

DP (PSID)

2289.37

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: *Z.B. Harkins* DATE 09/20/86
UNIT 1 HPCI MOTOR OPER VALVE Reviewed By: *W.T. Barr* DATE 09/20/86
DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-015 SHEET 46 OF 61.

DIFFERENTIAL PRESSURE CALCULATION 09/19/86

<u>MPL NUMBER</u>	1E41-F012
<u>VALVE DESCRIPTION</u>	PMP MIN FLO BYP TO SUPP POOL
<u>VALVE FUNCTION</u>	HPCI PUMP MIN FLO BYP ISOL VALVE
<u>SAFETY ACTION (YES/NO)</u>	YES
<u>DP CALCULATION FORMULA</u>	DP=PMF+PELM+PVEL3
<u>MAXIMUM DP ON OPEN OR CLOSE</u>	CLOSE
<u>MAXIMUM DP UPSTREAM/DOWNSTREAM</u>	UPSTREAM
<u>SAFETY ACTION ON OPEN/CLOSE</u>	OPEN/CLOSE

VALUES USED:

PMF	=	2255
PELM	=	29.37
PVEL3	=	5.541

DP (PSID) 2289.911

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: J.B. Hinkle DATE 09/20/86
UNIT 1 HPCI MOTOR OPER VALVE Reviewed By: W.T. Barn DATE 09/20/86
DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-015 SHEET 47 OF 61.

DIFFERENTIAL PRESSURE CALCULATION 09/19/86

<u>MPL NUMBER</u>	1E41-F041
<u>VALVE DESCRIPTION</u>	PMP SUCT FROM SUPP POOL
<u>VALVE FUNCTION</u>	HPCI SUPP POOL SUCT ISOL VALVE
<u>SAFETY ACTION (YES/NO)</u>	YES
<u>DP CALCULATION FORMULA</u>	DP=PRV-PELS
<u>MAXIMUM DP ON OPEN OR CLOSE</u>	OPEN
<u>MAXIMUM DP UPSTREAM/DOWNSTREAM</u>	DOWNSTREAM
<u>SAFETY ACTION ON OPEN/CLOSE</u>	OPEN/CLOSE
<u>VALUES USED:</u>	
PRV	= 100
PELS	= 4.28

DP (PSID) 95.72

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1	Prepared By: <i>J. B. Hinkley</i>	DATE 09/20/86
UNIT 1 HPCI MOTOR OPER VALVE	Reviewed By: <i>W. T. Ban</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-015	SHEET 48 OF 61.

DIFFERENTIAL PRESSURE CALCULATION 09/19/86

<u>MPL NUMBER</u>	1E41-F041
<u>VALVE DESCRIPTION</u>	PMP SUCT FROM SUPP POOL
<u>VALVE FUNCTION</u>	HPCI SUPP POOL SUCT ISOL VALVE
<u>SAFETY ACTION (YES/NO)</u>	YES
<u>DP CALCULATION FORMULA</u>	DP=PLOC+PLOM1
<u>MAXIMUM DP ON OPEN OR CLOSE</u>	CLOSE
<u>MAXIMUM DP UPSTREAM/DOWNSTREAM</u>	UPSTREAM
<u>SAFETY ACTION ON OPEN/CLOSE</u>	OPEN/CLOSE
<u>VALUES USED:</u>	

PLOC	=	30.5
PLOM1	=	5.43

<u>DP (PSID)</u>	35.93
------------------	-------

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: *Z.B. Haskin* DATE 09/20/86
UNIT 1 HPCI MOTOR OPER VALVE Reviewed By: *W.T. Barr* DATE 09/20/86
DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-015 SHEET 49 OF 61.

DIFFERENTIAL PRESSURE CALCULATION 09/19/86

<u>MPL NUMBER</u>	1E41-F042
<u>VALVE DESCRIPTION</u>	PMP SUCT FROM SUPP POOL
<u>VALVE FUNCTION</u>	HPCI SUPP POOL SUCT ISOL VALVE
<u>SAFETY ACTION (YES/NO)</u>	YES
<u>DP CALCULATION FORMULA</u>	DP=PRV-PELS
<u>MAXIMUM DP ON OPEN OR CLOSE</u>	OPEN
<u>MAXIMUM DP UPSTREAM/DOWNSTREAM</u>	DOWNSTREAM
<u>SAFETY ACTION ON OPEN/CLOSE</u>	OPEN/CLOSE
<u>VALUES USED:</u>	
PRV	= 100
PELS	= 4.28

DP (PSID) 95.72

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: *L.B. Harkin* DATE 09/20/86UNIT 1 HPCI MOTOR OPER VALVE Reviewed By: *W.T. Ban* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-015 SHEET 50 OF 61

DIFFERENTIAL PRESSURE CALCULATION 09/19/86MPL NUMBER

1E41-F042

VALVE DESCRIPTION

PMP SUCT FROM SUPP POOL

VALVE FUNCTION

HPCI SUPP POOL SUCT ISOL VALVE

SAFETY ACTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PLOC+PLOM1

MAXIMUM DP ON OPEN OR CLOSE

CLOSE

MAXIMUM DP UPSTREAM/DOWNSTREAM

UPSTREAM

SAFETY ACTION ON OPEN/CLOSE

OPEN/CLOSE

VALUES USED:

PLOC = 30.5

PLOM1 = 5.43

DP (PSID)

35.93

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: Y. B. Harker DATE 09/20/86UNIT 1 HPCI MOTOR OPER VALVE Reviewed By: W. T. Bar DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-015 SHEET 51 OF 61.

DIFFERENTIAL PRESSURE CALCULATION 09/19/86MPL NUMBER

1E41-F059

VALVE DESCRIPTION

COOLING WATER SUPPLY VALVE

VALVE FUNCTION

HPCI TURBINE ACCES COOLING WTR VLV

SAFETY ACTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PC+PLOM2

MAXIMUM DP ON OPEN OR CLOSE

OPEN

MAXIMUM DP UPSTREAM/DOWNSTREAM

UPSTREAM

SAFETY ACTION ON OPEN/CLOSE

OPEN/CLOSE

VALUES USED:

PC = 30.5

PLOM2 = 6.44

DP (PSID)

36.94

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: *J. B. Haskin* DATE 09/20/86UNIT 1 HPCI MOTOR OPER VALVE Reviewed By: *W. T. Ban* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-015 SHEET 52 OF 61.

DIFFERENTIAL PRESSURE CALCULATION 09/19/86MPL NUMBER

1E41-F059

VALVE DESCRIPTION

COOLING WATER SUPPLY VALVE

VALVE FUNCTION

HPCI TURBINE ACCES COOLING WTR VLV

SAFETY ACTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PC+PLOM2+PVEL4

MAXIMUM DP ON OPEN OR CLOSE

CLOSE

MAXIMUM DP UPSTREAM/DOWNSTREAM

UPSTREAM

SAFETY ACTION ON OPEN/CLOSE

OPEN/CLOSE

VALUES USED:

PC = 30.5
PLOM2 = 6.44
PVEL4 = 0.917

DP (PSID)

37.857

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1	Prepared By: <i>J. B. H. Kline</i>	DATE 09/26/86
UNIT 1 HPCI MOTOR OPER VALVE	Reviewed By: <i>W. T. Bass</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-015	SHEET 53 OF 61 .

DIFFERENTIAL PRESSURE CALCULATION 09/19/86

<u>MPL NUMBER</u>	1E41-F111
<u>VALVE DESCRIPTION</u>	GATE VALVE 2 IN MO
<u>VALVE FUNCTION</u>	HPCI VAC BREAKER LINE ISOL VALVE
<u>SAFETY ACTION (YES/NO)</u>	YES
<u>DP CALCULATION FORMULA</u>	DP=PC+PATM
<u>MAXIMUM DP ON OPEN OR CLOSE</u>	CLOSE
<u>MAXIMUM DP UPSTREAM/DOWNSTREAM</u>	UPSTREAM
<u>SAFETY ACTION ON OPEN/CLOSE</u>	CLOSE
<u>VALUES USED:</u>	

PC	= 30.5
PATM	= 0

<u>DP (PSID)</u>	30.5
------------------	------

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: *J. B. Hinkle* DATE 09/20/86UNIT 1 HPCI MOTOR OPER VALVE Reviewed By: *W. T. Ban* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-015 SHEET 54 OF 61.

DIFFERENTIAL PRESSURE CALCULATION 09/19/86MPL NUMBER

1E41-F104

VALVE DESCRIPTION

GATE VALVE 2 IN MO

VALVE FUNCTION

HPCI VAC BREAKER LINE ISOL VALVE

SAFETY ACTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PC+PATM

MAXIMUM DP ON OPEN OR CLOSE

CLOSE

MAXIMUM DP UPSTREAM/DOWNSTREAM

UPSTREAM

SAFETY ACTION ON OPEN/CLOSE

CLOSE

VALUES USED:

PC = 30.5

PATM = 0

DP (PSID)

30.5

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>David C. Wilson</i>	Date 09/19/86
Subject/Title Unit 1 HPCI Motor Operated Valve	Reviewed By <i>[Signature]</i>	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-015	Sheet 55 of 61

GATE VALVE PVEL CALCULATIONS

PAGE 1 OF 3

A3: [W11] ^MPL
 B3: ^VALVE
 C3: ^CLOSING
 D3: ^UPSTR
 E3: ^DNSTR
 F3: 'UPSTRSYS
 G3: 'DNSTRSYS
 I3: ^dT UP
 J3: ^dTDN
 K3: ^TIMEu1
 L3: ^TIMEu2
 M3: ^TIMEd1
 N3: ^TIMEd2
 O3: ^RISEu1
 P3: ^RISEu2
 Q3: ^RISEd1
 R3: ^RISEd2
 S3: ^CHORDu1
 T3: ^CHORDu2
 U3: ^CHORDd1
 V3: ^CHORDd2
 W3: 'MAX AREA
 X3: ^Aflul
 Y3: ^Aflu2
 Z3: ^Afld1
 AA3: ^Afld2
 AB3: ^a/Au1
 AC3: ^a/Au2
 AD3: ^a/Ad1
 AE3: ^a/Ad2
 AF3: ^Vu1
 AG3: ^Vu2
 AH3: ^Vd1
 AI3: ^Vd2
 AJ3: ^dVu
 AK3: ^dVd
 AL3: ^Pvu
 AM3: ^Pvd
 AN3: ^Pvel
 A4: [W11] ^NUMBER
 B4: ^DIA, "
 C4: ^T, SECS
 D4: ^PIPE L'
 E4: ^PIPE L'
 F4: ^VEL FPS
 G4: ^VEL FPS
 W4: 'FLOW
 A5: [W11] \-

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>Dawn C. Wilson</i>	Date 09/19/86
Subject/Title Unit 1 HPCI Motor Operated Valve	Reviewed By <i>A. J. M. H.</i>	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-015	Sheet 56 of 61

GATE VALVE PVEL CALCULATIONS

PAGE 2 OF 3

B5: \-
 C5: \-
 D5: \-
 E5: \-
 F5: \-
 G5: \-
 H5: [W2] \-
 I5: \-
 J5: \-
 K5: \-
 L5: \-
 M5: \-
 N5: \-
 O5: \-
 P5: \-
 Q5: \-
 R5: \-
 S5: \-
 T5: \-
 U5: \-
 V5: \-
 W5: \-
 X5: \-
 Y5: \-
 Z5: \-
 AA5: \-
 AB5: \-
 AC5: \-
 AD5: \-
 AE5: \-
 AF5: \-
 AG5: \-
 AH5: \-
 AI5: \-
 AJ5: \-
 AK5: \-
 AL5: \-
 AM5: \-
 AN5: \-
 A6: [W11] '1E51-F013
 B6: 3+5/16
 C6: 15
 D6: 99.9
 E6: 16.6
 F6: 11.62
 G6: 12.46
 H6: [W2] '|
 I6: (2*D6)/\$D\$29

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>Dawn C. Wilson</i>	Date 09/19/86
Subject/Title Unit 1 HPCI Motor Operated Valve	Reviewed By <i>AL M. Hall</i>	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-015	Sheet 57 of 61

GATE VALVE PVEL CALCULATIONS

PAGE 3 OF 3

J6: $(2 * E6) / \$D\29
 K6: $(\$D\$30 * \$C6) - I6$
 L6: $+\$D\$30 * \$C6$
 M6: $(\$D\$30 * \$C6) - J6$
 N6: $+\$D\$30 * \$C6$
 O6: $(K6 / \$C6) * (\$B6 / 2)$
 P6: $(L6 / \$C6) * (\$B6 / 2)$
 Q6: $(M6 / \$C6) * (\$B6 / 2)$
 R6: $(N6 / \$C6) * (\$B6 / 2)$
 S6: $@SQRT(8 * O6 * ((\$B6 / 2) - (O6 / 2)))$
 T6: $@SQRT(8 * P6 * ((\$B6 / 2) - (P6 / 2)))$
 U6: $@SQRT(8 * Q6 * ((\$B6 / 2) - (Q6 / 2)))$
 V6: $@SQRT(8 * R6 * ((\$B6 / 2) - (R6 / 2)))$
 W6: $2 * ((1 / 12) * (((3 * B6 * B6) / 4) + (4 * B6 * B6)))$
 X6: $(F6) (W6) - (2 * ((O6 / (6 * S6)) * ((3 * O6 * O6) + (4 * S6 * S6))))$
 Y6: $(F6) (W6) - (2 * ((P6 / (6 * T6)) * ((3 * P6 * P6) + (4 * T6 * T6))))$
 Z6: $(F6) (\$W6) - (2 * ((Q6 / (6 * U6)) * ((3 * Q6 * Q6) + (4 * U6 * U6))))$
 AA6: $(F6) (\$W6) - (2 * ((R6 / (6 * V6)) * ((3 * R6 * R6) + (4 * V6 * V6))))$
 AB6: $(F6) + X6 / ((@PI * \$B6 * \$B6) / 4)$
 AC6: $(F6) + Y6 / ((@PI * \$B6 * \$B6) / 4)$
 AD6: $(F6) + Z6 / ((@PI * \$B6 * \$B6) / 4)$
 AE6: $(F6) + AA6 / ((@PI * \$B6 * \$B6) / 4)$
 AF6: $(F6) + AB6 * \$F6$
 AG6: $(F6) + AC6 * \$F6$
 AH6: $(F6) + AD6 * \$G6$
 AI6: $(F6) + AE6 * \$G6$
 AJ6: $(F6) + AF6 - AG6$
 AK6: $(F6) + AH6 - AI6$
 AL6: $(F6) (AJ6 * \$D\$28 * \$D\$29) / (144 * 32.2)$
 AM6: $(F6) (AK6 * \$D\$28 * \$D\$29) / (144 * 32.2)$
 AN6: $(F6) + AL6 + AM6$
 C28: 'DENSITY
 D28: 61.996
 E28: 'LB/FT3
 C29: 'C
 D29: 4000
 E29: 'FT/SEC
 C30: 'FUDGE FAC
 D30: 1
 E30: 'DIMLESS

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>Kevin C. Wilson</i>	Date 09/19/86
Subject/Title Unit 1 HPCI Motor Operated Valve	Reviewed By <i>[Signature]</i>	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-015	Sheet 58 of 61

FOUR INCH GLOBE VALVE PVEL CALCULATIONS

PAGE 1 OF 2

A3: [W11] ^MPL
 B3: ^VALVE
 C3: ^CLOSING
 D3: ^UPSTR
 E3: ^DNSTR
 F3: 'UPSTRSYS
 G3: 'DNSTRSYS
 I3: ^dT UP
 J3: ^dTDN
 K3: ^TIMEu1
 L3: ^TIMEu2
 M3: ^TIMEd1
 N3: ^TIMEd2
 O3: ^% OPEN
 P3: ^% OPEN
 Q3: ^% OPEN
 R3: ^% OPEN
 S3: ^% CV
 T3: ^% CV
 U3: ^% CV
 V3: ^% CV
 W3: ^dVu
 X3: ^dVd
 Y3: ^Pvu
 Z3: ^Pvd
 AA3: ^Pvel
 A4: [W11] ^NUMBER
 B4: ^DIA, "
 C4: ^T, SECS
 D4: ^PIPE L'
 E4: ^PIPE L'
 F4: ^VEL FPS
 G4: ^VEL FPS
 O4: ^UPSTR1
 P4: ^UPSTR2
 Q4: ^DNSTR1
 R4: ^DNSTR2
 S4: ^UPSTR1
 T4: ^UPSTR2
 U4: ^DNSTR1
 V4: ^DNSTR2
 A5: [W11]
 B5: /-
 C5: /-
 D5: /-
 E5: /-
 F5: /-
 G5: /-

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>Dawn C. Wilson</i>	Date 09/19/86
Subject/Title Unit 1 HPCI Motor Operated Valve	Reviewed By <i>MD M. H. L.</i>	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-015	Sheet 59 of 61

FOUR INCH GLOBE VALVE PVEL CALCULATIONS

PAGE 2 OF 2

H5: [W2] \-

I5: \-

J5: \-

K5: \-

L5: \-

M5: \-

N5: \-

O5: \-

P5: \-

Q5: \-

R5: \-

S5: \-

T5: \-

U5: \-

V5: \-

W5: \-

X5: \-

Y5: \-

Z5: \-

AA5: \-

A6: [W11] '1E41-F012

B6: 2.5

C6: 10

D6: 61.05

E6: 38.958

F6: 12.561

G6: 11.347

H6: [W2] '|

I6: (2*D6)/\$D\$24

J6: (2*E6)/\$D\$24

K6: +\$C6*0.5

L6: +\$C6*0.5+I6

M6: +\$C6*0.5

N6: +\$C6*0.5+J6

O6: (+K6*100)/\$C6

P6: (+L6*100)/\$C6

Q6: (+M6*100)/\$C6

R6: (+N6*100)/\$C6

S6: +O6*1.714

T6: +P6*1.714

U6: +Q6*1.714

V6: +R6*1.714

W6: (+F6*(T6-S6))/100

X6: (+G6*(V6-U6))/100

Y6: (W6*\$D\$23*\$D\$24)/(144*32.2)

Z6: (X6*\$D\$23*\$D\$24)/(144*32.2)

AA6: +Y6+Z6

C23: 'DENSITY

D23: 61.996

E23: 'LB/FT3

C24: 'C

D24: 4000

E24: 'FT/SEC


Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>Dawn C. Wilson</i>	Date 09/19/86
Subject/Title Unit 1 HPCI Motor Operated Valve	Reviewed By <i>AD McNeil</i>	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-015	Sheet 60 of 61

TWO INCH GLOBE VALVE PVEL CALCULATIONS

PAGE 1 OF 2

A3: [W11] ^MPL
 B3: ^VALVE
 C3: ^CLOSING
 D3: ^UPSTR
 E3: ^DNSTR
 F3: 'UPSTRSYS
 G3: 'DNSTRSYS
 I3: ^dT UP
 J3: ^dTDN
 K3: ^TIMEu1
 L3: ^TIMEu2
 M3: ^TIMEd1
 N3: ^TIMEd2
 O3: ^% OPEN
 P3: ^% OPEN
 Q3: ^% OPEN
 R3: ^% OPEN
 S3: ^% CV
 T3: ^% CV
 U3: ^% CV
 V3: ^% CV
 W3: ^dVu
 X3: ^dVd
 Y3: ^Pvu
 Z3: ^Pvd
 AA3: ^Pvel
 A4: [W11] ^NUMBER
 B4: ^DIA, "
 C4: ^T, SECS
 D4: ^PIPE L'
 E4: ^PIPE L'
 F4: ^VEL FPS
 G4: ^VEL FPS
 O4: ^UPSTR1
 P4: ^UPSTR2
 Q4: ^DNSTR1
 R4: ^DNSTR2
 S4: ^UPSTR1
 T4: ^UPSTR2
 U4: ^DNSTR1
 V4: ^DNSTR2
 A5: [W11] \-
 B5: \-
 C5: \-
 D5: \-
 E5: \-
 F5: \-
 G5: \-

Design Calculations

Southern Company Services 

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>Dwight Wilson</i>	Date 09/19/96
Subject/Title Unit 1 HPCI Motor Operated Valve	Reviewed By <i>AL M...</i>	Date 9/21/96
Differential Pressure Calculation	Calculation Number SNH-86-015	Sheet 61 of 61

TWO INCH GLOBE VALVE PVEL CALCULATIONS

PAGE 2 OF 2

H5: [W2] \-

I5: \-

J5: \-

K5: \-

L5: \-

M5: \-

N5: \-

O5: \-

P5: \-

Q5: \-

R5: \-

S5: \-

T5: \-

U5: \-

V5: \-

W5: \-

X5: \-

Y5: \-

Z5: \-

AA5: \-

A6: [W11] '1E41-F059

B6: 1.75

C6: 10

D6: 25

E6: 31.42

F6: 7.601

G6: 7.601

H6: [W2] '|

I6: (2*D6)/\$D\$28

J6: (2*E6)/\$D\$28

K6: +\$C6*0.5

L6: +\$C6*0.5+I6

M6: +\$C6*0.5

N6: +\$C6*0.5+J6

O6: (+K6*100)/\$C6

P6: (+L6*100)/\$C6

Q6: (+M6*100)/\$C6

R6: (+N6*100)/\$C6

S6: +O6*0.8

T6: +P6*0.8

U6: +Q6*0.8

V6: +R6*0.8

W6: (+F6*(T6-S6))/100

X6: (+G6*(V6-U6))/100

Y6: (W6*\$D\$27*\$D\$28)/(144*32.2)

Z6: (X6*\$D\$27*\$D\$28)/(144*32.2)

AA6: +Y6+Z6

C27: 'DENSITY

D27: 61.996


E27: 'LB/FT3

C28: 'C

D28: 4000

E28: 'FT/SEC


ENCLOSURE 2



MPL NUMBER VALVE DESCRIPTION

1E51-F007	RCIC STEAM INBOARD ISOL VALVE
1E51-F008	RCIC STEAM OUTBOARD ISOL VLV
1E51-F010	PUMP SUCT FRM COND STG TMR
#1E51-F012	RCIC PUMP OUTBOARD DISCH VLV
1E51-F013	RCIC PUMP INBOARD DISCH VLV
1E51-F019	TEST BYPASS TO COND STG TANK
#1E51-F022	TEST BYPASS TO COND STG TANK
1E51-F029	RCIC PMP SUCT VLV FRM SUP POOL
1E51-F031	RCIC PMP SUCT VLV FRM SUP POOL
1E51-F043	TURBINE STEAM SUPPLY VALVE
1E51-F046	COOLING WATER SUPPLY VALVE
1E51-F104	GATE VALVE 1.5 IN MO
1E51-F105	GATE VALVE 2 IN MO

FOR
INFORMATION
ONLY



TI APERTURE CARD

Also Available On
Aperture Card


* THESE VALVES HAVE NO SAFETY ACTION ON OPEN/CLOSE
AND THEREFORE DO NOT REQUIRE DP TESTING.

RCIC SYSTEM UNIT NO. 1
MPL NO. E51-1010

SOUTHERN COMPANY SERVICES INC., INC.			
Georgia Power Company, Atlanta, Ga.			
General Engineering Department			
EDWIN HATCH NUCLEAR PLANT UNIT NO. 1			
RCIC SYSTEM FLOW DIAGRAM			
MOV DIFFERENTIAL PRESSURE STUDY			
APPROVAL	DATE	BY	CHKD

8610090442-02

Calculation Cover Sheet

Southern Company Services 

Project E.I. HATCH NUCLEAR PLANT UNIT 1		Calculation Number SNH-86-016
Objective Calculate DP for RCIC Motor Operated Valves		Discipline Mechanical
Subject/Title Unit 1 RCIC Motor Operated Valve Differential Pressure Calculation		SDS Number

Design Engineer's Signature <i>Chris Lorenson</i>	Date 9.19.86	Last Page Number 53
--	-----------------	------------------------

Contents

Topics	Page	Topics	Page
INTRODUCTION	1	DEFINITION OF TERMS	7
Summary of Conclusions	3	DERIVATION OF VALUES	9
Criteria and Assumptions	2		
Listed References	5		
Body of Calculations	9		
(Computer Printout)	49		

Record of Revisions

Rev. No.	Description	Originator Date	Reviewer Date	Proj. Engr. Date
0	APPROVED	<i>CL</i> 9/19/86	<i>WV</i> 9/21/86	<i>CL</i> 9/21/86



Notes

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>Dawn C. Wilson</i>	Date 09/19/86
Subject/Title Unit 1 RCIC Motor Operated Valve	Reviewed By <i>W. T. Barr</i>	Date 9/20/86
Differential Pressure Calculation	Calculation Number SNH-86-016	Sheet / of 53

INTRODUCTION

The Nuclear Regulatory Commission (NRC) IE Bulletin 85-03 (Motor Operated Valve Common Mode Failure) requested that owners of light water reactors develop and implement a program to ensure that torque switch settings on safety related motor-operated valves on high pressure systems are selected, set and maintained correctly to accomodate the maximum differential pressures expected on these valves during both normal and abnormal events within the design basis. The objective of this calculation is to determine the maximum Differential Pressure across each of the affected Unit 1 RCIC Motor Operated Valves.

00451

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By 	Date 9.19.86
Subject/Title Unit 1 RCIC Motor Operated Valve	Reviewed By 	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-016	Sheet 2 of 53

CRITERIA

- 1) The criteria, assumptions and formulas given in the General Electric "BWR Owner's Group Report on the Operational Design Basis of Selected Safety-Related Motor-Operated Valves," DRF-E12-00100-75, are assumed to be correct.

ASSUMPTIONS

- 1) PC is assumed to equal PLOC. The terms are defined as follows:
 - * PLOC is the maximum wet well LOCA pressure.
 - * PC is the maximum wetwell LOCA pressure which the valve is required to operate against.
- 2) In the PVEL calculation, it is assumed that the time required for a sound wave to travel to and return from an atmospheric vessel is infinity. Thus, the related term in the PVEL equation is equal to zero.
- 3) In the PVEL calculation, downstream velocities for lines of equal sizes with differing wall thicknesses are assumed to be equal. The impact upon the downstream pressure increase is small.
- 4) Disc and Port diameters are assumed to be equal. Equal diameters for disc and port yield higher rate of change therefore higher DV and is therefore more conservative.
- 5) The Formula for calculating area of the gate valve available for flow is approximated from a known geometric relationship and is off by a small percentage, however, the overall effect is negligible.
- 6) In the PVEL calculation, it is assumed that where a small line tees into a much larger line (i.e. Larger being two times or greater in diameter) the boundary for the small line ends at the line intersection.

00431

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>C. Lorenson</i>	Date 9.19.86
Subject/Title Unit 1 RCIC Motor Operated Valve	Reviewed By <i>W.T. Barr</i>	Date 9/20/86
Differential Pressure Calculation	Calculation Number SNH-86-016	Sheet 3 of 53

SUMMARY OF CONCLUSIONS

The following page is a summary table of the results for each RCIC motor operated valve in the scope of NRC IEB 85-03.

The first column titled "MPL Number" gives the mpl number of the valve.

The second column titled "Valve Description" is the Description of the Valve given in the Equipment Location Index (ELI).

The third column titled "Valve Function" is the function of the valve as stated in the General Electric "BWR Owners' Group Report on the Operational Design Basis of Selected Safety-Related Motor-Operated Valves."

The fourth column titled "Safety Act" gives the safety action of the valve.

The fifth column titled "DP Calculation Formula" gives the formula used to calculate the maximum differential pressure.

The sixth column titled "Maximum DP" gives the safety action for which the maximum DP was calculated. If the formula is the same for both opening and closing, then both are listed.

The seventh column titled " MAX DP " is where the maximum differential pressure occurs, either upstream or downstream.

The eighth column titled "DP (PSID)" is the calculated maximum Differential Pressure in PSID against which the valve must either open or close.

The ninth column indicates if the valve has any safety function.

00441

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT UNIT 1

PREPARED BY: *C. Stogerman*

DATE 09/20/86

UNIT 1 RCIC MOTOR OPERATED VALVE

REVIEWED BY: *J.B. Haller*

DATE 09/21/86

DIFFERENTIAL PRESSURE CALCULATION

CALC No. SNH-86-016

SHEET 4 OF 53

SUMMARY TABLE 09/21/86

MPL NUMBER	VALVE DESCRIPTION	VALVE FUNCTION	ISOLATION VALVE	SAFETY ACT	DP CALCULATION FORMULA	MAX DP ON	MAXIMUM DP	DP (PSID)	SAFETY
1ES1-F007	RCIC STEAM INBOARD ISOL VALVE	RCIC STEAM LINE	ISOLATION VALVE	CLOSE	DP=PRSS	CLOSE	UPSTREAM	1080	YES
1ES1-F008	RCIC STEAM OUTBOARD ISOL VLV	RCIC STEAM LINE	ISOLATION VALVE	CLOSE	DP=PRSS	CLOSE	UPSTREAM	1080	YES
1ES1-F010	PUMP SUCT FRM COND STG TANK	RCIC CST SUCTION	ISOLATION VALVE	CLOSE	DP=PELD+PV+PVEL1	CLOSE	UPSTREAM	29.406	YES
1ES1-F012	RCIC PUMP OUTBOARD DISCH VLV	RCIC INJECTION VALVE	TEST VALVE	NONE	NO SAFETY ACTION	N/A	N/A	N/A	NO
1ES1-F013	RCIC PUMP INBOARD DISCH VLV	RCIC INJECTION VALVE		OPEN/CLOSE	DP=PRSS+PEL	OPEN/CLOSE	DOWNSTREAM	1115.612	YES
1ES1-F019	TEST BYPASS TO COND STG TANK	RCIC MINIMUM FLOW BYPASS	ISOL VALVE	OPEN/CLOSE	DP=PSOH+PELM	OPEN	UPSTREAM	1305.687	YES
1ES1-F019	TEST BYPASS TO COND STG TANK	RCIC MINIMUM FLOW BYPASS	ISOL VALVE	OPEN/CLOSE	DP=PMF+PELM+PVEL3	CLOSE	UPSTREAM	1307.1232	YES
1ES1-F022	TEST BYPASS TO COND STG TANK	RCIC CST TEST RETURN VALVE		NONE	NO SAFETY ACTION	N/A	N/A	N/A	NO
1ES1-F029	RCIC PMP SUCT VLV FRM SUP POOL	RCIC SUPP POOL SUCTION	ISOL VALVE	OPEN/CLOSE	DP=PRV-PELS	OPEN	DOWNSTREAM	95.367	YES
1ES1-F029	RCIC PMP SUCT VLV FRM SUP POOL	RCIC SUPP POOL SUCTION	ISOL VALVE	OPEN/CLOSE	DP=PLDC+PLOW1	CLOSE	UPSTREAM	36.1	YES
1ES1-F031	RCIC PMP SUCT VLV FRM SUP POOL	RCIC SUPP POOL SUCTION	ISOL VALVE	OPEN/CLOSE	DP=PRV-PELS	OPEN	DOWNSTREAM	95.367	YES
1ES1-F031	RCIC PMP SUCT VLV FRM SUP POOL	RCIC SUPP POOL SUCTION	ISOL VALVE	OPEN/CLOSE	DP=PLDC+PLOW1	CLOSE	UPSTREAM	36.1	YES
1ES1-F045	TURBINE STEAM SUPPLY VALVE	RCIC STEAM ADMISSION VALVE		OPEN/CLOSE	DP=PRSS	OPEN/CLOSE	UPSTREAM	1080	YES
1ES1-F046	COOLING WATER SUPPLY VALVE	RCIC TURBINE ACCESSORY COOL MTR VALVE		OPEN/CLOSE	DP=PSOI+PELC	OPEN	UPSTREAM	288.179	YES
1ES1-F046	COOLING WATER SUPPLY VALVE	RCIC TURBINE ACCESSORY COOL MTR VALVE		OPEN/CLOSE	DP=PLDC+PLOW2+PVEL4	CLOSE	UPSTREAM	37.065	YES
1ES1-F104	GATE VALVE 1.5 IN MD	RCIC VACUUM BREAKER LINE	ISOL VALVE	CLOSE	DP=PC+PATM	CLOSE	UPSTREAM	30.5	YES
1ES1-F105	GATE VALVE 2 IN MD	RCIC VACUUM BREAKER LINE	ISOL VALVE	CLOSE	DP=PC+PATM	CLOSE	UPSTREAM	30.5	YES

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>C. Loren</i>	Date 9-19-86
Subject/Title Unit 1 RCIC Motor Operated Valve	Reviewed By <i>W. T. Ban</i>	Date 9-19-86
Differential Pressure Calculation	Calculation Number SNH-86-016	Sheet 5 of 53

UNIT 1
RCIC MOV CALCULATIONS
REFERENCES

- 1). H-11038 REV. 15 P & I DIAGRAM DEMINERALIZED WATER
- 2). H-16081 REV. 4 FEEDWATER PIPING REACTOR BLDG.
E1. 130'-0" & ABOVE
- 3). S-00090 REV. 0 KELLOGG ISOMETRIC
- 4). S-01467 REV. 5 KELLOGG ISOMETRIC
- 5). S-01469 REV. 0 KELLOGG ISOMETRIC
- 6). S-15290 REV. H GENERAL PLAN - CONTAINMENT
- 7). C-11020 REV. 1 COMPOSITE DRAWING OF MODEL LC RELIEF VALVE
- 8). UNIT NO. 1 TECHNICAL SPECIFICATIONS REV. 08-15-86
- 9). A-16237 REV. 12 SETPOINT INDEX
10. G.E. NEDO 24570 REV.2
11. H-16334 REV. 15 RCIC SYSTEM P & ID SHEET 1
12. H-16335 REV. 11 RCIC SYSTEM P & ID SHEET 2
13. SECTION F CRC HANDBOOK OF CHEMISTRY & PHYSICS
57TH EDITION. CONVERSION FACTORS
14. SECTION B CRANE "FLOW OF FLUIDS" - TECHNICAL PAPER
No. 410. PIPE DATA & FLOW EQUATIONS
15. BECHTEL RCIC SYSTEM CALCULATIONS IBM VOL. 1 BINDER 1 0045
DATED 11/11/71
16. BWR OWNERS GROUP REPORT ON THE OPERATIONAL DESIGN BASIS OF
SELECTED SAFETY RELATED MOTOR OPERATED VALVES,
DRF-E12-00100-75, AUGUST 1986.

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>C. Soren</i>	Date 9-19-86
Subject/Title Unit 2 RCIC Motor Operated Valve	Reviewed By <i>W. T. Barr</i>	Date 9/20/86
Differential Pressure Calculation	Calculation Number SNH-86-018	Sheet 6 of 53

UNIT 1
RCIC MOV CALCULATIONS
REFERENCES (Cont'd)

17. TELEPHONE CONFIRMATION 09-05-86 BETWEEN CHRIS SORENSEN OF SCS AND GORDON PARKS OF BINGHAM PUMP.
18. S-11551 REV. D 900 1b CAST STEEL GATE VALVE - CRANE
19. S-18627 REV. C 2" 1500 1b CS MOTOR OPERATED GLOBE - VELAN
20. S-00089 REV. 27 KELLOGG ISOMETRIC
21. S-01469 REV. 0 KELLOGG ISOMETRIC
22. S-01451 REV. 0 KELLOGG ISOMETRIC
23. S-01452 REV. 0 KELLOGG ISOMETRIC
24. S-00096 REV. 11 KELLOGG ISOMETRIC
25. S-00092 REV. 0 KELLOGG ISOMETRIC
26. S-15066 REV. B RCIC SYSTEM FLOW DIAGRAM
27. HNP-2 FSAR - TABLE 6.2-5 SHEET 2 NOTE 7
28. TELEPHONE CONFIRMATION R. KUBISCK OF VELAN VALVE CO. WITH JACK ROBYN OF SCS ON 9/11/86
29. BWROG ALTERNATIVE METHOD FOR CALCULATION OF PVEL SEPTEMBER 4, 1986.
30. A-16360 DATA SHEETS
31. ENGINEERING FORMULAS 4TH ED. SEGMENT OF CIRCLE AREA EQUATION.

0071d

DESIGN CLACULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1	Prepared By: <i>Dawn C. Wilson</i>	DATE 09/19/86
UNIT 1 RCIC MOTOR OPER VALVE	Reviewed By: <i>W.T. Barr</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-016	SHEET 7 OF 53.

DEFINITION OF TERMS

09/18/86

TERM	DEFINITION OF TERM
DP	VALVE MAXIMUM EXPECTED OPERATING DIFFERENTIAL PRESSURE
PSOH	DIFFERENTIAL PRESSURE DEVELOPED BY SYSTEM MAIN PUMPS AT ZERO FLOW RATE. (MAXIMUM NORMAL TURBINE SPEED)
PEL	MINIMUM HYDROSTATIC PRESSURE DIFFERENCE BETWEEN SUCTION AND DISCHARGE DUE TO ELEVATION. (DISCHARGE ELEVATION IS HIGHER THAN SUCTION)
PISO	LOW REACTOR PRESSURE AT WHICH STEAM SUPPLY LINES AUTOMATICALLY ISOLATE FLOW
PELM	MAXIMUM HYDROSTATIC PRESSURE DIFFERENCE BETWEEN SUCTION AND DISCHARGE SOURCE DUE TO ELEVATION
PRSS	REACTOR PRESSURE CORRESPONDING TO THE SPRING SETPOINT OF THE REACTOR SAFETY RELIEF VALVE WITH THE LOWEST NOMINAL SPRING SETPOINT
PELD	HYDROSTATIC PRESSURE DIFFERENCE BETWEEN CST AND SUPPRESSION POOL ASSUMING THE CST TO BE FULL AND THE SUPPRESSION POOL WATER LEVEL AT ITS MAXIMUM ALLOWABLE NORMAL LEVEL
PMF	DIFFERENTIAL PRESSURE DEVELOPED BY THE SYSTEM MAIN PUMPS AT A FLOW RATE EQUAL TO THE REQUIRED MINIMUM BYPASS FLOW RATE. (MAXIMUM NORMAL TURBINE SPEED)
PV	VELOCITY HEAD IN THE SUPPRESSION POOL SUCTION LINE

DESIGN CLACULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1	Prepared By: <i>Dawn Wilson</i>	DATE 09/19/86
UNIT 1 RCIC MOTOR OPER VALVE	Reviewed By: <i>W.T. Barr</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-016	SHEET 8 OF 53.

DEFINITION OF TERMS	09/18/86
---------------------	----------

<u>TERM</u>	<u>DEFINITION OF TERM</u>
	AT THE LOCATION WHERE THE CST LINE CONNECTS TO IT
PRV	SYSTEM SUCTION RELIEF VALVE ACTUATION SET PRESSURE
PELS	HYDROSTATIC PRESSURE DIFFERENCE BETWEEN THE MINIMUM SUPPRESSION POOL WATER LEVEL AND THE LOCATION OF THE RELIEF VALVE ON THE PUMP SUCTION LINE
PLOC	LOCA WETWELL PRESSURE WHEN THE SYSTEM IS ISOLATED
PLOM	HYDROSTATIC PRESSURE UPSTREAM OF THE VALVE DUE TO MAXIMUM LOCA SUPPRESSION POOL WATER LEVEL
PC	MAXIMUM LOCA WETWELL PRESSURE WHEN SYSTEM IS REQUIRED TO OPERATE (PC IS CONSERVATIVELY TAKEN TO EQUAL PLOC)
PELC	HYDROSTATIC PRESSURE DIFFERENCE BETWEEN CST AND LOCATION OF VALVE WHEN THE CST IS FULL
PSOI	RCIC PUMP DISCHARGE PRESSURE AT ZERO FLOW AND A TURBINE SPEED OF 2000 RPM
PATM	NORMAL ATMOSPHERIC PRESSURE
PVEL	DIFFERENTIAL PRESSURE ASSOCIATED WITH VALVE CLOSURE DUE TO FLUID VELOCITY CHANGES (I.E., WATER HAMMER TYPE PRESSURE INCREASE) INSIDE THE PIPE

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: *C. Sorensen* DATE 09/19/86UNIT 1 RCIC MOTOR OPER VALVE Reviewed By: *W.T. Barn* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-016 SHEET 9 OF 53.

DERIVATION OF VALUES 09/19/86

<u>TERM</u>	<u>PRESSURE (PSIG)</u>	<u>DERIVATION OF VALUE</u>
-------------	------------------------	----------------------------

.

PSOH	1276.271	TELEPHONE CONFIRMATION - C. SORENSEN OF SCS WITH G. PARKS OF BINGHAM PUMP ON SEPTEMBER 5, 1986.
------	----------	--

.

PEL	35.612	THE ELEVATION FOR THE INJECTION POINT OF DISCHARGE IS GIVEN AS 183' 9 1/2" ON DRAWING H-16081 REV. 4.
-----	--------	---

THE CENTERLINE OF THE SUPPRESSION POOL IS
GIVEN AS 103' 6 1/4" AND THE INSIDE DIAMETER
IS GIVEN AS 28' 1" ON DRAWING S-15290 REV. H.
THE INSIDE BOTTOM ELEVATION OF THE
SUPPRESSION POOL IS THE CENTERLINE
MINUS 1/2 THE DIAMETER:

$$103' 6 \frac{1}{4}" - (28' 1")/2 = 89' 5 \frac{3}{4}"$$

THE MINIMUM SUPPRESSION POOL LEVEL IS GIVEN
AS 12' 2" IN THE TECHNICAL SPECIFICATIONS
SECTION 3.7.

THE MINIMUM SUPPRESSION POOL ELEVATION IS
THE BOTTOM ELEVATION PLUS THE MINIMUM LEVEL:

$$89' 5 \frac{3}{4}" + 12' 2" = 101' 7 \frac{3}{4}"$$

THE HYDROSTATIC DIFFERENCE IS THUS:

$$183' 9 \frac{1}{2}" - 101' 7 \frac{3}{4}" = 82' 1 \frac{3}{4}"$$
$$= 985.75" \text{ H}_2\text{O}$$

AND HYDROSTATIC PRESSURE IS:

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: *C. Stevens* DATE 09/19/86UNIT 1 RCIC MOTOR OPER VALVE Reviewed By: *W.T. Barn* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-016 SHEET 10 OF 53.

DERIVATION OF VALUES 09/19/86TERM PRESSURE (PSIG) DERIVATION OF VALUE

PEL 985.75" H2O / 27.6807"H2O/PSIG
= 35.612 PSIG

PISO 850 A-16237 UNIT 1 REV 12 INSTRUMENT SETPOINT INDEX
FOR INSTRUMENTS 1B21-N015 A-D

PELM 29.416 THE MAXIMUM CST LEVEL IS GIVEN AS 169' 6"
FOR THE SETPOINT OF 1P21-R200 ON DRAWING
H-11038 REV. 15.
THE MINIMUM SUPPRESSION POOL LEVEL WAS
CALCULATED AS 101' 7 3/4" IN THE CALCULATION
FOR PEL ABOVE.
THUS THE HYDROSTATIC DIFFERENCE IS:
 $169' 6" - 101' 7 \frac{3}{4}" = 67' 10 \frac{1}{4}"$
= 814.25 "H2O
HYDROSTATIC PRESSURE IS:
 $814.25"H2O / 27.6807 "H2O/PSIG = 29.416$

PRSS 1080 UNIT 1 TECHNICAL SPECIFICATIONS SECTION 2.2

PELD 29.272 THE MAXIMUM CST LEVEL IS GIVEN AS 169' 6"
FOR THE SETPOINT OF 1P21-R200 ON DRAWING
H-11038 REV. 15.

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1	Prepared By: <i>C. Sorensen</i>	DATE 09/19/86
UNIT 1 RCIC MOTOR OPER VALVE	Reviewed By: <i>W. T. Barr</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-016	SHEET // OF 53.
DERIVATION OF VALUES		09/19/86

TERM	PRESSURE (PSIG)	DERIVATION OF VALUE
------	-----------------	---------------------

PELD

THE INSIDE BOTTOM ELEVATION OF THE SUPPRESSION POOL WAS CALCULATED AS 89' 5 3/4" IN THE CALCULATION FOR PEL. THE MAXIMUM SUPPRESSION POOL LEVEL IS GIVEN AS 12' 6" IN THE UNIT 1 TECHNICAL SPECIFICATIONS SECTION 3.7 THE MAXIMUM ELEVATION LEVEL OF THE SUPPRESSION POOL IS:

$$89' 5 \frac{3}{4}" + 12' 6" = 101' 11 \frac{3}{4}"$$

THUS THE HYDROSTATIC DIFFERENCE IS:

$$169' 6" - 101' 11 \frac{3}{4}" = 67' 6 \frac{1}{4}"$$

$$= 810.25 \text{ "H}_2\text{O}$$

HYDROSTATIC PRESSURE EQUALS:

$$810.25 \text{ "H}_2\text{O} / 27.6807 \text{ "H}_2\text{O/PSIG} = 29.272$$

PMF 1276.271

TELEPHONE CONFIRMATION - CHRIS SORENSEN OF SCS WITH G. PARKS OF BINGHAM PUMP ON SEPTEMBER 5, 1986.

PV 0.134

THE RCIC SYSTEM RATED FLOW IS GIVEN AS 198,930 lbm/hr IN BECHTEL CALCULATION 1BM VOL 01 BINDER 01 0045. THE SIZE OF THE SUCTION LINE IS GIVEN AS 6" SCH 40 ON DWG. S-00090 REV. 0. THE

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1

Prepared By: *C. Foreman*

DATE 09/19/86

UNIT 1 RCIC MOTOR OPER VALVE

Reviewed By: *W. T. Barr*

DATE 09/20/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-016

SHEET 12 OF 53

DERIVATION OF VALUES09/19/86TERM PRESSURE (PSIG) DERIVATION OF VALUE

PV

INTERNAL DIAMETER IS GIVEN IN CRANE AS 6.065".

 $6.065 \text{ INCHES} / 12 \text{ INCHES/FOOT} = 0.5054 \text{ FEET}$

THE VELOCITY HEAD IS EQUAL TO:

' $[V]^2 / 2 \times g_c, \text{FROM (CRANE 410 EQ NO. 2-1)}$ ' WHERE g_c IS THE GRAVITATIONAL CONSTANT' $g_c = 32.2 \text{ ft}/(\text{sec}^2)$ ' and $V = Q/A$, FROM (CRANE 410 EQ NO. 3-2) $PI = 3.1416$ $V = (198,930 \text{ lbm/hr}) \times (0.01613 \text{ ft}^3/\text{lbm}) /$ ' $[PI \times (0.5054^2)/4] \times 3600$ ' $= 4.46 \text{ ft/sec}$

VELOCITY HEAD IS:

' $[4.46^2] / 2 \times 32.2 = 0.309 \text{ ft H}_2\text{O}$

VELOCITY HEAD PRESSURE IS:

' $0.309 \text{ FT H}_2\text{O} \times 0.432781 \text{ PSIG/FT H}_2\text{O}$ ' $= 0.134 \text{ PSIG}$

PRV 100

DWG C-11020 REV. 1 VALVE COMPOSITE DRAWING FOR

E51-F018 GIVES THE RELIEF SETTING OF 100 PSIG

PELS 4.633

THE MINIMUM SUPPRESSION POOL ELEVATION WAS

DETERMINED TO BE 101' 7 3/4" IN THE

CALCULATION FOR PEL.

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1	Prepared By: <i>C. Loren</i>	DATE 09/19/86
UNIT 1 RCIC MOTOR OPER VALVE	Reviewed By: <i>W.T. Ban</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-016	SHEET /3 OF 53.
DERIVATION OF VALUES		09/19/86

<u>TERM</u>	<u>PRESSURE (PSIG)</u>	<u>DERIVATION OF VALUE</u>
-------------	------------------------	----------------------------

PELS THE ELEVATION FOR THE SUCTION RELIEF VALVE
1E51-F017 IS GIVEN AS 90'-11 1/2" ON DRAWING
S-01467 REV. 5.

THUS THE HYDROSTATIC DIFFERENCE IS:

$$101' 7 \frac{3}{4}" - 90' -11 \frac{1}{2}" = 10' -8' 1 \frac{1}{4}"$$

$$= 128.25 \text{ "H}_2\text{O}$$

HYDROSTATIC PRESSURE IS:

$$128.25 \text{ "H}_2\text{O} / 27.6807 \text{ "H}_2\text{O/PSIG} = 4.633$$

PLOC 30.5

NEDO-24570-2 FIG H1 4.1.2-1 PG 12

PLOM1 5.6

THE ACCIDENT SUPPRESSION POOL LEVEL IS GIVEN
AS 102' 7 1/2" ON DRAWING S-15290 REV. H.

THE ELEVATION FOR THE SUPPRESSION POOL

ISOLATION VALVES 1E51-F029 AND F031 ARE GIVEN

AS 89' 8 7/8" ON DRAWING S-00090 REV. 0.

THUS THE HYDROSTATIC DIFFERENCE IS:

$$102' 7 \frac{1}{2}" - 89' 8 \frac{7}{8}" = 12' 10 \frac{5}{8}"$$

$$= 154.625 \text{ "H}_2\text{O}$$

THE HYDROSTATIC PRESSURE IS:

$$154.625 \text{ "H}_2\text{O} / 27.6087 \text{ "H}_2\text{O/PSIG} = 5.60$$

PLOM2 6.449

THE ACCIDENT SUPPRESSION POOL LEVEL IS GIVEN

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: *C. Loren* DATE 09/19/86UNIT 1 RCIC MOTOR OPER VALVE Reviewed By: *W.T. Ban* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-016 SHEET 14 OF 53.

DERIVATION OF VALUES 09/19/86

<u>TERM</u>	<u>PRESSURE (PSIG)</u>	<u>DERIVATION OF VALUE</u>
-------------	------------------------	----------------------------

PLOM2

AS 102' 7 1/2" ON DRAWING S-15290 REV. H.

THE ELEVATION FOR THE TURBINE ACCESSORIES

VALVE 1E51-F046 IS GIVEN AS 87' 9" ON

DRAWING S-01469 REV. 0.

THUS THE HYDROSTATIC DIFFERENCE IS:

.

. 102' 7 1/2" - 87' 9" = 14' 10 1/2"

. = 178.5" H2O

THE HYDROSTATIC PRESSURE IS:

178.5 "H2O / 27.6807 "H2O/PSIG = 6.449

.

PC 30.5

PC=PLOC

.

PELC 35.44

THE MAXIMUM CST LEVEL IS GIVEN AS 169' 6"

PER SETPOINT FOR 1P21-R200 ON DRAWING H-11038

REV. 15.

THE ELEVATION FOR THE RCIC TURBINE

ACCESSORIES COOLING WATER VALVE 1E51-F046 IS

GIVEN AS 87' 9" ON DRAWING S-01469 REV. 0.

THUS THE HYDROSTATIC DIFFERENCE IS:

169' 6" - 87' 9" = 81' 9"

= 981 "H2O

THE HYDROSTATIC PRESSURE IS:

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1	Prepared By: <i>C. Sorensen</i>	DATE 09/19/86
UNIT 1 RCIC MOTOR OPER VALVE	Reviewed By: <i>W.T. Ban</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-016	SHEET 5 OF 53.
DERIVATION OF VALUES		09/20/86

TERM	PRESSURE (PSIG)	DERIVATION OF VALUE
PELC		981 "H2O / 27.6807 "H2O/PSIG = 35.440
PSOI	252.739	TELEPHONE CONFIRMATION -C.SORENSEN OF SCS AND G. PARKS OF BINGHAM PUMP ON SEPTEMBER 5, 1986. HEAD AT 2000 RPM AND ZERO FLOW = 583 ft = 6996 in 6996 "H2O/27.6807 "H2O/PSIG = 252.739 PSIG
PATM	0	NORMAL ATMOSPHERIC PRESSURE = 14.696 PSIA. PSIG = PSIA - 14.696 = 0
PVEL1	0	KELLOGG ISOMETRIC DRAWINGS S-00096 REV. 0, S-00092 REV. 0, AND S-00090 REV. 0 SHOW THAT THE UPSTREAM PIPING IS CONNECTED TO THE CONDENSATE STORAGE TANK. IT IS ASSUMED THAT ANY WATER HAMMER EFFECTS IN THE UPSTREAM PIPING WOULD BE DISSIPATED WITHIN THE CST VOLUME, AND PRODUCE NO RESULTANT PRESSURE RISE UPON THE VALVE. THE REFERENCED DRAWINGS ALSO SHOW THAT THE DOWNSTREAM PIPING IS INTERCONNECTED WITH THE SUPPRESSION POOL SUCTION LINE. IT IS ASSUMED THAT THE RCIC PUMP IS OPERATING TO DRAW A SUCTION FROM THE SUPPRESSION POOL WHEN E51-F010 BEGINS TO CLOSE. THEREFORE, NO DOWNSTREAM FLUID

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1	Prepared By: <i>C. Brown</i>	DATE 09/21/86
UNIT 1 RCIC MOTOR OPER VALVE	Reviewed By: <i>J.D. Perkins</i>	DATE 09/21/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-016	SHEET 16 OF 53.
DERIVATION OF VALUES		09/21/86

TERM	PRESSURE (PSIG)	DERIVATION OF VALUE
------	-----------------	---------------------

PVEL1

DECELERATION WILL RESULT. IT MAY BE CONCLUDED THAT NO INCREASE IN PRESSURE BECAUSE OF WATER HAMMER WILL RESULT. CONSIDERING THE ABOVE FACTS, VALVE 1E51-F010 CAN BE CONSIDERED TO HAVE NO WATER HAMMER PRESSURE INCREASE. THEREFORE PVEL1 = 0.

PVEL2 3.194

SYSTEM VELOCITY FOR 1E51-F013

FLOW RATE = 400 GPM FROM S-15066 REV. B

RCIC FLOW DIAGRAM

AREA OF 4" SCH 80 PIPE = 11.50 IN SQ

AREA OF 4" SCH 120 PIPE = 10.31 IN SQ

CRANE 410

VELOCITY UPSTREAM = $[400 \text{ GPM} \times 0.321] / 11.50 \text{ IN SQ}$

= 11.17 FT/SEC

VELOCITY DOWNSTRM = $[400 \text{ GPM} \times 0.321] / 10.31 \text{ IN SQ}$

= 12.45 FT/SEC

CLOSURE TIME

TC = 15 SEC FROM DATA SHEET A-16360

VALVE THROAT DIAMETER

VALVE DIAMETER = 3 5/16"

900 L CAST STEEL GATE VALVE S-11551 REV. D

LENGTH UPSTREAM (LU) AND DOWNSTREAM (LD)

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1	Prepared By: <i>C. J. Brennan</i>	DATE 09/21/86
UNIT 1 RCIC MOTOR OPER VALVE	Reviewed By: <i>J. B. Hallin</i>	DATE 09/21/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-016	SHEET 17 OF 53
DERIVATION OF VALUES		09/21/86

<u>TERM</u>	<u>PRESSURE (PSIG)</u>	<u>DERIVATION OF VALUE</u>
-------------	------------------------	----------------------------

PVEL2

LU = 102.44 FT

KELLOGG ISOMETRIC DWE S-00089 REV. 0.

LD = 16.6 FT

KELLOGG ISOMETRIC DWG S-00089 REV. 0.

PVEL2=3.194 FROM COMPUTER PRINTOUT

PVEL3 1.4362

SYSTEM VELOCITY FOR 1E51-F019

FLOW RATE = 50 GPM FROM S-15066 REV. B

RCIC SYSTEM FLOW DIAGRAM

AREA OF 2" SCH 80 PIPE = 2.953 IN**2

CRANE 410

VELOCITY = [50 GPM X 0.321]/2.953 IN**2

=5.435 FT/SEC

CLOSURE TIME

TC = 10 SEC FROM A-16368 SHT 1

PER STD STROKE TIME FROM HNP-2

FSAR TABLE 6.2-5 SHT 2 NOTE 7

VALVE THROAT DIAMETER

VALVE DIAMETER = 1 3/4"

1500# CS MOTOR OPERATED GLOBE VALVE

S-18627 REV. C.

LENGTH UPSTREAM (LU) AND DOWNSTREAM (LD)

LU = 53.3487 FT

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: *C. Anderson* DATE 09/21/86UNIT 1 RCIC MOTOR OPER VALVE Reviewed By: *T.B. Butler* DATE 09/21/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-016 SHEET /8 OF 53.

DERIVATION OF VALUES 09/21/86

TERM	PRESSURE (PSIG)	DERIVATION OF VALUE
PVEL3		<ul style="list-style-type: none"> . KELLOGG ISOMETRIC DWG S-00089 REV. 0. . KELLOGG ISOMETRIC DWG S-01451 REV 0. . KELLOGG ISOMETRIC DRAWING S-01452 REV 0 . LD = 70.1889 FT . KELLOGG ISOMETRIC DWG S-01451 REV 0. . KELLOGG ISOMETRIC DRAWING S-01452 REV 0.
		PVEL3 = 1.4362 FROM COMPUTER PRINTOUT
PVEL4	0.116	SYSTEM VELOCITY FOR 1E51-F046 <ul style="list-style-type: none"> . FLOW RATE = 16 GPM FROM S-15066 REV. 13 . RCIC SYSTEM FLOW DIAGRAM AREA OF 2" SCH 80 PIPE = 2.953 IN**2 <ul style="list-style-type: none"> . CRANE 410 VELOCITY = [16GPM X 0.321]/2.953 IN**2 <ul style="list-style-type: none"> . = 1.739 FT/SEC CLOSURE TIME <ul style="list-style-type: none"> . TC = 10 SEC FROM A-16368 SHT 1 . PER STD STROKE TIME HNP-2 . FSAR TABLE 6.2-5 SHT2 NOTE 7 VALVE THROAT DIAMETER <ul style="list-style-type: none"> . VALVE DIAMETER = 1 3/4" . 1500# CS MOTOR OPERATED GLOBE VALVE . FROM S-18627 REV. C LENGTH UPSTREAM (LU) AND DOWNSTREAM (LD)

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: *C. Foreman* DATE 09/19/86UNIT 1 RCIC MOTOR OPER VALVE Reviewed By: *J.D. Hall* DATE 09/21/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-016 SHEET 19 OF 53.

DERIVATION OF VALUES 09/19/86

<u>TERM</u>	<u>PRESSURE (PSIG)</u>	<u>DERIVATION OF VALUE</u>
-------------	------------------------	----------------------------

PVEL4

.

.

.

.

.

LU = 7 FT

KELLOGG ISOMETRIC DWG S-01469 REV 0.

LD = 24.218 FT

KELLOGG ISOMETRIC DWG S-01469 REV 0.


PVEL4 = 0.116136 FROM COMPUTER PRINTOUT

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>C. Soren</i>	Date 9-19-86
Subject/Title Unit 1 RCIC Motor Operated Valve	Reviewed By <i>AD M. H. L.</i>	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-016	Sheet 20 of 53

RELATIONSHIP OF THE GATE VALVE FLOW AREA TO THE
PERCENTAGE OPENING OF A TYPICAL GATE VALVE

It is assumed that the diameter of the gate is equal to the port diameter of the valve since the difference in diameters is insignificantly small.


THE FLOW AREA OF THE VALVE MAY BE DETERMINED BY SUBTRACTING THE AREA OF THE GATE OCCLUDING THE TOTAL PORT AREA.



A = Area

$$A_{\text{Flow}} = A_{\text{Port}} - A_{\text{Gate}}$$

THE AREA OF THE PORT IS CALCULATED USING THE CIRCULAR SEGMENT CALCULATION



$$A_{\text{SEG}} = h/6s (3h^2 + 4s^2)$$

WITH h = RISE = RADIUS
AND s = CHORD = DIAMETER

THE AREA OF THE PORT IS EQUAL TO TWICE ASEG



$$A_{\text{PORT}} = 2A_{\text{SEG}} = R/6D (3R^{**2} + 4D^{**2})$$

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>C. Stevens</i>	Date 9.19.86
Subject/Title Unit 1 RCIC Motor Operated Valve	Reviewed By <i>W. D. McAllister</i>	Date 4/21/86
Differential Pressure Calculation	Calculation Number SNH-86-016	Sheet 21 of 53

THE OCCLUDING AREA OF THE GATE IS FOUND BY USING THE AREA OF A CIRCULAR SEGMENT CALCULATION.



$$ASEG = h/6s (3h^2 + 4s^2)$$


$$r = h/2 + s^2/8h$$

TRANSFORMING THE LATER EQUATION

$$s = (8h (r - (h/2)))^{1/2}$$

WHICH COMBINED WITH THE ASEG CALCULATION MAY BE READILY SOLVED.

THE AREA OCCLUDED IS EQUAL TO TWICE ASEG.



$$AGATE = 2 ASEG.$$

THUS THE AREA OF FLOW THROUGH THE VALVE IS CALCULATED AS:


$$A_{Flow} = A_{PORT} - AGATE$$



$$A_{Flow}$$

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>C. Sorenson</i>	Date 9.19.86
Subject/Title Unit 1 RCIC Motor Operated Valve	Reviewed By <i>W.D. McArthur</i>	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-016	Sheet 22 of 53

A GRAPHIC PRESENTATION OF THE TYPICAL FLOW AREA VS. PERCENT VALVE OPENING IS GIVEN AS FOLLOWS.



REFERENCE: ENGINEERING FORMULAS 4th EDITION, PAGE B3.

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>C. Lorenson</i>	Date 9-19-86
Subject/Title Unit 1 RCIC Motor Operated Valve	Reviewed By <i>A. S. Kirk</i>	Date 9-19-86
Differential Pressure Calculation	Calculation Number SNH-86-016	Sheet 23 of 53

NUMERICAL RELATIONSHIP BETWEEN A GRAPHICAL PRESENTATION
OF MANUFACTURER'S 2" GLOBE VALVE OPENING
VS. MANUFACTURER'S CV DATA

Given a curve of 0-100 % opening (see attached), It is Desired to numerically relate the first 60% of opening to CV.

The First 60% of opening is a linear function thus, the curve may be equated using linear regression of the point-slope form.

$$y - y_1 = m(x - x_1)$$

Using the points (0,0) and (50,40)

$$40 - 0 = m(50 - 0)$$

Solving for m

$$m = 40/50 = 0.8$$

The equation of a line is given as:


$$y = mx$$

Hence, the equation relating cv with percent opening is:

$$CV = 0.8 (\text{percentage opening})$$

FOR ALL OPENINGS LESS THAN 60%.

Reference: THE ENGINEER'S COMPANION 1966 PG. 13.



Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>C. Loren</i>	Date 9-19-86
Subject/Title Unit 1 RCIC Motor Operated Valve	Reviewed By <i>A. S. Kirk</i>	Date 9-20-86
Differential Pressure Calculation	Calculation Number SNH-86-016	Sheet 25 of 53

DETERMINE THE PRESSURE INCREASE DUE TO THE RAPID
DECELERATION OF FLUID CAUSED BY THE MOVEMENT
OF A PROCESS GATE OR GLOBE VALVE

ASSUMPTIONS

- 1) Valve openings result in no waterhammer effects. The differential pressure across a valve during opening is decreased by an increase in fluid velocity. The maximum actuator loading takes place before the valve lift occurs.
- 2) Steam valve closure results in only minor or no waterhammer effect. The compressible nature of the fluid medium coupled with maximum anticipated velocity changes make the pressure addition insignificant.
- 3) Area of flow through a gate valve is a direct and linear relation to system velocity.
- 4) The percentage of valve opening is a direct relation to opening time.
- 5) It is assumed that flowing pressure does not drop below the fluids vapor pressure.

The pressure increase due to sudden deceleration of fluid may be expressed as:


$$P_{VEL} = P_1 + P_2$$

Where P_1 is the upstream pressure change, and P_2 is the downstream pressure change.

The respective values for P_1 and P_2 may be calculated as follows:

$$P_1, P_2 = \frac{f C \Delta V_{MAX}}{144 g}$$

Design Calculations

Southern Company Services 

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>C. Loren</i>	Date 9-19-86
Subject/Title Unit 1 RCIC Motor Operated Valve	Reviewed By <i>A. S. Kirk</i>	Date 9-20-86
Differential Pressure Calculation	Calculation Number SNH-86-016	Sheet 26 of 53

Incremental time is Defined As:

$$\Delta t = t_2 - t_1 = \frac{2L}{c}$$

Where the term $2L/C$ is the time require for a pressure wave to travel down a pipe's flow length and rebound to it's source valve.

Knowing the equation of the curve, the maximum ΔV for (ie; greatest slope) is calculated and entered into the pressure equations.

The procedure is once again performed for the down stream side of the valve and added as follows to produce PVEL.

$$PVEL = P_1 + P_2$$

Reference: BWROG REPORT APP. B

0082d

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>C. Soren</i>	Date 9-19-86
Subject/Title Unit 1 RCIC Motor Operated Valve	Reviewed By <i>A. S. Kirk</i>	Date 9-20-86
Differential Pressure Calculation	Calculation Number SNH-86-016	Sheet 27 of 53

Where: ρ is the fluid density

C is the speed of sound through the fluid

ΔV_{MAX} is the maximum system fluid differential velocity

144 is a conversion factor

and g is the Gravitational Constant



The fluid ΔV is assumed to be a direct relation to flow area, as shown in the gate valve area - percent open curves, and is a direct relation to C_v , as shown on the globe valve C_v - percent open curves.

The valve Δt is a direct relation to Δ percentage open.


Therefore:

$$\frac{\Delta A}{\Delta \% \text{ Open}} \approx \frac{\Delta C_v}{\Delta \% \text{ Open}} \approx \frac{\Delta V}{\Delta t}$$

Having plotted a velocity relation against a time relation the region of highest differential velocity is examined.



Design Calculations

Southern Company Services 

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>C. Loren</i>	Date 9-19-86
Subject/Title Unit 1 RCIC Motor Operated Valve	Reviewed By <i>A.S. Kirk</i>	Date 9-20-86
Differential Pressure Calculation	Calculation Number SNH-86-016	Sheet 28 of 53

Incremental time is Defined As:

$$\Delta t = t_2 - t_1 = \frac{2L}{c}$$

Where the term $2L/C$ is the time require for a pressure wave to travel down a pipe's flow length and rebound to it's source valve.

Knowing the equation of the curve, the maximum ΔV for Δt (ie; greatest slope) is calculated and entered into the pressure equations.

The procedure is once again performed for the down stream side of the valve and added as follows to produce PVEL

$$PVEL = P_1 + P_2$$

Reference: BWROG REPORT APP. B

0082d

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1&2

Prepared By: *C. Loren*

DATE 09/21/86

MOTOR OPERATED VALVE

Reviewed By: *F. B. Baker*

DATE 09/21/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-016

SHEET 29 OF 53.

GATE VALVE PVEL CALCULATION

MPL NUMBER	1E51-F013
VALVE DIAMETER (INCHES)	3.3125
CLOSING TIME (SECONDS)	15
UPSTREAM PIPE LENGTH (FT)	102.44
DOWNSTREAM PIPE LENGTH (FT)	16.6
UPSTREAM SYSTEM VEL (FT/SEC)	11.17
DOWNSTREAM SYSTEM VEL (FT/SEC)	12.46
delta TIME UPSTREAM (SECONDS)	0.05122
delta TIME DWNSTREAM (SECONDS)	0.0083
TIME UPSTREAM 1 (SECONDS)	14.94878
TIME UPSTREAM 2 (SECONDS)	15
TIME DOWNSTREAM 1 (SECONDS)	14.9917
TIME DOWNSTREAM 2 (SECONDS)	15
RISE UPSTREAM 1	1.6505945
RISE UPSTREAM 2	1.65625
RISE DOWNSTREAM 1	1.6553335
RISE DOWNSTREAM 2	1.65625
CHORD UPSTREAM 1	3.3124807
CHORD UPSTREAM 2	3.3125
CHORD DOWNSTREAM 1	3.3124995
CHORD DOWNSTREAM 2	3.3125
MAX AREA (IN SQ)	8.6866862
AREA FLOW UPSTREAM 1	0.0390158
AREA FLOW UPSTREAM 2	0
AREA FLOW DOWNSTREAM 1	0.0063242
AREA FLOW DOWNSTREAM 2	0
a/Au1	0.0045273
a/Au2	0
a/Ad1	0.0007338
a/Ad2	0
VELOCITY UPSTREAM 1 (FT/SEC)	0.0505699
VELOCITY UPSTREAM 2 (FT/SEC)	0
VELOCITY DOWNSTREAM 1 (FT/SEC)	0.0091437
VELOCITY DOWNSTREAM 2 (FT/SEC)	0
delta VEL UPSTREAM (FT/SEC)	0.0505699
delta VEL DOWNSTREAM (FT/SEC)	0.0091437
Pvu UPSTREAM PRESSURE (PSIG)	2.7045639
Pvd DOWNSTREAM PRESSURE (PSIG)	0.4890182

Pvel (PSIG)

3.1935821

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1&2

Prepared By: *C. Foreman*

DATE 09/21/86

MOTOR OPERATED VALVE

Reviewed By: *J. D. Smith*

DATE 09/21/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-016

SHEET 30 OF 53.

TWO INCH GLOBE VALVE PVEL CALCULATIONS

MPL NUMBER	1E51-F019
VALVE DIAMETER (INCHES)	1.75
CLOSING TIME (SECONDS)	10
UPSTREAM PIPE LENGTH (FT)	53.349
DOWNSTREAM PIPE LENGTH (FT)	70.1889
UPSTREAM SYSTEM VEL (FT/SEC)	5.435
DOWNSTREAM SYSTEM VEL (FT/SEC)	5.435
delta TIME UPSTREAM (SECONDS)	0.0266745
delta TIME DWNSTREAM (SECONDS)	0.0350944
TIME UPSTREAM 1 (SECONDS)	5
TIME UPSTREAM 2 (SECONDS)	5.0266745
TIME DOWNSTREAM 1 (SECONDS)	5
TIME DOWNSTREAM 2 (SECONDS)	5.0350944
% OPEN UPSTREAM 1	50
% OPEN UPSTREAM 2	50.266745
% OPEN DOWNSTREAM 1	50
% OPEN DOWNSTREAM 2	50.350944
% CV UPSTREAM 1	40
% CV UPSTREAM 2	40.213396
% CV DOWNSTREAM 1	40
% CV DOWNSTREAM 2	40.280756
delta VEL UPSTREAM (FT/SEC)	0.0115981
delta VEL DOWNSTREAM (FT/SEC)	0.0152591
Pvu UPSTREAM (PSIG)	0.6202848
Pvd DOWNSTREAM (PSIG)	0.816081

Pvel (PSIG)

1.4363658

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1&2

Prepared By: *C. Foreman*

DATE 09/19/86

MOTOR OPERATED VALVE

Reviewed By: *T. D. Hall*

DATE 09/21/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-016

SHEET 3 / OF 53.

TWO INCH GLOBE VALVE PVEL CALCULATIONS

<u>MPL NUMBER</u>	1E51-F046
<u>VALVE DIAMETER (INCHES)</u>	1.75
<u>CLOSING TIME (SECONDS)</u>	10
<u>UPSTREAM PIPE LENGTH (FT)</u>	7
<u>DOWNSTREAM PIPE LENGTH (FT)</u>	24.218
<u>UPSTREAM SYSTEM VEL (FT/SEC)</u>	1.739
<u>DOWNSTREAM SYSTEM VEL (FT/SEC)</u>	1.739
 <u>delta TIME UPSTREAM (SECONDS)</u>	 0.0035
<u>delta TIME DWNSTREAM (SECONDS)</u>	0.012109
<u>TIME UPSTREAM 1 (SECONDS)</u>	5
<u>TIME UPSTREAM 2 (SECONDS)</u>	5.0035
<u>TIME DOWNSTREAM 1 (SECONDS)</u>	5
<u>TIME DOWNSTREAM 2 (SECONDS)</u>	5.012109
<u>% OPEN UPSTREAM 1</u>	50
<u>% OPEN UPSTREAM 2</u>	50.035
<u>% OPEN DOWNSTREAM 1</u>	50
<u>% OPEN DOWNSTREAM 2</u>	50.12109
<u>% CV UPSTREAM 1</u>	40
<u>% CV UPSTREAM 2</u>	40.028
<u>% CV DOWNSTREAM 1</u>	40
<u>% CV DOWNSTREAM 2</u>	40.096872
<u>delta VEL UPSTREAM (FT/SEC)</u>	0.0004869
<u>delta VEL DOWNSTREAM (FT/SEC)</u>	0.0016846
<u>Pvu UPSTREAM (PSIG)</u>	0.0260413
<u>Pvd DOWNSTREAM (PSIG)</u>	0.0900955

Pvel (PSIG)

0.1161368

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: *C. Lorenson* DATE 09/19/86UNIT 1 RCIC MOTOR OPER VALVE Reviewed By: *W.T. Barr* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-016 SHEET 32 OF 53.

DIFFERENTIAL PRESSURE CALCULATION 09/18/86

<u>MPL NUMBER</u>	1E51-F007
<u>VALVE DESCRIPTION</u>	RCIC STEAM INBOARD ISOL VALVE
<u>VALVE FUNCTION</u>	RCIC STEAM LINE ISOLATION VALVE
<u>SAFETY FUNCTION (YES/NO)</u>	YES
<u>DP CALCULATION FORMULA</u>	DP=PRSS
<u>MAX DP UPSTREAM/DOWNSTREAM</u>	UPSTREAM
<u>SAFETY ON OPEN/CLOSE</u>	CLOSE
<u>MAXIMUM DP ON OPEN/CLOSE</u>	CLOSE
<u>VALUES USED: (PSIG)</u>	
PRSS	= 1080

<u>DP (PSID)</u>	1080
------------------	------

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1

Prepared By: *C. Loren*

DATE 09/19/86

UNIT 1 RCIC MOTOR OPER VALVE

Reviewed By: *W.T. Barr*

DATE 09/20/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-016

SHEET 13 OF 53 .

DIFFERENTIAL PRESSURE CALCULATION

09/18/86

MPL NUMBER

1E51-F008

VALVE DESCRIPTION

RCIC STEAM OUTBOARD ISOL VLV

VALVE FUNCTION

RCIC STEAM LINE ISOLATION VALVE

SAFETY FUNCTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PRSS

MAX DP UPSTREAM/DOWNSTREAM

UPSTREAM

SAFETY ON OPEN/CLOSE

CLOSE

MAXIMUM DP ON OPEN/CLOSE

CLOSE

VALUES USED: {PSIG}

PRSS = 1080

DP (PSID)

1080

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1

Prepared By: C. Loren

DATE 09/19/86

UNIT 1 RCIC MOTOR OPER VALVE

Reviewed By: W. T. Barr

DATE 09/20/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-016

SHEET 34 OF 53.

DIFFERENTIAL PRESSURE CALCULATION09/18/86MPL NUMBER

1E51-F010

VALVE DESCRIPTION

PUMP SUCT FRM COND STG TNK

VALVE FUNCTION

RCIC CST SUCTION ISOLATION VALVE

SAFETY FUNCTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PELD+PV+PVEL1

MAX DP UPSTREAM/DOWNSTREAM

UPSTREAM

SAFETY ON OPEN/CLOSE

CLOSE

MAXIMUM DP ON OPEN/CLOSE

CLOSE

VALUES USED: (PSIG)

PELD = 29.272

PV = 0.134

PVEL1 = 0

DP (PSID)

29.406

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1

Prepared By: *C. Loren*

DATE 09/19/86

UNIT 1 RCIC MOTOR OPER VALVE

Reviewed By: *W. T. Ban*

DATE 09/20/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-016

SHEET 35 OF 53 .

DIFFERENTIAL PRESSURE CALCULATION09/18/86MPL NUMBER

1E51-F012

VALVE DESCRIPTION

RCIC PUMP OUTBOARD DISCH VLV

VALVE FUNCTION

RCIC INJECTION VALVE TEST VALVE

SAFETY FUNCTION (YES/NO)

NO

DP CALCULATION FORMULA

NO SAFETY ACTION

MAX DP UPSTREAM/DOWNSTREAM

N/A

SAFETY ON OPEN/CLOSE

NONE

MAXIMUM DP ON OPEN/CLOSE

N/A

VALUES USED: (PSIG)

=

DP (PSID)

N/A

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1

Prepared By: *C. Loren*

DATE 09/19/86

UNIT 1 RCIC MOTOR OPER VALVE

Reviewed By: *W.T. Barr*

DATE 09/20/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-016

SHEET 16 OF 53 .

DIFFERENTIAL PRESSURE CALCULATION09/18/86MPL NUMBER

1E51-F013

VALVE DESCRIPTION

RCIC PUMP INBOARD DISCH VLV

VALVE FUNCTION

RCIC INJECTION VALVE

SAFETY FUNCTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PRSS+PEL (b)

MAX DP UPSTREAM/DOWNSTREAM

DOWNSTREAM

SAFETY ON OPEN/CLOSE

OPEN/CLOSE

MAXIMUM DP ON OPEN/CLOSE

OPEN/CLOSE

VALUES USED: (PSIG)

PRSS = 1080

PEL = 35.612

DP (PSID)

1115.612

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1

Prepared By: *C. Perera*

DATE 09/19/86

UNIT 1 RCIC MOTOR OPER VALVE

Reviewed By: *W. T. Barr*

DATE 09/20/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-016

SHEET 17 OF 53.

DIFFERENTIAL PRESSURE CALCULATION09/18/86MPL NUMBER

1E51-F019

VALVE DESCRIPTION

TEST BYPASS TO COND STG TANK

VALVE FUNCTION

RCIC MINIMUM FLOW BYPASS ISOL VALVE

SAFETY FUNCTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PSOH+PELM

MAX DP UPSTREAM/DOWNSTREAM

UPSTREAM

SAFETY ON OPEN/CLOSE

OPEN/CLOSE

MAXIMUM DP ON OPEN/CLOSE

OPEN

VALUES USED: (PSIG)

PSOH = 1276.271

PELM = 29.416

DP (PSID)

1305.687

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: *C. Sorenson* DATE 09/21/86UNIT 1 RCIC MOTOR OPER VALVE Reviewed By: *T.B. Haddad* DATE 09/21/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-016 SHEET 38 OF 53.

DIFFERENTIAL PRESSURE CALCULATION 09/21/86

<u>MPL NUMBER</u>	1E51-F019
<u>VALVE DESCRIPTION</u>	TEST BYPASS TO COND STG TANK
<u>VALVE FUNCTION</u>	RCIC MINIMUM FLOW BYPASS ISOL VALVE
<u>SAFETY FUNCTION (YES/NO)</u>	YES
<u>DP CALCULATION FORMULA</u>	DP=PMF+PELM+PVEL3
<u>MAX DP UPSTREAM/DOWNSTREAM</u>	UPSTREAM
<u>SAFETY ON OPEN/CLOSE</u>	OPEN/CLOSE
<u>MAXIMUM DP ON OPEN/CLOSE</u>	CLOSE
<u>VALUES USED: (PSIG)</u>	
PMF	= 1276.271
PELM	= 29.416
PVEL3	= 1.4362

DP (PSID) 1307.1232

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1

Prepared By: *C. J. Jernigan*

DATE 09/19/86

UNIT 1 RCIC MOTOR OPER VALVE

Reviewed By: *W. T. Barr*

DATE 09/20/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-016

SHEET 39 OF 53 .

DIFFERENTIAL PRESSURE CALCULATION09/18/86MPL NUMBER

1E51-F022

VALVE DESCRIPTION

TEST BYPASS TO COND STG TANK

VALVE FUNCTION

RCIC CST TEST RETURN VALVE

SAFETY FUNCTION (YES/NO)

NO

DP CALCULATION FORMULA

NO SAFETY ACTION

MAX DP UPSTREAM/DOWNSTREAM

N/A

SAFETY ON OPEN/CLOSE

NONE

MAXIMUM DP ON OPEN/CLOSE

N/A

VALUES USED: (PSIG)

=

DP (PSID)

N/A

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: *C. Loren* DATE 09/19/86UNIT 1 RCIC MOTOR OPER VALVE Reviewed By: *W. T. Bam* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-016 SHEET 40 OF 53.

DIFFERENTIAL PRESSURE CALCULATION 09/18/86MPL NUMBER

1E51-F029

VALVE DESCRIPTION

RCIC PMP SUCT VLV FRM SUP POOL

VALVE FUNCTION

RCIC SUPP POOL SUCTION ISOL VALVE

SAFETY FUNCTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PLOC+PLOM1 (c)

MAX DP UPSTREAM/DOWNSTREAM

UPSTREAM

SAFETY ON OPEN/CLOSE

OPEN/CLOSE

MAXIMUM DP ON OPEN/CLOSE

CLOSE

VALUES USED: (PSIG)

PLOC = 30.5

PLOM1 = 5.6

DP (PSID)

36.1

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1	Prepared By: <i>C. [Signature]</i>	DATE 09/19/86
UNIT 1 RCIC MOTOR OPER VALVE	Reviewed By: <i>W. T. [Signature]</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-016	SHEET 41 OF 53
DIFFERENTIAL PRESSURE CALCULATION		09/18/86

<u>MPL NUMBER</u>	1E51-F029
<u>VALVE DESCRIPTION</u>	RCIC PMP SUCT VLV FRM SUP POOL
<u>VALVE FUNCTION</u>	RCIC SUPP POOL SUCTION ISOL VALVE
<u>SAFETY FUNCTION (YES/NO)</u>	YES
<u>DP CALCULATION FORMULA</u>	DP=PRV-PELS
<u>MAX DP UPSTREAM/DOWNSTREAM</u>	DOWNSTREAM
<u>SAFETY ON OPEN/CLOSE</u>	OPEN/CLOSE
<u>MAXIMUM DP ON OPEN/CLOSE</u>	OPEN
<u>VALUES USED: (PSIG)</u>	
PRV	= 100
PELS	= 4.633

<u>DP (PSID)</u>	95.367
------------------	--------

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: *C. Lorenson* DATE 09/19/86
UNIT 1 RCIC MOTOR OPER VALVE Reviewed By: *W. T. Bass* DATE 09/20/86
DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-016 SHEET 42 OF 53 .
DIFFERENTIAL PRESSURE CALCULATION 09/18/86

MPL NUMBER 1E51-F031
VALVE DESCRIPTION RCIC PMP SUCT VLV FRM SUP POOL
VALVE FUNCTION RCIC SUPP POOL SUCTION ISOL VALVE
SAFETY FUNCTION (YES/NO) YES
DP CALCULATION FORMULA DP=PRV-PELS
MAX DP UPSTREAM/DOWNSTREAM DOWNSTREAM
SAFETY ON OPEN/CLOSE OPEN/CLOSE
MAXIMUM DP ON OPEN/CLOSE OPEN
VALUES USED: (PSIG)
PRV = 100
PELS = 4.633

DP (PSID) 95.367

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1	Prepared By: <i>C. Lorenson</i>	DATE 09/19/86
UNIT 1 RCIC MOTOR OPER VALVE	Reviewed By: <i>W.T. Bass</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-016	SHEET 43 OF 53.
DIFFERENTIAL PRESSURE CALCULATION		09/18/86

<u>MPL NUMBER</u>	1E51-F031
<u>VALVE DESCRIPTION</u>	RCIC PMP SUCT VLV FRM SUP POOL
<u>VALVE FUNCTION</u>	RCIC SUPP POOL SUCTION ISOL VALVE
<u>SAFETY FUNCTION (YES/NO)</u>	YES
<u>DP CALCULATION FORMULA</u>	DP=PLOC+PLOM1 (c)
<u>MAX DP UPSTREAM/DOWNSTREAM</u>	UPSTREAM
<u>SAFETY ON OPEN/CLOSE</u>	OPEN/CLOSE
<u>MAXIMUM DP ON OPEN/CLOSE</u>	CLOSE
<u>VALUES USED: (PSIG)</u>	
PLOC	= 30.5
PLOM1	= 5.6

<u>DP (PSID)</u>	36.1
------------------	------

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1

Prepared By: C. Foreman

DATE 09/19/86

UNIT 1 RCIC MOTOR OPER VALVE

Reviewed By: W.T. Ban

DATE 09/20/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-016

SHEET 44 OF 53.

DIFFERENTIAL PRESSURE CALCULATION09/18/86MPL NUMBER

1E51-F045

VALVE DESCRIPTION

TURBINE STEAM SUPPLY VALVE

VALVE FUNCTION

RCIC STEAM ADMISSION VALVE

SAFETY FUNCTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PRSS

MAX DP UPSTREAM/DOWNSTREAM

UPSTREAM

SAFETY ON OPEN/CLOSE

OPEN/CLOSE

MAXIMUM DP ON OPEN/CLOSE

OPEN/CLOSE

VALUES USED: (PSIG)

PRSS = 1080

DP (PSID)

1080

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: C. *Foreman* DATE 09/19/86UNIT 1 RCIC MOTOR OPER VALVE Reviewed By: *W.T. Burr* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-016 SHEET 45 OF 53.

DIFFERENTIAL PRESSURE CALCULATION 09/18/86

<u>MPL NUMBER</u>	1E51-F046
<u>VALVE DESCRIPTION</u>	COOLING WATER SUPPLY VALVE
<u>VALVE FUNCTION</u>	RCIC TURBINE ACCESSORY COOL WTR VALVE
<u>SAFETY FUNCTION (YES/NO)</u>	YES
<u>DP CALCULATION FORMULA</u>	DP=PLOC+PLOM2+PVEL4
<u>MAX DP UPSTREAM/DOWNSTREAM</u>	UPSTREAM
<u>SAFETY ON OPEN/CLOSE</u>	OPEN/CLOSE
<u>MAXIMUM DP ON OPEN/CLOSE</u>	CLOSE

VALUES USED: (PSIG)

PLOC	=	30.5
PLOM2	=	6.449
PVEL4	=	0.116136

<u>DP (PSID)</u>	37.065136
------------------	-----------

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1

Prepared By: *C. Forester*

DATE 09/19/86

UNIT 1 RCIC MOTOR OPER VALVE

Reviewed By: *W.T. Ban*

DATE 09/20/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-016

SHEET 46 OF 53.

DIFFERENTIAL PRESSURE CALCULATION09/18/86MPL NUMBER

1E51-F046

VALVE DESCRIPTION

COOLING WATER SUPPLY VALVE

VALVE FUNCTION

RCIC TURBINE ACCESSORY COOL WTR VALVE

SAFETY FUNCTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PSOI+PELC

MAX DP UPSTREAM/DOWNSTREAM

UPSTREAM

SAFETY ON OPEN/CLOSE

OPEN/CLOSE

MAXIMUM DP ON OPEN/CLOSE

OPEN

VALUES USED: (PSIG)

PSOI = 252.739

PELC = 35.44

DP (PSID)

288.179

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1 Prepared By: *C. Loran* DATE 09/19/86UNIT 1 RCIC MOTOR OPER VALVE Reviewed By: *W.T. Ban* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-016 SHEET 47 OF 53 .

DIFFERENTIAL PRESSURE CALCULATION 09/18/86

<u>MPL NUMBER</u>	1E51-F104
<u>VALVE DESCRIPTION</u>	GATE VALVE 1.5 IN MO
<u>VALVE FUNCTION</u>	RCIC VACUUM BREAKER LINE ISOL VALVE
<u>SAFETY FUNCTION (YES/NO)</u>	YES
<u>DP CALCULATION FORMULA</u>	DP=PC+PATM
<u>MAX DP UPSTREAM/DOWNSTREAM</u>	UPSTREAM
<u>SAFETY ON OPEN/CLOSE</u>	CLOSE
<u>MAXIMUM DP ON OPEN/CLOSE</u>	CLOSE
<u>VALUES USED: (PSIG)</u>	
PC	= 30.5
PATM	= 0

DP (PSID) 30.5

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1

Prepared By: C. Loren

DATE 09/19/86

UNIT 1 RCIC MOTOR OPER VALVE

Reviewed By: D.T. Barr

DATE 09/20/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-016

SHEET 48 OF 53.

DIFFERENTIAL PRESSURE CALCULATION

09/18/86

MPL NUMBER

1E51-F105

VALVE DESCRIPTION

GATE VALVE 2 IN MO

VALVE FUNCTION

RCIC VACUUM BREAKER LINE ISOL VALVE

SAFETY FUNCTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PC+PATM

MAX DP UPSTREAM/DOWNSTREAM

UPSTREAM

SAFETY ON OPEN/CLOSE

CLOSE

MAXIMUM DP ON OPEN/CLOSE

CLOSE

VALUES USED: (PSIG)

PC = 30.5

PATM = 0

DP (PSID)

30.5

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>Kevin C. Wilson</i>	Date 09/19/86
Subject/Title Unit 1 RCIC Motor Operated Valve	Reviewed By <i>[Signature]</i>	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-016	Sheet 49 of 53

TWO INCH GLOBE VALVE PVEL CALCULATIONS

PAGE 1 OF 2

A3: [W11] ^MPL
 B3: ^VALVE
 C3: ^CLOSING
 D3: ^UPSTR
 E3: ^DNSTR
 F3: 'UPSTRSYS
 G3: 'DNSTRSYS
 I3: ^dT UP
 J3: ^dTDN
 K3: ^TIMEu1
 L3: ^TIMEu2
 M3: ^TIMEd1
 N3: ^TIMEd2
 O3: ^% OPEN
 P3: ^% OPEN
 Q3: ^% OPEN
 R3: ^% OPEN
 S3: ^% CV
 T3: ^% CV
 U3: ^% CV
 V3: ^% CV
 W3: ^dVu
 X3: ^dVd
 Y3: ^Pvu
 Z3: ^Pvd
 AA3: ^Pvel
 A4: [W11] ^NUMBER
 B4: ^DIA, "
 C4: ^T, SECS
 D4: ^PIPE L'
 E4: ^PIPE L'
 F4: ^VEL FPS
 G4: ^VEL FPS
 O4: ^UPSTR1
 P4: ^UPSTR2
 Q4: ^DNSTR1
 R4: ^DNSTR2
 S4: ^UPSTR1
 T4: ^UPSTR2
 U4: ^DNSTR1
 V4: ^DNSTR2
 A5: [W11] \-
 B5: \-
 C5: \-
 D5: \-
 E5: \-
 F5: \-
 G5: \-

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>Kawn C. Wilson</i>	Date 09/19/86
Subject/Title Unit 1 RCIC Motor Operated Valve	Reviewed By <i>AD McAL</i>	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-016	Sheet 50 of 53

TWO INCH GLOBE VALVE PVEL CALCULATIONS

PAGE 2 OF 2

H5: [W2] \-

I5: \-

J5: \-

K5: \-

L5: \-

M5: \-

N5: \-

O5: \-

P5: \-

Q5: \-

R5: \-

S5: \-

T5: \-

U5: \-

V5: \-

W5: \-

X5: \-

Y5: \-

Z5: \-

AA5: \-

A6: [W11] '1E41-F059

B6: 1.75

C6: 10

D6: 25

E6: 31.42

F6: 7.601

G6: 7.601

H6: [W2] '|

I6: (2*D6)/\$D\$28

J6: (2*E6)/\$D\$28

K6: +\$C6*0.5

L6: +\$C6*0.5+I6

M6: +\$C6*0.5

N6: +\$C6*0.5+J6

O6: (+K6*100)/\$C6

P6: (+L6*100)/\$C6

Q6: (+M6*100)/\$C6

R6: (+N6*100)/\$C6

S6: +O6*0.8

T6: +P6*0.8

U6: +Q6*0.8

V6: +R6*0.8

W6: (+F6*(T6-S6))/100

X6: (+G6*(V6-U6))/100

Y6: (W6*\$D\$27*\$D\$28)/(144*32.2)

Z6: (X6*\$D\$27*\$D\$28)/(144*32.2)

AA6: +Y6+Z6

C27: 'DENSITY

D27: 61.996

E27: 'LB/FT3

C28: 'C

D28: 4000

E28: 'FT/SEC

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>Dawn C. Wilson</i>	Date 09/19/86
Subject/Title Unit 1 RCIC Motor Operated Valve	Reviewed By <i>J. D. McNeil</i>	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-016	Sheet 51 of 53

GATE VALVE PVEL CALCULATIONS

PAGE 1 OF 3

A3: [W11] ^MPL
 B3: ^VALVE
 C3: ^CLOSING
 D3: ^UPSTR
 E3: ^DNSTR
 F3: 'UPSTRSYS
 G3: 'DNSTRSYS
 I3: ^dT UP
 J3: ^dTDN
 K3: ^TIMEu1
 L3: ^TIMEu2
 M3: ^TIMEd1
 N3: ^TIMEd2
 O3: ^RISEu1
 P3: ^RISEu2
 Q3: ^RISEd1
 R3: ^RISEd2
 S3: ^CHORDu1
 T3: ^CHORDu2
 U3: ^CHORDd1
 V3: ^CHORDd2
 W3: 'MAX AREA
 X3: ^Aflu1
 Y3: ^Aflu2
 Z3: ^Afld1
 AA3: ^Afld2
 AB3: ^a/Au1
 AC3: ^a/Au2
 AD3: ^a/Ad1
 AE3: ^a/Ad2
 AF3: ^Vu1
 AG3: ^Vu2
 AH3: ^Vd1
 AI3: ^Vd2
 AJ3: ^dVu
 AK3: ^dVd
 AL3: ^Pvu
 AM3: ^Pvd
 AN3: ^Pvel
 A4: [W11] ^NUMBER
 B4: ^DIA, "
 C4: ^T, SECS
 D4: ^PIPE L'
 E4: ^PIPE L'
 F4: ^VEL FPS
 G4: ^VEL FPS
 W4: 'FLOW
 A5: [W11] \-

Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>Lawson C. Wilson</i>	Date 09/19/86
Subject/Title Unit 1 RCIC Motor Operated Valve	Reviewed By <i>[Signature]</i>	Date 7/21/86
Differential Pressure Calculation	Calculation Number SNH-86-016	Sheet 52 of 53

GATE VALVE PVEL CALCULATIONS

PAGE 2 OF 3

B5: \-
 C5: \-
 D5: \-
 E5: \-
 F5: \-
 G5: \-
 H5: [W2] \-
 I5: \-
 J5: \-
 K5: \-
 L5: \-
 M5: \-
 N5: \-
 O5: \-
 P5: \-
 Q5: \-
 R5: \-
 S5: \-
 T5: \-
 U5: \-
 V5: \-
 W5: \-
 X5: \-
 Y5: \-
 Z5: \-
 AA5: \-
 AB5: \-
 AC5: \-
 AD5: \-
 AE5: \-
 AF5: \-
 AG5: \-
 AH5: \-
 AI5: \-
 AJ5: \-
 AK5: \-
 AL5: \-
 AM5: \-
 AN5: \-
 A6: [W11] '1E51-F013
 B6: 3+5/16
 C6: 15
 D6: 99.9
 E6: 16.6
 F6: 11.62
 G6: 12.46
 H6: [W2] '|
 I6: (2*D6)/\$D\$29


Project E.I. Hatch Nuclear Plant Unit 1	Prepared By <i>Rawn C. Wilson</i>	Date 09/19/86
Subject/Title Unit 1 RCIC Motor Operated Valve	Reviewed By <i>A. D. Smith</i>	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-016	Sheet 53 of 53


GATE VALVE PVEL CALCULATIONS

PAGE 3 OF 3

J6: $(2 * E6) / \$D\29
 K6: $(\$D\$30 * \$C6) - I6$
 L6: $+ \$D\$30 * \$C6$
 M6: $(\$D\$30 * \$C6) - J6$
 N6: $+ \$D\$30 * \$C6$
 O6: $(K6 / \$C6) * (\$B6 / 2)$
 P6: $(L6 / \$C6) * (\$B6 / 2)$
 Q6: $(M6 / \$C6) * (\$B6 / 2)$
 R6: $(N6 / \$C6) * (\$B6 / 2)$
 S6: $@SQRT(8 * O6 * ((\$B6 / 2) - (O6 / 2)))$
 T6: $@SQRT(8 * P6 * ((\$B6 / 2) - (P6 / 2)))$
 U6: $@SQRT(8 * Q6 * ((\$B6 / 2) - (Q6 / 2)))$
 V6: $@SQRT(8 * R6 * ((\$B6 / 2) - (R6 / 2)))$
 W6: $2 * ((1 / 12) * (((3 * B6 * B6) / 4) + (4 * B6 * B6)))$
 X6: $(F6) (W6) - (2 * ((O6 / (6 * S6)) * ((3 * O6 * O6) + (4 * S6 * S6))))$
 Y6: $(F6) (W6) - (2 * ((P6 / (6 * T6)) * ((3 * P6 * P6) + (4 * T6 * T6))))$
 Z6: $(F6) (\$W6) - 2 * ((Q6 / (6 * U6)) * ((3 * Q6 * Q6) + (4 * U6 * U6)))$
 AA6: $(F6) (\$W6) - 2 * ((R6 / (6 * V6)) * ((3 * R6 * R6) + (4 * V6 * V6)))$
 AB6: $(F6) + X6 / ((@PI * \$B6 * \$B6) / 4)$
 AC6: $(F6) + Y6 / ((@PI * \$B6 * \$B6) / 4)$
 AD6: $(F6) + Z6 / ((@PI * \$B6 * \$B6) / 4)$
 AE6: $(F6) + AA6 / ((@PI * \$B6 * \$B6) / 4)$
 AF6: $(F6) + AB6 * \$F6$
 AG6: $(F6) + AC6 * \$F6$
 AH6: $(F6) + AD6 * \$G6$
 AI6: $(F6) + AE6 * \$G6$
 AJ6: $(F6) + AF6 - AG6$
 AK6: $(F6) + AH6 - AI6$
 AL6: $(F6) (AJ6 * \$D\$28 * \$D\$29) / (144 * 32.2)$
 AM6: $(F6) (AK6 * \$D\$28 * \$D\$29) / (144 * 32.2)$
 AN6: $(F6) + AL6 + AM6$
 C28: 'DENSITY
 D28: 61.996
 E28: 'LB/FT3
 C29: 'C
 D29: 4000
 E29: 'FT/SEC
 C30: 'FUDGE FAC
 D30: 1
 E30: 'DIMLESS

ENCLOSURE 3






ATI
APERTURE
CARD

Also Available On
Aperture Card

8610090442-03

Calculation Cover Sheet

Southern Company Services 

Project E.I. HATCH NUCLEAR PLANT UNIT 2		Calculation Number SNH-86-017
Objective Calculate DP for HPCI Motor Operated Valves		Discipline Mechanical
Subject/Title Unit 2 HPCI Motor Operated Valve Differential Pressure Calculation		SDS Number

Design Engineer's Signature <i>L.B. Haskins</i>	Date 9-20-86	Last Page Number 59
--	-----------------	------------------------

Contents

Topics	Page	Topics	Page
INTRODUCTION	1	DEFINITION OF TERMS	7
Summary of Conclusions	3	DEFINITION OF VALVES	9
Criteria and Assumptions	2		
Listed References	5		
Body of Calculations	9		
(Computer Printout)	53		

Record of Revisions

Rev. No.	Description	Originator Date	Reviewer Date	Proj. Engr. Date
0	APPROVED	<i>L.B.H.</i> 9-20-86	<i>W.M.D.</i> 9/21/86	<i>J.V.L.</i> 9/21/86

Notes

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>Dawn C. Wilson</i>	Date 09/19/86
Subject/Title Unit 2 HPCI Motor Operated Valve	Reviewed By <i>W.T. Barn</i>	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-017	Sheet 1 of 59

INTRODUCTION

The Nuclear Regulatory Commission (NRC) IE Bulletin 85-03 (Motor Operated Valve Common Mode Failure) requested that owners of light water reactors develop and implement a program to ensure that torque switch settings on safety related motor-operated valves on high pressure systems are selected, set and maintained correctly to accomodate the maximum differential pressures expected on these valves during both normal and abnormal events within the design basis. The objective of this calculation is to determine the maximum Differential Pressure across each of the affected Unit 2 HPCI Motor Operated Valves.

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>JB Hopkins</i>	Date 9-20-86
Subject/Title Unit 2 HPCI Motor Operated Valve	Reviewed By <i>W.D. McNamee</i>	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-017	Sheet 2 of 59

CRITERIA

- 1) The criteria, assumptions and formulas given in the General Electric "BWR Owner's Group Report on the Operational Design Basis of Selected Safety-Related Motor-Operated Valves," DRF-E12-00100-75, are assumed to be correct.

ASSUMPTIONS

- 1) PC is assumed to equal PLOC. The terms are defined as follows:
 - * PLOC is the maximum wet well LOCA pressure.
 - * PC is the maximum wetwell LOCA pressure which the valve is required to operate against.
- 2) In the PVEL calculation, it is assumed that the time required for a sound wave to travel to and return from an atmospheric vessel is infinity. Thus, the related term in the PVEL equation is equal to zero.
- 3) Disc and Port diameters are assumed to be equal. Equal diameters for disc and port yield higher rate of change therefore higher DV and is therefore more conservative.
- 4) The Formula for calculating area of the gate valve available for flow is approximated from a known geometric relationship and is off by a small percentage, however, the overall effect is negligible.
- 5) In the PVEL calculation, it is assumed that where a small line tees into a much larger line (i.e. Larger being two times or greater in diameter) the boundary for the small line ends at the line intersection.

00431

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>L B Hulse</i>	Date 9-20-86
Subject/Title Unit 2 HPCI Motor Operated Valve	Reviewed By <i>W. T. Ban</i>	Date 9/20/86
Differential Pressure Calculation	Calculation Number SNH-86-017	Sheet 3 of 54

UNIT 2
HPCI MOV CALCULATIONS
REFERENCES

1. A-26497 REV. 12 INSTRUMENT SETPOINT INDEX
2. A-26503 REV. N/A SHT. 1, 2, 16 AND 30 MOV DATA SHEETS
3. H-26020 REV. 17 HPCI SYSTEM P & ID SHEET 1
4. H-26021 REV. 14 HPCI SYSTEM P & ID SHEET 2
5. H-26289 REV. 4 FEEDWATER PIPING DRYWELL ELEV. 130' & ABOVE
6. S-25176 REV. 0 PROCESS DIAGRAM HPCI SYSTEM
7. S-25701 REV. E BYRON JACKSON PUMP MANUAL, PUMP CURVE T-33713-1
8. S-25711 REV. 0 4" PRESS SEAL GLOBE VALVE, VELAN
9. S-26835 REV. E KELLOGG ISOMETRIC DWG. 2E41-1
10. S-26837 REV. M KELLOGG ISOMETRIC DWG. 2E41-2
11. S-26839 REV. G KELLOGG ISOMETRIC DWG. 2E41-3
12. S-26841 REV. N KELLOGG ISOMETRIC DWG. 2E41-4
13. S-26843 REV. M KELLOGG ISOMETRIC DWG. 2E41-5
14. S-26845 REV. J KELLOGG ISOMETRIC DWG. 2E41-6
15. S-26847 REV. L KELLOGG ISOMETRIC DWG. 2E41-7
16. S-27026 REV. B 16" 150LB OSY GATE VALVE, POWELL 1523WE
17. S-27131 REV. F 14" 900LB OSY GATE VALVE, POWELL 19023WE
18. S-27294 REV. F MODEL LCT-20 SERIES RELIEF VALVE
19. S-27535 REV. 0 GENERAL PLAN DRYWELL AND TORUS LAYOUT
20. S-28978 REV. N KELLOGG ISOMETRIC DWG. 2B21-3
21. S-28980 REV. M KELLOGG ISOMETRIC DWG. 2B21-4
22. S-29112 REV. H KELLOGG ISOMETRIC DWG 2B21-5
23. S-36017 REV. 0 KELLOGG ISOMETRIC DWG. 2E41-F6

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>E.B. Hallin</i>	Date 9-20-86
Subject/Title Unit 2 HPCI Motor Operated Valve	Reviewed By <i>W.T. Barr</i>	Date 9/20/86
Differential Pressure Calculation	Calculation Number SNH-86-017	Sheet 4 of 59

UNIT 2
HPCI MOV CALCULATIONS
REFERENCES CONT'D

24. S-36034 REV. A KELLOGG ISOMETRIC DWG. 2E41-F23
25. S-36035 REV. O KELLOGG ISOMETRIC DWG. 2E41-F24
26. S-36036 REV. O KELLOGG ISOMETRIC DWG. 2E41-F25
27. S-36037 REV. O KELLOGG ISOMETRIC DWG. 2E41-F26
28. S-36038 REV. A KELLOGG ISOMETRIC DWG. 2E41-F27
29. S-36040 REV. A KELLOGG ISOMETRIC DWG. 2E41-F28
30. S-43166 REV. O 4" PRESS SEAL GLOBE VALVE, VELAN
31. SX-24013 REV. O YARWAY WELBOND VALVE FIG. 5515B
32. SX-22585 REV. D KELLOGG ISOMETRIC DWG. 2E41-17
33. SX-24226 REV. C KELLOGG ISOMETRIC DWG. 2E41-20
34. UNIT NO. 2 TECHNICAL SPECIFICATIONS AMENDMENT 62
36. UNIT 2 FSAR TABLE 6.2-5 SHT. 2 NOTE 7
37. BWR OWNERS GROUP REPORT ON THE OPERATIONAL DESIGN BASIS OF SELECTED SAFETY RELATED MOTOR OPERATED VALVES, DRF-E12-00100-75, AUGUST 1986.
38. NEDO DOCUMENT 24569 REV. 2 FIGURE H2 4.1.2-1
39. CRANE TECHNICAL PAPER NO. 410, 18TH PRINTING
40. ENGINEERS COMPANION 1966 PAGE 13
41. TELECOPY TO JACK ROBYN OF SCS FROM PAUL COUTINHO OF VELAN ON 9-18-86
42. TELECOPY TO JACK ROBYN OF SCS FROM DAN ^{HORASOWYCH} ~~HARASENYCH~~ OF YARWAY ON 9-11-86
43. TELEPHONE CONFIRMATION FROM BRAD HARKINS OF SCS TO DENNIS SCHERER OF POWELL ON 9-11-86
44. ENGINEERING FORMULAS 4TH EDITION, PAGE B3

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>E.B. Hawkins</i>	Date 9-20-86
Subject/Title Unit 2 HPCI Motor Operated Valve	Reviewed By <i>W.T. Barr</i>	Date 9/20/86
Differential Pressure Calculation	Calculation Number SNH-86-017	Sheet 5 of 59

SUMMARY OF CONCLUSIONS

The following page is a summary table of the results for each HPCI Motor Operated Valve in the Scope of NRC IEB 85-03.

The first column titled "MPL Number" gives the MPL number of the valve.

The second column titled "Valve Description" is the description of the valve given in the equipment location index (ELI).

The third column titled "Valve Function" is the function of the valve as stated in the General Electric "BWR Owners' Group Report on the Operational Design Basis of Selected Safety-Related Motor-Operated Valves."

The fourth column titled "Safety" indicates if the valve has any safety-related action.

The fifth column titled "DP Calculation Formula" gives the formula used to calculate the maximum differential pressure.

The sixth column titled "Maximum DP" indicates whether the maximum DP occurs upstream or downstream of the valve.

The seventh column titled "Max DP ON" indicates whether the maximum DP is calculated for opening or closing.

The eighth column titled "DP (PSID)" gives the calculated maximum DP in psid.

The ninth column titled "Safety On" gives the safety action of the valve.

00471

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT UNIT 2

PREPARED BY:

J.B. Gordon

DATE

09/12/1986

UNIT 2 HPCI MOTOR OPERATED VALVE

REVIEWED BY:

C. Gordon

DATE

09/21/86

DIFFERENTIAL PRESSURE CALCULATION

CALCULATION NUMBER SMH-86-017

SHEET 6 OF 59

SUMMARY TABLE

09/21/86

MPL NUMBER	VALVE DESCRIPTION	VALVE FUNCTION	SAFETY	DP CALCULATION FORMULA	MAXIMUM DP OPEN	MAXIMUM DP UPSTREAM	DP (PSID) 1090	SAFETY YES
2E41-F001	TURBINE STEAM SUPPLY VALVE	HPCI TURBINE STEAM ADMISSION VALVE	OPEN	DP=PRSS				
2E41-F002	STEAM SUPPLY INBOARD ISOL VALVE	HPCI STEAM LINE ISOLATION VALVE	CLOSE	DP=PRSS	CLOSE	UPSTREAM	1090	YES
2E41-F003	STEAM SUPPLY OUTBD ISOL VALVE	HPCI STEAM LINE ISOLATION VALVE	CLOSE	DP=PRSS	CLOSE	UPSTREAM	1090	YES
2E41-F004	PUMP SUCT FROM COND STOR TANK	HPCI CST SUCTION VALVE	CLOSE	DP=PELD+PV+PVEL1	CLOSE	UPSTREAM	29.814	YES
2E41-F006	HPCI PUMP INBD DISCH VALVE	HPCI INJECTION/ISOLATION VALVE	OPEN/CLOSE	DP=PSOH-PISO-PEL	OPEN	UPSTREAM	1379.03	YES
2E41-F006	HPCI PUMP INBD DISCH VALVE	HPCI INJECTION/ISOLATION VALVE	OPEN/CLOSE	DP=PSOH-PISO-PEL+PVEL2	CLOSE	UPSTREAM	1387.193	YES
2E41-F007	HPCI PUMP OUTBD DISCH VALVE	HPCI INJECTION VALVE TEST VALVE	NONE	NO SAFETY ACTION	N/A	N/A	N/A	NO
2E41-F008	TEST BYPASS VALVE TO COND STOR	HPCI CST TEST RETURN VALVE	NONE	NO SAFETY ACTION	N/A	N/A	N/A	NO
2E41-F011	REDUNDANT SHUTOFF W/F008	HPCI CST TEST RETURN VALVE	NONE	NO SAFETY ACTION	N/A	N/A	N/A	NO
2E41-F012	PHP MIN FLO BYP TO SUPP POOL	HPCI PUMP MIN FLO BYP ISOL VALVE	OPEN/CLOSE	DP=PSOH+PELM	OPEN	UPSTREAM	2269.58	YES
2E41-F012	PHP MIN FLO BYP TO SUPP POOL	HPCI PUMP MIN FLO BYP ISOL VALVE	OPEN/CLOSE	DP=PMF+PELM+PVEL3	CLOSE	UPSTREAM	2270.605	YES
2E41-F041	PHP SUCT FROM SUPP POOL	HPCI SUPP POOL SUCT ISOL VALVE	OPEN/CLOSE	DP=PRV-PELS	OPEN	DOWNSTREAM	97.12	YES
2E41-F041	PHP SUCT FROM SUPP POOL	HPCI SUPP POOL SUCT ISOL VALVE	OPEN/CLOSE	DP=PLOC+PLOW1	CLOSE	UPSTREAM	37.06	YES
2E41-F042	PHP SUCT FROM SUPP POOL	HPCI SUPP POOL SUCT ISOL VALVE	OPEN/CLOSE	DP=PRV-PELS	OPEN	DOWNSTREAM	97.12	YES
2E41-F042	PHP SUCT FROM SUPP POOL	HPCI SUPP POOL SUCT ISOL VALVE	OPEN/CLOSE	DP=PLOC+PLOW1	CLOSE	UPSTREAM	37.06	YES
2E41-F059	COOLING WATER SUPPLY VALVE	HPCI TURBINE ACCES COOLING WTR VLV	OPEN/CLOSE	DP=PC+PLOW2	OPEN	UPSTREAM	37.01	YES
2E41-F059	COOLING WATER SUPPLY VALVE	HPCI TURBINE ACCES COOLING WTR VLV	OPEN/CLOSE	DP=PC+PLOW2+PVEL4	CLOSE	UPSTREAM	37.947	YES
2E41-F104	GATE VALVE 2 IN MO	HPCI VAC BREAKER LINE ISOL VALVE	CLOSE	DP=PC+PATM	CLOSE	UPSTREAM	31.6	YES
2E41-F111	GATE VALVE 2 IN MO	HPCI VAC BREAKER LINE ISOL VALVE	CLOSE	DP=PC+PATM	CLOSE	UPSTREAM	31.6	YES

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2

Prepared By:

DATE 09/19/86

UNIT 2 HPCI MOTOR OPER VALVE

Reviewed By:

DATE 09/20/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-017

SHEET 7 OF 59.

DEFINITION OF TERMS

09/19/86

TERMDEFINITION OF TERM

DP

VALVE MAXIMUM EXPECTED OPERATING DIFFERENTIAL
PRESSURE

PSOH

DIFFERENTIAL PRESSURE DEVELOPED BY SYSTEM MAIN
PUMPS AT ZERO FLOW RATE. FOR STEAM TURBINE DRIVEN
PUMPS, USE MAXIMUM NORMAL TURBINE SPEED

PEL

MINIMUM HYDROSTATIC PRESSURE DIFFERENCE BETWEEN
SUCTION AND DISCHARGE DUE TO ELEVATION. (DISCHARGE
ELEVATION IS HIGHER THAN SUCTION)

PISO

LOW REACTOR PRESSURE AT WHICH STEAM SUPPLY LINES
AUTOMATICALLY ISOLATE

PELM

MAXIMUM HYDROSTATIC PRESSURE DIFFERENCE BETWEEN
SUCTION AND DISCHARGE SOURCE DUE TO ELEVATION

PRSS

REACTOR PRESSURE CORRESPONDING TO THE SPRING
SETPOINT OF THE REACTOR SAFETY RELIEF VALVE WITH
THE LOWEST NOMINAL SPRING SETPOINT

PELD

HYDROSTATIC PRESSURE DIFFERENCE BETWEEN CST AND
SUPPRESSION POOL ASSUMING THE CST TO BE FULL AND
THE SUPPRESSION POOL WATER LEVEL AT ITS MAXIMUM
ALLOWABLE NORMAL LEVEL

PMF

DIFFERENTIAL PRESSURE DEVELOPED BY THE SYSTEM MAIN
PUMPS AT A FLOW RATE EQUAL TO THE REQUIRED MINIMUM
BYPASS FLOW RATE. FOR STEAM DRIVEN PUMPS USE
MAXIMUM NORMAL TURBINE SPEED

PV

VELOCITY HEAD IN THE SUPPRESSION POOL SUCTION LINE

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2

Prepared By: *Dawn C. Wilson*

DATE 09/17/86

UNIT 2 HPCI MOTOR OPER VALVE

Reviewed By: *W. T. Barn*

DATE 09/20/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-017

SHEET 8 OF 59.

DEFINITION OF TERMS09/19/86

<u>TERM</u>	<u>DEFINITION OF TERM</u>
	AT THE LOCATION WHERE THE CST LINE CONNECTS TO IT
PRV	SYSTEM SUCTION RELIEF VALVE ACTUATION SET PRESSURE
PELS	HYDROSTATIC PRESSURE DIFFERENCE BETWEEN THE MINIMUM SUPPRESSION POOL WATER LEVEL AND THE LOCATION OF THE RELIEF VALVE ON THE PUMP SUCTION LINE
PLOC	LOCA WETWELL PRESSURE WHEN THE SYSTEM IS ISOLATED
PLOM	HYDROSTATIC PRESSURE UPSTREAM OF THE VALVE DUE TO MAXIMUM LOCA SUPPRESSION POOL WATER LEVEL
PC	MAXIMUM LOCA WETWELL PRESSURE WHEN SYSTEM IS REQUIRED TO OPERATE
PATM	ATMOSPHERIC PRESSURE
PVEL	DIFFERENTIAL PRESSURE ASSOCIATED WITH VALVE CLOSURE DUE TO FLUID VELOCITY CHANGES (I.E., WATER HAMMER TYPE PRESSURE INCREASE) INSIDE THE PIPE

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2	Prepared By: <i>J.B. Hickman</i>	DATE 09/19/86
UNIT 2 HPCI MOTOR OPER VALVE	Reviewed By: <i>W.T. Barr</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-017	SHEET 9 OF 59.
DERIVATION OF VALUES		09/19/86

TERM	PRESSURE (PSIG)	DERIVATION OF VALUE
------	-----------------	---------------------

PSOH	2240	FROM S-25701 REV. E, BYRON JACKSON PUMP MANUAL, PUMP CURVE T-33713-1 @ A TURBINE SPEED OF 4000 RPM.
------	------	---

PEL	5.97	THE ELEVATION OF THE FEEDWATER PIPING NOZZLE AT THE REACTOR IS GIVEN AS 183' 9 1/2" IN H-26298 REV. 4. THE MAXIMUM WATER LEVEL IN THE CST IS GIVEN AS 170' 0" IN A-26497 REV. 12. FOR 2P21-N002. THUS THE DIFFERENCE IN ELEVATION IS: $183' 9 \frac{1}{2}" - 170' 0" = 7' 9 \frac{1}{2}"$ $= 13.79 \text{ FT H2O}.$ AND THE HYDROSTATIC PRESSURE IS: $13.79 \text{ FT H2O} \times 0.432781 \text{ PSIG/FT H2O} = 5.97 \text{ PSIG}$
-----	------	---

PISO	855	FROM A-26497 REV.12 INSTRUMENT SETPOINT INDEX. USE THE MSL ISOLATION SETPOINT AS GIVEN FOR INSTRUMENTS 2B21-N015 A-D.
------	-----	---

PELM	29.58	THE CST IS AT ITS MAXIMUM WATER LEVEL AND THE SUPPRESSION POOL IS AT ITS MINIMUM WATER LEVEL WHEN THE MINIMUM FLOW BYPASS VALVE IS REQUIRED
------	-------	--

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *J.B. Harkin* DATE 09/20/86UNIT 2 HPCI MOTOR OPER VALVE Reviewed By: *W.T. Bam* DATE 09/21/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-017 SHEET 10 OF 59.

DERIVATION OF VALUES 09/20/86

TERM	PRESSURE (PSIG)	DERIVATION OF VALUE
------	-----------------	---------------------

PELM

TO OPERATE.

THE MAXIMUM WATER LEVEL IN THE CST
IS GIVEN AS 170' 0" IN A-26497 REV. 12
FOR INSTRUMENT 2P21-N002.

THE MINIMUM WATER LEVEL IN THE
SUPPRESSION POOL IS GIVEN AS 12' 2"
IN THE UNIT 2 TECHNICAL SPECIFICATION
SECTION 3.6.2.1 AMENDMENT NO. 62.

THE INSIDE BOTTOM ELEVATION OF THE
SUPPRESSION POOL IS GIVEN AS 89' 5 3/4",
DERIVED FROM 103' 6 1/4" - 14' 1/2 ",
IN S-27535 REV. 0.

THE ELEVATION OF THE SUPPRESSION POOL AT
MINIMUM WATER LEVEL IS THE INSIDE BOTTOM
ELEVATION PLUS THE MINIMUM WATER LEVEL:

$$89' 5 \frac{3}{4}" + 12' 2" = 101' 7 \frac{3}{4}"$$

THE HEAD DIFFERENCE IS THEN:

$$170' 0" - 101' 7 \frac{3}{4}" = 68' 4 \frac{1}{4}"$$

$$= 68.35 \text{ FT H}_2\text{O}$$

THUS THE HYDROSTATIC PRESSURE IS:

$$68.35 \text{ FT H}_2\text{O} \times 0.432781 \text{ PSIG/FT H}_2\text{O}$$

$$= 29.58 \text{ PSIG}$$

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2	Prepared By: <i>J.B. Hubler</i>	DATE 09/20/86
UNIT 2 HPCI MOTOR OPER VALVE	Reviewed By: <i>W.T. Barr</i>	DATE 09/21/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-017	SHEET 11 OF 59.
DERIVATION OF VALUES		09/20/86

TERM	PRESSURE (PSIG)	DERIVATION OF VALUE
PRSS	1090	FROM UNIT 2 TECHNICAL SPECIFICATION SECTION 3.4.2.1 AMENDMENT NO. 62.
PELD	29.44	THE MAXIMUM WATER LEVEL IN THE CST IS GIVEN AS 170' 0" IN A-26497 REV. 12 FOR INSTRUMENT 2P21-N002. THE MAXIMUM WATER LEVEL IN THE SUPPRESSION POOL IS 12' 6" GIVEN IN UNIT 2 TECHNICAL SPECIFICATION SECTION 3.6.2.1 AMENDMENT NO. 62. THE INSIDE BOTTOM ELEVATION OF THE SUPPRESSION POOL IS 89' 5 3/4", DERIVED FROM 103' 6 1/4" - 14' 1/2", IN S-27535 REV. 0. THE ELEVATION OF THE SUPPRESSION POOL MAXIMUM WATER LEVEL IS THE INSIDE BOTTOM ELEVATION PLUS THE MAXIMUM WATER LEVEL: $89' 5 \frac{3}{4}" + 12' 6" = 101' 11 \frac{3}{4}"$ THE HEAD DIFFERENCE IS THEN: $170' 0" - 101' 11 \frac{3}{4}" = 68' 0 \frac{1}{4}"$ $= 68.02 \text{ FT H2O}$ THUS THE HYDROSTATIC PRESSURE IS: $68.02 \text{ FT} \times 0.432781 \text{ PSI/FT H2O} = 29.44 \text{ PSIG}$
PMF	2235	FROM S-25701 REV.E, BYRON JACKSON PUMP MANUAL, PUMP CURVE T-33713-1 AT A MINIMUM FLOW

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2	Prepared By: <i>L.B. Harkins</i>	DATE 09/20/86
UNIT 2 HPCI MOTOR OPER VALVE	Reviewed By: <i>W.T. Barr</i>	DATE 09/21/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-017	SHEET 12 OF 59.
DERIVATION OF VALUES		09/20/86

<u>TERM</u>	<u>PRESSURE (PSIG)</u>	<u>DERIVATION OF VALUE</u>
-------------	------------------------	----------------------------

PMF

BYPASS RATE OF 450 GPM, S-25176 REV. 0
PROCESS DIAGRAM HPCI SYSTEM, AND A TURBINE
SPEED OF 4000 RPM.

PV

0.374

THE HPCI SYSTEM RATED FLOW IS GIVEN
AS 4250 GPM IN THE UNIT 2 TECHNICAL
SPECIFICATION SECTION 4.5.1 AMENDMENT
NO. 62.
THE INSIDE DIAMETER OF THE SUPPRESSION POOL
SUCTION LINE IS 15.250 GIVEN IN
H-26020 REV. 17, UNIT 2 PIPE SPECIFICATION
AND THE CRANE TECHNICAL PAPER NO. 410,
18TH PRINTING. THE VELOCITY HEAD IS
EQUAL TO: $(V)^{**2}/2*gc$ FROM CRANE TP NO 410,
WHERE:

gc IS GRAVITATIONAL CONSTANT

$$= 32.2 \text{ FT}/(\text{SEC})^{**2}$$

$$PI = 3.1416$$

$$V = Q/A$$

$$V = (4250 * 0.13368) * (144/60) /$$

$$[PI (15.250)^{**2}/4]$$

$$= 7.46 \text{ FT/SEC}$$

THUS THE VELOCITY HEAD IS:

$$(7.46)^{**2}/2(32.2) = 0.865 \text{ FT H2O}$$

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *L.B. Haykin* DATE 09/20/86UNIT 2 HPCI MOTOR OPER VALVE Reviewed By: *W.T. Barr* DATE 09/21/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-017 SHEET 13 OF 59.

DERIVATION OF VALUES 09/20/86

<u>TERM</u>	<u>PRESSURE (PSIG)</u>	<u>DERIVATION OF VALUE</u>
PV		AND VELOCITY HEAD PRESSURE IS: $0.865 \text{ FT H}_2\text{O} \times 0.432781 \text{ PSIG/FT H}_2\text{O}$ $= 0.374 \text{ PSIG}$
PRV	100	FROM S-27294 REV. F MODEL LCT-20 SERIES RELIEF VALVE.
PELS	2.88	THE MINIMUM SUPPRESSION POOL ELEVATION WAS DETERMINED TO BE $101' 7 \frac{3}{4}"$ IN THE CALCULATION FOR PELM ABOVE. THE ELEVATION FOR THE SUCTION RELIEF VALVE 2E41-F020 IS GIVEN AS $95' 0"$ IN S-36017 REV. 0. THUS THE HYDROSTATIC HEAD IS: $101' 7 \frac{3}{4}" - 95' 0" = 6' 7 \frac{3}{4}"$ $= 6.65 \text{ FT H}_2\text{O}$ AND THE HYDROSTATIC PRESSURE IS: $6.65 \text{ FT.} \times 0.432781 \text{ PSIG/FT H}_2\text{O}$ $= 2.88 \text{ PSIG}$
PLOC	31.6	PLOC=PC. THE ECCS OPERATION MAY REQUIRE THE CLOSURE OF THE SUPPRESSION POOL ISOLATION VALVES TO PROVIDE PRIMARY CONTAINMENT ISOLATION FOR EXTREME LOCA

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *L.B. Hopkins* DATE 09/20/86UNIT 2 HPCI MOTOR OPER VALVE Reviewed By: *W.T. Barr* DATE 09/21/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-017 SHEET 14 OF 59.

DERIVATION OF VALUES 09/20/86TERM PRESSURE (PSIG) DERIVATION OF VALUE

PLOC CONDITIONS FOLLOWING UTILIZATION OF THE
WETWELL INVENTORY.

PLOM1 5.46 THE MAXIMUM LOCA SUPPRESSION POOL WATER LEVEL
IS 102' 7 1/2" GIVEN IN S-27535 REV. 0.
THE CENTERLINE ELEVATION OF VALVES 2E41-F041
AND 2E41-F042 IS 90' 0" FROM
S-26835 REV. E.
THE HEAD DIFFERENCE IS:
 $102' 7 \frac{1}{2}" - 90' 0" = 12' 7 \frac{1}{2}"$
 $= 12.625 \text{ FT H}_2\text{O}.$
THUS THE HYDROSTATIC PRESSURE IS:
 $12.625 \text{ FT H}_2\text{O} \times 0.432781 \text{ PSIG/FT H}_2\text{O}$
 $= 5.46 \text{ PSIG}$

PLOM2 5.41 THE MAXIMUM LOCA SUPPRESSION POOL WATER
LEVEL IS 102' 7 1/2" GIVEN IN S-27535 REV. 0.
THE CENTERLINE ELEVATION OF VALVE 2E41-F059
IS 90' 1 1/2" FROM S-36034 REV. A.
THE HEAD DIFFERENCE IS:
 $102' 7 \frac{1}{2}" - 90' 1 \frac{1}{2}" = 12' 6"$
 $= 12.5 \text{ FT H}_2\text{O}$
THUS THE HYDROSTATIC PRESSURE IS:
 $12.5 \text{ FT H}_2\text{O} \times 0.432781 \text{ PSIG/FT H}_2\text{O}$

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *J.B. Hatcher* DATE 09/21/86UNIT 2 HPCI MOTOR OPER VALVE Reviewed By: *C. Brown* DATE 09/21/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-017 SHEET 15 OF 59.

DERIVATION OF VALUES 09/21/86

<u>TERM</u>	<u>PRESSURE (PSIG)</u>	<u>DERIVATION OF VALUE</u>
PLOM2		= 5.41 PSIG
PC	31.6	FROM NEDO DOC. 24569 REV. 2 FIGURE H2 4.1.2-1.
PATM	0	NORMAL ATMOSPHERIC PRESSURE = 14.6976 PSIA $PSIG = PSIA - 14.696 = 0$
PVEL1	0	KELLOGG ISOMETRIC DRAWINGS S-26835 REV. E, S-26837 REV. M, SX-22585 REV. D, AND SX-24226 REV. C SHOW THAT THE UPSTREAM PIPING IS CONNECTED TO THE CONDENSATE STORAGE TANK. IT IS ASSUMED THAT ANY WATER HAMMER EFFECTS IN THE UPSTREAM PIPING WOULD BE DISSIPATED WITHIN THE CST VOLUME AND PRODUCE NO RESULTANT PRESSURE RISE ON THE VALVE. THE REFERENCED DRAWINGS ALSO SHOW THAT THE DOWNSTREAM PIPING IS INTERCONNECTED WITH THE SUPPRESSION POOL SUCTION LINE. IT IS ASSUMED THE HPCI PUMP IS OPERATING TO DRAW A SUCTION FROM THE SUPPRESSION POOL WHEN 2E41-F004 BEGINS TO CLOSE. THEREFORE NO DOWNSTREAM FLUID DECELERATION WILL RESULT. IT MAY BE CONCLUDED THAT NO INCREASE IN PRESSURE

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2	Prepared By: <i>L.B. Harkin</i>	DATE 09/21/86
UNIT 2 HPCI MOTOR OPER VALVE	Reviewed By: <i>C. Brown</i>	DATE 09/21/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-017	SHEET 16 OF 59.
<u>DERIVATION OF VALUES</u>		<u>09/21/86</u>

<u>TERM</u>	<u>PRESSURE (PSIG)</u>	<u>DERIVATION OF VALUE</u>
-------------	------------------------	----------------------------

PVEL1

RESULTS BECAUSE OF WATER HAMMER.

CONSIDERING THE ABOVE FACTS VALVE 2E41-F004

CAN BE CONSIDERED TO HAVE NO WATER

HAMMER PRESSURE INCREASE.

PVEL2 8.163

DIFFERENTIAL PRESSURE ACROSS THE VALVE DUE

TO WATER HAMMER FOR 2E41-F006:

THE VALUE FOR PVEL2 IS CALCULATED BY COMPUTER.

A DERIVATION FOR PVEL AND THE GATE VALVE

AREA VS PERCENT OPEN CURVE USED IN THE CALCULATION

ARE FOUND ATTACHED. THE FOLLOWING DATA IS USED

IN THE CALCULATION TO DERIVE PVEL2:

SYSTEM VELOCITY UPSTREAM (V_{su}) AND SYSTEM VELOCITY
DOWNSTREAM (V_{sd}), WHERE:

FLOWRATE = 4250 GPM FROM S-25176 REV. 0.

AREA OF 14" SCH 80 PIPE = 122.72 IN SQ

AREA OF 14" SCH 100 PIPE = 115.49 IN SQ

FROM CRANE TECHNICAL PAPER No. 410.

THEN:

$V_{su} = (4250 \text{ GPM} \times 0.321) / 122.72 \text{ IN SQ}$

$= 11.12 \text{ FT/SEC}$

$V_{sd} = (4250 \text{ GPM} \times 0.321) / 115.49 \text{ IN SQ}$

$= 11.81 \text{ FT/SEC}$

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2	Prepared By: <i>LB Harkin</i>	DATE 09/21/86
UNIT 2 HPCI MOTOR OPER VALVE	Reviewed By: <i>C. Brown</i>	DATE 09/21/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-017	SHEET 17 OF 59.
DERIVATION OF VALUES		09/21/86

TERM	PRESSURE (PSIG)	DERIVATION OF VALUE
------	-----------------	---------------------

PVEL2

CLOSURE TIME = 20 SEC FROM A-26503 SH 2

VALVE THROAT DIAMETER

. DIAM VALVE = 11.25" PER TELEPHONE CONFIRMATION

. FROM BRAD HARKINS OF SCS TO DENNIS

. SCHERER OF POWELL ON 09/11/86

LENGTH UPSTREAM (LU) AND DOWNSTREAM (LD)

. LU = 252.36 FT FROM S-26839 REV. G,

. S-26841 REV. N AND S-26843 REV. M

. LD = 152.35 FT FROM S-26843 REV. M, S-29112

. REV. H, S-28980 REV. M AND S-28978 REV. N

PVEL2 = 8.163 FROM COMPUTER PRINTOUT.

PVEL3 6.025

DIFFERENTIAL PRESSURE ACROSS THE VALVE DUE TO
WATER HAMMER FOR 2E41-F012:

THE VALUE FOR PVEL3 IS CALCULATED BY COMPUTER.

A DERIVATION FOR PVEL AND THE GLOBE VALVE

CV VS PERCENT OPEN CURVE USED IN THE CALCULATION

ARE FOUND ATTACHED. THE FOLLOWING DATA IS USED

IN THE CALCULATION TO DERIVE PVEL3:

. SYSTEM VELOCITY UPSTREAM (V_{su}) AND SYSTEMVELOCITY DOWNSTREAM (V_{sd}) WHERE:

. FLOWRATE = 450 GPM FROM S-25176 REV. 0

. AREA IF 4" SCH 80 PIPE = 11.5 IN SQ

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2	Prepared By: <i>JB Huber</i>	DATE 09/21/86
UNIT 2 HPCI MOTOR OPER VALVE	Reviewed By: <i>C. Brown</i>	DATE 09/21/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-017	SHEET 10 OF 59.
DERIVATION OF VALUES		09/21/86

TERM	PRESSURE (PSIG)	DERIVATION OF VALUE
------	-----------------	---------------------

PVEL3

. AREA OF 4" SCH 40 PIPE = 12.73 IN SQ
. FROM CRANE TECHNICAL PAPER No. 410

THEN:

$$V_{su} = (450 \text{ GPM} \times 0.321) / 11.5 \text{ IN SQ}$$

. = 12.561 FT/SEC

$$V_{sd} = (450 \text{ GPM} \times 0.321) / 12.73 \text{ IN SQ}$$

. = 11.347 FT/SEC

CLOSURE TIME = 10 SEC FROM A-26503 SH 30

VALVE THROAT DIAMETER

. DIAM VALVE = 2.5" PER TELECOPY TO JACK
. ROBYN OF SCS FROM PAUL COUTINHO OF VELAN
. ON 9/18/86.

LENGTH UPSTREAM (LU) AND LENGTH DOWNSTREAM (LD)

. LU = 59.86 FT FROM S-26845 REV. J

. AND S-26839 REV. G

. LD = 49.59 FT FROM S-26845 REV. J

. AND S-26847 REV. L

. FOR LD IT IS ASSUMED THAT THE WATER HAMMER
. BOUNDARY ENDS AT THE TIE IN TO THE
. RHR TEST LINE.

PVEL3 = 6.025 FROM COMPUTER PRINTOUT

PVEL4 0.937

DIFERENTIAL PRESSURE ACROSS THE VALVE DUE TO
WATER HAMMER FOR 2E41-F059.

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: E. B. Harkins DATE 09/21/86UNIT 2 HPCI MOTOR OPER VALVE Reviewed By: C. J. Jern DATE 09/21/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-017 SHEET 19 OF 59.

DERIVATION OF VALUES 09/21/86TERM PRESSURE (PSIG) DERIVATION OF VALUE

PVEL4

THE VALUE FOR PVEL4 IS CALCULATED BY COMPUTER.

A DERIVATION FOR PVEL AND THE GLOBE VALVE

CV VS PERCENT OPEN CURVE USED IN THE CALCULATION

ARE FOUND ATTACHED. THE FOLLOWING DATA IS USED

IN THE CALCULATION TO DERIVE PVEL4:

SYSTEM VELOCITY UPSTREAM (V_{su}) AND SYSTEM
VELOCITY DOWNSTREAM (V_{sd}) WHERE:

- . FLOWRATE = 70 GPM FROM S-25176 REV. 0
- . AREA OF 2" SCH 80 PIPE = 2.953 IN SQ
- . FROM CRANE TECHNICAL PAPER No. 410

THEN

- . $V_{su} = (70 \text{ gpm} \times 0.321) / 2.953 \text{ IN SQ}$
- . $= 7.601 \text{ FT/SEC}$
- . $V_{sd} = V_{su}$

CLOSURE TIME = 10 SEC FROM A-26503 SH 1

- . PER STD. STROKE TIME HNP2
- . FSAR TABLE 6.2-5 SH 2 NOTE 7

VALVE THROAT DIAMETER

- . DIAM VALVE = 1.403" PER TELECOPY TO JACK
- . ROBYN OF SCS FROM DAN HARASENGCH OF
- . YARWAY ON 9/11/86.

LENGTH UPSTREAM (LU) AND LENGTH DOWNSTREAM (LD)

- . $LU = 16.23 \text{ FT}$ FROM S-36034 REV. A

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *J.B. Harkin* DATE 09/21/86UNIT 2 HPCI MOTOR OPER VALVE Reviewed By: *C. Brown* DATE 09/21/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-017 SHEET 20 OF 59 .

DERIVATION OF VALUES 09/21/86TERM PRESSURE (PSIG) DERIVATION OF VALUE

PVEL4

. LD = 41.39 FT FROM S-36034 REV. A, S-36035
. REV. 0, S-36036 REV. 0, S-36037 REV. 0,
. S-36038 REV. A, AND S-36040 REV. A.

PVEL4 = 0.937 FROM COMPUTER PRINTOUT

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>JB Hopkins</i>	Date 9-19-86
Subject/Title Unit 2 HPCI Motor Operated Valve	Reviewed By <i>A.S. Kirk</i>	Date 9-20-86
Differential Pressure Calculation	Calculation Number SNH-86-017	Sheet 21 of 59

DETERMINE THE PRESSURE INCREASE DUE TO THE RAPID
DECELERATION OF FLUID CAUSED BY THE MOVEMENT
OF A PROCESS GATE OR GLOBE VALVE

ASSUMPTIONS

- 1) Valve openings result in no waterhammer effects. The differential pressure across a valve during opening is decreased by an increase in fluid velocity. The maximum actuator loading takes place before the valve lift occurs.
- 2) Steam valve closure results in only minor or no waterhammer effect. The compressible nature of the fluid medium coupled with maximum anticipated velocity changes make the pressure addition insignificant.
- 3) Area of flow through a gate valve is a direct and linear relation to system velocity.
- 4) The percentage of valve opening is a direct relation to opening time.
- 5) It is assumed that flowing pressure does not drop below the fluids vapor pressure.

The pressure increase due to sudden deceleration of fluid may be expressed as:

$$PVEL = P1 + P2$$

Where P1 is the upstream pressure change, and P2 is the downstream pressure change.

The respective values for P1 and P2 may be calculated as follows:

$$P1, P2 = \frac{f C \Delta V_{MAX}}{144 g}$$

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>T.B. Hubbs</i>	Date 9-19-86
Subject/Title Unit 2 HPCI Motor Operated Valve	Reviewed By <i>A.S. Kirk</i>	Date 9-20-86
Differential Pressure Calculation	Calculation Number SNH-86-017	Sheet 22 of 59

Where: ρ is the fluid density

C is the speed of sound through the fluid

ΔV_{MAX} is the maximum system fluid differential velocity

144 is a conversion factor

and g is the Gravitational Constant



The fluid ΔV is assumed to be a direct relation to flow area, as shown in the gate valve area - percent open curves, and is a direct relation to Cv, as shown on the globe valve Cv - percent open curves.

The valve Δt is a direct relation to Δ percentage open.


Therefore:

$$\frac{\Delta A}{\Delta \% \text{ Open}} \approx \frac{\Delta C_v}{\Delta \% \text{ Open}} \approx \frac{\Delta V}{\Delta t}$$

Having plotted a velocity relation against a time relation the region of highest differential velocity is examined.



Design Calculations

Southern Company Services 

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>YB Hopkins</i>	Date 9-19-86
Subject/Title Unit 2 HPCI Motor Operated Valve	Reviewed By <i>A.S. Kib</i>	Date 9-20-86
Differential Pressure Calculation	Calculation Number SNH-86-017	Sheet 23 of 59

Incremental time is Defined As:

$$\Delta t = t_2 - t_1 = \frac{2L}{c}$$

Where the term $2L/C$ is the time require for a pressure wave to travel down a pipe's flow length and rebound to it's source valve.

Knowing the equation of the curve, the maximum ΔV for Δt (ie; greatest slope) is calculated and entered into the pressure equations.

The procedure is once again performed for the down stream side of the valve and added as follows to produce PVEL

$$PVEL = P_1 + P_2$$

Reference: BWROG REPORT APP. B


0082d

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>C. L. Loran</i>	Date 9-19-86
Subject/Title Unit 2 HPCI Motor Operated Valve	Reviewed By <i>AD McPherson</i>	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-017	Sheet 24 of 59

RELATIONSHIP OF THE GATE VALVE FLOW AREA TO THE
PERCENTAGE OPENING OF A TYPICAL GATE VALVE

It is assumed that the diameter of the gate is equal to the port diameter of the valve since the difference in diameters is insignificantly small.


THE FLOW AREA OF THE VALVE MAY BE DETERMINED BY SUBTRACTING THE AREA OF THE GATE OCCLUDING THE TOTAL PORT AREA.



A = Area

$$A_{\text{Flow}} = A_{\text{Port}} - A_{\text{Gate}}$$

THE AREA OF THE PORT IS CALCULATED USING THE CIRCULAR SEGMENT CALCULATION



$$A_{\text{SEG}} = h/6s (3h^2 + 4s^2)$$

WITH h = RISE = RADIUS
AND s = CHORD = DIAMETER


THE AREA OF THE PORT IS EQUAL TO TWICE ASEG



$$A_{\text{PORT}} = 2A_{\text{SEG}} = R/6D (3R^{**2} + 4D^{**2})$$

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>S. L. Brown</i>	Date 9.19.86
Subject/Title Unit 2 HPCI Motor Operated Valve	Reviewed By <i>AD McAllister</i>	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-017	Sheet 25 of 59

THE OCCLUDING AREA OF THE GATE IS FOUND BY USING THE AREA OF A CIRCULAR SEGMENT CALCULATION.



$$ASEG = h/6s (3h^2 + 4s^2)$$


$$r = h/2 + s^2/8h$$

TRANSFORMING THE LATER EQUATION

$$s = (8h (r - (h/2)))^{1/2}$$

WHICH COMBINED WITH THE ASEG CALCULATION MAY BE READILY SOLVED.

THE AREA OCCLUDED IS EQUAL TO TWICE ASEG.



$$AGATE = 2 ASEG.$$


THUS THE AREA OF FLOW THROUGH THE VALVE IS CALCULATED AS:

$$A_{Flow} = A_{PORT} - A_{GATE}$$




$$A_{Flow}$$

Design Calculations

Southern Company Services 

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>C. Sorenson</i>	Date 9-19-86
Subject/Title Unit 2 HPCI Motor Operated Valve	Reviewed By <i>W.D. McNeil</i>	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-017	Sheet 26 of 59

A GRAPHIC PRESENTATION OF THE TYPICAL FLOW AREA VS. PERCENT VALVE OPENING IS GIVEN AS FOLLOWS.



REFERENCE: ENGINEERING FORMULAS 4th EDITION, PAGE P3.

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>C. Lorenson</i>	Date 9-19-86
Subject/Title Unit 2 HPCI Motor Operated Valve	Reviewed By <i>A.S. Kirk</i>	Date 9-19-86
Differential Pressure Calculation	Calculation Number SNH-86-017	Sheet 27 of 59

NUMERICAL RELATIONSHIP BETWEEN A GRAPHICAL PRESENTATION
OF MANUFACTURER'S 2" GLOBE VALVE OPENING
VS. MANUFACTURER'S CV DATA

Given a curve of 0-100 % opening (see attached), It is Desired to numerically relate the first 60% of opening to CV.

The First 60% of opening is a linear function thus, the curve may be equated using linear regression of the point-slope form.

$$y - y_1 = m(x - x_1)$$

Using the points (0,0) and (50,40)

$$40 - 0 = m(50 - 0)$$

Solving for m

$$m = 40/50 = 0.8$$

The equation of a line is given as:

$$y = mx$$


Hence, the equation relating cv with percent opening is:

$$CV = 0.8 (\text{percentage opening})$$

FOR ALL OPENINGS LESS THAN 60%.

Reference: THE ENGINEER'S COMPANION 1966 PG. 13.

BRN 8/3/65



Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>T.B. Haysler</i>	Date 9-19-86
Subject/Title Unit 2 HPCI Motor Operated Valve	Reviewed By <i>A.S. Kirk</i>	Date 9-19-86
Differential Pressure Calculation	Calculation Number SNH-86-017	Sheet 29 of 59

NUMERICAL RELATIONSHIP BETWEEN A GRAPHICAL PRESENTATION
OF MANUFACTURER'S 4" GLOBE VALVE OPENING
VS. MANUFACTURER'S CV DATA

Given a curve of 0-100 % opening (see attached), It is Desired to numerically relate the first 45% of opening to CV.

The First 45% of opening is a linear function thus, the curve may be equated using linear regression of the point-slope form.

$$y - y_1 = m(x - x_1)$$

Using the points (10,15) and (30,49)

$$49 - 15 = m(30 - 10)$$

Solving for m

$$m = 34/20 = 1.7$$

The equation of a line is given as:

$$y = mx$$

Hence, the equation relating cv with percent opening is:

$$CV = 1.7 (\text{percentage opening})$$

FOR ALL OPENINGS LESS THAN 49%.

Reference: THE ENGINEER'S COMPANION 1966 PG. 13.

TELECOPY MESSAGE - MR. JACK ROBYN
TELECOPY NO.: 205-868-5143
FROM: RAUL COUTINHO - SEPT. 18/86

C_v - PERCENTAGE OF MAX.

GENERIC CURVE
 C_v VERSUS LIFT

OLD STYLE GLOBE
VALVES (FORGED)

CURVE NO.: 001

PERCENTAGE OF LIFT

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1&2

Prepared By: *A.B. Harkins*

DATE 09/21/86

MOTOR OPERATED VALVE

Reviewed By: *D. Wilson*

DATE 09/21/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-017

SHEET 31 OF 59.

GATE VALVE PVEL CALCULATION

MPL NUMBER	2E41-F006
VALVE DIAMETER (INCHES)	11.25
CLOSING TIME (SECONDS)	20
UPSTREAM PIPE LENGTH (FT)	252.36
DOWNSTREAM PIPE LENGTH (FT)	152.35
UPSTREAM SYSTEM VEL (FT/SEC)	11.12
DOWNSTREAM SYSTEM VEL (FT/SEC)	11.81
delta TIME UPSTREAM (SECONDS)	0.12618
delta TIME DWNSTREAM (SECONDS)	0.076175
TIME UPSTREAM 1 (SECONDS)	19.87382
TIME UPSTREAM 2 (SECONDS)	20
TIME DOWNSTREAM 1 (SECONDS)	19.923825
TIME DOWNSTREAM 2 (SECONDS)	20
RISE UPSTREAM 1	5.5895119
RISE UPSTREAM 2	5.625
RISE DOWNSTREAM 1	5.6035758
RISE DOWNSTREAM 2	5.625
CHORD UPSTREAM 1	11.249776
CHORD UPSTREAM 2	11.25
CHORD DOWNSTREAM 1	11.249918
CHORD DOWNSTREAM 2	11.25
MAX AREA (IN SQ)	100.19531
AREA FLOW UPSTREAM 1	0.8312275
AREA FLOW UPSTREAM 2	0
AREA FLOW DOWNSTREAM 1	0.5019387
AREA FLOW DOWNSTREAM 2	0
a/Au1	0.0083623
a/Au2	0
a/Ad1	0.0050496
a/Ad2	0
VELOCITY UPSTREAM 1 (FT/SEC)	0.0929886
VELOCITY UPSTREAM 2 (FT/SEC)	0
VELOCITY DOWNSTREAM 1 (FT/SEC)	0.0596356
VELOCITY DOWNSTREAM 2 (FT/SEC)	0
delta VEL UPSTREAM (FT/SEC)	0.0929886
delta VEL DOWNSTREAM (FT/SEC)	0.0596356
Pvu UPSTREAM PRESSURE (PSIG)	4.97319
Pvd DOWNSTREAM PRESSURE (PSIG)	3.1894146

Pvel (PSIG)

8.1626046

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1&2

Prepared By: *ZB Huber*

DATE 09/19/86

MOTOR OPERATED VALVE

Reviewed By: *D Wilson*

DATE 09/20/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-017

SHEET 32 OF 59 .

FOUR INCH GLOBE VALVE PVEL CALCULATIONS

MPL NUMBER	2E41-F012
VALVE DIAMETER (INCHES)	2.5
CLOSING TIME (SECONDS)	10
UPSTREAM PIPE LENGTH (FT)	59.86
DOWNSTREAM PIPE LENGTH (FT)	49.59
UPSTREAM SYSTEM VEL (FT/SEC)	12.561
DOWNSTREAM SYSTEM VEL (FT/SEC)	11.347
delta TIME UPSTREAM (SECONDS)	0.02993
delta TIME DWNSTREAM (SECONDS)	0.024795
TIME UPSTREAM 1 (SECONDS)	5
TIME UPSTREAM 2 (SECONDS)	5.02993
TIME DOWNSTREAM 1 (SECONDS)	5
TIME DOWNSTREAM 2 (SECONDS)	5.024795
% OPEN UPSTREAM 1	50
% OPEN UPSTREAM 2	50.2993
% OPEN DOWNSTREAM 1	50
% OPEN DOWNSTREAM 2	50.24795
% CV UPSTREAM 1	85.7
% CV UPSTREAM 2	86.213
% CV DOWNSTREAM 1	85.7
% CV DOWNSTREAM 2	86.124986
delta VEL UPSTREAM (FT/SEC)	0.064438
delta VEL DOWNSTREAM (FT/SEC)	0.0482232
Pvu UPSTREAM (PSIG)	3.4462521
Pvd DOWNSTREAM (PSIG)	2.579059
Pvel3 (PSIG)	6.0253112

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1&2	Prepared By: <i>J.B. Hatcher</i>	DATE 09/19/86
MOTOR OPERATED VALVE	Reviewed By: <i>D. Wilson</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-017	SHEET 33 OF 59.

TWO INCH GLOBE VALVE PVEL CALCULATIONS

MPL NUMBER	2E41-F059
VALVE DIAMETER (INCHES)	1.403
CLOSING TIME (SECONDS)	10
UPSTREAM PIPE LENGTH (FT)	16.23
DOWNSTREAM PIPE LENGTH (FT)	41.39
UPSTREAM SYSTEM VEL (FT/SEC)	7.601
DOWNSTREAM SYSTEM VEL (FT/SEC)	7.601
delta TIME UPSTREAM (SECONDS)	0.008115
delta TIME DWNSTREAM (SECONDS)	0.020695
TIME UPSTREAM 1 (SECONDS)	5
TIME UPSTREAM 2 (SECONDS)	5.008115
TIME DOWNSTREAM 1 (SECONDS)	5
TIME DOWNSTREAM 2 (SECONDS)	5.020695
% OPEN UPSTREAM 1	50
% OPEN UPSTREAM 2	50.08115
% OPEN DOWNSTREAM 1	50
% OPEN DOWNSTREAM 2	50.20695
% CV UPSTREAM 1	40
% CV UPSTREAM 2	40.06492
% CV DOWNSTREAM 1	40
% CV DOWNSTREAM 2	40.16556
delta VEL UPSTREAM (FT/SEC)	0.0049346
delta VEL DOWNSTREAM (FT/SEC)	0.0125842
Pvu UPSTREAM (PSIG)	0.2639092
Pvd DOWNSTREAM (PSIG)	0.6730254

Pvel 4(PSIG)

0.9369346

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2	Prepared By: <i>J.B. Hopkins</i>	DATE 09/20/86
UNIT 2 HPCI MOTOR OPER VALVE	Reviewed By: <i>W.T. Barr</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-017	SHEET 34 OF 59 .

DIFFERENTIAL PRESSURE CALCULATION 09/19/86MPL NUMBER

2E41-F001

VALVE DESCRIPTION

TURBINE STEAM SUPPLY VALVE

VALVE FUNCTION

HPCI TURBINE STEAM ADMISSION VALVE

SAFETY ACTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PRSS

MAXIMUM DP UPSTREAM/DOWNSTREAM

OPEN

SAFETY ON OPEN/CLOSE

OPEN

MAXIMUM DP ON OPEN OR CLOSE

UPSTREAM

VALUES

PRSS = 1090

DP (PSID)

1090

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2	Prepared By: <i>J.B. Harkin</i>	DATE 09/20/86
UNIT 2 HPCI MOTOR OPER VALVE	Reviewed By: <i>D.T. Barr</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-017	SHEET 35 OF 59 .

DIFFERENTIAL PRESSURE CALCULATION 09/19/86MPL NUMBER

2E41-F002

VALVE DESCRIPTION

STEAM SUPPLY INBOARD ISOL VALVE

VALVE FUNCTION

HPCI STEAM LINE ISOLATION VALVE

SAFETY ACTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PRSS

MAXIMUM DP UPSTREAM/DOWNSTREAM

CLOSE

SAFETY ON OPEN/CLOSE

CLOSE

MAXIMUM DP ON OPEN OR CLOSE

UPSTREAM

VALUES

PRSS = 1090

DP (PSID)

1090

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *L.B. Hinkle* DATE 09/20/86UNIT 2 HPCI MOTOR OPER VALVE Reviewed By: *W.T. Ban* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-017 SHEET 36 OF 59 .

DIFFERENTIAL PRESSURE CALCULATION 09/19/86MPL NUMBER

2E41-F003

VALVE DESCRIPTION

STEAM SUPPLY OUTBD ISOL VALVE

VALVE FUNCTION

HPCI STEAM LINE ISOLATION VALVE

SAFETY ACTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PRSS

MAXIMUM DP UPSTREAM/DOWNSTREAM

CLOSE

SAFETY ON OPEN/CLOSE

CLOSE

MAXIMUM DP ON OPEN OR CLOSE

UPSTREAM

VALUES

PRSS = 1090

DP (PSID)

1090

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *J.B. Harker* DATE 09/20/86UNIT 2 HPCI MOTOR OPER VALVE Reviewed By: *W.T. Ban* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-017 SHEET 37 OF 59 .

DIFFERENTIAL PRESSURE CALCULATION 09/19/86MPL NUMBER

2E41-F004

VALVE DESCRIPTION

PUMP SUCT FRM COND STOR TANK

VALVE FUNCTION

HPCI CST SUCTION VALVE

SAFETY ACTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PELD+PV+PVEL1

MAXIMUM DP UPSTREAM/DOWNSTREAM

CLOSE

SAFETY ON OPEN/CLOSE

CLOSE

MAXIMUM DP ON OPEN OR CLOSE

UPSTREAM

VALUES

PELD = 29.44

PV = 0.374

PVEL1 = 0

DP (PSID)

29.814

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2

Prepared By: *LB*

DATE 09/21/86

UNIT 2 HPCI MOTOR OPER VALVE

Reviewed By: *C*

DATE 09/21/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-36-017

SHEET 38 OF 59

DIFFERENTIAL PRESSURE CALCULATION09/21/86MPL NUMBER

2E41-F006

VALVE DESCRIPTION

HPCI PUMP INBD DISCH VALVE

VALVE FUNCTION

HPCI INJECTION/ISOLATION VALVE

SAFETY ACTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PSOH-PISO-PEL+PVEL2

MAXIMUM DP UPSTREAM/DOWNSTREAM

CLOSE

SAFETY ON OPEN/CLOSE

OPEN/CLOSE

MAXIMUM DP ON OPEN OR CLOSE

UPSTREAM

VALUES

PSOH = 2240

PISO = 855

PEL = 5.97

PVEL2 = 8.163

DP (PSID)

1387.193

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *L.B. Huskisson* DATE 09/20/86
UNIT 2 HPCI MOTOR OPER VALVE Reviewed By: *W.T. Barr* DATE 09/20/86
DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-017 SHEET 39 OF 59 .

DIFFERENTIAL PRESSURE CALCULATION 09/19/86MPL NUMBER

2E41-F006

VALVE DESCRIPTION

HPCI PUMP INBD DISCH VALVE

VALVE FUNCTION

HPCI INJECTION/ISOLATION VALVE

SAFETY ACTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PSOH-PISO-PEL

MAXIMUM DP UPSTREAM/DOWNSTREAM

OPEN

SAFETY ON OPEN/CLOSE

OPEN/CLOSE

MAXIMUM DP ON OPEN OR CLOSE

UPSTREAM

VALUES

PSOH = 2240

PISO = 855

PEL = 5.97

DP (PSID)

1379.03

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *J.B. Harrison* DATE 09/20/86
UNIT 2 HPCI MOTOR OPER VALVE Reviewed By: *W.T. Barr* DATE 09/20/86
DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-017 SHEET 40 OF 59 .

DIFFERENTIAL PRESSURE CALCULATION 09/19/86MPL NUMBER

2E41-F007

VALVE DESCRIPTION

HPCI PUMP OUTBD DISCH VALVE

VALVE FUNCTION

HPCI INJECTION VALVE TEST VALVE

SAFETY ACTION (YES/NO)

NO

DP CALCULATION FORMULA

NO SAFETY ACTION

MAXIMUM DP UPSTREAM/DOWNSTREAM

N/A

SAFETY ON OPEN/CLOSE

NONE

MAXIMUM DP ON OPEN OR CLOSE

N/A

VALUESDP (PSID)

N/A

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2	Prepared By: <i>L.B. [Signature]</i>	DATE 09/20/86
UNIT 2 HPCI MOTOR OPER VALVE	Reviewed By: <i>W.T. [Signature]</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-017	SHEET 41 OF 59 .

DIFFERENTIAL PRESSURE CALCULATION 09/19/86MPL NUMBER

2E41-F008

VALVE DESCRIPTION

TEST BYPASS VALVE TO COND STOR

VALVE FUNCTION

HPCI CST TEST RETURN VALVE

SAFETY ACTION (YES/NO)

NO

DP CALCULATION FORMULA

NO SAFETY ACTION

MAXIMUM DP UPSTREAM/DOWNSTREAM

N/A

SAFETY ON OPEN/CLOSE

NONE

MAXIMUM DP ON OPEN OR CLOSE

N/A

VALUESDP (PSID)

N/A

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2	Prepared By: <i>J.B. Harker</i>	DATE 09/20/86
UNIT 2 HPCI MOTOR OPER VALVE	Reviewed By: <i>W.T. Barr</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-017	SHEET 42 OF 59 .
DIFFERENTIAL PRESSURE CALCULATION		09/19/86

MPL NUMBER

2E41-F011

VALVE DESCRIPTION

REDUNDANT SHUTOFF W/F008

VALVE FUNCTION

HPCI CST TEST RETURN VALVE

SAFETY ACTION (YES/NO)

NO

DP CALCULATION FORMULA

NO SAFETY ACTION

MAXIMUM DP UPSTREAM/DOWNSTREAM

N/A

SAFETY ON OPEN/CLOSE

NONE

MAXIMUM DP ON OPEN OR CLOSE

N/A

VALUESDP (PSID)

N/A

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *J.B. Harker* DATE 09/20/86UNIT 2 HPCI MOTOR OPER VALVE Reviewed By: *W.T. Barr* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-017 SHEET 43 OF 59 .

DIFFERENTIAL PRESSURE CALCULATION 09/19/86MPL NUMBER

2E41-F012

VALVE DESCRIPTION

PMP MIN FLO BYP TO SUPP POOL

VALVE FUNCTION

HPCI PUMP MIN FLO BYP ISOL VALVE

SAFETY ACTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PMF+PELM+PVEL3

MAXIMUM DP UPSTREAM/DOWNSTREAM

CLOSE

SAFETY ON OPEN/CLOSE

OPEN/CLOSE

MAXIMUM DP ON OPEN OR CLOSE

UPSTREAM

VALUES

PMF = 2235

PELM = 29.58

PVEL3 = 6.025

DP (PSID)

2270.605

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *J.B. Harrison* DATE 09/20/86
UNIT 2 HPCI MOTOR OPER VALVE Reviewed By: *W.T. Ban* DATE 09/20/86
DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-017 SHEET 44 OF 57 .

DIFFERENTIAL PRESSURE CALCULATION 09/19/86

MPL NUMBER

2E41-F012

VALVE DESCRIPTION

PMP MIN FLO BYP TO SUPP POOL

VALVE FUNCTION

HPCI PUMP MIN FLO BYP ISOL VALVE

SAFETY ACTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PSOH+PELM

MAXIMUM DP UPSTREAM/DOWNSTREAM

OPEN

SAFETY ON OPEN/CLOSE

OPEN/CLOSE

MAXIMUM DP ON OPEN OR CLOSE

UPSTREAM

VALUES

PSOH = 2240

PELM = 29.58

DP (PSID)

2269.58

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *J.B. Harkins* DATE 09/20/86UNIT 2 HPCI MOTOR OPER VALVE Reviewed By: *W.T. Barr* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-017 SHEET 45 OF 59 .

DIFFERENTIAL PRESSURE CALCULATION 09/19/86MPL NUMBER

2E41-F041

VALVE DESCRIPTION

PMP SUCT FROM SUPP POOL

VALVE FUNCTION

HPCI SUPP POOL SUCT ISOL VALVE

SAFETY ACTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PRV-PELS

MAXIMUM DP UPSTREAM/DOWNSTREAM

OPEN

SAFETY ON OPEN/CLOSE

OPEN/CLOSE

MAXIMUM DP ON OPEN OR CLOSE

DOWNSTREAM

VALUES

PRV = 100

PELS = 2.88

DP (PSID)

97.12

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2	Prepared By: <i>L.B. Hinkle</i>	DATE 09/20/86
UNIT 2 HPCI MOTOR OPER VALVE	Reviewed By: <i>W.T. Barr</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-017	SHEET 46 OF 59
DIFFERENTIAL PRESSURE CALCULATION		09/19/86

MPL NUMBER

2E41-F041

VALVE DESCRIPTION

PMP SUCT FROM SUPP POOL

VALVE FUNCTION

HPCI SUPP POOL SUCT ISOL VALVE

SAFETY ACTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PLOC+PLOM1

MAXIMUM DP UPSTREAM/DOWNSTREAM

CLOSE

SAFETY ON OPEN/CLOSE

OPEN/CLOSE

MAXIMUM DP ON OPEN OR CLOSE

UPSTREAM

VALUES

PLOC = 31.6

PLOM1 = 5.46

DP (PSID)

37.06

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *J.B. Hinkle* DATE 09/20/86UNIT 2 HPCI MOTOR OPER VALVE Reviewed By: *W.T. Barr* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-017 SHEET 47 OF 59 .

DIFFERENTIAL PRESSURE CALCULATION 09/19/86MPL NUMBER

2E41-F042

VALVE DESCRIPTION

PMP SUCT FROM SUPP POOL

VALVE FUNCTION

HPCI SUPP POOL SUCT ISOL VALVE

SAFETY ACTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PRV-PELS

MAXIMUM DP UPSTREAM/DOWNSTREAM

OPEN

SAFETY ON OPEN/CLOSE

OPEN/CLOSE

MAXIMUM DP ON OPEN OR CLOSE

DOWNSTREAM

VALUES

PRV = 100

PELS = 2.88

DP (PSID)

97.12

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2

Prepared By: *J.B. Hatcher*

DATE 09/20/86

UNIT 2 HPCI MOTOR OPER VALVE

Reviewed By: *W.T. Bar*

DATE 09/20/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-017

SHEET 48 OF 59 .

DIFFERENTIAL PRESSURE CALCULATION

09/19/86

MPL NUMBER

2E41-F042

VALVE DESCRIPTION

PMP SUCT FROM SUPP POOL

VALVE FUNCTION

HPCI SUPP POOL SUCT ISOL VALVE

SAFETY ACTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PLOC+PLOM1

MAXIMUM DP UPSTREAM/DOWNSTREAM

CLOSE

SAFETY ON OPEN/CLOSE

OPEN/CLOSE

MAXIMUM DP ON OPEN OR CLOSE

UPSTREAM

VALUES

PLOC = 31.6

PLOM1 = 5.46

DP (PSID)

37.06

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *T.B. Harrison* DATE 09/20/86UNIT 2 HPCI MOTOR OPER VALVE Reviewed By: *W.T. Ban* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-017 SHEET 49 OF 59 .

DIFFERENTIAL PRESSURE CALCULATION 09/19/86MPL NUMBER

2E41-F059

VALVE DESCRIPTION

COOLING WATER SUPPLY VALVE

VALVE FUNCTION

HPCI TURBINE ACCES COOLING WTR VLV

SAFETY ACTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PC+PLOM2

MAXIMUM DP UPSTREAM/DOWNSTREAM

OPEN

SAFETY ON OPEN/CLOSE

OPEN/CLOSE

MAXIMUM DP ON OPEN OR CLOSE

UPSTREAM

VALUES

PC = 31.6

PLOM2 = 5.41

DP (PSID)

37.01

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2

Prepared By: *J.B. Hinkle*

DATE 09/20/86

UNIT 2 HPCI MOTOR OPER VALVE

Reviewed By: *W.T. Barr*

DATE 09/20/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-017

SHEET 50 OF 59

DIFFERENTIAL PRESSURE CALCULATION09/19/86MPL NUMBER

2E41-F059

VALVE DESCRIPTION

COOLING WATER SUPPLY VALVE

VALVE FUNCTION

HPCI TURBINE ACCES COOLING WTR VLV

SAFETY ACTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PC+PLOM2+PVEL4

MAXIMUM DP UPSTREAM/DOWNSTREAM

CLOSE

SAFETY ON OPEN/CLOSE

OPEN/CLOSE

MAXIMUM DP ON OPEN OR CLOSE

UPSTREAM

VALUES

PC = 31.6

PLOM2 = 5.41

PVEL4 = 0.937

DP (PSID)

37.947

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *J.B. Hinkley* DATE 09/20/86UNIT 2 HPCI MOTOR OPER VALVE Reviewed By: *W.T. Ban* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-017 SHEETS 51 OF 59 .

DIFFERENTIAL PRESSURE CALCULATION 09/19/86MPL NUMBER

2E41-F104

VALVE DESCRIPTION

GATE VALVE 2 IN MO

VALVE FUNCTION

HPCI VAC BREAKER LINE ISOL VALVE

SAFETY ACTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PC+PATM

MAXIMUM DP UPSTREAM/DOWNSTREAM

CLOSE

SAFETY ON OPEN/CLOSE

CLOSE

MAXIMUM DP ON OPEN OR CLOSE

UPSTREAM

VALUES

PC = 31.6

PATM = 0

DP (PSID)

31.6

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2

Prepared By: *J.B. Hukins*

DATE 09/20/86

UNIT 2 HPCI MOTOR OPER VALVE

Reviewed By: *W.T. Barr*

DATE 09/20/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-017

SHEET 52 OF 59 .

DIFFERENTIAL PRESSURE CALCULATION

09/19/86

MPL NUMBER

2E41-F111

VALVE DESCRIPTION

GATE VALVE 2 IN MO

VALVE FUNCTION

HPCI VAC BREAKER LINE ISOL VALVE

SAFETY ACTION (YES/NO)

YES

DP CALCULATION FORMULA

DP=PC+PATM

MAXIMUM DP UPSTREAM/DOWNSTREAM

CLOSE

SAFETY ON OPEN/CLOSE

CLOSE

MAXIMUM DP ON OPEN OR CLOSE

UPSTREAM

VALUES

PC = 31.6

PATM = 0

DP (PSID)

31.6

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>Dawn C. Wilson</i>	Date 09/19/86
Subject/Title Unit 2 HPCI Motor Operated Valve	Reviewed By <i>J.D. McArthur</i>	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-017	Sheet 53 of 59

GATE VALVE PVEL CALCULATIONS

PAGE 1 OF 3

A3: [W11] ^MPL
 B3: ^VALVE
 C3: ^CLOSING
 D3: ^UPSTR
 E3: ^DNSTR
 F3: 'UPSTRSYS
 G3: 'DNSTRSYS
 I3: ^dT UP
 J3: ^dTDN
 K3: ^TIMEu1
 L3: ^TIMEu2
 M3: ^TIMEd1
 N3: ^TIMEd2
 O3: ^RISEu1
 P3: ^RISEu2
 Q3: ^RISEd1
 R3: ^RISEd2
 S3: ^CHORDu1
 T3: ^CHORDu2
 U3: ^CHORDd1
 V3: ^CHORDd2
 W3: 'MAX AREA
 X3: ^Aflul
 Y3: ^Aflu2
 Z3: ^Afld1
 AA3: ^Afld2
 AB3: ^a/Au1
 AC3: ^a/Au2
 AD3: ^a/Ad1
 AE3: ^a/Ad2
 AF3: ^Vu1
 AG3: ^Vu2
 AH3: ^Vd1
 AI3: ^Vd2
 AJ3: ^dVu
 AK3: ^dVd
 AL3: ^Pvu
 AM3: ^Pvd
 AN3: ^Pvel
 A4: [W11] ^NUMBER
 B4: ^DIA, "
 C4: ^T, SECS
 D4: ^PIPE L'
 E4: ^PIPE L'
 F4: ^VEL FPS
 G4: ^VEL FPS
 W4: 'FLOW
 A5: [W11] \-

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>Devin C. Wilson</i>	Date 09/19/86
Subject/Title Unit 2 HPCI Motor Operated Valve	Reviewed By <i>A.D. McArthur</i>	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-017	Sheet 54 of 59

GATE VALVE PVEL CALCULATIONS

PAGE 2 OF 3

B5: \-
 C5: \-
 D5: \-
 E5: \-
 F5: \-
 G5: \-
 H5: [W2] \-
 I5: \-
 J5: \-
 K5: \-
 L5: \-
 M5: \-
 N5: \-
 O5: \-
 P5: \-
 Q5: \-
 R5: \-
 S5: \-
 T5: \-
 U5: \-
 V5: \-
 W5: \-
 X5: \-
 Y5: \-
 Z5: \-
 AA5: \-
 AB5: \-
 AC5: \-
 AD5: \-
 AE5: \-
 AF5: \-
 AG5: \-
 AH5: \-
 AI5: \-
 AJ5: \-
 AK5: \-
 AL5: \-
 AM5: \-
 AN5: \-
 A6: [W11] '1E51-F013
 B6: 3+5/16
 C6: 15
 D6: 99.9
 E6: 16.6
 F6: 11.62
 G6: 12.46
 H6: [W2] '|
 I6: (2*D6)/\$D\$29

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>Dawn C. Wilson</i>	Date 09/19/86
Subject/Title Unit 2 HPCI Motor Operated Valve	Reviewed By <i>A. D. McArthur</i>	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-017	Sheet 55 of 59

GATE VALVE PVEL CALCULATIONS

PAGE 3 OF 3

J6: $(2 * E6) / \$D\29
 K6: $(\$D\$30 * \$C6) - I6$
 L6: $+\$D\$30 * \$C6$
 M6: $(\$D\$30 * \$C6) - J6$
 N6: $+\$D\$30 * \$C6$
 O6: $(K6 / \$C6) * (\$B6 / 2)$
 P6: $(L6 / \$C6) * (\$B6 / 2)$
 Q6: $(M6 / \$C6) * (\$B6 / 2)$
 R6: $(N6 / \$C6) * (\$B6 / 2)$
 S6: $@SQRT(8 * O6 * ((\$B6 / 2) - (O6 / 2)))$
 T6: $@SQRT(8 * P6 * ((\$B6 / 2) - (P6 / 2)))$
 U6: $@SQRT(8 * Q6 * ((\$B6 / 2) - (Q6 / 2)))$
 V6: $@SQRT(8 * R6 * ((\$B6 / 2) - (R6 / 2)))$
 W6: $2 * ((1 / 12) * (((3 * B6 * B6) / 4) + (4 * B6 * B6)))$
 X6: $(F6) (W6) - (2 * ((O6 / (6 * S6)) * ((3 * O6 * O6) + (4 * S6 * S6))))$
 Y6: $(F6) (W6) - (2 * ((P6 / (6 * T6)) * ((3 * P6 * P6) + (4 * T6 * T6))))$
 Z6: $(F6) (\$W6) - (2 * ((Q6 / (6 * U6)) * ((3 * Q6 * Q6) + (4 * U6 * U6))))$
 AA6: $(F6) (\$W6) - (2 * ((R6 / (6 * V6)) * ((3 * R6 * R6) + (4 * V6 * V6))))$
 AB6: $(F6) + X6 / ((@PI * \$B6 * \$B6) / 4)$
 AC6: $(F6) + Y6 / ((@PI * \$B6 * \$B6) / 4)$
 AD6: $(F6) + Z6 / ((@PI * \$B6 * \$B6) / 4)$
 AE6: $(F6) + AA6 / ((@PI * \$B6 * \$B6) / 4)$
 AF6: $(F6) + AB6 * \$F6$
 AG6: $(F6) + AC6 * \$F6$
 AH6: $(F6) + AD6 * \$G6$
 AI6: $(F6) + AE6 * \$G6$
 AJ6: $(F6) + AF6 - AG6$
 AK6: $(F6) + AH6 - AI6$
 AL6: $(F6) (AJ6 * \$D\$28 * \$D\$29) / (144 * 32.2)$
 AM6: $(F6) (AK6 * \$D\$28 * \$D\$29) / (144 * 32.2)$
 AN6: $(F6) + AL6 + AM6$
 C28: 'DENSITY
 D28: 61.996
 E28: 'LB/FT3
 C29: 'C
 D29: 4000
 E29: 'FT/SEC
 C30: 'FUDGE FAC
 D30: 1
 E30: 'DIMLESS

Project	Prepared By	Date
E.I. Hatch Nuclear Plant Unit 2	<i>Dawn C. Wilson</i>	09/19/86
Subject/Title	Reviewed By	Date
Unit 2 HPCI Motor Operated Valve	<i>A.D. McArthur</i>	9/21/86
Differential Pressure Calculation	Calculation Number	Sheet
	SNH-86-017	56 of 59

FOUR INCH GLOBE VALVE PVEL CALCULATIONS

PAGE 1 OF 2

A3: [W11] ^MPL
 B3: ^VALVE
 C3: ^CLOSING
 D3: ^UPSTR
 E3: ^DNSTR
 F3: ^UPSTRSYS
 G3: ^DNSTRSYS
 I3: ^dT UP
 J3: ^dT DN
 K3: ^TIMEu1
 L3: ^TIMEu2
 M3: ^TIMEd1
 N3: ^TIMEd2
 O3: ^% OPEN
 P3: ^% OPEN
 Q3: ^% OPEN
 R3: ^% OPEN
 S3: ^% CV
 T3: ^% CV
 U3: ^% CV
 V3: ^% CV
 W3: ^dVu
 X3: ^dVd
 Y3: ^Pvu
 Z3: ^Pvd
 AA3: ^Pvel
 A4: [W11] ^NUMBER
 B4: ^DIA, "
 C4: ^T, SECS
 D4: ^PIPE L'
 E4: ^PIPE L'
 F4: ^VEL FPS
 G4: ^VEL FPS
 O4: ^UPSTR1
 P4: ^UPSTR2
 Q4: ^DNSTR1
 R4: ^DNSTR2
 S4: ^UPSTR1
 T4: ^UPSTR2
 U4: ^DNSTR1
 V4: ^DNSTR2
 A5: [W11] \-
 B5: \-
 C5: \-
 D5: \-
 E5: \-
 F5: \-
 G5: \-

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>Dawn C. Wilson</i>	Date 09/19/86
Subject/Title Unit 2 HPCI Motor Operated Valve	Reviewed By <i>R.D. McArthur</i>	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-017	Sheet 57 of 59

FOUR INCH GLOBE VALVE PVEL CALCULATIONS

PAGE 2 OF 2

H5: [W2] \-	C23: 'DENSITY
I5: \-	D23: 61.996
J5: \-	E23: 'LB/FT3
K5: \-	C24: 'C
L5: \-	D24: 4000
M5: \-	E24: 'FT/SEC
N5: \-	
O5: \-	
P5: \-	
Q5: \-	
R5: \-	
S5: \-	
T5: \-	
U5: \-	
V5: \-	
W5: \-	
X5: \-	
Y5: \-	
Z5: \-	
AA5: \-	
A6: [W11] '1E41-F012	
B6: 2.5	
C6: 10	
D6: 61.05	
E6: 38.958	
F6: 12.561	
G6: 11.347	
H6: [W2] '	
I6: (2*D6)/\$D\$24	
J6: (2*E6)/\$D\$24	
K6: +\$C6*0.5	
L6: +\$C6*0.5+I6	
M6: +\$C6*0.5	
N6: +\$C6*0.5+J6	
O6: (+K6*100)/\$C6	
P6: (+L6*100)/\$C6	
Q6: (+M6*100)/\$C6	
R6: (+N6*100)/\$C6	
S6: +O6*1.714	
T6: +P6*1.714	
U6: +Q6*1.714	
V6: +R6*1.714	
W6: (+F6*(T6-S6))/100	
X6: (+G6*(V6-U6))/100	
Y6: (W6*\$D\$23*\$D\$24)/(144*32.2)	
Z6: (X6*\$D\$23*\$D\$24)/(144*32.2)	
AA6: +Y6+Z6	

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By Dawn C. Wilson	Date 09/19/86
Subject/Title Unit 2 HPCI Motor Operated Valve	Reviewed By [Signature]	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-017	Sheet 58 of 59

TWO INCH GLOBE VALVE PVEL CALCULATIONS

PAGE 1 OF 2

A3: [W11] ^MPL
 B3: ^VALVE
 C3: ^CLOSING
 D3: ^UPSTR
 E3: ^DNSTR
 F3: ^UPSTRSYS
 G3: ^DNSTRSYS
 I3: ^dT UP
 J3: ^dTDN
 K3: ^TIMEu1
 L3: ^TIMEu2
 M3: ^TIMEd1
 N3: ^TIMEd2
 O3: ^% OPEN
 P3: ^% OPEN
 Q3: ^% OPEN
 R3: ^% OPEN
 S3: ^% CV
 T3: ^% CV
 U3: ^% CV
 V3: ^% CV
 W3: ^dVu
 X3: ^dVd
 Y3: ^Pvu
 Z3: ^Pvd
 AA3: ^Pvel
 A4: [W11] ^NUMBER
 B4: ^DIA, "
 C4: ^T, SECS
 D4: ^PIPE L'
 E4: ^PIPE L'
 F4: ^VEL FPS
 G4: ^VEL FPS
 O4: ^UPSTR1
 P4: ^UPSTR2
 Q4: ^DNSTR1
 R4: ^DNSTR2
 S4: ^UPSTR1
 T4: ^UPSTR2
 U4: ^DNSTR1
 V4: ^DNSTR2
 A5: [W11] \-
 B5: \-
 C5: \-
 D5: \-
 E5: \-
 F5: \-
 G5: \-

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>Lawrence C. Wilson</i>	Date 09/19/86
Subject/Title Unit 2 HPCI Motor Operated Valve	Reviewed By <i>A.D. McArthur</i>	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-017	Sheet 59 of 59

TWO INCH GLOBE VALVE PVEL CALCULATIONS

PAGE 2 OF 2

H5: [W2] \-

I5: \-

J5: \-

K5: \-

L5: \-

M5: \-

N5: \-

O5: \-

P5: \-

Q5: \-

R5: \-

S5: \-

T5: \-

U5: \-

V5: \-

W5: \-

X5: \-

Y5: \-

Z5: \-

AA5: \-

A6: [W11] '1E41-F059

B6: 1.75

C6: 10

D6: 25

E6: 31.42

F6: 7.601

G6: 7.601

H6: [W2] '|

I6: (2*D6)/\$D\$28

J6: (2*E6)/\$D\$28

K6: +\$C6*0.5

L6: +\$C6*0.5+I6

M6: +\$C6*0.5

N6: +\$C6*0.5+J6

O6: (+K6*100)/\$C6

P6: (+L6*100)/\$C6

Q6: (+M6*100)/\$C6

R6: (+N6*100)/\$C6

S6: +O6*0.8

T6: +P6*0.8

U6: +Q6*0.8

V6: +R6*0.8

W6: (+F6*(T6-S6))/100

X6: (+G6*(V6-U6))/100

Y6: (W6*\$D\$27*\$D\$28)/(144*32.2)

Z6: (X6*\$D\$27*\$D\$28)/(144*32.2)

AA6: +Y6+Z6

C27: 'DENSITY

D27: 61.996


E27: 'LB/FT3


C28: 'C

D28: 4000

E28: 'FT/SEC

ENCLOSURE 4





TI APERTURE CARD

Also Available On
Aperture Card

RCIC SYSTEM UNIT NO. 2
MPL NO. ESI 1010

* THESE VALVES HAVE NO SAFETY ACTION ON OPEN/CLOSE
AND THEREFORE DO NOT REQUIRE TESTING.

SOUTHERN COMPANY SERVICES INC.			
Georgia Power Company, Atlanta, Ga.			
General Engineering Department			
EDWIN HATCH NUCLEAR PLANT UNIT NO. 2			
RCIC SYSTEM FLOW DIAGRAM			
MOV DIFFERENTIAL PRESSURE STUDY			
APERTURE	DATE	BY	CHKD
		M. B.	G. B.
		NONE	9/19/82
		REVISIONS	
		LOCATION	
		SHEET NO.	

8610090442-04

Project E.I. HATCH NUCLEAR PLANT UNIT 2		Calculation Number SNH-86-018
Objective Calculate DP for RCIC Motor Operated Valves		Discipline Mechanical
Subject/Title Unit 2 RCIC Motor Operated Valve Differential Pressure Calculation		SDS Number

Design Engineer's Signature <i>Chris Lorenson</i>	Date 9.19.86	Last Page Number 52
--	-----------------	------------------------

Contents

Topics	Page	Topics	Page
INTRODUCTION	1	DEFINITION OF TERMS	7
Summary of Conclusions	3	DERIVATION OF VALUES	9
Criteria and Assumptions	2		
Listed References	5		
Body of Calculations	9		
Computer Printout)	48		

Record of Revisions

Rev. No.	Description	Originator Date	Reviewer Date	Proj. Engr. Date
0	APPROVED	<i>CL</i> 9.19.86	<i>WMM</i> 9/21/86	<i>AKM</i> 9/21/86

Notes


Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>Lawrence Wilson</i>	Date 09/19/86
Subject/Title Unit 2 RCIC Motor Operated Valve	Reviewed By <i>W.T. Barr</i>	Date 9/20/86
Differential Pressure Calculation	Calculation Number SNH-86-018	Sheet 1 of 52



INTRODUCTION

The Nuclear Regulatory Commission (NRC) IE Bulletin 85-03 (Motor Operated Valve Common Mode Failure) requested that owners of light water reactors develop and implement a program to ensure that torque switch settings on safety related motor-operated valves on high pressure systems are selected, set and maintained correctly to accommodate the maximum differential pressures expected on these valves during both normal and abnormal events within the design basis. The objective of this calculation is to determine the maximum Differential Pressure across each of the affected Unit 2 RCIC Motor Operated Valves.

00451

Design Calculations

Southern Company Services 

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By 	Date 9.19.86
Subject/Title Unit 2 RCIC Motor Operated Valve	Reviewed By 	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-018	Sheet 2 of 52

CRITERIA

- 1) The criteria, assumptions and formulas given in the General Electric "BWR Owner's Group Report on the Operational Design Basis of Selected Safety-Related Motor-Operated Valves," DRF-E12-00100-75, are assumed to be correct.

ASSUMPTIONS

- 1) PC is assumed to equal PLOC. The terms are defined as follows:
 - * PLOC is the maximum wet well LOCA pressure.
 - * PC is the maximum wetwell LOCA pressure which the valve is required to operate against.
- 2) In the PVEL calculation, it is assumed that the time required for a sound wave to travel to and return from an atmospheric vessel is infinity. Thus, the related term in the PVEL equation is equal to zero.
- 3) In the PVEL calculation, downstream velocities for lines of equal sizes with differing wall thicknesses are assumed to be equal. The impact upon the downstream pressure increase is small.
- 4) Disc and Port diameters are assumed to be equal. Equal diameters for disc and port yield higher rate of change therefore higher DV and is therefore more conservative.
- 5) The Formula for calculating area of the gate valve available for flow is approximated from a known geometric relationship and is off by a small percentage, however, the overall effect is negligible.
- 6) In the PVEL calculation, it is assumed that where a small line tees into a much larger line (i.e. Larger being two times or greater in diameter) the boundary for the small line ends at the line intersection.

00431

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>C. Schuman</i>	Date 9.19.86
Subject/Title Unit 2 RCIC Motor Operated Valve	Reviewed By <i>W. T. Barr</i>	Date 9/20/86
Differential Pressure Calculation	Calculation Number SNH-86-018	Sheet 3 of 52

SUMMARY OF CONCLUSIONS

The following page is a summary table of the results for each RCIC Motor Operated Valve in the Scope of NRC IEB 85-03.

The first column titled "MPL Number" gives the MPL number of the valve.

The second column titled "Valve Description" is the description of the valve given in the equipment location index (ELI).

The third column titled "Valve Function" is the function of the valve as stated in the General Electric "BWR Owners' Group Report on the Operational Design Basis of Selected Safety-Related Motor-Operated Valves."

The fourth column titled "Safety" indicates if the valve has any safety-related action.

The fifth column titled "DP Calculation Formula" gives the formula used to calculate the maximum differential pressure.

The sixth column titled "Maximum DP" indicates whether the maximum DP occurs upstream or downstream of the valve.

The seventh column titled "Max DP ON" indicates whether the maximum DP is calculated for opening or closing.

The eighth column titled "DP (PSID)" gives the calculated maximum DP in psid.

The ninth column titled "Safety On" gives the safety action of the valve.

DESIGN CALCULATIONS

E.I. HATCH NUCLEAR PLANT UNIT 2

UNIT 2 RCIC MOTOR OPERATED VALVE

DIFFERENTIAL PRESSURE CALCULATION

SOUTHERN COMPANY SERVICES

DATE 09/21/86

DATE 09/21/86

SHEET 4 OF 52

PREPARED BY: *C. Colson*
 REVIEWED BY: *J.B. Hudson*
 CALCULATION NUMBER SNH-86-018

SUMMARY TABLE 09/21/86

MPL NUMBER	VALVE DESCRIPTION	VALVE FUNCTION	SAFETY	DP CALCULATION FORMULA	MAXIMUM DP CLOSE	MAXIMUM DP UPSTREAM	DP (PSID) 1090	SAFETY YES
2E51-F007	RCIC STEAM INBOARD ISOL VALVE	RCIC STEAM LINE ISOLATION VALVE	CLOSE	DP=PRSS	CLOSE	UPSTREAM	1090	YES
2E51-F008	RCIC STEAM OUTBOARD ISOL VLV	RCIC STEAM LINE ISOLATION VALVE	CLOSE	DP=PRSS	CLOSE	UPSTREAM	1090	YES
2E51-F010	PUMP SUCT FRM COND ST6 TNK	RCIC CST SUCTION ISOLATION VALVE	CLOSE	DP=PELD+PV+PVEL1	CLOSE	UPSTREAM	29.6217	YES
2E51-F012	RCIC PUMP OUTBOARD DISCH VLV	RCIC INJECTION VALVE TEST VALVE	NONE	NO SAFETY ACTION	N/A	N/A	N/A	NO
2E51-F013	RCIC PUMP INBOARD DISCH VLV	RCIC INJECTION VALVE	OPEN/CLOSE	DP=PRSS+PEL	OPEN/CLOSE	DOWNSTREAM	1125.612	YES
2E51-F019	TEST BYPASS TO COND ST6 TANK	RCIC MINIMUM FLOW BYPASS ISOL VALVE	OPEN/CLOSE	DP=PSDH+PELM	OPEN	UPSTREAM	1330.173	YES
2E51-F019	TEST BYPASS TO COND ST6 TANK	RCIC MINIMUM FLOW BYPASS ISOL VALVE	OPEN/CLOSE	DP=PMF+PELM+PVEL3	CLOSE	UPSTREAM	1333.883641	YES
2E51-F022	TEST BYPASS TO COND ST6 TANK	RCIC CST TEST RETURN VALVE	NONE	NO SAFETY ACTION	N/A	N/A	N/A	NO
2E51-F029	RCIC PHP SUCT VLV FRM SUP POOL	RCIC SUPP POOL SUCTION ISOL VALVE	OPEN/CLOSE	DP=PRV-PELS	OPEN	DOWNSTREAM	95.6	YES
2E51-F029	RCIC PHP SUCT VLV FRM SUP POOL	RCIC SUPP POOL SUCTION ISOL VALVE	OPEN/CLOSE	DP=PLOC+PLOW1	CLOSE	UPSTREAM	37.317	YES
2E51-F031	RCIC PHP SUCT VLV FRM SUP POOL	RCIC SUPP POOL SUCTION ISOL VALVE	OPEN/CLOSE	DP=PRV-PELS	OPEN	DOWNSTREAM	95.6	YES
2E51-F031	RCIC PHP SUCT VLV FRM SUP POOL	RCIC SUPP POOL SUCTION ISOL VALVE	OPEN/CLOSE	DP=PLOC+PLOW1	CLOSE	UPSTREAM	37.317	YES
2E51-F045	TURBINE STEAM SUPPLY VALVE	RCIC STEAM ADMISSION VALVE	OPEN/CLOSE	DP=PRSS	OPEN/CLOSE	UPSTREAM	1090	YES
2E51-F046	COOLING WATER SUPPLY VALVE	RCIC TURBINE ACCESSORY COOL WTR VALVE	OPEN/CLOSE	DP=PSOI+PELC	OPEN	UPSTREAM	291.974	YES
2E51-F046	COOLING WATER SUPPLY VALVE	RCIC TURBINE ACCESSORY COOL WTR VALVE	OPEN/CLOSE	DP=PLOC+PLOW2+PVEL4	CLOSE	UPSTREAM	37.381729	YES
2E51-F104	GATE VALVE 1.5 IN MD	RCIC VACUUM BREAKER LINE ISOL VALVE	CLOSE	DP=PC+PATM	CLOSE	UPSTREAM	31.6	YES
2E51-F105	GATE VALVE 2 IN MD	RCIC VACUUM BREAKER LINE ISOL VALVE	CLOSE	DP=PC+PATM	CLOSE	UPSTREAM	31.6	YES
2E51-F119	LSTB VALVE	RCIC STEAM ADMISSION BYPASS VALVE	CLOSE	DP=PRSS	CLOSE	UPSTREAM	1090	YES

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>C. Sorenson</i>	Date 9.19.86
Subject/Title Unit 2 RCIC Motor Operated Valve	Reviewed By <i>W. T. Barr</i>	Date 9/20/86
Differential Pressure Calculation	Calculation Number SNH-86-018	Sheet 5 of 52

UNIT 2
RCIC MOV CALCULATIONS
REFERENCES

1. H-26281 REV. 5 RCIC SYSTEM BAROMETRIC CONDENSER PIPING PLANS & SECTIONS
2. H-26298 REV. 4 FEEDWATER PIPING - DRYWELL ELEVATION 130'-0" AND ABOVE
3. H-26844 REV. H RCIC SYSTEM SUCTION FROM TORUS, RHR HEAT EXCHANGE AND CONDENSATE STORAGE TANK.
4. H-27535 REV. A GENERAL PLAN - CONTAINMENT
5. UNIT NO. 2 TECHNICAL SPECIFICATIONS REV. 05-25-86
6. A-26497 REV. 12 INSTRUMENT SETPOINT INDEX
7. G.E. NEDO - 24569 REV. 2
8. H-26023 REV. 15 RCIC SYSTEM P & ID SHEET 1
9. H-26024 REV. 13 RCIC SYSTEM P & ID SHEET 2
10. SECTION F CRC HANDBOOK OF CHEMISTRY & PHYSICS
57TH EDITION - CONVERSION FACTORS
11. SECTION B CRANE " FLOW OF FLUIDS " TECHNICAL PAPER
NO. 410 - PIPE DATA
12. BWR OWNERS GROUP REPORT ON THE OPERATIONAL DESIGN BASIS OF
SELECTED SAFETY RELATED MOTOR OPERATED VALVES,
DRF-E12-00100-75, AUGUST 1986.
13. TELEPHONE CONFIRMATION 09-05-86 BETWEEN CHRIS SORENSON OF SCS
AND GORDON PARKS OF BINGHAM PUMP.
14. S-2⁵₁₇₁ REV. A RCIC FLOW DIAGRAM
15. A-26503 DATA SHEET
16. TELEPHONE CONFIRMATION D. SCHERER OF POWELL VALVE AND B.
HARKINS OF SCS ON 9-11-86

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>C. Sorenson</i>	Date 9.19.86
Subject/Title Unit 2 RCIC Motor Operated Valve	Reviewed By <i>W.T. Barr</i>	Date 9/24/86
Differential Pressure Calculation	Calculation Number SNH-86-018	Sheet 6 of 52

UNIT 2
RCIC MOV CALCULATIONS
REFERENCES CONT'D

17. S-27083 REV. J KELLOGG ISOMETRIC
18. S-27085 REV. J KELLOGG ISOMETRIC
19. S-27087 REV. J KELLOGG ISOMETRIC
20. S-36100 REV. A KELLOGG ISOMETRIC
21. S-36095 REV. A KELLOGG ISOMETRIC
22. S-36096 REV. A KELLOGG ISOMETRIC
23. S-36097 REV. A KELLOGG ISOMETRIC
24. S-36098 REV. A KELLOGG ISOMETRIC
25. TELECOPY FROM D ~~BRASOWYCH~~ ^{HORASOWYCH} OF YARWAY TO JACK ROBYN OF SCS ON 9-11-86
26. HNP-2-FSAR TABLE 6.2-5 SHT 21 NOTE 7
27. S-28657 REV. 2 6" 150LB OSY GATE VALVE POWELL 1523 WE
28. S-⁸⁵~~286~~82 REV. H YARWAY FIG. 5515B WELBOND VALVE
29. BM-26509 REV. 5 BILL OF MATERIALS
30. BM-26502 REV. 4 BILL OF MATERIALS
31. S-27294 REV. F VALVE COMPOSITE DRAWING
32. S-36136 REV. A KELLOGG ISOMETRIC DRAWING

0073d

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2	Prepared By: <i>Rawn Chilton</i>	DATE 09/19/86
UNIT 2 RCIC MOTOR OPER VALVE	Reviewed By: <i>W.T. Ban</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-018	SHEET 7 OF 52 .

UNIT 2 RCIC TERM DEFINITIONS 09/19/86

<u>TERM</u>	<u>DEFINITION OF TERM</u>
DP	VALVE MAXIMUM EXPECTED OPERATING DIFFERENTIAL PRESSURE
PSOH	DIFFERENTIAL PRESSURE DEVELOPED BY SYSTEM MAIN PUMPS AT ZERO FLOW RATE. (MAXIMUM NORMAL TURBINE SPEED)
PEL	MINIMUM HYDROSTATIC PRESSURE DIFFERENCE BETWEEN SUCTION AND DISCHARGE DUE TO ELEVATION. (DISCHARGE ELEVATION IS HIGHER THAN SUCTION)
PISO	LOW REACTOR PRESSURE AT WHICH STEAM SUPPLY LINES AUTOMATICALLY ISOLATE
PELM	MAXIMUM HYDROSTATIC PRESSURE DIFFERENCE BETWEEN SUCTION AND DISCHARGE SOURCE DUE TO ELEVATION
PRSS	REACTOR PRESSURE CORRESPONDING TO THE SPRING SETPOINT OF THE REACTOR SAFETY RELIEF VALVE WITH THE LOWEST NOMINAL SPRING SETPOINT
PELD	HYDROSTATIC PRESSURE DIFFERENCE BETWEEN CST AND SUPPRESSION POOL ASSUMING THE CST TO BE FULL AND THE SUPPRESSION POOL WATER LEVEL AT ITS MAXIMUM ALLOWABLE NORMAL LEVEL
PMF	DIFFERENTIAL PRESSURE DEVELOPED BY THE SYSTEM MAIN PUMPS AT A FLOW RATE EQUAL TO THE REQUIRED MINIMUM BYPASS FLOW RATE. (MAXIMUM NORMAL TURBINE SPEED)
PV	VELOCITY HEAD IN THE SUPPRESSION POOL SUCTION LINE

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *Dawn C. Wilson* DATE 09/19/86UNIT 2 RCIC MOTOR OPER VALVE Reviewed By: *W.T. Ban* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-018 SHEET 8 OF 52 .

UNIT 2 RCIC TERM DEFINITIONS 09/19/86

<u>TERM</u>	<u>DEFINITION OF TERM</u>
	AT THE LOCATION WHERE THE CST LINE CONNECTS TO IT
PRV	SYSTEM SUCTION RELIEF VALVE ACTUATION SET PRESSURE
PELS	HYDROSTATIC PRESSURE DIFFERENCE BETWEEN THE MINIMUM SUPPRESSION POOL WATER LEVEL AND THE LOCATION OF THE RELIEF VALVE ON THE PUMP SUCTION LINE
PLOC	LOCA WETWELL PRESSURE WHEN THE SYSTEM IS ISOLATED
PLOM	HYDROSTATIC PRESSURE UPSTREAM OF THE VALVE DUE TO MAXIMUM LOCA SUPPRESSION POOL WATER LEVEL
PC	MAXIMUM LOCA WETWELL PRESSURE WHEN SYSTEM IS REQUIRED TO OPERATE
PELC	HYDROSTATIC PRESSURE DIFFERENCE BETWEEN CST AND LOCATION OF VALVE WHEN THE CST IS FULL
PSOI	RCIC PUMP DISCHARGE PRESSURE AT ZERO FLOW AND A TURBINE SPEED OF 2000 RPM
PATM	ATMOSPHERIC PRESSURE
PVEL	DIFFERENTIAL PRESSURE ASSOCIATED WITH VALVE CLOSURE DUE TO FLUID VELOCITY CHANGES (I.E., WATER HAMMER TYPE PRESSURE INCREASE) INSIDE THE PIPE

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *C. Sorensen* DATE 09/19/86
 UNIT 2 RCIC MOTOR OPER VALVE Reviewed By: *W. T. Ban* DATE 09/20/86
 DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-018 SHEET 9 OF 52 .

UNIT 2 RCIC TERM DERIVATIONS 09/19/86

TERM	PRESSURE (PSIG)	DERIVATION OF TERM
------	-----------------	--------------------

PSOH	1300.54	TELEPHONE CONFIRMATION -C.SORENSEN/G.PARKS ON SEPTEMBER 5, 1986
------	---------	--

PEL	35.612	<p>THE ELEVATION FOR THE INJECTION POINT OF DISCHARGE IS GIVEN AS 183' 9 1/2" ON DRAWING H-26298 REV.4.</p> <p>THE CENTERLINE OF THE SUPPRESSION POOL IS GIVEN AS 103' 6 1/4" AND THE INSIDE DIAMETER IS GIVEN AS 28' 1" ON DRAWING S-27535 REV. A.</p> <p>THE INSIDE BOTTOM ELEVATION OF THE SUPPRESSION POOL IS THE CENTERLINE MINUS 1/2 THE DIAMETER: $103' 6 \frac{1}{4}" - (28' 1") / 2 = 89' 5 \frac{3}{4}"$</p> <p>THE MINIMUM SUPPRESSION POOL LEVEL IS GIVEN AS 12' 2" IN THE TECHNICAL SPECIFICATIONS SECTION 3.6.2.1</p> <p>THE MINIMUM SUPPRESSION POOL ELEVATION IS THE BOTTOM ELEVATION PLUS THE MINIMUM LEVEL: $89' 5 \frac{3}{4}" + 12' 2" = 101' 7 \frac{3}{4}"$</p> <p>THE HYDROSTATIC DIFFERENCE IS THUS: $183' 9 \frac{1}{2}" - 101' 7 \frac{3}{4}" = 82' 1 \frac{3}{4}"$ $= 985.75" \text{ H}_2\text{O}$</p> <p>AND HYDROSTATIC PRESSURE IS: $985.75" \text{ H}_2\text{O} / 27.6807" \text{ H}_2\text{O/PSIG} = 35.612$</p>
-----	--------	--

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *C. Loren* DATE 09/19/86UNIT 2 RCIC MOTOR OPER VALVE Reviewed By: *W.T. Bam* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-018 SHEET 10 OF 52 .

UNIT 2 RCIC TERM DERIVATIONS 09/19/86TERM PRESSURE (PSIG) DERIVATION OF TERM

PISO 855 A-26497 UNIT 2 REV.12 INSTRUMENT SETPOINT
INDEX INSTRUMENTS 2B21-N015 A-D

PELM 29.633 THE MAXIMUM CST LEVEL IS GIVEN AS 170' 0"
FOR THE SETPOINT OF 2P21 N002 ON DRAWING
A-26497 REV. 12.
THE MINIMUM SUPPRESSION POOL LEVEL WAS
CALCULATED AS 101' 7 3/4" IN THE CALCULATION
FOR PEL ABOVE.
THUS THE HYDROSTATIC DIFFERENCE IS:
 $170' 0" - 101' 7 \frac{3}{4}" = 68' 4 \frac{1}{4}"$
 $= 820.25 \text{ "H}_2\text{O}$
HYDROSTATIC PRESSURE IS:
 $820.25 \text{ "H}_2\text{O} / 27.6807 \text{ "H}_2\text{O/PSIG} = 29.633$

PRSS 1090 UNIT 2 TECHNICAL SPECIFICATIONS
SECTION 3.4.2.1

PELD 29.488 THE MAXIMUM CST LEVEL IS GIVEN AS 170' 0"
FOR THE SETPOINT OF 2P21-N002 ON DRAWING
A-26497 REV. 12.
THE INSIDE BOTTOM ELEVATION OF THE
SUPPRESSION POOL WAS CALCULATED AS

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *J. Soren* DATE 09/19/86UNIT 2 RCIC MOTOR OPER VALVE Reviewed By: *W.T. Barr* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-018 SHEET 4 OF 52 .

UNIT 2 RCIC TERM DERIVATIONS 09/20/86

TERM	PRESSURE (PSIG)	DERIVATION OF TERM
------	-----------------	--------------------

PELD

89' 5 3/4" IN THE CALCULATION FOR PEL.

THE MAXIMUM SUPPRESSION POOL LEVEL IS GIVEN

AS 12' 6" IN THE UNIT 2 TECHNICAL

SPECIFICATIONS SECTION 3.6.2.1

THE MAXIMUM ELEVATION LEVEL OF THE

SUPPRESSION POOL IS:

 $89' 5 \frac{3}{4}" + 12' 6" = 101' 11 \frac{3}{4}"$

THUS THE HYDROSTATIC DIFFERENCE IS:

 $170' 0" - 101' 11 \frac{3}{4}" = 68' 1 \frac{1}{4}"$ $= 816.25" \text{H}_2\text{O}$

HYDROSTATIC PRESSURE EQUALS

 $816.25" \text{H}_2\text{O} / 27.6807" \text{H}_2\text{O}/\text{PSIG} = 29.488$

PMF

1300.54

TELEPHONE CONFIRMATION - C.SORENSEN/G.PARKS

ON SEPTEMBER 5, 1986.

PV

0.1337

THE RCIC SYSTEM RATED FLOW IS GIVEN AS 400 GPM

IN DRAWING S-25171 REV. A. THE SIZE OF THE

SIZE OF THE SUCTION LINE IS GIVEN AS 6" HLB ON

DRAWING H-26023 REV. 15, WHICH IS SCHEDULE 40

PIPE IN THE UNIT 2 PIPE SPECS. THE INTERNAL

DIAMETER IS GIVEN IN CRANE AS 6.065".

 $6.065" \times 12 \text{ IN}/\text{FT} = 0.5054 \text{ FEET}$

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *C. Foreman* DATE 09/19/86
 UNIT 2 RCIC MOTOR OPER VALVE Reviewed By: *W.T. Ban* DATE 09/20/86
 DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-018 SHEET 12 OF 52 .

UNIT 2 RCIC TERM DERIVATIONS 09/19/86

TERM	PRESSURE (PSIG)	DERIVATION OF TERM
------	-----------------	--------------------

PV

THE VELOCITY HEAD IS EQUAL TO:

- . $[(V)^{**2}] / 2 \times gc$, FROM CRANE 410 eqn 2-1
- . WHERE gc IS THE GRAVITATIONAL CONSTANT
- . $gc = 32.2 \text{ FT/SEC}^{**2}$
- . AND $V = Q/A$; FROM CRANE 410 eqn 3-2

PI=3.1416

 $V = [400 \times 60 \times 8.3378] / [PI \times (0.5054^{**2})/4]$

. = 4.46 FT/SEC

VELOCITY HEAD IS:

- . $[4.46^{**2}] / 2 \times 32.2 = 0.3089 \text{ FT H}_2\text{O}$

VELOCITY HEAD PRESSURE IS

- . $0.3089 \text{ FT H}_2\text{O} \times 0.432781 \text{ PSIG/FT H}_2\text{O}$
- . = 0.1337 PSIG

PRV 100

DWG S-27294 REV. F. VALVE COMPOSITE DRAWING
 FOR 2E51-F017 GIVES THE RELIEF
 SETTING OF 100 PSIG

PELS 4.4

THE MINIMUM SUPPRESSION POOL ELEVATION WAS
 DETERMINED TO BE 101' 7 3/4" IN THE
 CALCULATION FOR PEL.

THE ELEVATION FOR THE SUCTION RELIEF VALVE
 2E51-F017 IS GIVEN AS 91' 6" ON DRAWING

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: G. J. Jernigan DATE 09/19/86UNIT 2 RCIC MOTOR OPER VALVE Reviewed By: W. T. Bar DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-018 SHEET 13 OF 52 .

UNIT 2 RCIC TERM DERIVATIONS 09/19/86

<u>TERM</u>	<u>PRESSURE (PSIG)</u>	<u>DERIVATION OF TERM</u>
-------------	------------------------	---------------------------

PELS

S-36136 REV. 6.

THUS THE HYDROSTATIC DIFFERENCE IS:

$$101' 7 \frac{3}{4}" - 91' 6" = 10' 1 \frac{3}{4}"$$

$$= 121.75 \text{ "H}_2\text{O}$$

HYDROSTATIC PRESSURE IS:

$$121.75 \text{ "H}_2\text{O} / 27.6807 \text{ "H}_2\text{O/PSIG} = 4.40$$

PLOC

31.6

NEDO-27569-2 FIG. H2 4.1.2.-1 PG 9.

PLOM1

5.717

THE ACCIDENT SUPPRESSION POOL LEVEL IS GIVEN

AS 102' 7 1/2" ON DRAWING S-27535 REV. 1

THE ELEVATION FOR THE SUPPRESSION POOL

ISOLATION VALVES 2E51-F029 AND F031 ARE GIVEN

AS 89' 5 1/4" ON DRAWING H-26844 REV. H.

THUS THE HYDROSTATIC DIFFERENCE IS:

$$102' 7 \frac{1}{2}" - 89' 5 \frac{1}{4}" = 13' 2 \frac{1}{4}"$$

$$= 158.25 \text{ "H}_2\text{O}$$

THE HYDROSTATIC PRESSURE IS:

$$158.25 \text{ "H}_2\text{O} / 27.6807 \text{ "H}_2\text{O/PSIG} = 5.717$$

PLOM2

5.69

THE ACCIDENT SUPPRESSION POOL LEVEL IS GIVEN

AS 102' 7 1/2" ON DRAWING S-27535 REV. 1

THE ELEVATION FOR THE TURBINE ACCESSORIES

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2	Prepared By: <i>C. Sorensen</i>	DATE 09/19/86
UNIT 2 RCIC MOTOR OPER VALVE	Reviewed By: <i>W.T. Barr</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-018	SHEET 14 OF 52
UNIT 2 RCIC TERM DERIVATIONS		09/20/86

TERM	PRESSURE (PSIG)	DERIVATION OF TERM
PLOM2		<p>VALVE 2E51-F046 IS GIVEN AS 89' 6"</p> <p>DRAWING S-36097 REV. A.</p> <p>THUS THE HYDROSTATIC DIFFERENCE IS:</p> $102' 7 \frac{1}{2}" - 89' 6" = 157.5$ $= 157.5 \text{ "H}_2\text{O}$ <p>THE HYDROSTATIC PRESSURE IS:</p> $157.5 \text{ "H}_2\text{O} / 27.6807 \text{ "H}_2\text{O/PSIG} = 5.690$
PC	31.6	NEDO-27569-2 FIG.H2 4.1.2-1 PG 9.
PELC	34.9	<p>THE MAXIMUM CST LEVEL IS GIVEN AS 170' 0"</p> <p>PER SETPOINT FOR 2P21-N002 ON DRAWING A-26497 REV. 12.</p> <p>THE ELEVATION FOR THE RCIC TURBINE ACCESSORIES COOLING WATER VALVE 2E51-F046 IS GIVEN AS 89' 6" ON DRAWING S-36097 REV. A.</p> <p>THUS THE HYDROSTATIC DIFFERENCE IS:</p> $170' 0" - 89' 6" = 80' 6"$ $= 966 \text{ "H}_2\text{O}$ <p>THE HYDROSTATIC PRESSURE IS:</p> $966 \text{ "H}_2\text{O} / 27.6807 \text{ "H}_2\text{O/PSIG} = 34.90$
PSOI	257.074	TELEPHONE CONFIRMATION C.SORENSEN/G.PARKS

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *C. Sorensen* DATE 09/19/86
UNIT 2 RCIC MOTOR OPER VALVE Reviewed By: *JB. Harkins* DATE 09/21/86
DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-018 SHEET 15 OF 52 .

UNIT 2 RCIC TERM DERIVATIONS 09/19/86

<u>TERM</u>	<u>PRESSURE (PSIG)</u>	<u>DERIVATION OF TERM</u>
-------------	------------------------	---------------------------

PSOI		ON SEPTEMBER 5, 1986.
------	--	-----------------------

PATM	0	NORMAL ATMOSPHERIC PRESSURE = 14.696 PSIA. PSIG = PSIA - 14.696 = 0
------	---	--

PVEL1	0	<p>P & I DIAGRAMS H-26023 REV.15 AND H-26024 REV. 13 SHOW THAT THE UPSTREAM PIPING IS CONNECTED TO THE CONDENSATE STORAGE TANK.</p> <p>IT IS ASSUMED THAT ANY WATER HAMMER EFFECTS IN THE UPSTREAM PIPING WOULD BE DISSIPATED WITHIN THE CST VOLUME, AND PRODUCE NO RESULTANT PRESSURE RISE UPON THE VALVE.</p> <p>THE REFERENCED DRAWINGS ALSO SHOW THAT THE DOWNSTREAM PIPING IS INTERCONNECTED WITH THE SUPPRESSION POOL SUCTION LINE. IT IS ASSUMED THAT THE RCIC PUMP IS OPERATING TO DRAW A SUCTION FROM THE SUPPRESSION POOL WHEN 2E51-F010 BEGINS TO CLOSE. THEREFORE, NO DOWNSTREAM FLUID DECELERATION WILL RESULT. IT MAY BE CONCLUDED THAT NO INCREASE IN PRESSURE BECAUSE OF WATER HAMMER WILL RESULT. CONSIDERING THE ABOVE FACTS, VALVE 2E51-F010 CAN BE CONSIDERED TO HAVE NO WATER HAMMER PRESSURE</p>
-------	---	--

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2	Prepared By: <i>C. Lorey</i>	DATE 09/21/86
UNIT 2 RCIC MOTOR OPER VALVE	Reviewed By: <i>J.B. Hopkins</i>	DATE 09/21/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-018	SHEET 16 OF 52
UNIT 2 RCIC TERM DERIVATIONS		09/21/86

<u>TERM</u>	<u>PRESSURE (PSIG)</u>	<u>DERIVATION OF TERM</u>
PVEL1		INCREASE. THEREFORE PVEL1 = 0
PVEL2	3.029	<p>SYSTEM VELOCITY GATE FOR 2E51-F013</p> <p>FLOW RATE = 400 GPM FROM</p> <p>RCIC FLOW DIAGRAM S-25171 REV. A</p> <p>AREA OF 4" SCH 80 PIPE = 11.5 SQ IN</p> <p>FROM CRANE 410</p> <p>VELOCITY = [400 GPM X 0.3211] / 11.5 SQ IN</p> <p>11.1687 FT/SEC</p> <p>CLOSURE TIME</p> <p>TC = 15 SEC</p> <p>FROM DATA SHEET A-26503</p> <p>VALVE THROAT DIAMETER</p> <p>VALVE DIAMETER = 3 7/16"</p> <p>TELEPHONE CON. D SCHERER OF POWELL AND</p> <p>B. HARRIN OF SCS ON 9/11/86</p> <p>LENGTH UPSTREAM (LU) AND DOWNSTREAM (LD)</p> <p>LU = 99.995 FT</p> <p>KELLOGG ISOMETRIC S-27083 REV. J</p> <p>KELLOGG ISOMETRIC S-27085 REV. J</p> <p>LD = 19.75 FT</p> <p>KELLOGG ISOMETRIC S-27085 REV. J</p> <p>KELLOGG ISOMETRIC SX-23286 REV. B</p>

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *C. Loren* DATE 09/21/86UNIT 2 RCIC MOTOR OPER VALVE Reviewed By: *J.B. Hatcher* DATE 09/21/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-018 SHEET 17 OF 52 .

UNIT 2 RCIC TERM DERIVATIONS 09/21/86

TERM	PRESSURE (PSIG)	DERIVATION OF TERM
------	-----------------	--------------------

PVEL2		PVEL2 = 3.029 FROM COMPUTER PRINTOUT
-------	--	--------------------------------------

PVEL3	3.710641	<p>SYSTEM VELOCITY FOR 2E51-F019</p> <p>FLOW RATE = 50 GPM FROM</p> <p>RCIC FLOW DIAGRAM S-25171 REV. A</p> <p>AREA OF 2" SCH 80 PIPE = 2.953 SQ IN</p> <p>CRANE 410</p> <p>VELOCITY = $[50 \text{ GPM} \times 0.3211] / 2.953 \text{ SQ IN}$</p> <p>= 5.4368 FT/SEC</p> <p>CLOSURE TIME</p> <p>TC = 4 SEC</p> <p>DATA SHEET A-26503</p> <p>VALVE THROAT DIAMETER</p> <p>VALVE DIAMETER = 1.403</p> <p>TELECOPY D. HARASONYSH OF YARWAY TO</p> <p>J. ROBYN OF SCS ON 9/11/86.</p> <p>LENGTH UPSTREAM (LU) AND DOWNSTREAM (LD)</p> <p>LU = 8.6146 FT</p> <p>KELLOGG ISOMETRICS S-36100A, S-27083J</p> <p>LD = 119 FT</p> <p>KELLOGG ISOMETRICS S-36102 A, S-36095 A,</p> <p>AND S-36096 REV. 0.</p> <p>PVEL3 = 3.710641 FROM COMPUTER PRINTOUT</p>
-------	----------	--

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *C. Brown* DATE 09/21/86UNIT 2 RCIC MOTOR OPER VALVE Reviewed By: *J.B. Harbluk* DATE 09/21/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-018 SHEET 18 OF 52

UNIT 2 RCIC TERM DERIVATIONS 09/21/86

<u>TERM</u>	<u>PRESSURE (PSIG)</u>	<u>DERIVATION OF TERM</u>
-------------	------------------------	---------------------------

PVEL4	0.091729	
-------	----------	--

SYSTEM VELOCITY FOR 2E51-F046

FLOW RATE = 16 GPM FROM

. RCIC FLOW DIAGRAM S-25171 REV. A

AREA OF 2" SCH 80 PIPE = 2.953 SQ IN

. CRANE 410

VELOCITY = $[16 \text{ GPM} \times 0.3211] / 2.953 \text{ SQ IN}$

. = 1.7398 FT/SEC

CLOSURE TIME

. TC = 10 SEC FROM DATA SHEET A-26503

. HNP2 FSAR TABLE 6.2-5 SHT 21 NOTE 7.

VALVE THROAT DIAMETER

. VALVE DIAMETER = 1.403

. TELECOPY D. HARASONYSH OF YARWAY TO

. J. ROBYN OF SCS ON 9/11/86

LENGTH UPSTREAM (LU) AND DOWNSTREAM (LD)

. LU = 9.3125 FT

. KELLOGG ISOMETRIC S-36097 A

. LD = 15.3333 FT

. KELLOGG ISOMETRIC S-36097 A

. KELLOGG ISOMETRIC S-36098 A

PVEL4 = 0.091729 FROM COMPUTER PRINTOUT

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1&2 Prepared By: *C. Low* DATE 09/21/86MOTOR OPERATED VALVE Reviewed By: *D. Wilson* DATE 09/21/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-018 SHEET 19 OF 52.

GATE VALVE PVEL CALCULATION

MPL NUMBER	2E51-F013
VALVE DIAMETER (INCHES)	3.4375
CLOSING TIME (SECONDS)	15
UPSTREAM PIPE LENGTH (FT)	94.995
DOWNSTREAM PIPE LENGTH (FT)	19.75
UPSTREAM SYSTEM VEL (FT/SEC)	11.1687
DOWNSTREAM SYSTEM VEL (FT/SEC)	11.1687
delta TIME UPSTREAM (SECONDS)	0.0474975
delta TIME DWNSTREAM (SECONDS)	0.009875
TIME UPSTREAM 1 (SECONDS)	14.952502
TIME UPSTREAM 2 (SECONDS)	15
TIME DOWNSTREAM 1 (SECONDS)	14.990125
TIME DOWNSTREAM 2 (SECONDS)	15
RISE UPSTREAM 1	1.7133076
RISE UPSTREAM 2	1.71875
RISE DOWNSTREAM 1	1.7176185
RISE DOWNSTREAM 2	1.71875
CHORD UPSTREAM 1	3.4374828
CHORD UPSTREAM 2	3.4375
CHORD DOWNSTREAM 1	3.4374993
CHORD DOWNSTREAM 2	3.4375
MAX AREA (IN SQ)	9.3546549
AREA FLOW UPSTREAM 1	0.0389633
AREA FLOW UPSTREAM 2	0
AREA FLOW DOWNSTREAM 1	0.0081027
AREA FLOW DOWNSTREAM 2	0
a/Au1	0.0041984
a/Au2	0
a/Ad1	0.0008731
a/Ad2	0
VELOCITY UPSTREAM 1 (FT/SEC)	0.0468903
VELOCITY UPSTREAM 2 (FT/SEC)	0
VELOCITY DOWNSTREAM 1 (FT/SEC)	0.0097512
VELOCITY DOWNSTREAM 2 (FT/SEC)	0
delta VEL UPSTREAM (FT/SEC)	0.0468903
delta VEL DOWNSTREAM (FT/SEC)	0.0097512
Pvu UPSTREAM PRESSURE (PSIG)	2.5077756
Pvd DOWNSTREAM PRESSURE (PSIG)	0.5215117

Pvel2(PSIG)

3.0292873

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1&2

Prepared By: *C. Foreman*

DATE 09/19/86

MOTOR OPERATED VALVE

Reviewed By: *D. Wilson*

DATE 09/21/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-018

SHEET 20 OF 52.

TWO INCH GLOBE VALVE PVEL CALCULATIONS

<u>MPL NUMBER</u>	2E51-F019
<u>VALVE DIAMETER (INCHES)</u>	1.403
<u>CLOSING TIME (SECONDS)</u>	4
<u>UPSTREAM PIPE LENGTH (FT)</u>	8.6146
<u>DOWNSTREAM PIPE LENGTH (FT)</u>	119
<u>UPSTREAM SYSTEM VEL (FT/SEC)</u>	5.4368
<u>DOWNSTREAM SYSTEM VEL (FT/SEC)</u>	5.4368
 <u>delta TIME UPSTREAM (SECONDS)</u>	 0.0043073
<u>delta TIME DWNSTREAM (SECONDS)</u>	0.0595
<u>TIME UPSTREAM 1 (SECONDS)</u>	2
<u>TIME UPSTREAM 2 (SECONDS)</u>	2.0043073
<u>TIME DOWNSTREAM 1 (SECONDS)</u>	2
<u>TIME DOWNSTREAM 2 (SECONDS)</u>	2.0595
<u>% OPEN UPSTREAM 1</u>	50
<u>% OPEN UPSTREAM 2</u>	50.107682
<u>% OPEN DOWNSTREAM 1</u>	50
<u>% OPEN DOWNSTREAM 2</u>	51.4875
<u>% CV UPSTREAM 1</u>	40
<u>% CV UPSTREAM 2</u>	40.086146
<u>% CV DOWNSTREAM 1</u>	40
<u>% CV DOWNSTREAM 2</u>	41.19
<u>delta VEL UPSTREAM (FT/SEC)</u>	0.0046836
<u>delta VEL DOWNSTREAM (FT/SEC)</u>	0.0646979
<u>Pvu UPSTREAM (PSIG)</u>	0.2504862
<u>Pvd DOWNSTREAM (PSIG)</u>	3.4601555

Pvel3(PSIG)

3.7106417

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 1&2

Prepared By: *C. Brown*

DATE 09/19/86

MOTOR OPERATED VALVE

Reviewed By: *R. Wilson*

DATE 09/20/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-018

SHEET 2, OF 52.

TWO INCH GLOBE VALVE PVEL CALCULATIONS

MPL NUMBER	2E51-F046
VALVE DIAMETER (INCHES)	1.403
CLOSING TIME (SECONDS)	10
UPSTREAM PIPE LENGTH (FT)	9.3125
DOWNSTREAM PIPE LENGTH (FT)	15.3333
UPSTREAM SYSTEM VEL (FT/SEC)	1.7398
DOWNSTREAM SYSTEM VEL (FT/SEC)	1.7398
delta TIME UPSTREAM (SECONDS)	0.0046562
delta TIME DWNSTREAM (SECONDS)	0.0076666
TIME UPSTREAM 1 (SECONDS)	5
TIME UPSTREAM 2 (SECONDS)	5.0046563
TIME DOWNSTREAM 1 (SECONDS)	5
TIME DOWNSTREAM 2 (SECONDS)	5.0076666
% OPEN UPSTREAM 1	50
% OPEN UPSTREAM 2	50.046563
% OPEN DOWNSTREAM 1	50
% OPEN DOWNSTREAM 2	50.076667
% CV UPSTREAM 1	40
% CV UPSTREAM 2	40.03725
% CV DOWNSTREAM 1	40
% CV DOWNSTREAM 2	40.061333
delta VEL UPSTREAM (FT/SEC)	0.0006481
delta VEL DOWNSTREAM (FT/SEC)	0.0010671
Pvu UPSTREAM (PSIG)	0.0346602
Pvd DOWNSTREAM (PSIG)	0.057069

Pvel4(PSIG)

0.0917292

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>C. Brenner</i>	Date 9-19-86
Subject/Title Unit 2 RCIC Motor Operated Valve	Reviewed By <i>A. S. Kirk</i>	Date 9-20-86
Differential Pressure Calculation	Calculation Number SNH-86-018	Sheet 22 of 52

DETERMINE THE PRESSURE INCREASE DUE TO THE RAPID
DECELERATION OF FLUID CAUSED BY THE MOVEMENT
OF A PROCESS GATE OR GLOBE VALVE

ASSUMPTIONS

- 1) Valve openings result in no waterhammer effects. The differential pressure across a valve during opening is decreased by an increase in fluid velocity. The maximum actuator loading takes place before the valve lift occurs.
- 2) Steam valve closure results in only minor or no waterhammer effect. The compressible nature of the fluid medium coupled with maximum anticipated velocity changes make the pressure addition insignificant.
- 3) Area of flow through a gate valve is a direct and linear relation to system velocity.
- 4) The percentage of valve opening is a direct relation to opening time.
- 5) It is assumed that flowing pressure does not drop below the fluids vapor pressure.

The pressure increase due to sudden deceleration of fluid may be expressed as:


$$P_{VEL} = P_1 + P_2$$

Where P1 is the upstream pressure change, and P2 is the downstream pressure change.

The respective values for P1 and P2 may be calculated as follows:

$$P_1, P_2 = \frac{f C \Delta V_{MAX}}{144 g}$$

Design Calculations

Southern Company Services 

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>C. Loren</i>	Date 9-19-86
Subject/Title Unit 2 RCIC Motor Operated Valve	Reviewed By <i>A. S. Kirk</i>	Date 9-20-86
Differential Pressure Calculation	Calculation Number SNH-86-018	Sheet 23 of 52

Where: ρ is the fluid density

C is the speed of sound through the fluid

ΔV_{MAX} is the maximum system fluid differential velocity

144 is a conversion factor

and g is the Gravitational Constant



The fluid ΔV is assumed to be a direct relation to flow area, as shown in the gate valve area - percent open curves, and is a direct relation to C_v , as shown on the globe valve C_v - percent open curves.

The valve Δt is a direct relation to Δ percentage open.


Therefore:

$$\frac{\Delta A}{\Delta \% \text{ Open}} \approx \frac{\Delta C_v}{\Delta \% \text{ Open}} \approx \frac{\Delta V}{\Delta t}$$

Having plotted a velocity relation against a time relation the region of highest differential velocity is examined.



Design Calculations

Southern Company Services 

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>C. Lorenson</i>	Date 9-19-86
Subject/Title Unit 2 RCIC Motor Operated Valve	Reviewed By <i>A.S. Kirk</i>	Date 9-20-86
Differential Pressure Calculation	Calculation Number SNH-86-018	Sheet 24 of 52

Incremental time is Defined As:

$$\Delta t = t_2 - t_1 = \frac{2L}{c}$$

Where the term $2L/C$ is the time require for a pressure wave to travel down a pipe's flow length and rebound to it's source valve.

Knowing the equation of the curve, the maximum ΔV for Δt (ie; greatest slope) is calculated and entered into the pressure equations.

The procedure is once again performed for the down stream side of the valve and added as follows to produce PVEL

$$PVEL = P1 + P2$$

Reference: BWROG REPORT APP. B


0082d

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>[Signature]</i>	Date 9-19-86
Subject/Title Unit 2 RCIC Motor Operated Valve	Reviewed By <i>[Signature]</i>	Date 4/21/86
Differential Pressure Calculation	Calculation Number SNH-86-018	Sheet 25 of 52

RELATIONSHIP OF THE GATE VALVE FLOW AREA TO THE
PERCENTAGE OPENING OF A TYPICAL GATE VALVE

It is assumed that the diameter of the gate is equal to the port diameter of the valve since the difference in diameters is insignificantly small.


THE FLOW AREA OF THE VALVE MAY BE DETERMINED BY SUBTRACTING THE AREA OF THE GATE OCCLUDING THE TOTAL PORT AREA.



A = Area

$$A_{\text{Flow}} = A_{\text{Port}} - A_{\text{Gate}}$$

THE AREA OF THE PORT IS CALCULATED USING THE CIRCULAR SEGMENT CALCULATION



$$A_{\text{SEG}} = h/6s (3h^2 + 4s^2)$$

WITH h = RISE = RADIUS
AND s = CHORD = DIAMETER


THE AREA OF THE PORT IS EQUAL TO TWICE ASEG



$$A_{\text{PORT}} = 2A_{\text{SEG}} = R/6D (3R^{**2} + 4D^{**2})$$

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>C. Scoville</i>	Date 9-19-86
Subject/Title Unit 2 RCIC Motor Operated Valve	Reviewed By <i>GD McKel</i>	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-018	Sheet 26 of 52

THE OCCLUDING AREA OF THE GATE IS FOUND BY USING THE AREA OF A CIRCULAR SEGMENT CALCULATION.



$$ASEG = h/6s (3h^2 + 4s^2)$$


$$r = h/2 + s^2/8h$$

TRANSFORMING THE LATER EQUATION

$$s = (8h (r - (h/2)))^{1/2}$$

WHICH COMBINED WITH THE ASEG CALCULATION MAY BE READILY SOLVED.

THE AREA OCCLUDED IS EQUAL TO TWICE ASEG.



$$AGATE = 2 ASEG.$$


THUS THE AREA OF FLOW THROUGH THE VALVE IS CALCULATED AS:



$$A_{Flow} = A_{PORT} - A_{GATE}$$




$$A_{Flow}$$

Design Calculations

Southern Company Services 

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By 	Date 9-19-86
Subject/Title Unit 2 RCIC Motor Operated Valve	Reviewed By 	Date 9/21/86
Differential Pressure Calculation	Calculation Number SNH-86-018	Sheet 27 of 52

A GRAPHIC PRESENTATION OF THE TYPICAL FLOW AREA VS. PERCENT VALVE OPENING IS GIVEN AS FOLLOWS.



REFERENCE: ENGINEERING FORMULAS 4th EDITION, PAGE B3.

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>C. Lora</i>	Date 9-19-86
Subject/Title Unit 2 RCIC Motor Operated Valve	Reviewed By <i>A.S. Kirk</i>	Date 9-19-86
Differential Pressure Calculation	Calculation Number SNH-86-018	Sheet 28 of 52

NUMERICAL RELATIONSHIP BETWEEN A GRAPHICAL PRESENTATION
OF MANUFACTURER'S 2" GLOBE VALVE OPENING
VS. MANUFACTURER'S CV DATA

Given a curve of 0-100 % opening (see attached), It is Desired to numerically relate the first 60% of opening to CV.

The First 60% of opening is a linear function thus, the curve may be equated using linear regression of the point-slope form.

$$y - y_1 = m(x - x_1)$$

Using the points (0,0) and (50,40)

$$40 - 0 = m(50 - 0)$$

Solving for m

$$m = 40/50 = 0.8$$

The equation of a line is given as:

$$y = mx$$


Hence, the equation relating cv with percent opening is:

$$CV = 0.8 (\text{percentage opening})$$

FOR ALL OPENINGS LESS THAN 60%.

Reference: THE ENGINEER'S COMPANION 1966 PG. 13.

2304
0/13/65



DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *G. Strensen* DATE 09/19/86
UNIT 2 RCIC MOTOR OPER VALVE Reviewed By: *W. T. Bass* DATE 09/20/86
DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-018 SHEET 30 OF 52.

DIFFERENTIAL PRESSURE CALCULATION

MPL NUMBER: 2E51-F007
VALVE DESCRIPTION: RCIC STEAM INBOARD ISOL VALVE
VALVE FUNCTION: RCIC STEAM LINE ISOLATION VALVE
SAFETY ACTION (YES/NO): YES
DP CALCULATION FORMULA: DP=PRSS
SAFETY ACTION ON OPEN/CLOSE: CLOSE
MAXIMUM DP ON OPEN/CLOSE: CLOSE
MAXIMUM DP UPSTREAM/DOWNSTREAM UPSTREAM
VALUES USED:

PRSS =1090

DP (PSID) 1090

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *C. Lorenson* DATE 09/19/86UNIT 2 RCIC MOTOR OPER VALVE Reviewed By: *W. Z. Barr* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-018 SHEET 31 OF 52 .

DIFFERENTIAL PRESSURE CALCULATION

MPL NUMBER: 2E51-F008

VALVE DESCRIPTION: RCIC STEAM OUTBOARD ISOL VLV

VALVE FUNCTION: RCIC STEAM LINE ISOLATION VALVE

SAFETY ACTION (YES/NO): YES

DP CALCULATION FORMULA: DP=PRSS

SAFETY ACTION ON OPEN/CLOSE: CLOSE

MAXIMUM DP ON OPEN/CLOSE: CLOSE

MAXIMUM DP UPSTREAM/DOWNSTREAM UPSTREAM

VALUES USED:

PRSS =1090

DP (PSID) 1090

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2

Prepared By: *C. Foreman*

DATE 09/19/86

UNIT 2 RCIC MOTOR OPER VALVE

Reviewed By: *W. T. Ban*

DATE 09/20/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-018

SHEET 32 OF 52.

DIFFERENTIAL PRESSURE CALCULATIONMPL NUMBER:

2E51-F010

VALVE DESCRIPTION:

PUMP SUCT FRM COND STG TNK

VALVE FUNCTION:

RCIC CST SUCTION ISOLATION VALVE

SAFETY ACTION (YES/NO):

YES

DP CALCULATION FORMULA:

DP=PELD+PV+PVEL1

SAFETY ACTION ON OPEN/CLOSE:

CLOSE

MAXIMUM DP ON OPEN/CLOSE:

CLOSE

MAXIMUM DP UPSTREAM/DOWNSTREAM UPSTREAMVALUES USED:

PELD = 29.488

PV = 0.1337

PVEL1 = 0

DP (PSID)

29.6217

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2

Prepared By: *G. Brenner*

DATE 09/19/86

UNIT 2 RCIC MOTOR OPER VALVE

Reviewed By: *D. T. Bass*

DATE 09/20/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-018

SHEET 33 OF 52 .

DIFFERENTIAL PRESSURE CALCULATIONMPL NUMBER:

2E51-F012

VALVE DESCRIPTION:

RCIC PUMP OUTBOARD DISCH VLV

VALVE FUNCTION:

RCIC INJECTION VALVE TEST VALVE

SAFETY ACTION (YES/NO):

NO

DP CALCULATION FORMULA:

NO SAFETY ACTION

SAFETY ACTION ON OPEN/CLOSE:

NONE

MAXIMUM DP ON OPEN/CLOSE:

N/A

MAXIMUM DP UPSTREAM/DOWNSTREAM N/AVALUES USED:

=

DP (PSID)

N/A

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2	Prepared By: <i>C. Foreman</i>	DATE 09/19/86
UNIT 2 RCIC MOTOR OPER VALVE	Reviewed By: <i>W.T. Ban</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-018	SHEET 34 OF 52 .

DIFFERENTIAL PRESSURE CALCULATION

MPL NUMBER: 2E51-F013

VALVE DESCRIPTION: RCIC PUMP INBOARD DISCH VLV

VALVE FUNCTION: RCIC INJECTION VALVE

SAFETY ACTION (YES/NO): YES

DP CALCULATION FORMULA: $DP = PRSS + PEL$ (b)

SAFETY ACTION ON OPEN/CLOSE: OPEN/CLOSE

MAXIMUM DP ON OPEN/CLOSE: OPEN/CLOSE

MAXIMUM DP UPSTREAM/DOWNSTREAM DOWNSTREAM

VALUES USED:

PRSS = 1090

PEL = 35.612

DP (PSID) 1125.612

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *C. Boyer* DATE 09/19/86UNIT 2 RCIC MOTOR OPER VALVE Reviewed By: *W.T. Burr* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-018 SHEET 35 OF 52.

DIFFERENTIAL PRESSURE CALCULATION

MPL NUMBER: 2E51-F019

VALVE DESCRIPTION: TEST BYPASS TO COND STG TANK

VALVE FUNCTION: RCIC MINIMUM FLOW BYPASS ISOL VALVE

SAFETY ACTION (YES/NO): YES

DP CALCULATION FORMULA: $DP = PSOH + PELM$

SAFETY ACTION ON OPEN/CLOSE: OPEN/CLOSE

MAXIMUM DP ON OPEN/CLOSE: OPEN

MAXIMUM DP UPSTREAM/DOWNSTREAM UPSTREAM

VALUES USED:

PSOH = 1300.54

PELM = 29.633

DP (PSID) 1330.173

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2	Prepared By: <i>C. Lorenson</i>	DATE 09/19/86
UNIT 2 RCIC MOTOR OPER VALVE	Reviewed By: <i>W.T. Barr</i>	DATE 09/20/86
DIFFERENTIAL PRESSURE CALC	CALC No. SNH-86-018	SHEET 36 OF 52.

DIFFERENTIAL PRESSURE CALCULATION

MPL NUMBER: 2E51-F019

VALVE DESCRIPTION: TEST BYPASS TO COND STG TANK

VALVE FUNCTION: RCIC MINIMUM FLOW BYPASS ISOL VALVE

SAFETY ACTION (YES/NO): YES

DP CALCULATION FORMULA: $DP = PMF + PELM + PVEL3$

SAFETY ACTION ON OPEN/CLOSE: OPEN/CLOSE

MAXIMUM DP ON OPEN/CLOSE: CLOSE

MAXIMUM DP UPSTREAM/DOWNSTREAM UPSTREAM

VALUES USED:

PMF	=1300.54
PELM	=29.633
PVEL3	=3.710641

DP (PSID) 1333.883641

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *S. Brown* DATE 09/19/86UNIT 2 RCIC MOTOR OPER VALVE Reviewed By: *W.T. Ban* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-018 SHEET 37 OF 52 .

DIFFERENTIAL PRESSURE CALCULATIONMPL NUMBER:

2E51-F022

VALVE DESCRIPTION:

TEST BYPASS TO COND STG TANK

VALVE FUNCTION:

RCIC CST TEST RETURN VALVE

SAFETY ACTION (YES/NO):

NO

DP CALCULATION FORMULA:

NO SAFETY ACTION

SAFETY ACTION ON OPEN/CLOSE:

NONE

MAXIMUM DP ON OPEN/CLOSE:

N/A

MAXIMUM DP UPSTREAM/DOWNSTREAM N/AVALUES USED:

=

DP (PSID)

N/A

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *J. Sorenson* DATE 09/19/86UNIT 2 RCIC MOTOR OPER VALVE Reviewed By: *W.T. Ban* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-018 SHEET 38 OF 52.

DIFFERENTIAL PRESSURE CALCULATION

MPL NUMBER: 2E51-F029

VALVE DESCRIPTION: RCIC PMP SUCT VLV FRM SUP POOL

VALVE FUNCTION: RCIC SUPP POOL SUCTION ISOL VALVE

SAFETY ACTION (YES/NO): YES

DP CALCULATION FORMULA: $DP = PLOC + PLOM1 (c)$

SAFETY ACTION ON OPEN/CLOSE: OPEN/CLOSE

MAXIMUM DP ON OPEN/CLOSE: CLOSE

MAXIMUM DP UPSTREAM/DOWNSTREAM UPSTREAM

VALUES USED:

PLOC = 31.6

PLOM1 = 5.717

DP (PSID) 37.317

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2

Prepared By: *C. Foreman*

DATE 09/19/86

UNIT 2 RCIC MOTOR OPER VALVE

Reviewed By: *W. T. Ban*

DATE 09/20/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-018

SHEET 39 OF 52.

DIFFERENTIAL PRESSURE CALCULATIONMPL NUMBER:

2E51-F029

VALVE DESCRIPTION:

RCIC PMP SUCT VLV FRM SUP POOL

VALVE FUNCTION:

RCIC SUPP POOL SUCTION ISOL VALVE

SAFETY ACTION (YES/NO):

YES

DP CALCULATION FORMULA:

DP=PRV-PELS

SAFETY ACTION ON OPEN/CLOSE:

OPEN/CLOSE

MAXIMUM DP ON OPEN/CLOSE:

OPEN

MAXIMUM DP UPSTREAM/DOWNSTREAM

DOWNSTREAM

VALUES USED:

FRV = 100

PELS = 4.4

DP (PSID)

95.6

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *S. Foreman* DATE 09/19/86UNIT 2 RCIC MOTOR OPER VALVE Reviewed By: *W.T. Ban* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-018 SHEET 40 OF 52.

DIFFERENTIAL PRESSURE CALCULATION

MPL NUMBER: 2E51-F031

VALVE DESCRIPTION: RCIC PMP SUCT VLV FRM SUP POOL

VALVE FUNCTION: RCIC SUPP POOL SUCTION ISOL VALVE

SAFETY ACTION (YES/NO): YES

DP CALCULATION FORMULA: DP=PRV-PELS

SAFETY ACTION ON OPEN/CLOSE: OPEN/CLOSE

MAXIMUM DP ON OPEN/CLOSE: OPEN

MAXIMUM DP UPSTREAM/DOWNSTREAM DOWNSTREAM

VALUES USED:

PRV = 100

PELS = 4.4

DP (PSID) 95.6

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *J. Lorenson* DATE 09/19/86UNIT 2 RCIC MOTOR OPER VALVE Reviewed By: *D.T. Barr* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-018 SHEET 41 OF 52.

DIFFERENTIAL PRESSURE CALCULATION

MPL NUMBER: 2E51-F031

VALVE DESCRIPTION: RCIC PMP SUCT VLV FRM SUP POOL

VALVE FUNCTION: RCIC SUPP POOL SUCTION ISOL VALVE

SAFETY ACTION (YES/NO): YES

DP CALCULATION FORMULA: $DP = PLOC + PLOM1 (c)$

SAFETY ACTION ON OPEN/CLOSE: OPEN/CLOSE

MAXIMUM DP ON OPEN/CLOSE: CLOSE

MAXIMUM DP UPSTREAM/DOWNSTREAM UPSTREAM

VALUES USED:

PLOC = 31.6

PLOM1 = 5.717

DP (PSID) 37.317

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *C. Brennan* DATE 09/19/86UNIT 2 RCIC MOTOR OPER VALVE Reviewed By: *W.T. Barr* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-018 SHEET 42 OF 52.

DIFFERENTIAL PRESSURE CALCULATION

MPL NUMBER: 2E51-F045

VALVE DESCRIPTION: TURBINE STEAM SUPPLY VALVE

VALVE FUNCTION: RCIC STEAM ADMISSION VALVE

SAFETY ACTION (YES/NO): YES

DP CALCULATION FORMULA: DP=PRSS

SAFETY ACTION ON OPEN/CLOSE: OPEN/CLOSE

MAXIMUM DP ON OPEN/CLOSE: OPEN/CLOSE

MAXIMUM DP UPSTREAM/DOWNSTREAM UPSTREAM

VALUES USED:

PRSS =1090

DP (PSID) 1090

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *C. Brenner* DATE 09/19/86UNIT 2 RCIC MOTOR OPER VALVE Reviewed By: *W.T. Barr* DATE 09/20/86

DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-018 SHEET 43 OF 52.

DIFFERENTIAL PRESSURE CALCULATION

MPL NUMBER: 2E51-F046

VALVE DESCRIPTION: COOLING WATER SUPPLY VALVE

VALVE FUNCTION: RCIC TURBINE ACCESSORY COOL WTR VALVE

SAFETY ACTION (YES/NO): YES

DP CALCULATION FORMULA: $DP = PLOC + PLOM2 + PVEL4$

SAFETY ACTION ON OPEN/CLOSE: OPEN/CLOSE

MAXIMUM DP ON OPEN/CLOSE: CLOSE

MAXIMUM DP UPSTREAM/DOWNSTREAM UPSTREAM

VALUES USED:

PLOC = 31.6

PLOM2 = 5.69

PVEL4 = 0.091729

DP (PSID) 37.381729

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *C. Sorenson* DATE 09/19/86
UNIT 2 RCIC MOTOR OPER VALVE Reviewed By: *W. T. Barr* DATE 09/20/86
DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-018 SHEET 44 OF 52.

DIFFERENTIAL PRESSURE CALCULATION

MPL NUMBER: 2E51-F046
VALVE DESCRIPTION: COOLING WATER SUPPLY VALVE
VALVE FUNCTION: RCIC TURBINE ACCESSORY COOL WTR VALVE
SAFETY ACTION (YES/NO): YES
DP CALCULATION FORMULA: $DP = PSOI + PELC$
SAFETY ACTION ON OPEN/CLOSE: OPEN/CLOSE
MAXIMUM DP ON OPEN/CLOSE: OPEN
MAXIMUM DP UPSTREAM/DOWNSTREAM UPSTREAM

VALUES USED:

PSOI = 257.074

PELC = 34.9

DP (PSID) 291.974

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2

Prepared By: *C. Foreman*

DATE 09/19/86

UNIT 2 RCIC MOTOR OPER VALVE

Reviewed By: *W. J. Bass*

DATE 09/20/86

DIFFERENTIAL PRESSURE CALC

CALC No. SNH-86-018

SHEET 45 OF 52.

DIFFERENTIAL PRESSURE CALCULATIONMPL NUMBER:

2E51-F104

VALVE DESCRIPTION:

GATE VALVE 1.5 IN MO

VALVE FUNCTION:

RCIC VACUUM BREAKER LINE ISOL VALVE

SAFETY ACTION (YES/NO):

YES

DP CALCULATION FORMULA:

DP=PC+PATM

SAFETY ACTION ON OPEN/CLOSE:

CLOSE

MAXIMUM DP ON OPEN/CLOSE:

CLOSE

MAXIMUM DP UPSTREAM/DOWNSTREAM UPSTREAMVALUES USED:

PC = 31.6

PATM = 0

DP (PSID)

31.6

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *C. Brenner* DATE 09/19/86
UNIT 2 RCIC MOTOR OPER VALVE Reviewed By: *W.T. Barr* DATE 09/20/86
DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-018 SHEET 46 OF 52.

DIFFERENTIAL PRESSURE CALCULATION

MPL NUMBER: 2E51-F105
VALVE DESCRIPTION: GATE VALVE 2 IN MO
VALVE FUNCTION: RCIC VACUUM BREAKER LINE ISOL VALVE
SAFETY ACTION (YES/NO): YES
DP CALCULATION FORMULA: $DP = PC + PATM$
SAFETY ACTION ON OPEN/CLOSE: CLOSE
MAXIMUM DP ON OPEN/CLOSE: CLOSE
MAXIMUM DP UPSTREAM/DOWNSTREAM UPSTREAM

VALUES USED:

PC = 31.6
PATM = 0

DP (PSID) 31.6

DESIGN CALCULATIONS

SOUTHERN COMPANY SERVICES

E.I. HATCH NUCLEAR PLANT U 2 Prepared By: *C. Loren* DATE 09/19/86
UNIT 2 RCIC MOTOR OPER VALVE Reviewed By: *W.T. Barr* DATE 09/20/86
DIFFERENTIAL PRESSURE CALC CALC No. SNH-86-018 SHEET 47 OF 52.

DIFFERENTIAL PRESSURE CALCULATION

MPL NUMBER: 2E51-F119
VALVE DESCRIPTION: LSTB VALVE
VALVE FUNCTION: RCIC STEAM ADMISSION BYPASS VALVE
SAFETY ACTION (YES/NO): YES
DP CALCULATION FORMULA: DP=PRSS
SAFETY ACTION ON OPEN/CLOSE: CLOSE
MAXIMUM DP ON OPEN/CLOSE: CLOSE
MAXIMUM DP UPSTREAM/DOWNSTREAM UPSTREAM
VALUES USED:

PRSS =1090

DP (PSID) 1090


Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>Ramon C. Wilson</i>	Date 09/19/86
Subject/Title Unit 2 RCIC Motor Operated Valve	Reviewed By <i>A. J. McHale</i>	Date 9/20/86
Differential Pressure Calculation	Calculation Number SNH-86-018	Sheet 48 of 52

TWO INCH GLOBE VALVE PVEL CALCULATIONS

PAGE 1 OF 2

A3: [W11] ^MPL
 B3: ^VALVE
 C3: ^CLOSING
 D3: ^UPSTR
 E3: ^DNSTR
 F3: 'UPSTRSYS
 G3: 'DNSTRSYS
 I3: ^dT UP
 J3: ^dT DN
 K3: ^TIMEu1
 L3: ^TIMEu2
 M3: ^TIMEd1
 N3: ^TIMEd2
 O3: ^% OPEN
 P3: ^% OPEN
 Q3: ^% OPEN
 R3: ^% OPEN
 S3: ^% CV
 T3: ^% CV
 U3: ^% CV
 V3: ^% CV
 W3: ^dVu
 X3: ^dVd
 Y3: ^Pvu
 Z3: ^Pvd
 AA3: ^Pvel
 A4: [W11] ^NUMBER
 B4: ^DIA, "
 C4: ^T, SECS
 D4: ^PIPE L'
 E4: ^PIPE L'
 F4: ^VEL FPS
 G4: ^VEL FPS
 O4: ^UPSTR1
 P4: ^UPSTR2
 Q4: ^DNSTR1
 R4: ^DNSTR2
 S4: ^UPSTR1
 T4: ^UPSTR2
 U4: ^DNSTR1
 V4: ^DNSTR2
 A5: [W11] \-
 B5: \-
 C5: \-
 D5: \-
 E5: \-
 F5: \-
 G5: \-

Design Calculations

Southern Company Services 


Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>Dawn C. Wilson</i>	Date 09/19/86
Subject/Title Unit 2 RCIC Motor Operated Valve	Reviewed By <i>A. J. McHugh</i>	Date 9/20/86
Differential Pressure Calculation	Calculation Number SNH-86-018	Sheet 49 of 52

TWO INCH GLOBE VALVE PVEL CALCULATIONS

PAGE 2 OF 2

H5: [W2] \-	C27: 'DENSITY
I5: \-	D27: 61.996
J5: \-	E27: 'LB/FT3
K5: \-	C28: 'C
L5: \-	D28: 4000
M5: \-	E28: 'FT/SEC
N5: \-	
O5: \-	
P5: \-	
Q5: \-	
R5: \-	
S5: \-	
T5: \-	
U5: \-	
V5: \-	
W5: \-	
X5: \-	
Y5: \-	
Z5: \-	
AA5: \-	
A6: [W11] '1E41-F059	
B6: 1.75	
C6: 10	
D6: 25	
E6: 31.42	
F6: 7.601	
G6: 7.601	
H6: [W2] '	
I6: (2*D6)/\$D\$28	
J6: (2*E6)/\$D\$28	
K6: +\$C6*0.5	
L6: +\$C6*0.5+I6	
M6: +\$C6*0.5	
N6: +\$C6*0.5+J6	
O6: (+K6*100)/\$C6	
P6: (+L6*100)/\$C6	
Q6: (+M6*100)/\$C6	
R6: (+N6*100)/\$C6	
S6: +O6*0.8	
T6: +P6*0.8	
U6: +Q6*0.8	
V6: +R6*0.8	
W6: (+F6*(T6-S6))/100	
X6: (+G6*(V6-U6))/100	
Y6: (W6*\$D\$27*\$D\$28)/(144*32.2)	
Z6: (X6*\$D\$27*\$D\$28)/(144*32.2)	
AA6: +Y6+Z6	

Design Calculations

Southern Company Services 


Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>David C. Wilson</i>	Date 09/19/86
Subject/Title Unit 2 RCIC Motor Operated Valve	Reviewed By <i>J.D. McFadden</i>	Date 9/20/86
Differential Pressure Calculation	Calculation Number SNH-86-018	Sheet 50 of 52

GATE VALVE PVEL CALCULATIONS

PAGE 1 OF 3

A3: [W11] ^MPL
 B3: ^VALVE
 C3: ^CLOSING
 D3: ^UPSTR
 E3: ^DNSTR
 F3: 'UPSTRSYS
 G3: 'DNSTRSYS
 I3: ^dT UP
 J3: ^dT DN
 K3: ^TIMEu1
 L3: ^TIMEu2
 M3: ^TIMEd1
 N3: ^TIMEd2
 O3: ^RISEu1
 P3: ^RISEu2
 Q3: ^RISEd1
 R3: ^RISEd2
 S3: ^CHORDu1
 T3: ^CHORDu2
 U3: ^CHORDd1
 V3: ^CHORDd2
 W3: 'MAX AREA
 X3: ^Afl u1
 Y3: ^Afl u2
 Z3: ^Afl d1
 AA3: ^Afl d2
 AB3: ^a/Au1
 AC3: ^a/Au2
 AD3: ^a/Ad1
 AE3: ^a/Ad2
 AF3: ^Vu1
 AG3: ^Vu2
 AH3: ^Vd1
 AI3: ^Vd2
 AJ3: ^dVu
 AK3: ^dVd
 AL3: ^Pvu
 AM3: ^Pvd
 AN3: ^Pvel
 A4: [W11] ^NUMBER
 B4: ^DIA, "
 C4: ^T, SECS
 D4: ^PIPE L'
 E4: ^PIPE L'
 F4: ^VEL FPS
 G4: ^VEL FPS
 W4: 'FLOW
 A5: [W11] \-

Design Calculations

Southern Company Services 

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>Raymond C. Wilson</i>	Date 09/19/86
Subject/Title Unit 2 RCIC Motor Operated Valve	Reviewed By <i>A. D. McPherson</i>	Date 9/20/86
Differential Pressure Calculation	Calculation Number SNH-86-018	Sheet 51 of 52

GATE VALVE PVEL CALCULATIONS

PAGE 2 OF 3

B5: /-
 C5: /-
 D5: /-
 E5: /-
 F5: /-
 G5: /-
 H5: [W2] /-
 I5: /-
 J5: /-
 K5: /-
 L5: /-
 M5: /-
 N5: /-
 O5: /-
 P5: /-
 Q5: /-
 R5: /-
 S5: /-
 T5: /-
 U5: /-
 V5: /-
 W5: /-
 X5: /-
 Y5: /-
 Z5: /-
 AA5: /-
 AB5: /-
 AC5: /-
 AD5: /-
 AE5: /-
 AF5: /-
 AG5: /-
 AH5: /-
 AI5: /-
 AJ5: /-
 AK5: /-
 AL5: /-
 AM5: /-
 AN5: /-
 A6: [W11] '1E51-F013
 B6: 3+5/16
 C6: 15
 D6: 99.9
 E6: 16.6
 F6: 11.62
 G6: 12.46
 H6: [W2] '|
 I6: (2*D6)/\$D\$29

Project E.I. Hatch Nuclear Plant Unit 2	Prepared By <i>Dave C Wilson</i>	Date 09/19/86
Subject/Title Unit 2 RCIC Motor Operated Valve	Reviewed By <i>J.D. McGee</i>	Date 9/20/86
Differential Pressure Calculation	Calculation Number SNH-86-018	Sheet 52 of 52

GATE VALVE PVEL CALCULATIONS

PAGE 3 OF 3

J6: $(2 * E6) / \$D\29
 K6: $(\$D\$30 * \$C6) - I6$
 L6: $+\$D\$30 * \$C6$
 M6: $(\$D\$30 * \$C6) - J6$
 N6: $+\$D\$30 * \$C6$
 O6: $(K6 / \$C6) * (\$B6 / 2)$
 P6: $(L6 / \$C6) * (\$B6 / 2)$
 Q6: $(M6 / \$C6) * (\$B6 / 2)$
 R6: $(N6 / \$C6) * (\$B6 / 2)$
 S6: $@SQRT(8 * O6 * ((\$B6 / 2) - (O6 / 2)))$
 T6: $@SQRT(8 * P6 * ((\$B6 / 2) - (P6 / 2)))$
 U6: $@SQRT(8 * Q6 * ((\$B6 / 2) - (Q6 / 2)))$
 V6: $@SQRT(8 * R6 * ((\$B6 / 2) - (R6 / 2)))$
 W6: $2 * ((1 / 12) * (((3 * B6 * B6) / 4) + (4 * B6 * B6)))$
 X6: $(F6) (W6) - (2 * ((O6 / (6 * S6)) * ((3 * O6 * O6) + (4 * S6 * S6))))$
 Y6: $(F6) (W6) - (2 * ((P6 / (6 * T6)) * ((3 * P6 * P6) + (4 * T6 * T6))))$
 Z6: $(F6) (\$W6) - (2 * ((Q6 / (6 * U6)) * ((3 * Q6 * Q6) + (4 * U6 * U6))))$
 AA6: $(F6) (\$W6) - (2 * ((R6 / (6 * V6)) * ((3 * R6 * R6) + (4 * V6 * V6))))$
 AB6: $(F6) + X6 / ((@PI * \$B6 * \$B6) / 4)$
 AC6: $(F6) + Y6 / ((@PI * \$B6 * \$B6) / 4)$
 AD6: $(F6) + Z6 / ((@PI * \$B6 * \$B6) / 4)$
 AE6: $(F6) + AA6 / ((@PI * \$B6 * \$B6) / 4)$
 AF6: $(F6) + AB6 * \$F6$
 AG6: $(F6) + AC6 * \$F6$
 AH6: $(F6) + AD6 * \$G6$
 AI6: $(F6) + AE6 * \$G6$
 AJ6: $(F6) + AF6 - AG6$
 AK6: $(F6) + AH6 - AI6$
 AL6: $(F6) (AJ6 * \$D\$28 * \$D\$29) / (144 * 32.2)$
 AM6: $(F6) (AK6 * \$D\$28 * \$D\$29) / (144 * 32.2)$
 AN6: $(F6) + AL6 + AM6$
 C28: 'DENSITY
 D28: 61.996
 E28: 'LB/FT3
 C29: 'C
 D29: 4000
 E29: 'FT/SEC
 C30: 'FUDGE FAC
 D30: 1
 E30: 'DIMLESS

ENCLOSURE 5

SCHEDULE FOR MOV TESTING

ACTIVITY \ MONTH	YEAR 1986			1987											
	OC	NO	DE	JA	FE	MA	AP	MA	JU	JU	AU	SE	OC	NO	DE
1 BUDGET & APPROVAL	*														
2 PREPARE SPECIFICATION	*_*														
3 REVIEW SPECIFICATION		*_*													
4 DETERMINE FULL DP VALVES	*_*														
5 ISSUE INQUIRY PACKAGE			*_*												
6 REVIEW BID PACKAGE				*_*											
7 ISSUE PURCHASE ORDER					*_*										
8 DETERMINE THRUST VALUES U1	*_*														
9 PREPARE SITE PROCEDURES U1						*_*									
10 *SET TORQUE SWITCHES U1							*_*								
11 DETERMINE THRUST VALUES U2								*_*							
12 PREPARE SITE PROCEDURES U2									*_*						
13 *SET TORQUE SWITCHES U2										*_*					
UNIT # 1 1987 OUTAGE								*****							
UNIT # 2 1987 OUTAGE												*****			

* NOTE: BASED ON CURRENT INFORMATION ON OUTAGE SCHEDULES.