Tennessee Valley Authority
ATTN: Mr. S. A. White
Manager of Power and
Engineering (Nuclear)
1101 Market Street
Chattanooga, TN 37402-2801

Gentlemen:

SUBJECT: PLANT RADIOLOGICAL EMERGENCY PLAN REVIEW, BROWNS FERRY NUCLEAR STATION

DOCKET NOS. 50-259, 50-260 AND 50-296

We have just completed our review of Revision 27 of the Browns Ferry Radiological Emergency Plan dated September 26, 1985.

Our review indicated the recent changes that were submitted for the Browns Ferry Radiological Emergency Plan meet the planning standards of 10 CFR 50.47(b) and the requirements of Appendix E to 10 CFR 50.

Please be reminded that 10 CFR 50.54(q) requires NRC approval of any changes to your plan which may decrease the effectiveness of the Plan. However, if your safety review indicates no decrease in emergency preparedness, then changes can be made without NRC approval. In all cases you should furnish copies of each change to the NRC in accordance with 10 CFR 50.54(q). Also, any changes to the Emergency Plan Implementing Procedures should be made in accordance with the requirements of 10 CFR 50, Appendix E, Section V (Implementing Procedures).

Should you have any questions regarding this letter, please contact Mr. Thomas R. Decker of our staff at (404) 331-2600.

Sincerely,

Stephen P. Weise, Chief Reactor Projects Branch 1 Division of Reactor Projects

cc: W. C. Bibb, Browns Ferry

Nuclear Plant Site Director

R. L. Lewis, Acting Plant Manager

K. W. Whitt, Chief, Nuclear

Safety Review Staff

D. L. Williams, Jr., Supervisor

Licensing Section

R. E. Rogers, Project Engineer

bcc: (See page 2)

8606020236 860516 PDR ADDCK 05000259 F PDR bcc: R. J. Clark, Licensing Project Manager, NRR

J. N. Grace H. R. Denton, NRR

H. L. Thompson, NRR

J. M. Taylor, IE

B. B. Hayes, OI

M. Grotenhuis, Project Manager, NRR

NRC Resident Inspector Licensee Fee Management Branch State of Alabama

MPoston-Brown

TDecker 5/0 /86

FCantrel1