Date: 1/23/87

## PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-II-87-09

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region II staff on this date.

Facility:	Licensee Emergency Classification:			
Duke Power Company	Notification of Unusual Event			
Docket No: 50-370	Alert			
McGuire Unit 2	Site Area Emergency			
Cornelius, North Carolina	General Emergency			
	X Not Applicable			

SUBJECT: SHUTDOWN GREATER THAN 48 HOURS

Unit 2 tripped from 100 percent power at 9:53 a.m. (EST) on January 20, when a false hotwell emergency low level signal resulted in a trip of both hotwell pumps, resulting in a loss of condensate flow which caused both condensate booster pumps to trip. This resulted in the loss of both main feedwater pumps, causing a turbine trip which initiated the reactor trip signal.

Linkage binding of the main feedwater pump turbine stop valve caused the "A" main feedwater pump/turbine to overspeed to greater than 7,000 revolutions per minute. The pump's seals failed, allowing water to enter the lubricating oil system.

The licensee is investigating the cause of the event and is keeping the unit shut down for more than 48 hours due to an alignment check on the "B" feedwater pump and repair of the "A" pump, while testing the 2B emergency diesel. Problems were encountered which have caused additional delay of startup.

The NRC resident inspectors will follow up.

The State of North Carolina has been informed.

This information is current as of 2:00 p.m. (EST) on January 23.

CONTACT: T. Peebles, 242-4196 and V. Brownlee, 242-5583

## DISTRIBUTION .

DISTRIBUTION:				
H. St.9:50 Chairman Zech	MNBB 9:53 Phillip	s 9:53 E/WILLIS	Willste: 17 Mail:	ADM: DMB DOT: Trans only
Comm. Roberts	PA	OIA	RES	Doi. It alls only
Comm. Asselstine	ELD	AEOD	RES	
	ELU	Bernthal		
Comm.		Cann	-1	
Comm.		Carr INPO-	7/	
ACRS	Air Rights	INPO-#		
SECY	SP	NSAC		
CA		PTAD MA		
PDR	Regional Offices /	(1-2)W-KAII-21	OTMI Resident Sect	ion
	RV	45 BTV-850	OTMI Resident Sect	ce
		1.11 LET O.	1116	K .
	Licensee	- 9:25	UN	
	CICO.	( )	/ / *	A1 + F34

9702190001 870123 PDR 1&E PND-II-87-009 PDR