

June 3, 1986

Docket No. 50-285

Mr. R. L. Andrews  
Division Manager - Nuclear Production  
Omaha Public Power District  
1623 Harney Street  
Omaha, Nebraska 68102

Dear Mr. Andrews:

DISTRIBUTION:

Docket File

NRC-PDR

L PDR

PBD#8 Rdg

JPartlow

PMKreutzer-3

DSells

OELD

LHarmon

Gray File +4

WRegan

LFMB

OPA

ACRS-10

FMiraglia

WJones

TBarnhart-4

BGrimes

EJordan

EButcher

The Commission has issued the enclosed Amendment No. 97 to Facility Operating License No. DPR-40 for the Fort Calhoun Station, Unit No. 1. This amendment consists of changes to the Technical Specifications in response to your application dated January 26, 1983.

The amendment transfers the recirculation heat removal system surveillance requirements from the containment test part of the TS to a new section of the TS entitled "Recirculation Heat Removal System Integrity Testing." The amendment also deletes containment related surveillance requirements that were in effect in early plant life and are no longer required or performed.

A copy of the Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's next regular bi-weekly Federal Register notice.

Sincerely,

/S/

Donald E. Sells, Project Manager  
PWR Project Directorate #8  
Division of PWR Licensing-B

Enclosures:

1. Amendment No. 97 to DPR-40
2. Safety Evaluation

cc w/enclosures:

See next page

\*See previous white for concurrences - PM name change only

PBD#8\*  
PMKreutzer  
2/26/86

PBD#8\*  
ETourigny  
3/3/86

PBD#8\*  
ATHadani  
3/3/86

OELD\*  
GSM  
5/14/86

8606110478 860603  
PDR ADOCK 05000285  
P PDR

Docket No. 50-285

Mr. R. L. Andrews  
Division Manager - Nuclear Production  
Omaha Public Power District  
1623 Harney Street  
Omaha, Nebraska 68102

Dear Mr. Andrews:

DISTRIBUTION:

|              |              |
|--------------|--------------|
| Docket File  | LTremper     |
| NRC & L PDRs | LFMB         |
| WRegan       | OPA          |
| PBD#8 Rdg    | ACRS-10      |
| FMiraglia    | JPartlow     |
| PMKreutzer-3 | WJones       |
| ETourigny    | TBarnhart-4  |
| OELD         | BGrimes      |
| SECY         | LHarmon      |
| EJordan      | Gray File +4 |

The Commission has issued the enclosed Amendment No. to Facility Operating License No. DPR-40 for the Fort Calhoun Station, Unit No. 1. This amendment consists of changes to the Technical Specifications in response to your application dated January 26, 1983.

The amendment transfers the recirculation heat removal system surveillance requirements from the containment test part of the TS to a new section of the TS entitled "Recirculation Heat Removal System Integrity Testing." The amendment also deletes containment related surveillance requirements that were in effect in early plant life and are no longer required or performed.

A copy of the Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's next regular bi-weekly Federal Register notice.

Sincerely,

E. G. Tourigny, Project Manager  
PWR Project Directorate #8  
Division of PWR Licensing-B

Enclosures:

1. Amendment No. to DPR-40
2. Safety Evaluation

cc w/enclosures:  
See next page

PBD#8:DL  
PMKreutzer  
2/1/86

PBD#8:DL  
ETourigny  
3/3/86

PBD#8:DL  
ATHadani  
1/86

OELD

5/14/86

WAX 7/15/86

Mr. R. L. Andrews  
Omaha Public Power District

Fort Calhoun Station  
Unit No. 1

cc:

Harry H. Voigt, Esq.  
LeBoeuf, Lamb, Leiby & MacRae  
1333 New Hampshire Avenue, NW  
Washington, D.C. 20036

Mr. Jack Jensen, Chairman  
Washington County Board  
of Supervisors  
Blair, Nebraska 68023

Metropolitan Planning Agency  
ATTN: Dagnia Prieditis  
7000 West Center Road  
Omaha, Nebraska 68107

Mr. Phillip Harrell, Resident Inspector  
U.S. Nuclear Regulatory Commission  
P. O. Box 309  
Fort Calhoun, Nebraska 68023

Mr. Charles B. Brinkman, Manager  
Washington Nuclear Operations  
C-E Power Systems  
7910 Woodmont Avenue  
Bethesda, Maryland 20814

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
Office of Executive Director  
for Operations  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011