



Gary R. Peterson
Vick President

Duke Power
Catawba Nuclear Station
4800 Concord Road
York, SC 29745
(803) 831-4251 OFFICE
(803) 831-3426 FAX

August 16, 1999

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Subject: Catawba Nuclear Station, Units 1 and 2
Docket Nos. 50-413 and 50-414
Licensee Event Report 413/99-011

Attached is Licensee Event Report 413/99-011 titled "Missed Surveillance on Both Trains of Control Room Area Ventilation System Resulted in a Technical Specification Violation Due to a Defective Procedure."

The planned corrective action stated in this report represents a regulatory commitment.

This event is considered to be of no significance with respect to the health and safety of the public. If there are any questions on this report, please contact L.J. Rudy at (803) 831-3084.

Sincerely,

Gary R. Peterson

Attachment

11
IE22

9908240288 990816
PDR ADOCK 05000413
S PDR

Document Control Desk
Page 2
August 16, 1999

xc (with attachment):

Mr. Luis A. Reyes
Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
61 Forsyth Street, S.W., Suite 23T85
Atlanta, GA 30303

Mr. Peter S. Tam
U.S. Nuclear Regulatory Commission
Mail Stop 08-H12
11555 Rockville Pike
Rockville, MD 20852-2738

Mr. Darrell J. Roberts
NRC Senior Resident Inspector
Catawba Nuclear Station

INPO Records Center
700 Galleria Place
Atlanta, GA 30339-5957

Marsh & McLennan, Inc.
Mr. Kenneth W. Gannaway
100 N. Tryon Street
Charlotte, NC 28202