



# Florida Power

CORPORATION  
Crystal River Unit 3  
Docket No. 50-302  
Operating License No. DPR-72

August 16, 1999  
3F0899-02

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555-0001

Subject: Crystal River Unit 3 Core Operating Limits Report, Cycle 11, Revision 2

Dear Sir:

Florida Power Corporation (FPC) hereby submits Revision 2 of the Cycle 11 Core Operating Limits Report (COLR) for Crystal River Unit 3 (CR-3). Revisions to the COLR are required to be submitted to the NRC upon issuance in accordance with CR-3 Improved Technical Specifications Section 5.6.2.18.

FPC did not previously submit Revision 1 of the Cycle 11 COLR due to an administrative error. The changes made in Revision 1 of the Cycle 11 COLR are incorporated in the attached revision and consisted of the following changes:

- Page 2 Added a reference to Revision 1 of the CR-3 Cycle 11 Reload Report (BAW-2262)
- Page 4 Added a clarification to the shutdown margin to reflect a reactor coolant system boration requirement for plant cooldown
- Page 24 Improved method for calculating the nuclear enthalpy rise hot channel factor by using an assembly specific approach

This letter establishes no new regulatory commitments. If you have any questions regarding this submittal, please contact Mr. Sid Powell, Manager, Nuclear Licensing at (352) 563-4883.

Sincerely,

Daniel L. Roderick  
Director, Nuclear Engineering & Projects

DLR/dah

9908250066 990816  
PDR ADOCK 05000302  
P PDR

Attachment

xc: Regional Administrator, Region II  
NRR Project Manager  
Senior Resident Inspector

1/1  
A001