



Duquesne Light

Nuclear Group
P.O. Box 4
Shippingport, PA 15077-0004

Telephone (412) 393-6000

February 10, 1987

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Reference: Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
Proposed Operating License Change Request No. 124

Gentlemen:

Enclosed are:


1. One (1) original and thirty-seven (37) copies of an Application for Amendment to our Operating License to revise the applicable radiation monitoring instrumentation setpoints in Table 3.3-6, revise the meteorological monitoring instrumentation in Table 3.3-8 to include both the primary and redundant instruments, and revise Action statements 27 and 29 in Table 3.3-13 to allow an alternative to grab sampling by providing for initiation of continuous monitoring by alternate monitoring equipment.

These changes have been reviewed by the OSC and ORC and have been determined to be safe and do not involve an unreviewed safety question.

2. Thirty-eight (38) copies of documents designated Attachments A and B which set forth the change in Technical Specifications and its no significant hazards determination.

A check in the amount of \$150.00 will be provided under separate cover as payment of the license amendment application fee in accordance with 10 CFR 170.

Very truly yours,


J. D. Sieber
Vice President, Nuclear

Attachment

8702200010 870210
PDR ADOCK 05000334
P PDR

1001
Add: NRR PWRA - AOTS *Ltr Encl* *1 1*

Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
Technical Specification Change No. 1A-124
Page 2

cc: Mr. W. M. Troskoski, Resident Inspector
U. S. Nuclear Regulatory Commission
Beaver Valley Power Station
Shippingport, PA 15077

U. S. Nuclear Regulatory Commission
Regional Administrator
Region 1
631 Park Avenue
King of Prussia, PA 19406

Mr. Peter S. Tam
U. S. Nuclear Regulatory Commission
Project Directorate No. 2
Division of PWR Licensing - A
Washington, DC 20555
- Mail Stop 340
Addressee only

Director, Safety Evaluation & Control
Virginia Electric & Power Company
P.O. Box 26666
One James River Plaza
Richmond, VA 23261