

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of )  
 ) Docket No. 50-334  
Duquesne Light Company )  
(Beaver Valley Power Station, Unit No. 1) )

APPLICATION FOR AMENDMENT  
TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the U.S. Nuclear Regulatory Commission (the "Commission"), Duquesne Light Company ("DLC"), holder of Operating License No. DPR-66, hereby requests that the Technical Specifications set forth in Appendix A to that license be amended by revising applicable radiation monitor instrumentation setpoints in Table 3.3-6, revise the meteorological monitoring instrumentation in Table 3.3-8 to include both the primary and redundant instruments, and revise Action statements 27 and 29 in Table 3.3-13 to allow an alternative to grab sampling by providing for initiation of continuous monitoring by alternate monitoring equipment.

The proposed technical specification change is set forth in Attachment A to this Application. A No Significant Hazard Evaluation is set forth in Attachment B. Based on the guidance provided by the Commission, the proposed changes have been determined to involve no significant hazards consideration in accordance with 10 CFR 50.92.

WHEREFORE, Applicant respectfully requests that Appendix A to Operating License No., DPR-66 be amended in the form attached hereto as Attachment A.

Duquesne Light Company

By J. D. Sieber  
J. D. Sieber  
Vice President, Nuclear

8702200016 870210  
PDR ADOCK 05000334  
P PDR

Subscribed and sworn to before me

on this 10th day of February, 1987

Sheila M. Fattore

SHEILA M. FATTORE, NOTARY PUBLIC  
SHIPPINGPORT BORO, BEAVER COUNTY  
MY COMMISSION EXPIRES OCT. 23, 1989  
Member, Pennsylvania Association of Notaries