

September 17, 1997

Mr. J. E. Cross
President - Generation Group
Duquesne Light Company
Post Office Box 4
Shippingport, PA 15077

SUBJECT: REVIEW OF BEAVER VALLEY POWER STATION, UNIT NO. 1 (BVPS-1) 1996
STEAM GENERATOR TUBE INSPECTION 90-DAY REPORT (TAC NO. M96250)

Dear Mr. Cross:

By letter dated August 2, 1996, as supplemented July 1, 1997, Duquesne Light Company (DLC) submitted a copy of the "Beaver Valley Unit 1, 1996 Alternate Repair Criteria 90 Day Report." The 90-day report was submitted to satisfy a commitment as a part of the NRC staff's approved voltage-based alternate repair criteria for the BVPS-1 technical specifications. The alternate repair criteria were implemented based on NRC Generic Letter (GL) 95-05, "Voltage-Based Repair Criteria for Westinghouse Steam Generator Tube Affected By Outside Diameter Stress Corrosion Cracking."

The NRC staff has reviewed the 90-day report for BVPS-1 and has concluded in the enclosure that the structural integrity analyses and data contained in the 90-day report are consistent with those specified in GL 95-05. This completes our effort for TAC No. M96250.

Sincerely,

Original signed by Tilda Liu for
Donald S. Brinkman, Senior Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-334

Enclosure: Review of BVPS-1 Steam Generator
90-Day Report

cc w/encl: See next page

DISTRIBUTION:

~~Docket File~~

PUBLIC

PDI-2 Reading

BBoger

DBrinkman

TLiu

CBeardslee

THarris (SE only)

MO'Brien

OGC

PEselgroth, RI

JStolz

JTsao

ACRS

NRC FILE CENTER COPY

OFFICE	PDI-2/PM	PDI-2/LA	PDI-2/D
NAME	DBrinkman:cw	MO'Brien	JStolz
DATE	9/11/97	9/10/97	9/17/97

OFFICIAL RECORD COPY

DOCUMENT NAME: BV96250.RPT

9709290254 970917
PDR ADDCK 05000334
P PDR





UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-4001

September 17, 1997

Mr. J. E. Cross
President - Generation Group
Duquesne Light Company
Post Office Box 4
Shippingport, PA 15077

SUBJECT: REVIEW OF BEAVER VALLEY POWER STATION, UNIT NO. 1 (BVPS-1) 1996
STEAM GENERATOR TUBE INSPECTION 90-DAY REPORT (TAC NO. M96250)

Dear Mr. Cross:

By letter dated August 2, 1996, as supplemented July 1, 1997, Duquesne Light Company (DLC) submitted a copy of the "Beaver Valley Unit 1, 1996 Alternate Repair Criteria 90 Day Report." The 90-day report was submitted to satisfy a commitment as a part of the NRC staff's approved voltage-based alternate repair criteria for the BVPS-1 technical specifications. The alternate repair criteria were implemented based on NRC Generic Letter (GL) 95-05, "Voltage-Based Repair Criteria for Westinghouse Steam Generator Tube Affected By Outside Diameter Stress Corrosion Cracking."

The NRC staff has reviewed the 90-day report for BVPS-1 and has concluded in the enclosure that the structural integrity analyses and data contained in the 90-day report are consistent with those specified in GL 95-05. This completes our effort for TAC No. M96250.

Sincerely,

A handwritten signature in cursive script, appearing to read "Donald S. Brinkman".

Donald S. Brinkman, Senior Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-334

Enclosure: Review of BVPS-1 Steam Generator
90-Day Report

cc w/encl: See next page

J. E. Cross
Duquesne Light Company

Beaver Valley Power Station
Units 1 & 2

cc:

Jay E. Silberg, Esquire
Shaw, Pittman, Potts & Trowbridge
2300 N Street, NW.
Washington, DC 20037

Director-Safety and Licensing
Department (BV-A)
Duquesne Light Company
Beaver Valley Power Station
PO Box 4
Shippingport, PA 15077

Commissioner Roy M. Smith
West Virginia Department of Labor
Building 3, Room 319
Capitol Complex
Charleston, WVA 25305

Director, Utilities Department
Public Utilities Commission
180 East Broad Street
Columbus, OH 43266-0573

Director, Pennsylvania Emergency
Management Agency
Post Office Box 3321
Harrisburg, PA 17105-3321

Ohio EPA-DERR
ATTN: Zack A. Clayton
Post Office Box 1049
Columbus, OH 43266-0149

Dr. Judith Johnsrud
National Energy Committee
Sierra Club
433 Orlando Avenue
State College, PA 16803

Duquesne Light Company
Beaver Valley Power Station
PO Box 4
Shippingport, PA 15077
ATTN: R. L. Grand, Division Vice
President, Nuclear Operations Group
and Plant Manager (BV-SOSB-7)

Bureau of Radiation Protection
Pennsylvania Department of
Environmental Resources
ATTN: Michael P. Murphy
Post Office Box 2063
Harrisburg, PA 17120

Mayor of the Borough of
Shippingport
Post Office Box 3
Shippingport, PA 15077

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Resident Inspector
U.S. Nuclear Regulatory Commission
Post Office Box 298
Shippingport, PA 15077

Duquesne Light Company
Beaver Valley Power Station
PO Box 4
Shippingport, PA 15077
ATTN: S. C. Jain, Vice President
Nuclear Services (BV-A)