

Docket No.: 50-368

OCT 23 1986

Mr. T. Gene Campbell
Vice President
Nuclear Operations
Arkansas Power & Light Company
Post Office Box 551
Little Rock, Arkansas 72203

Dear Mr. Campbell:

SUBJECT: EMERGENCY RESPONSE CAPABILITY - REGULATORY GUIDE 1.97

The Commission has completed the review of your responses dated April 13, 1984 and July 1, 1985 pertaining to the above subject matter for the Arkansas Nuclear One, Unit 2. Our evaluation concludes that your responses are acceptable. However, there are two items for which we do not have adequate information. The two items relate to the instrument range of the reactor coolant system pressure instrumentation and the lack of instrumentation to monitor containment sump water temperature. We request that you provide the additional information to resolve our concerns detailed in our Safety Evaluation related to the above-stated items within 60 days of receipt of this letter. Our Safety Evaluation with attached Technical Evaluation Report is enclosed.

The reporting and/or recordkeeping requirements contained in this letter affect fewer than ten respondents. Therefore, OMB clearance is not required under P.L. 96-511.

Please contact us if you have any questions concerning this letter.

Sincerely,

151

Robert S. Lee, Project Manager
PWR Project Directorate No. 7
Division of PWR Licensing-B

Enclosure:
As stated

8611030204 861023
PDR ADOCK 05000368
P PDR

cc: See next page

DISTRIBUTION:

Docket File ✓	F. Miraglia	J. Partlow
NRC PDR	OGC-Bethesda	N. Thompson
LPDR	E. Jordan	R. Lee
PD7 Reading	B. Grimes	J. Lee
		ACRS (10)

PRD7
Lee
10/22/86

PRD7
for Lee
10/22/86

D:PRD7
GWKnighton
10/23/86

Jean Lee concurred
to the previous one.

Mr. T. Gene Campbell
Arkansas Power & Light Company

Arkansas Nuclear One
Unit No. 2

cc:

Mr. J. Ted Enos, Manager
Nuclear Engineering and Licensing
Arkansas Power and Light Company
P. O. Box 551
Little Rock, Arkansas 72203

Mr. Charlie B. Brinkman, Manager
Washington Nuclear Operations
C-E Power Systems
7910 Woodmont Avenue
Suite 1310
Bethesda, Maryland 20814

Mr. James M. Levine, Director
Site Nuclear Operations
Arkansas Nuclear One
P. O. Box 608
Russellville, Arkansas 72801

Nicholas S. Reynolds, Esq.
Bishop, Liberman, Cook,
Purcell & Reynolds
1200 Seventeenth Street, N.W.
Suite 700
Washington, D.C. 20036

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Office of Executive Director for
Operations
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 2090
Russellville, Arkansas 72801

Mr. Frank Wilson, Director
Division of Environmental Health
Protection
Arkansas Department of Health
4815 West Markam Street
Little Rock, Arkansas 72201

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 22C
7910 Woodmont Avenue
Bethesda, Maryland 20814