

. ...

June 5, 1986

Public Service of New Hampshire

SBN- 1091 T.F. 02.2.2

NEW HAMPSHIRE YANKEE DIVISION

United States Nuclear Regulatory Commission Region I 631 Park Avenue King of Prussia, PA 19406

Attention:

Mr. Richard W. Starostecki, Director Division of Project and Resident Programs

References:

- (a) Construction Permits CPPR-135 and CPPR-136, Docket Nos. 50-443 and 50-444
- (b) Telecon of July 14, 1983, A. L. Legendre (YAEC) to Eugene Kelley (NRC, Region I)
- (c) PSNH Letter (SBN-669), dated June 19, 1984, "Interim 10CFR50.55(e) Report: Service Air System NNS Supports", J. DeVincentis to R. W. Starostecki

Subject:

Final 10CFR50.55(e) Report: Service Air System NNS Supports (CDR 83-00-14)

Dear Sir:

In Reference (b), we reported a potential 10CFR50.55(e) deficiency regarding supports for the Service Air System and other systems which carry a Non-Nuclear Safety (NNS) designation. Because of the proximity to safety-related equipment, the proper classification should have been Non-Nuclear Seismic (NNS-1), whereby the structural integrity of a support during seismic/operating event is assured.

The following corrective action for all pipe supports that did not meet NNS-1 pipe support criteria has been completed:

1. All affected lines were reviewed to determine whether the supports should be NNS or NNS-1. Basic criteria used in this review was to avoid any adverse impact on the safety related systems, components or structures.

8606230498 860605 PDR ADDCK 05000443

- 2. Pipe analysis was reviewed and/or revised using the latest available design information such as ARS, field change etc., to assure that the stresses are within the allowable limits. New support loads were generated when reanalysis was required.
- 3. Support designs were reviewed using the following information:
 - Latest loads and classification based on piping analysis and review.
 - b) All change documents.
- 4. Where required, the support classification was changed, support modifications were made, and drawings were issued for construction.

As such, this is considered our final report on this item.

Very truly yours,

John DeVincentis

Director of Engineering

cc: Atomic Safety and Licensing Board Service List

Director, Office of Inspection and Enforcement United States Nuclear Regulatory Commission Washington, DC 20555 Diane Curran, Esquire Harmon & Weiss 2001 S. Street, M.W. Suite 430 Washington, D.C. 20009 -

Sherwin E. Turk, Esq.

Office of the Executive Legal Director

U.S. Buclear Regulatory Commission

Tenth Floor

Washington, DC 20555

Robert A. Backus, Esquire 116 Lowell Street P.O. Box 516 Manchester, MH 03105

Philip Ahrens, Esquire Assistant Attorney General Department of The Attorney General Statehouse Station #6 Augusta, ME 04333

Mrs. Sandra Gavutis Chairman, Board of Selectmen RFD 1 - Box 1154 Kennsington, WH 03827

Carol S. Sneider, Esquire Assistant Attorney General Department of the Attorney General One Ashburton Place, 19th Floor Boston, MA 02108

Senator Gordon J. Humphrey U.S. Senate Washington, DC 20510 (ATTW: Tom Burack)

Richard A. Hampe, Esq. Hampe and McWicholas 35 Pleasant Street Concord, MH 03301

Donald E. Chick Town Manager Town of Exeter 10 Front Street Exeter, EH 03833

Brentwood Board of Selectmen RFD Dalton Road Brentwood, WH 03833

Peter J. Mathews, Mayor City Hall Newburyport, MA 01950 Calvin A. Canney City Manager City Hall 126 Daniel Street Portsmouth, NH 03801

Stephen E. Merrill, Esquire Attorney General George Dana Bisbee, Esquire Assistant Attorney General Office of the Attorney General 25 Capitol Street Concord, NH 03301-6397

Mr. J. P. Wedeau Selectmen's Office 10 Central Road Rye, WH 03870

Mr. Angle Machiros Chairman of the Board of Selectmen Town of Newbury Newbury, MA 01950

Mr. William S. Lord Board of Selectmen Town Hall - Friend Street Amesbury, MA 01913

Senator Gordon J. Humphrey 1 Pillebury Street Concord, WH 03301 (ATTN: Herb Boynton)

H. Joseph Flynn, Esquire
Office of General Counsel
Federal Emergency Hanagement Agency (
500 C Street, SW
Washington, DC 20472

Paul McEachern, Esquire Matthew T. Brock, Esquire Shaines & McEachern 25 Maplewood Avenue P.O. Box 360 Portsmouth, EM 03801

Gary W. Holmes, Esq. Holmes & Ells 47 Winnacunnet Road Hampton, WH 03841

Mr. Ed Thomas FEMA Region I 442 John W. McCormack PO & Courthouse Boston, MA 02109

Stanley W. Knowles, Chairman Board of Selectmen P.O. Box 710 North Hampton, NH 03862