

Arkansas Nuclear One (ANO) Units 1 & 2

10 CFR 50.69 License Amendment Request NRC Pre-submittal Meeting

August 4, 2020



Agenda

- ✓ Introduction/Opening Remarks
- ✓ ANO 10 CFR 50.69 Overview
 - ✓ PRA Technical Adequacy
 - ✓ Deviations from NEI 00-04
 - ✓ Extreme Wind or Tornado
 - ✓ Seismic Hazard
 - ✓ Passive Categorization
- ✓ Schedule
- ✓ Closing Remarks

ANO 10 CFR 50.69 Overview

- ✓ LAR and Program follow NEI 00-04 (exceptions noted on later slides)
- ✓ Standard approval timeframe requested (12 to 15 months)

PRA Technical Adequacy

- ✓ Internal Events (Including Flooding and Fire)
 - ✓ Probabilistic Risk Assessment (PRA) model technical adequacy previously evaluated by the NRC for TSTF-425 and NFPA 805.
 - ✓ Facts & Observations (F&O) closure peer reviews performed in accordance with the NEI 05-04 Appendix X approach in 2019.
 - ✓ Additional updates/upgrades have been peer reviewed. A Flood and LERF Peer Review was conducted in 2017 and 2019, respectively.
 - ✓ Changes to the as-built, as-operated plant are reviewed periodically to determine if model impacts require an off-cycle update.
 - ✓ Sensitivity studies will be performed in accordance with NEI 00-04 for areas such as Human Reliability Analysis (HRA) and Common Cause Failures (CCF).
 - ✓ Additional sensitivity studies will be performed to address applicable uncertainties associated with specific system(s) being categorized.

PRA Uncertainty Evaluation

- ✓ Process Defined in NUREG-1855 Revision 1 and EPRI Technical Reports 1016737 and 1026511
 - ✓ Identification of internal events/internal flooding PRA model plant-specific sources, and generic sources per EPRI 1016737
 - ✓ Identification of internal fire PRA model plant-specific sources, and generic sources per Appendix B of EPRI 1026511.
 - ✓ Consideration of generic Level 2 model sources per Appendix E of EPRI 1026511, as applicable to LERF.
 - ✓ Consideration of Parameter and Completeness uncertainties
 - ✓ Documented in Sources of Uncertainty Reports / Model Notebooks
- ✓ NEI 00-04 specifies sensitivity studies to be conducted for each PRA model to address key sources of uncertainty.
 - ✓ Human Error, Common Cause, Maintenance, Fire Suppression

- ✓ FLEX Feed Pump
 - ✓ Internal Events - Credited in Unit 1 for extended loss of AC power (ELAP) cases
 - ✓ Internal Events - Not Credited in Unit 2 (will be credited in future model)
 - ✓ Fire - Not Credited in either unit

- ✓ FLEX portable DG
 - ✓ Internal Events – Not Credited.
 - ✓ Fire – Credited for long term DC power for Unit 2 ELAP
 - ✓ Fire - Not Credited in Unit 1


Incipient Detection

- ✓ Very Early Warning Fire Detection System (VEWFDS)
 - ✓ Installed in Unit 2 Only
 - ✓ Installed in Key Electrical Cabinets
 - ✓ Procedures Established to Address System Operation and Response
 - ✓ Credit in the Fire PRA removed during NFPA-805 Approval Process given NUREG 2180 was not published

Deviations from NEI 00-04

- ✓ Tornado Safe Shutdown Equipment List (TSSEL)
 - ✓ ANO1/2 will use a Tornado Safe Shutdown Equipment List (TSSEL) for extreme wind or tornado hazard (missiles only)
 - ✓ Tornado Safe Shutdown paths developed to identify the safety functions and associated sets of equipment credited to achieve and maintain safe shutdown
 - ✓ Similar to Seismic Margins Analysis (SMA) SSEL approach - High Safety Significant (HSS) components are identified by determining if the component is credited on the TSSEL.
 - ✓ ANO1/2 will ensure that the TSSEL reflects the as built as operated plant.
 - ✓ As stated in NEI 00-04, a structure, system, or component (SSC) identified as HSS by a non-PRA method for external events “may not be re-categorized by the IDP.”

Deviations from NEI 00-04



Deviations from NEI 00-04

Seismic Justification Referencing EPRI 3002017583

- ✓ ANO1/2 will reference EPRI 3002017583 for seismic considerations in the categorization process.
- ✓ ANO1/2 will document justification for being a “Tier 2 Plant” and provide justification to the integrated decision-making panel (IDP).
- ✓ Conclusions and results from existing seismic studies and walkdowns, as they apply to the system being categorized, will be included in information provided to the IDP.
- ✓ ANO1/2 will follow the guidance for the lead Tier 2 plant, LaSalle.

Deviations from NEI 00-04

- ✓ Passive components and the passive function of active components will be evaluated using the ANO Risk-Informed Repair/Replacement Activities (RI-PRA) method.
- ✓ The use of this method was previously approved by the NRC in the Vogtle 10 CFR 50.69 application.
- ✓ ASME Code Class 1 SSCs with a pressure retaining function, as well as supports, will be assigned as HSS for passive categorization. This will result in HSS for its risk-informed safety classification and cannot be changed by the IDP.

Schedule

- LAR Submittal expected by end of September 2020
- Standard approval timeframe requested (12 to 15 months)



Closing Remarks