DATE: 10/02/97 TIME: 09:05:14

## UNION ELECTRIC COMPANY CALLAWAY RECORDS INFORMATION SYSTEM REPORT: ARCP7301 CALC COVER SHEET

PAGE: 0

RECORD NUMBER: KJ-08

EVISION: 000

A170.0166/2090 CALCULATIONS - UNION ELECTRIC

VENDOR: U050-UNION ELECTRIC COMPANY

CALC TITLE AND DESCRIPTION:

RECALCULATION OF ANTICIPATED RUNNING TIME TO ACCOUNT FOR THE USE OF 139 DEGREES F. IN PLACE OF THE ORIGINALLY REPORTED 137 DEGREES F. THIS CALCULATION WILL DOCUMENT THAT THE DIESEL GENERATOR EQUIPMENT CAN BE EXPECTED TO SUCESSFULLY RUN FOR 720 HOURS (30 DAYS) IN AN AMBIENT TEMPERATURE OF 139 DEGREES F. WITHOUT ENVIRONMENTALLY INDUCED FAILURE.

EASYLIPMANING PROPERTY CHANGE
December of Residence
And the state of t
CONTROL OF CHARACTER STREET, S
Action of the second se
environment and y section and annual and a section of the section of section and section a
AND RESIDENCE AND PROPERTY OF THE PROPERTY OF
AND THE PERSON OF THE PERSON O
STREET, STREET
A ATTENDED THE PERSON NAMED IN
THE SECRETARY VALUE OF THE
AND A SECURITY OF THE PARTY OF
MARKATAN AND PRINCIPLE CONTRACTOR
CALLE THE ADMINISTRATION MANAGEMENT
CONCRETE TO PROPER AND ADDRESS OF
APPROVED PROF CATALOGUES
REPORTED AND VALUE OF THE PARTY OF THE PARTY.

RESP ENGR: Kold of Main	DATE:	10/2/97
REVIEWED BY: Lyoy O. Sellmys	DATE:	10-2-97
		10/2/47

TOTAL PAGES:

(COMPLETED BY: ADMIN DEPT)

DATE: 10//2/97

## UNION ELECTRIC COMPANY TIME: 09:05:15 UNION ELECTRIC COMPANY CALLAWAY RECORDS INFORMATION SYSTEM KJ-08 DATA SHEET

PAGE:

REPORT: ARCP2191

UPDATE INFO: SL24737 19971002 09:04:51:9

RECORD TYPE: C090 RETENTION: PURGE DATE: 0 GENERATION PERIOD: OP II-NUMBER: A170.0166/C090 BARCODE: C090KJ08/000 STATUS: 50-DEPT INITIATED

(R) FILE NUMBER

: A170.0166

(R) RECORD NUMBER

: KJ-08

(R) REVISION NUMBER

: 000

(R) FROM RECORD DATE

19971002

(F) DATE TYPE CODE I-INITIATED DATE

(R) PLANT PROGRAM : DB

(R) KEYWORD

: QUALIFICATION

(R) DISCIPLINE : E

(R) SITE APPLICABILITY : 2-CALLAWAY

(R) DESCRIPTION

RECALCULATION OF ANTICIPATED RUNNING TIME TO ACCOUNT FOR THE USE OF 139 DEJREES F. IN PLACE OF THE ORIGINALLY REPORTED 137 DEGREES F. THIS CALCULATION WILL DOCUMENT THAT THE DIESEL GENERATOR EQUIPMENT CAN BE EXPECTED TO SUCESSFULLY RUN FOR 720 HOURS (30 DAYS) IN AN AMBIENT TEMPERATURE OF 139 DEGREES F. WITHOUT ENVIRONMENTALLY INDUCED FAILURE.

(R) MEDIA LOCATION : DEPT (R) MEDIA : N-NUMBERING LOG

COMPONENT NUMBER : KKJ01A

NE01 NE106 KJ121

KKJ01B NE02 NE107 KJ122

(R) SYSTEM

: KJ NE

COMPUTER CODE :

REFERENCE TYPE
DRAW D350
DRAW D350 DRAW D350 M-018-00822
DRAW D350 M-018-00823
DRAW D350 M-018-00824
DRAW D350 M-018-00825

REFERENCE NUMBER M-018-00821 M-018-00822

REF REV REFERENCE ATTACHED 001 003 003 003

(R) NAME

HAINES ROBERT G

(R) ORG/VENDOR CODE : U050 UNION ELECTRIC

The areas where the Emergency Diesel Generators are installed are defined as "Mild Environment per the requirements of 10-CFR-50.49. Therefore, the individual pieces of equipment which makes up the Emergency Diesel Generator System are not included within the scope of "Harsh Environment" items covered by 10-CFR-50.49 and the qualified lives established by the vendor environmental qualification reports are not absolute. The qualified lives established by the vendor have been incorporated into the licencee's maintanance and surveillance programs to establish a defined 'working life'. The data contained within the vendor qualification report has been reviewed and the expected running time of 10,512 hours recalculated to account for the 1.2°C temperature difference between 137°F and 139°F. As documented below, for all devices that had a calculated life of less than 40 years, the recalculated running hours at the higher temperature ranged from 8989.1 to 9675.4 hours. This running time exceeds the required 720 hours (30 days) by a factor greater than 10.

The following formula was used to recalculate the resulting running hours.

t, = Original Required Test Time

E = Activation Energy

k = Boltzmans constant

T, = New Running Temperature

T<sub>2</sub> = Original Test Temperature

## Recalculated running time using 139°F.

Component Name Article Number	Recalculated Running Hours	t1 k	E	T1	T2	Percentage Change
Governor Actuator Solenoid I.A.1	9415.6	3042 8.617E-05	1.05	378	365.2	-10.4%
Governor Control Box I.A.2	9626.1	1370	0.77	378	349.2	-8.4%
Rocker Arm Lube Oil Level High Level Switch I.A.4.c	9670.9	1524	0.75	383	354.2	-8.0%
Engine Overspeed Limit Switch I.A.5.a	9572.3	433	0.75	378	333.2	-8.9%
Barring Device Upper Limit Switch I.A.5.b	9668.9	2058	0.75	378	354.2	-8.0%
Barring Device Lower Limit Switch I.A.5.c	9668.9	2058	0.75	378	354.2	-8.0%
Motor Operated Potentioneter I.A.6	9539.9	530	0.8	378	338.2	-9.2%
Crankcase ;-2" WC Pressure Switch I A.8.a	9452.8	297	0.86	378	334.2	-10.1%
Tube Oil Pressure Low Pressure Switch I.A.B.b	9549.9	1620	0.86	378	354.2	-9.2%
Lube Oil Pressure Low Pressure Switch I.A.8.c	9549.9	1620	0.86	378	354.2	-9.2%
Lube Oil Pressure Low Pressure Switch I.A.8.d	9549.9	1620	0.86	378	354.2	-9.2%

Recalculated running time using 139°F.

Lube Oil Pressure Low Pressure Switch I.A.8.e	9549.9	1620	0.86	378	354.2	-9.2%
Relay, Tachometer I.A.9	9675.4	2662	0.68	358	338.2	-8.0%
Signal Generator I.A.10	9543.9	591	0.86	393	354.2	-9.2%
Right Bank Air Start Solenoid Valve I.A.ll.a	9552.3	7083	0.86	358	354.2	-9.1%
Left Bank Air Start Solenoid Valve I.A.11.b	9552.3	7083	0.86	358	354.2	-9.1%
Engine Shutdown Solenoid Valve I.A.11.c	9552.3	7083	0.86	358	354.2	-9.1%
Ratio 1500 o 5 Current Transformer I.A.14	9666.5	6492	0.9	393	387.2	-8.0%
Shielded 2 Conductor Wire I.B.10.a	9419.3	103	1.04	423	365.2	-10.4%
Shielded 3 Conductor Wire I.B.10.b	9419.3	103	1.04	423	365.2	-10.4%
#2 AWG 7 Strand Wire I.B.10.c	9419.3	103	1.04	423	365.2	-10.4%
#6 AWG 7 Strand Wire I.B.10.d	9419.3	103	1.04	423	365.2	-10.4%
#8 AWG 7 Strand Wire I.B.10.e	9419.3	103	1.04	423	365.2	-10.4%
#8 AWG Wire I.B.10.f	8989.1	23	1.13	438	365.2	-14.5%
#14 AWG 41 Strand Wire I.B.10.g	9419.3	103	1.04	423	365.2	-10.4%

## OVERSIZE ODOCUMENT PAGE(S) PULLED

SEE APERTURE CARD FILES