Docket No.: 50-219

Mr. P. B. Fiedler Vice President & Director Oyster Creek Nuclear Generating Station Post Office Box 388 Forked River, New Jersey 08731

Dear Mr. Fiedler:

SUBJECT: OYSTER CREEK NUCLEAR GENERATING STATION IPSAR SECTION 4.22.2 REMOTE MANUAL VALVES

In Section 4.22.2 of the Integrated Plant Safety Assessment Report (IPSAR) for Oyster Creek, NUREG-0822, the staff raised an issue regarding lines with remote manual isolation valves. Operator action is required to isolate such lines (if a significant leak or break occurs); therefore, leakage detection capability, accessible location for valve controls and suitable procedures are needed. As discussed in the enclosed safety evaluation, the staff concludes that the existing plant design with the proposed procedural revisions are adequate to resolve this issue.

Sincerely,

Original signed by: J. Zwolinski

John A. Zwolinski, Director BWR Project Directorate #1 Division of BWR Licensing

Enclosure: As Stated

cc: See Next Page

DISTRIBUTION
Docket File
ISAP Reading
NRC PDR
Local PDR
F. Miraglia
NSIC
OGC-Bethesda
E. Jordan

B. Grimes
J. Partlow
E. McKenna
P. Anderson
ACRS (10)
J. Zwolinski
C. Grimes
J. Donohew

C. Jamerson(3)

PD#1: DPL-A ISAPD: DRL-B EMCKENNA (mn 8/13/86 ISAPD: DPL-B CGrimes 4/5/86

BWCM OBL JOdnonew 8 14 /86

BWR#1:DBL JZwolinski 8/20/86



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

August 20, 1986

Docket No.: 50-219

Mr. P. B. Fiedler Vice President & Director Oyster Creek Nuclear Generating Station Post Office Box 388 Forked River, New Jersey 08731

Dear Mr. Fiedler:

SUBJECT: OYSTER CREEK NUCLEAR GENERATING STATION -

IPSAR SECTION 4.22.2 REMOTE MANUAL VALVES

In Section 4.22.2 of the Integrated Plant Safety Assessment Report (IPSAR) for Oyster Creek, NUREG-0822, the staff raised an issue regarding lines with remote manual isolation valves. Operator action is required to isolate such lines (if a significant leak or break occurs); therefore, leakage detection capability, accessible location for valve controls and suitable procedures are needed. As discussed in the enclosed safety evaluation, the staff concludes that the existing plant design with the proposed procedural revisions are adequate to resolve this issue.

Sincerely,

John A. Zwolinski, Director BWR Project Directorate #1 Division of BWR Licensing

Enclosure: As Stated

cc: See Next Page

Mr. P. B. Fiedler Oyster Creek Nuclear Generating Station

cc: G. F. Trowbridge, Esquire Shaw, Pittman, Potts and Trowbridge 1800 M Street, N.W. Washington, D.C. 20036

J.B. Liberman, Esquire Bishop, Liberman, Cook, et al. 1155 Avenue of the Americas New York, New York 10036

Regional Administrator, Region I U.S. Nuclear Regulatory Commission 631 Park Avenue King of Prussia, Pennsylvania 19406

BWR Licensing Manager GPU Nuclear 100 Interpace Parkway Parsippany, New Jersey 07054

Deputy Attorney General State of New Jersey Department of Law and Public Safety 36 West State Street - CN 112 Trenton, New Jersey 08625

Mayor Lacey Township 818 West Lacey Road Forked River, New Jersey 08731

D. G. Holland Licensing Manager Oyster Creek Nuclear Generating Station Post Office Box 388 Forked River, New Jersey 08731 Oyster Creek Nuclear Generating Station

Resident Inspector c/o U.S. NRC Post Office Box 445 Forked River, New Jersey 08731

Commissioner New Jersey Department of Energy 101 Commerce Street Newark, New Jersey 07102

Eugene Fisher, Assistant Director Division of Environmental Quality Department of Environmental Protection 380 Scotch Road Trenton, New Jersey 08628