

TEXAS UTILITIES GENERATING COMPANY

SKYWAY TOWER - 400 NORTH OLIVE STREET, L.B. 81 - DALLAS, TEXAS 75201

January 26, 1987

WILLIAM G. COUNSIL
EXECUTIVE VICE PRESIDENT

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446
POLAR CRANE SUPPORT STRUCTURE
SDAR: CP-86-62 (INTERIM REPORT)

Dear Mr. Johnson:

On October 3, 1986, we notified you by our letter logged TXX-6011 of a deficiency involving a misinterpretation of the polar crane load cases which we deemed reportable under the provisions of 10CFR50.55(e). We have submitted an interim report logged TXX-6177, dated December 19, 1986. This is an interim report submitted to status corrective action implemented to date.

In the last interim report, we concluded that reduced loading exists for the polar crane support structure. An analysis of the acceptability of the crane rail structure for these reduced loads is currently under joint evaluation with the third party reviewers.

We anticipate submitting our next report no later than March 30, 1987.

Very truly yours,

W. G. Council
W. G. Council

RWH/dl

c - Mr. Eric H. Johnson, Region IV
Mr. D. L. Kelley, RI - Region IV
Mr. H. S. Phillips, RI - Region IV

8702020437 870126
PDR ADOCK 05000445
PDR

IE 27
1/0