

Alabama Power Company
600 North 18th Street
Post Office Box 2641
Birmingham, Alabama 35291-0400
Telephone 205 250-1835

86 NOV 17 All : 38



Alabama Power
the southern electric system

R. P. McDonald
Senior Vice President

November 12, 1986

Docket Nos. 50-348
50-364

U. S. Nuclear Regulatory Commission
Region II, Suite 2900
101 Marietta Street N. W.
Atlanta, GA 30323

Attention: Dr. J. N. Grace

Gentlemen:

Joseph M. Farley Nuclear Plant - Units 1 and 2
IE Compliance Bulletin No. 86-03, Potential Failure
of Multiple ECCS Pumps Due to Single Failure of
Air-Operated Valve in Minimum Flow Recirculation Line

IE Compliance Bulletin 86-03 dated October 8, 1986 requested that a report be provided to the NRC on the single-failure vulnerability of the ECCS pump minimum flow recirculation line. It has been determined that no such vulnerability exists at Farley Nuclear Plant.

If you have any questions, please advise.

Respectfully submitted,

R. P. McDonald

RPM/JAR:kpc-D-T.S.6

cc: Mr. L. B. Long
Mr. L. S. Rubenstein
Mr. E. A. Reeves
Mr. W. H. Bradford
Mr. J. M. Taylor
US Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

SWORN TO AND SUBSCRIBED BEFORE ME

THIS 12th DAY OF November, 1986

James A. Hipple
Notary Public

My Commission Expires: 9-11-88

8612010091 861112
PDR ADOCK 05000348
Q PDR

IE11
110
#001