

DUKE POWER COMPANY

P.O. BOX 33189

CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

May 19, 1987


U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Subject: Oconee Nuclear Station, Unit 3
Docket Nos. 50-287
OTSG Tube Plugging

Gentlemen:

Pursuant to Oconee Nuclear Station Technical Specification 4.17.6(a), Duke Power Company is providing the following information concerning the Oconee Unit 3 steam generators. The steam generator plugging for the current Unit 3 outage was completed on April 29, 1987. The "A" OTSG had a total of eight (8) tubes removed from service by plugging.

Very truly yours,



Hal B. Tucker

PJN/172/jgm

xc: Dr. J. Nelson Grace, Regional Administrator
U.S. Nuclear Regulatory Commission - Region II
101 Marietta Street, NW, Suite 2900
Atlanta, GA. 30323

Ms. Helen Pastis
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. J.C. Bryant
NRC Resident Inspector
Oconee Nuclear Station

8705270590 870519
PDR ADOCK 05000287
P PDR

ADOC
1/0