



Log # TXX-6455
File # 10110
908.3
Ref # 10CFR50.55(e)

William G. Counsil
Executive Vice President

May 20, 1987

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446
TRACEABILITY OF 1E PIGTAIL EXTENSIONS
SDAR: CP-86-38 (INTERIM REPORT)

Gentlemen:

On May 27, 1986, we verbally notified your Mr. T. F. Westerman of a deficiency involving the failure of project procedures to adequately address the installation and inspection criteria for cable runs used as device pigtail extensions. This is an interim report of a potentially reportable item under the provisions of 10CFR50.55(e). Our latest interim report, logged TXX-6256 was submitted on February 4, 1987.

The Unit 1 field verification effort to obtain cable and splice data is complete. The evaluation of the as-built data for Unit 1 and our assessment of safety significance is scheduled to be completed by September 10, 1987.

A field verification program for Unit 2 will be performed in the same manner as the program implemented for Unit 1. This effort is scheduled to begin in July, 1987, and be completed in March, 1988.

Our next report on this issue will be submitted no later than October 5, 1987.

Very truly yours,

W. G. Counsil

W. G. Counsil

By:

G. S. Keeley

G. S. Keeley
Manager, Nuclear Licensing

RSB/mlh

c - Mr. R. D. Martin - Region IV
Mr. D. L. Kelley, RI - Region IV
Mr. H. S. Phillips, RI - Region IV

8705280033 870520
PDR ADOCK 05000445
S PDR

IR27
1/0