


Mailing Address

Alabama Power Company
600 North 18th Street
Post Office Box 2641
Birmingham, Alabama 35291
Telephone 205 783-6090

R. P. McDonald
Senior Vice President
Flintridge Building

August 8, 1986



Docket Nos. 50-348
50-364

U. S. Nuclear Regulatory Commission
Region II, Suite 2900
101 Marietta Street N. W.
Atlanta, GA 30323

Attention: Dr. J. N. Grace

Gentlemen:

Joseph M. Farley Nuclear Plant - Units 1 and 2
IE Bulletin No. 86-02, Static "O" Ring (SOR)
Differential Pressure Switches

By letter of July 25, 1986, Alabama Power Company committed to providing the final results of its investigation into the use of SOR Model 102 and 103 differential pressure switches at Farley Nuclear Plant. This investigation has been concluded with the determination that none of these switches have been installed at Farley Nuclear Plant. Therefore, no special test or reports are required.

If you have any questions, please advise.

Respectfully submitted,

R. P. McDonald

RPM/JAR:dst-D-T.S.5

cc: Mr. L. B. Long
Mr. L. S. Rubenstein
Mr. E. A. Reeves
Mr. W. H. Bradford
Mr. J. M. Taylor
U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

SWORN TO AND SUBSCRIBED BEFORE ME

THIS 8th DAY OF August, 1986

James A. Rygle
Notary Public

My Commission Expires: 9-11-88

8608150053 860808
PDR ADOCK 05000348
Q PDR

IE11
10