

PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

(215) 841-5001

JOSEPH W. GALLAGHER
VICE PRESIDENT
NUCLEAR OPERATIONS

Mr. W. R. Butler, Director
Project Directorate I-2
Division of Reactor Projects I/II
U.S. Nuclear Regulatory Commission
ATTENTION: Document Control Desk
Washington, DC 20555

May 20, 1987
Docket No. 50-352

SUBJECT: Limerick Generating Station Unit 1

REFERENCES: 1) January 30, 1987 Application for Amendment
of Facility Operating License NPF-39
2) Letter, J. W. Gallagher to W. R. Butler,
dated March 27, 1987
3) Letter, J. W. Gallagher to W. R. Butler,
dated May 13, 1987

Dear Mr. Butler:

The Reference 1) Application for Amendment relates to a change in the allowable control room leakage during the operation of the Control Room Emergency Fresh Air Supply (CREFAS). References 2) and 3) provided additional information for the Reference 1) Application for Amendment.

This letter requests that the change discussed in Reference 1) be self-closing upon issuance of the Limerick Unit 2 full power operating license at which time the allowable control room leakage will return to its previous value. We request that this be accomplished by the addition of a footnote to the current Technical Specification outdoor air flow rate value to reflect that an outdoor air flow rate of less than or equal to 2100 cfm is permissible until the issuance of the Unit 2 full power operating license.


The Safety Discussion and Significant Hazards Consideration Determination in the Application and the additional information provided in References 2) and 3) are not affected by this request because a reduction in the period of applicability for the change in the allowable control room leakage during operation of the CREFAS system does not increase the probability or the consequences of an accident, create the possibility for a new or different type of accident, or decrease a margin of safety.

8705280216 870520
PDR ADOCK 05000352
P PDR

*A001
10*

If you have any questions or require additional information,
please do not hesitate to contact us.

Very truly yours,



RDC/cb/05148703

Attachment

Copy to: W. T. Russell, Administrator, Region I, U.S. NRC
E. M. Kelley, Senior Resident Site Inspector
R. E. Martin, PBAPS Project Manager
R. J. Clark, LGS Project Manager
See Attached Service List


COMMONWEALTH OF PENNSYLVANIA :

: ss.

COUNTY OF PHILADELPHIA :


J. W. Gallagher, being first duly sworn, deposes and says:

That he is Vice President of Philadelphia Electric Company; that he has read the foregoing response to the NRC staff request for additional information regarding Licensee's January 30, 1987 Application for Amendment of Facility Operating License NPF-39 and knows the contents thereof; and that the statements and matters set forth therein are true and correct to the best of his knowledge, information, and belief.



Vice President

Subscribed and sworn to
before me this 21ST day
of May, 1987



Notary Public

JUDITH Y. FRANKLIN
Notary Public, Phila., Phila. Co.
My Commission Expires July 28, 1987