

WCAP 11415

WESTINGHOUSE CLASS 3  
CUSTOMER DESIGNATED DISTRIBUTION


ANALYSIS OF CAPSULE V FROM THE  
VIRGINIA ELECTRIC AND POWER COMPANY  
SURRY UNIT 1 REACTOR VESSEL  
RADIATION SURVEILLANCE PROGRAM

S. E. Yanichko  
V. A. Perone

February 1987

Work performed under Shop Order No. VCKJ-106

APPROVED:



T. A. Meyer, Manager

Structural Materials and Reliability Technology

Prepared by Westinghouse for the Virginia Electric and Power Company

Although information contained in this report is nonproprietary, no distribution shall be made outside Westinghouse or its licensees without the customer's approval.

WESTINGHOUSE ELECTRIC CORPORATION  
Power Systems Division  
P.O. Box 2728  
Pittsburgh, Pennsylvania 15230-2728

2200a/0335e-041387-10

8706010154 870522  
PDR ADDCK 05000280  
P PDR

PREFACE

This report has been technically reviewed and verified.


Reviewer

Sections 1 through 5 and 7  
Section 6

C. C. Heinecke  
S. L. Anderson

CC Heinecke  
S L Anderson





## TABLE OF CONTENTS

| Section | Title                                              | Page |
|---------|----------------------------------------------------|------|
| 1       | SUMMARY OF RESULTS                                 | 1-1  |
| 2       | INTRODUCTION                                       | 2-1  |
| 3       | BACKGROUND                                         | 3-1  |
| 4       | DESCRIPTION OF PROGRAM                             | 4-1  |
| 5       | TESTING OF SPECIMENS FROM CAPSULE V                | 5-1  |
|         | 5-1. Overview                                      | 5-1  |
|         | 5-2. Charpy V-Notch Impact Test Results            | 5-3  |
|         | 5-3. Tension Test Results                          | 5-4  |
|         | 5-4. Wedge Opening Loading Tests                   | 5-4  |
| 6       | RADIATION ANALYSIS AND NEUTRON DOSIMETRY           | 6-1  |
|         | 6-1. Introduction                                  | 6-1  |
|         | 6-2. Discrete Ordinates Analysis                   | 6-1  |
|         | 6-3. Neutron Dosimetry                             | 6-5  |
|         | 6-4. Transport Analysis Results                    | 6-10 |
|         | 6-5. Dosimetry Results                             | 6-12 |
|         | 6-6. Surveillance Capsule Withdrawal Schedules     | 6-14 |
|         | 6-7. Influence of an Energy Dependent Damage Model | 6-14 |
| 7       | SURVEILLANCE CAPSULE WITHDRAWAL SCHEDULE           | 7-1  |
| 8       | REFERENCES                                         | 8-1  |

## LIST OF ILLUSTRATIONS

| Figure | Title                                                                                                                                          | Page |
|--------|------------------------------------------------------------------------------------------------------------------------------------------------|------|
| 4-1    | Arrangement of Surveillance Capsules in the Surry Unit 1                                                                                       | 4-5  |
| 4-2    | Capsule V Diagram Showing Location of Specimens, Thermal Monitors, and Dosimeters                                                              | 4-6  |
| 5-1    | Irradiated Charpy V-Notch Impact Properties for Surry Unit 1 Reactor Vessel Lower Shell Plate C4415-1                                          | 5-17 |
| 5-2    | Irradiated Charpy V-Notch Impact Properties for Surry Unit 1 Reactor Pressure Vessel Weld Metal                                                | 5-18 |
| 5-3    | Irradiated Charpy V-Notch Impact Properties for Surry Unit 1 Reactor Pressure Vessel Weld Heat Affected Zone Metal                             | 5-19 |
| 5-4    | Irradiated Charpy V-Notch Impact Properties for Surry Unit 1 A533 Grade B Class 1 Correlation Monitor Material (HSST Plate 02)                 | 5-20 |
| 5-5    | Tensile Properties for Surry Unit 1 Reactor Vessel Lower Shell Plate C4415-1                                                                   | 5-21 |
| 5-6    | Tensile Properties for Surry Unit 1 Reactor Vessel Weld Metal                                                                                  | 5-22 |
| 6-1    | Surry Unit 1 Reactor Geometry                                                                                                                  | 6-39 |
| 6-2    | Reactor Vessel Surveillance Capsule                                                                                                            | 6-40 |
| 6-3    | Surry Unit 1 Maximum Fast Neutron ( $E > 1$ MeV) Fluence at the Beltline Weld Locations as a Function of Full Power Operating Time             | 6-41 |
| 6-4    | Surry Unit 1 Maximum Fast Neutron ( $E > 1$ MeV) Fluence at the Center of the Surveillance Capsules as a Function of Full Power Operation Time | 6-42 |
| 6-5    | Surry Unit 1 Maximum Fast Neutron ( $E > 1.0$ MeV) Fluence at the Pressure Vessel Inner Radius as a Function of Azimuthal Angle                | 6-43 |
| 6-6    | Surry Unit 1 Relative Radial Distribution of Fast Neutron ( $E > 1.0$ MeV) Flux and Fluence Within the Pressure Vessel Wall                    | 6-44 |
| 6-7    | Surry Unit 1 Relative Axial Variation of Fast Neutron ( $E > 1.0$ MeV) Flux and Fluence Within the Pressure Vessel Wall                        | 6-45 |



LIST OF TABLES

| Table | Title                                                                                                                                                                                   | Page |
|-------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------|
| 4-1   | Chemical Composition of the Surry Unit 1 Reactor Vessel Surveillance Materials                                                                                                          | 4-3  |
| 4-2   | Heat Treatment of the Surry Unit 1 Reactor Vessel Surveillance Materials                                                                                                                | 4-4  |
| 5-1   | Charpy V-Notch Impact Data for the Surry Unit 1 Lower Shell Plate C4415-1 Irradiated at 550°F, Fluence $1.94 \times 10^{19}$ n/cm <sup>2</sup> (E > 1 MeV)                              | 5-5  |
| 5-2   | Charpy V-Notch Impact Data for the Surry Unit 1 Pressure Vessel Weld Metal Irradiated at 550°F, Fluence $1.94 \times 10^{19}$ n/cm <sup>2</sup> (E > 1 MeV)                             | 5-6  |
| 5-3   | Charpy V-Notch Impact Data for the Surry Unit 1 Pressure Vessel Weld Heat Affected Zone Metal Irradiated at 550°F, Fluence $1.94 \times 10^{19}$ n/cm <sup>2</sup> (E > 1 MeV)          | 5-7  |
| 5-4   | Charpy V-Notch Impact Data for the Surry Unit 1 A533 Grade B Class 1 Correlation Monitor Material (HSST Plate 02) at 550°F, Fluence $1.94 \times 10^{19}$ n/cm <sup>2</sup> (E > 1 MeV) | 5-8  |
| 5-5   | Instrumented Charpy Impact Test Results for Surry Unit 1 Lower Shell Plate C4415-1                                                                                                      | 5-9  |
| 5-6   | Instrumented Charpy Impact Test Results for Surry Unit 1 Weld Metal                                                                                                                     | 5-10 |
| 5-7   | Instrumented Charpy Impact Test Results for Surry Unit 1 Weld Heat Affected Zone Metal                                                                                                  | 5-11 |
| 5-8   | Instrumented Charpy Impact Test Results for Surry Unit 1 A533 Grade B Class 1 Correlation Monitor Material (HSST Plate 02)                                                              | 5-12 |
| 5-9   | The Effect of 550°F Irradiation at $1.94 \times 10^{19}$ (E > 1 MeV) on the Notch Toughness Properties of The Surry Unit 1 Reactor Vessel Materials                                     | 5-13 |
| 5-10  | Summary of Surry Unit 1 Reactor Vessel Surveillance Capsule Charpy Impact Test Results                                                                                                  | 5-14 |
| 5-11  | Comparison of Measured $\Delta RT_{NDT}$ Versus Regulatory Guide 1.99 Revision 2 Predicted $RT_{NDT}$                                                                                   | 5-15 |
| 5-12  | Tensile Properties for Surry Unit 1 Reactor Vessel Material Irradiated to $1.94 \times 10^{19}$ n/cm <sup>2</sup>                                                                       | 5-16 |

LIST OF TABLES (Cont)

| Table | Title                                                                                                                                 | Page |
|-------|---------------------------------------------------------------------------------------------------------------------------------------|------|
| 6-1   | 47 Energy Group Structure                                                                                                             | 6-16 |
| 6-2   | Nuclear Parameters for Neutron Flux Monitors                                                                                          | 6-17 |
| 6-3   | Surry Unit 1 Calculated Fast Neutron ( $E > 1.0$ MeV)<br>Exposure at the Pressure Vessel Inner Radius - $0^\circ$<br>Azimuthal Angle  | 6-18 |
| 6-4   | Surry Unit 1 Calculated Fast Neutron ( $E > 1.0$ MeV)<br>Exposure at the Pressure Vessel Inner Radius - $15^\circ$<br>Azimuthal Angle | 6-19 |
| 6-5   | Surry Unit 1 Calculated Fast Neutron ( $E > 1.0$ MeV)<br>Exposure at the Pressure Vessel Inner Radius - $30^\circ$<br>Azimuthal Angle | 6-20 |
| 6-6   | Surry Unit 1 Calculated Fast Neutron ( $E > 1.0$ MeV)<br>Exposure at the Pressure Vessel Inner Radius - $45^\circ$<br>Azimuthal Angle | 6-21 |
| 6-7   | Surry Unit 1 Calculated Fast Neutron ( $E > 1.0$ MeV)<br>Exposure at the $15^\circ$ Surveillance Capsule Center                       | 6-22 |
| 6-8   | Surry Unit 1 Calculated Fast Neutron ( $E > 1.0$ MeV)<br>Exposure at the $25^\circ$ Surveillance Capsule Center                       | 6-23 |
| 6-9   | Surry Unit 1 Calculated Fast Neutron ( $E > 1.0$ MeV)<br>Exposure at the $35^\circ$ Surveillance Capsule Center                       | 6-24 |
| 6-10  | Surry Unit 1 Calculated Fast Neutron ( $E > 1.0$ MeV)<br>Exposure at the $45^\circ$ Surveillance Capsule Center                       | 6-25 |
| 6-11  | Irradiation History of Surry Unit 1 Reactor Vessel<br>Surveillance Capsule V                                                          | 6-26 |
| 6-12  | Measured Flux Monitor Activities from Surry Unit 1,<br>Capsule T                                                                      | 6-30 |
| 6-13  | Measured Flux Monitor Activities from Surry Unit 1,<br>Capsule W                                                                      | 6-31 |
| 6-14  | Measured Flux Monitor Activities from Surry Unit 1,<br>Capsule V                                                                      | 6-32 |
| 6-15  | Calculated Neutron Energy Spectra at the Center of<br>Surry Unit 1 Surveillance Capsules                                              | 6-33 |
| 6-16  | Spectrum Averaged Reaction Cross-Sections at the Center<br>of Surry Unit 1 Surveillance Capsules                                      | 6-35 |

LIST OF TABLES (Cont)

| Table | Title                                                                               | Page |
|-------|-------------------------------------------------------------------------------------|------|
| 6-17  | Thermal Neutron Flux Data from Capsules T, W, and V                                 | 6-36 |
| 6-18  | Comparison of Measured and Calculated Fast Neutron Fluence for Capsules T, W, and V | 6-37 |
| 6-19  | dPa/ $\phi$ ( $E > 1.0$ MeV) Ratios for Surry Unit 1                                | 6-38 |



SECTION 1  
SUMMARY OF RESULTS

The analysis of the reactor vessel material contained in Capsule V, the third surveillance capsule to be removed from the Surry Unit 1 reactor pressure vessel, led to the following conclusions:

- o The capsule received an average fast neutron fluence ( $E > 1.0 \text{ MeV}$ ) of  $1.94 \times 10^{19} \text{ n/cm}^2$ .
- o Irradiation of the reactor vessel lower shell plate C4415-1, to  $1.94 \times 10^{19} \text{ n/cm}^2$ , resulted in 30 and 50 ft-lb transition temperature increases of 110°F and 130°F, respectively for specimens oriented parallel to the major working direction (longitudinal orientation). The upper shelf energy decreased from 125 to 116 ft-lb as a result of the irradiation.
- o Weld metal irradiated to  $1.94 \times 10^{19} \text{ n/cm}^2$  resulted in a 30 ft-lb transition temperature increase of 240°F. The upper shelf energy decreased to ~ 50 ft-lb as a result of the irradiation.
- o Comparison of the 30 ft-lb transition temperature increases ( $\Delta RT_{\text{NDT}}$ ) for the Surry Unit 1 surveillance material with predicted increases using the methods of NRC Regulatory Guide 1.99, Revision 2, shows that the plate material and weld metal transition temperature increase were in relatively good agreement with predicted increases.

## SECTION 2 INTRODUCTION

This report presents the results of the examination of Capsule V, the third capsule to be removed from the reactor in the continuing surveillance program which monitors the effects of neutron irradiation on the Virginia Electric and Power Company Surry Unit 1 reactor pressure vessel materials under actual operating conditions.

The surveillance program for the Surry Unit 1 reactor pressure vessel materials was designed and recommended by the Westinghouse Electric Corporation. A description of the surveillance program and the preirradiation mechanical properties of the reactor vessel materials are presented by Yanichko.<sup>[1]</sup> The surveillance program was planned to cover the 40-year design life of the reactor pressure vessel and was based on ASTM E-185-73, "Recommended Practice for Surveillance Tests for Nuclear Reactors".<sup>[2]</sup> Westinghouse Nuclear Energy Systems personnel were contracted for the preparation of procedures for removing the capsule from the reactor and its shipment to the Westinghouse Research and Development Laboratory, where the postirradiation mechanical testing of the Charpy V-notch impact and tensile surveillance specimens was performed.

This report summarizes testing and the postirradiation data obtained from surveillance Capsule V removed from the Surry Unit 1 reactor vessel and discusses the analysis of the data. The data are also compared to capsule T<sup>[3]</sup> which was removed from the reactor in 1974 and capsule W<sup>[4]</sup> which was removed in 1978. It should be noted that only dosimetry was measured for the capsule W. A new reactor vessel surveillance capsule withdrawal schedule was developed to meet the requirements of ASTM E-185-82, as proposed by Babcock and Wilcox<sup>[5]</sup>.



### SECTION 3 BACKGROUND

The ability of the large steel pressure vessel containing the reactor core and its primary coolant to resist fracture constitutes an important factor in ensuring safety in the nuclear industry. The beltline region of the reactor pressure vessel is the most critical region of the vessel because it is subjected to significant fast neutron bombardment. The overall effects of fast neutron irradiation on the mechanical properties of low alloy ferritic pressure vessel steels such as SA533 Grade B Class 1 plate (base material of the Surry Unit 1 reactor pressure vessel beltline) are well documented in the literature. Generally, low alloy ferritic materials show an increase in hardness and tensile properties and a decrease in ductility and toughness under certain conditions of irradiation.

A method for performing analyses to guard against fast fracture in reactor pressure vessels has been presented in "Protection Against Non-ductile Failure," Appendix G to Section III of the ASME Boiler and Pressure Vessel Code. The method utilizes fracture mechanics concepts and is based on the reference nil-ductility temperature ( $RT_{NDT}$ ).

$RT_{NDT}$  is defined as the greater of either the drop weight nil-ductility transition temperature (NDTT per ASTM E-208) or the temperature 60°F less than the 50 ft lb (and 35-mil lateral expansion) temperature as determined from Charpy specimens oriented normal (transverse) to the major working direction of the material. The  $RT_{NDT}$  of a given material is used to index that material to a reference stress intensity factor curve ( $K_{IR}$  curve) which appears in Appendix G of the ASME Code. The  $K_{IR}$  curve is a lower bound of dynamic, crack arrest, and static fracture toughness results obtained from several heats of pressure vessel steel. When a given material is indexed to



the  $K_{IR}$  curve, allowable stress intensity factors can be obtained for this material as a function of temperature. Allowable operating limits can then be determined utilizing these allowable stress intensity factors.

$RT_{NDT}$  and, in turn, the operating limits of nuclear power plants can be adjusted to account for the effects of radiation on the reactor vessel material properties. The radiation embrittlement or changes in mechanical properties of a given reactor pressure vessel steel can be monitored by a reactor surveillance program such as the Surry Unit 1 Reactor Vessel Radiation Surveillance Program,<sup>[1]</sup> in which a surveillance capsule is periodically removed from the operating nuclear reactor and the encapsulated specimens are tested. The increase in the average Charpy V-notch 30 ft lb temperature ( $\Delta RT_{NDT}$ ) due to irradiation is added to the original  $RT_{NDT}$  to adjust the  $RT_{NDT}$  for radiation embrittlement. This adjusted  $RT_{NDT}$  ( $RT_{NDT}$  initial +  $\Delta RT_{NDT}$ ) is used to index the material to the  $K_{IR}$  curve and, in turn, to set operating limits for the nuclear power plant which take into account the effects of irradiation on the reactor vessel materials.

## SECTION 4 DESCRIPTION OF PROGRAM

Eight surveillance capsules for monitoring the effects of neutron exposure on the Surry Unit 1 reactor pressure vessel core region material were inserted in the reactor vessel prior to initial plant startup. The capsules were positioned in the reactor vessel between the thermal shield and the vessel wall at locations shown in figure 4-1. The vertical center of the capsules is opposite the vertical center of the core.

Capsule V was removed after 8.02 effective full power years of plant operation. The capsule contained Charpy V-notch impact and tensile specimens from the lower shell plate C4415-1 and submerged arc weld metal representative of the beltline weld seams of the reactor vessel, WOL specimens from the weld metal and Charpy V-notch specimens from weld heat-affected zone (HAZ) material (Figure 4-2). All heat-affected zone specimens were obtained from within the HAZ of plate C4415-1 of the representative weld.

The chemistry and heat treatment of the surveillance material are presented in table 4-1 and table 4-2, respectively. The chemical analyses reported in table 4-1 were obtained from unirradiated material used in the surveillance program. In addition, a chemical analysis was performed on an irradiated Charpy specimen from the weld metal and plate C4415-1 and is reported in table 4-1.

All test specimens were machined from the 1/4 thickness location of the plate after stress relieving. Test specimens represent material taken at least one plate thickness from the quenched edges of the plate. Base metal Charpy V-notch impact specimens were oriented with the longitudinal axis of the specimen parallel to the major working direction of the plate (longitudinal orientation). Charpy V-notch and tensile specimens from the weld metal were oriented with the longitudinal axis of the specimens transverse to the welding direction. The WOL specimens in Capsule V were machined such that the simulated crack in the specimen would propagate parallel to the weld direction.

Capsule V contained dosimeter wires of pure copper, nickel, and aluminum-cobalt (cadmium-shielded and unshielded). In addition, cadmium-shielded dosimeters of Neptunium ( $\text{Np}^{237}$ ) and Uranium ( $\text{U}^{238}$ ) were contained in the capsule.

Thermal monitors made from two low-melting eutectic alloys and sealed in Pyrex tubes were included in the capsule and were located as shown in Figure 4-2. The two eutectic alloys and their melting points are:

|                              |                             |
|------------------------------|-----------------------------|
| 2.5% Ag, 97.5% Pb            | Melting Point 579°F (304°C) |
| 1.75% Ag, 0.75% Sn, 97.5% Pb | Melting Point 590°F (310°C) |

The arrangement of the various mechanical test specimens, dosimeters and thermal monitors contained in Capsule V are shown in Figure 4-2.



TABLE 4-1

CHEMICAL COMPOSITION OF  
THE SURRY UNIT 1 REACTOR VESSEL  
SURVEILLANCE MATERIALS

| Element        | Intermediate<br>Shell Plate<br>C4326-1 | Lower<br>Shell Plate<br>C4415-1 |          | Weld Metal(d) |           | Correlation<br>Monitor |
|----------------|----------------------------------------|---------------------------------|----------|---------------|-----------|------------------------|
| C              | 0.23                                   | 0.22                            | 0.245(b) | 0.10          | 0.185(c)  | 0.22                   |
| Mn             | 1.35                                   | 1.33                            | 1.46 (b) | 1.49          | 1.47 (c)  | 1.48                   |
| P              | 0.008                                  | 0.014                           | 0.012(b) | 0.011         | 0.011(c)  | 0.012                  |
| S              | 0.015                                  | 0.014                           | 0.017(b) | 0.010         | 0.017(c)  | 0.018                  |
| Si             | 0.23                                   | 0.23                            | 0.42 (b) | 0.37          | 0.43 (c)  | 0.25                   |
| Ni             | 0.55                                   | 0.50                            | 0.569(b) | 0.68          | 0.643(c)  | 0.68                   |
| Cr             | 0.069                                  | 0.078                           | 0.105(b) | 0.076         | 0.074(c)  | -                      |
| V              | 0.001(a)                               | 0.001(a)                        | 0.004(b) | 0.001         | <0.002(c) | -                      |
| Mo             | 0.55                                   | 0.55                            | 0.618(b) | 0.46          | 0.405(c)  | 0.52                   |
| Co             | 0.014                                  | 0.015                           | 0.006(b) | 0.001         | 0.011(c)  | -                      |
| Cu             | 0.11                                   | 0.11                            | 0.115(b) | 0.25          | 0.243(c)  | 0.14                   |
| Sn             | 0.008                                  | 0.008                           | -        | -             | -         | -                      |
| Zn             | 0.001(a)                               | 0.001(a)                        | -        | -             | -         | -                      |
| Al             | 0.037                                  | 0.036                           | -        | 0.013         | -         | -                      |
| N <sub>2</sub> | 0.007                                  | 0.007                           | -        | 0.008         | -         | -                      |
| Ti             | 0.001(a)                               | 0.001(a)                        | -        | -             | -         | -                      |
| Zr             | 0.002                                  | 0.002                           | -        | -             | -         | -                      |
| As             | 0.007                                  | 0.007                           | -        | -             | -         | -                      |
| B              | 0.003(a)                               | 0.003(a)                        | -        | -             | -         | -                      |

- 
- [a] Not detected. The number indicates the minimum limit of detection.  
 [b] Analysis performed on irradiated Charpy plate specimen V-25.  
 [c] Analysis performed on irradiated Charpy weld specimen W-10.  
 [d] Surveillance weld fabricated from same heat of weld wire (299L44) and Linde 80 flux lot (8596) as used in the vessel lower shell vertical weld seam (L2).
-

TABLE 4-2

HEAT TREATMENT OF THE SURRY UNIT 1  
REACTOR VESSEL SURVEILLANCE MATERIALS

| <u>Material</u>                       | <u>Heat Treatment</u>      |                           |
|---------------------------------------|----------------------------|---------------------------|
| Intermediate shell<br>(Plate C4326-1) | 1650°-1700° - 9 hours      | - Water-quenched          |
|                                       | 1210°F - 9 hours           | - Air-cooled              |
|                                       | 1125°F - 15-1/2 hours      | - Furnace cooled to 600°F |
| Lower shell<br>(Plate C4415-1)        | 1650-1700°F - 9 hours      | - Water-quenched          |
|                                       | 1200°F - 9 hours           | - Air-cooled              |
|                                       | 1125°F - 15-1/2 hours      | - Furnace-cooled to 600°F |
| Weldment                              | 1125°F - 15-1/2 hours      | - Furnace-cooled to 600°F |
| Correlation Monitor                   | 1675 $\pm$ 25°F - 4 hours  | - Air-cooled              |
|                                       | 1600 $\pm$ 25°F - 4 hours  | - Water-quenched          |
|                                       | 1225 $\pm$ 25°F - 4 hours  | - Furnace-cooled          |
|                                       | 1150 $\pm$ 25°F - 40 hours | - Furnace-cooled to 600°F |








Figure 4-2 Capsule V Diagram Showing Location of Specimens, Thermal Monitors and Dosimeters

SECTION 5  
TESTING OF SPECIMENS FROM CAPSULE V

5-1. OVERVIEW

The postirradiation mechanical testing of the Charpy V-notch and tensile specimens was performed at the Westinghouse Research and Development Laboratory with consultation by Westinghouse Nuclear Energy Systems personnel. Testing was performed in accordance with 10CFR50, Appendices G and H, ASTM Specification E185-82 and Westinghouse Procedure MHL 8402, Revision 0 as modified by RMF Procedures 8102 and 8103.

Upon receipt of the capsule at the laboratory, the specimens and spacer blocks were carefully removed, inspected for identification number, and checked against the master list in WCAP-7723.<sup>[1]</sup> No discrepancies were found.

Examination of the two low-melting 304°C (579°F) and 310°C (590°F) eutectic alloys indicated no melting of either type of thermal monitor. Based on this examination, the maximum temperature to which the test specimens were exposed was less than 304°C (579°F).

The Charpy impact tests were performed per ASTM Specification E23-82 and RMF Procedure 8103 on a Tinius-Olsen Model 74, 358J machine. The tup (striker) of the Charpy machine is instrumented with an Effects Technology model 500 instrumentation system. With this system, load-time and energy-time signals can be recorded in addition to the standard measurement of Charpy energy ( $E_D$ ). From the load-time curve, the load of general yielding ( $P_{GY}$ ), the time to general yielding ( $t_{GY}$ ), the maximum load ( $P_M$ ), and the time to maximum load ( $t_M$ ) can be determined. Under some test conditions, in the Charpy transition region, a sharp drop in load indicative of fast fracture was observed. The load at which fast fracture was initiated is identified as the

fast fracture load ( $P_F$ ), and the load at which fast fracture terminated is identified as the arrest load ( $P_A$ ).

The energy at maximum load ( $E_M$ ) was determined by comparing the energy-time record and the load-time record. The energy at maximum load is approximately equivalent to the energy required to initiate a crack in the specimen. Therefore, the propagation energy for the crack ( $E_p$ ) is the difference between the total energy to fracture ( $E_D$ ) and the energy at maximum load.

The yield stress ( $\sigma_y$ ) is calculated from the three point bend formula. The flow stress is calculated from the average of the yield and maximum loads, also using the three point bend formula.

Percentage shear was determined from postfracture photographs using the ratio-of-areas methods in compliance with ASTM Specification A370-77. The lateral expansion was measured using a dial gage rig similar to that shown in the same specification.

Tension tests were performed on a 20,000-pound Instron, split-console test machine (Model 1115) per ASTM Specifications E8-83 and E21-79, and RMF Procedure 8102. All pull rods, grips, and pins were made of Inconel 718 hardened to  $R_C45$ . The upper pull rod was connected through a universal joint to improve axially of loading. The tests were conducted at a constant crosshead speed of 0.05 inch per minute throughout the test.

Deflection measurements were made with a linear variable displacement transducer (LVDT) extensometer. The extensometer knife edges were spring-loaded to the specimen and operated through specimen failure. The extensometer gage length is 1.00 inch. The extensometer is rated as Class B-2 per ASTM E83-67.

Elevated test temperatures were obtained with a three-zone electric resistance split-tube furnace with a 9-inch hot zone. All tests were conducted in air.



Because of the difficulty in remotely attaching a thermocouple directly to the specimen, the following procedure was used to monitor specimen temperature. Chromel-alumel thermocouples were inserted in shallow holes in the center and each end of the gage section of a dummy specimen and in each grip. In test configuration, with a slight load on the specimen, a plot of specimen temperature versus upper and lower grip and controller temperatures was developed over the range room temperature to 550°F (288°C). The upper grip was used to control the furnace temperature. During the actual testing the grip temperatures were used to obtain desired specimen temperatures. Experiments indicated that this method is accurate to plus or minus 2°F.

The yield load, ultimate load, fracture load, total elongation, and uniform elongation were determined directly from the load-extension curve. The yield strength, ultimate strength, and fracture strength were calculated using the original cross-sectional area. The final diameter and final gage length were determined from postfracture photographs. The fracture area used to calculate the fracture stress (true stress at fracture) and percent reduction in area was computed using the final diameter measurement.

## 5.2. CHARPY V-NOTCH IMPACT TEST RESULTS

The results of Charpy V-notch impact tests performed on the various materials contained in Capsule V irradiated at  $1.94 \times 10^{19}$  n/cm<sup>2</sup> are presented in Tables 5-1 through 5-8 and Figures 5-1 through 5-4. The transition temperature increases and upper shelf energy decreases for the Capsule V materials are shown in Table 5-9. Table 5-10 summarizes the Charpy impact test results from Capsule V with the previous Capsule T.

Irradiation of vessel lower shell plate C4415-1 material (longitudinal orientation) specimens to  $1.94 \times 10^{19}$  n/cm<sup>2</sup> (Figure 5-1) resulted in 30 and 50 ft-lb transition temperature increases of 110°F and 130°F respectively, and an upper shelf energy decrease of 9 ft lbs.

Weld metal irradiated to  $1.94 \times 10^{19}$  n/cm<sup>2</sup> (Figure 5-2) resulted in a 30 ft-lb transition temperature increase of 240°F and an upper shelf energy decrease of ~ 20 ft-lb which resulted in an upper shelf energy of approximately 50 ft-lb.

Weld HAZ metal irradiated to  $1.94 \times 10^{19}$  n/cm<sup>2</sup> (Figure 5-3) resulted in a 30 and 50 ft-lb transition temperature increases of 80°F and 85°F, respectively, and an upper shelf energy decrease of 8 ft-lb. However because of the large data scatter these values are considered to be highly questionable.

Correlation monitor material (HSST Plate 02) irradiated to  $1.94 \times 10^{19}$  n/cm<sup>2</sup> (Figure 5-4) resulted in 30 and 50 ft-lb transition temperature increases of 145 and 150°F respectively. These increases are in good agreement with other irradiation program tests.

Table 5-11 shows a comparison of the 30 ft-lb transition temperature ( $\Delta T_{NDT}$ ) increases for the various Surry Unit 1 surveillance materials with predicted increases using the methods of NRC Regulatory Guide 1.99, Revision 2.<sup>[6]</sup> This comparison shows that the transition temperature increase resulting from irradiation to 0.281 and  $1.94 \times 10^{19}$  n/cm<sup>2</sup> is in relatively good agreement with the increase predicted by the Guide.

### 5-3. TENSION TEST RESULTS

The results of tension tests performed on plate C4415-1 (longitudinal orientation) and weld metal irradiated to  $1.94 \times 10^{19}$  n/cm<sup>2</sup> are shown in Table 5-12 and Figures 5-5 and 5-6, respectively. These results shown that irradiation produced an increase of 14 to 17 ksi in 0.2 percent yield strength for plate C4415-1 and approximately a 23 to 27 ksi increase for the weld metal.

### 5-4. WEDGE OPENING LOADING TESTS

At the request of the Virginia Electric and Power Company, Wedge Open Loading (WOL) specimen will not be tested. The specimens will be stored at the Hot Cell at the Westinghouse R&D Center.

TABLE 5-1

CHARPY V-NOTCH IMPACT DATA FOR THE SURRY UNIT 1  
 LOWER SHELL PLATE C4415-1  
 IRRADIATED AT 550°F, FLUENCE  $1.94 \times 10^{19}$  n/cm<sup>2</sup> (E > 1 MeV)

| <u>Sample No.</u> | <u>Temperature<br/>°F (°C)</u> | <u>Impact Energy<br/>ft-lbs (Joules)</u> | <u>Lateral Expansion<br/>mils (mm)</u> | <u>% Shear</u> |
|-------------------|--------------------------------|------------------------------------------|----------------------------------------|----------------|
| V50               | 50 ( 10)                       | 11.0 ( 15.0)                             | 10.0 (0.25)                            | 3              |
| V52               | 100 ( 38)                      | 37.0 ( 50.0)                             | 30.5 (0.77)                            | 10             |
| V49               | 150 ( 66)                      | 50.0 ( 68.0)                             | 43.0 (1.09)                            | 41             |
| V53               | 200 ( 93)                      | 72.0 ( 97.5)                             | 56.5 (1.44)                            | 66             |
| V54               | 250 (121)                      | 117.0 (158.5)                            | 79.5 (2.02)                            | 100            |
| V55               | 300 (149)                      | 116.0 (157.5)                            | 78.5 (1.99)                            | 100            |
| V51               | 400 (204)                      | 115.0 (156.0)                            | 77.5 (1.97)                            | 100            |



TABLE 5-2

CHARPY V-NOTCH IMPACT DATA FOR THE SURRY UNIT 1  
 PRESSURE VESSEL WELD METAL IRRADIATED AT 550°F,  
 FLUENCE  $1.94 \times 10^{19}$  n/cm<sup>2</sup> (E > 1 MeV)

| <u>Sample No.</u> | <u>Temperature<br/>°F (°C)</u> | <u>Impact Energy<br/>ft-lbs (Joules)</u> | <u>Lateral Expansion<br/>mils (mm)</u> | <u>% Shear</u> |
|-------------------|--------------------------------|------------------------------------------|----------------------------------------|----------------|
| W12               | 50 ( 10)                       | 4.0 ( 5.5)                               | 3.5 (0.09)                             | 0              |
| W14               | 150 ( 66)                      | 17.0 ( 23.0)                             | 19.5 (0.50)                            | 12             |
| W13               | 200 ( 93)                      | 22.0 ( 30.0)                             | 17.5 (0.44)                            | 28             |
| W16               | 250 (121)                      | 39.0 ( 53.0)                             | 28.5 (0.72)                            | 73             |
| W10               | 250 (121)                      | 33.0 ( 44.5)                             | 32.0 (0.81)                            | 52             |
| W15               | 300 (149)                      | 41.0 ( 55.5)                             | 31.0 (0.79)                            | 96             |
| W11               | 400 (204)                      | 47.0 ( 63.5)                             | 41.0 (1.04)                            | 100            |
| W9                | 450 (232)                      | 52.0 ( 70.5)                             | 45.5 (1.16)                            | 100            |

TABLE 5-3

CHARPY V-NOTCH IMPACT DATA FOR THE SURRY UNIT 1  
 PRESSURE VESSEL WELD HEAT AFFECTED ZONE METAL  
 IRRADIATED AT 550°F, FLUENCE  $1.94 \times 10^{19}$  n/cm<sup>2</sup> (E > 1 MeV)

| <u>Sample No.</u> | <u>Temperature<br/>°F (°C)</u> | <u>Impact Energy<br/>ft-lbs (Joules)</u> | <u>Lateral Expansion<br/>mils (mm)</u> | <u>% Shear</u> |
|-------------------|--------------------------------|------------------------------------------|----------------------------------------|----------------|
| H10               | -25 (-32)                      | 12.0 ( 16.5)                             | 10.0 (0.25)                            | 12             |
| H9                | 25 ( -4)                       | 28.0 ( 38.0)                             | 20.5 (0.52)                            | 31             |
| H13               | 50 ( 10)                       | 53.0 ( 72.0)                             | 31.5 (0.80)                            | 51             |
| H11               | 100 ( 38)                      | 87.0 (118.0)                             | 59.0 (1.50)                            | 87             |
| H15               | 150 ( 66)                      | 22.0 ( 30.0)                             | 20.0 (0.51)                            | 58             |
| H14               | 200 ( 93)                      | 81.0 (110.0)                             | 61.5 (1.56)                            | 100            |
| H12               | 300 (149)                      | 52.0 ( 70.5)                             | 39.0 (0.99)                            | 100            |
| H16               | 400 (204)                      | 110.0 (149.0)                            | 70.0 (1.78)                            | 100            |

TABLE 5-4

CHARPY V-NOTCH IMPACT DATA FOR THE SURRY UNIT 1  
 A533 GRADE B CLASS 1 CORRELATION MONITOR MATERIAL (HSST PLATE 02)  
 IRRADIATED AT 550°F, FLUENCE  $1.94 \times 10^{19}$  n/cm<sup>2</sup> (E > 1 MeV)

| <u>Sample No.</u> | <u>Temperature<br/>°F (°C)</u> | <u>Impact Energy<br/>ft-lbs (Joules)</u> | <u>Lateral Expansion<br/>mils (mm)</u> | <u>% Shear</u> |
|-------------------|--------------------------------|------------------------------------------|----------------------------------------|----------------|
| R41               | 100 ( 38)                      | 10.0 ( 13.5)                             | 10.0 (0.25)                            | 4              |
| R43               | 150 ( 66)                      | 21.0 ( 28.5)                             | 18.5 (0.47)                            | 10             |
| R47               | 200 ( 93)                      | 33.0 ( 44.5)                             | 27.5 (0.70)                            | 33             |
| R48               | 200 ( 93)                      | 33.0 ( 44.5)                             | 23.0 (0.58)                            | 26             |
| R46               | 250 (121)                      | 73.0 ( 99.0)                             | 45.0 (1.14)                            | 43             |
| R44               | 300 (149)                      | 92.0 (124.5)                             | 69.0 (1.75)                            | 92             |
| R45               | 400 (204)                      | 101.0 (137.0)                            | 69.5 (1.77)                            | 100            |
| R42               | 450 (232)                      | 98.0 (133.0)                             | 72.5 (1.84)                            | 100            |



TABLE 5-5  
 INSTRUMENTED CHARPY IMPACT TEST RESULTS  
 FOR SURRY UNIT 1  
 LOWER SHELL PLATE C4415-1

| Sample No. | Test Temp. (°F) | Charpy Energy (FT LB) | Normalized Energies                  |              |           | Yield Load (KIPS) | Time to Yield (µSec) | Maximum Load (KIPS) | Time to Maximum (µSec) | Fracture Load (KIPS) | Arrest Load (KIPS) | Yield Stress (KSI) | Flow Stress (KSI) |
|------------|-----------------|-----------------------|--------------------------------------|--------------|-----------|-------------------|----------------------|---------------------|------------------------|----------------------|--------------------|--------------------|-------------------|
|            |                 |                       | Charpy Ed/A                          | Maximum Em/A | Prop Ep/A |                   |                      |                     |                        |                      |                    |                    |                   |
|            |                 |                       | ----- (FT-LB/in <sup>2</sup> ) ----- |              |           |                   |                      |                     |                        |                      |                    |                    |                   |
| V50        | 50              | 11.0                  | 89                                   | 36           | 52        | 3.05              | 135                  | 3.10                | 155                    | 3.15                 | .25                | 102                | 102               |
| V52        | 100             | 37.0                  | 298                                  | 210          | 88        | 3.10              | 125                  | 4.40                | 495                    | 4.35                 | .65                | 103                | 124               |
| V49        | 150             | 50.0                  | 403                                  | 258          | 145       | 3.15              | 135                  | 4.50                | 585                    | 4.45                 | 1.55               | 103                | 126               |
| V53        | 200             | 72.0                  | 580                                  | 282          | 297       | 2.90              | 135                  | 4.25                | 670                    | 3.85                 | 2.4                | 95                 | 118               |
| V54        | 250             | 117.0                 | 942                                  | 283          | 659       | 2.75              | 135                  | 4.10                | 690                    | -                    | -                  | 91                 | 113               |
| V55        | 300             | 116.0                 | 934                                  | 270          | 664       | 2.90              | 140                  | 4.15                | 645                    | -                    | -                  | 96                 | 117               |
| V51        | 400             | 115.0                 | 926                                  | 290          | 636       | 2.70              | 130                  | 4.10                | 715                    | -                    | -                  | 89                 | 112               |

5-9

**TABLE 5-6**  
**INSTRUMENTED CHARPY IMPACT TEST RESULTS**  
**FOR SURRY UNIT 1 WELD METAL**

| Sample No. | Test Temp. ( <sup>o</sup> F) | Charpy Energy (FT LB) | Normalized Energies                      |              |           | Yield Load (KIPS) | Time to Yield ( $\mu$ Sec) | Maximum Load (KIPS) | Time to Maximum ( $\mu$ Sec) | Fracture Load (KIPS) | Arrest Load (KIPS) | Yield Stress (KSI) | Flow Stress (KSI) |
|------------|------------------------------|-----------------------|------------------------------------------|--------------|-----------|-------------------|----------------------------|---------------------|------------------------------|----------------------|--------------------|--------------------|-------------------|
|            |                              |                       | Charpy Ed/A                              | Maximum Em/A | Prop Ep/A |                   |                            |                     |                              |                      |                    |                    |                   |
|            |                              |                       | -----( $\text{FT-LB}/\text{in}^2$ )----- |              |           |                   |                            |                     |                              |                      |                    |                    |                   |
| W12        | 50                           | 4.0                   | 32                                       | 16           | 16        | -                 | -                          | 2.80                | 85                           | 2.80                 | .15                | -                  | -                 |
| W14        | 150                          | 17.0                  | 137                                      | 89           | 48        | 3.10              | 125                        | 3.80                | 270                          | 3.75                 | .50                | 102                | 113               |
| W13        | 200                          | 22.0                  | 177                                      | 87           | 90        | 2.55              | 105                        | 3.55                | 275                          | 3.55                 | .95                | 85                 | 101               |
| W10        | 250                          | 33.0                  | 266                                      | 144          | 122       | 3.20              | 115                        | 4.10                | 350                          | 4.00                 | 2.75               | 106                | 121               |
| W16        | 250                          | 39.0                  | 314                                      | 165          | 149       | 3.55              | 130                        | 4.25                | 380                          | 4.20                 | 3.25               | 117                | 129               |
| W15        | 300                          | 41.0                  | 330                                      | 140          | 190       | 3.05              | 125                        | 3.80                | 370                          | -                    | -                  | 101                | 113               |
| W11        | 400                          | 47.0                  | 378                                      | 157          | 222       | 2.65              | 105                        | 3.80                | 410                          | -                    | -                  | 88                 | 107               |
| W9         | 450                          | 52.0                  | 419                                      | 184          | 235       | 3.40              | 140                        | 4.20                | 435                          | -                    | -                  | 113                | 126               |

5-10

TABLE 5-7  
 INSTRUMENTED CHARPY IMPACT TEST RESULTS  
 FOR SURRY UNIT 1 WELD HEAT AFFECTED ZONE METAL

| Sample No. | Test Temp. ( <sup>o</sup> F) | Charpy Energy (FT LB) | Normalized Energies                  |              |           | Yield Load (KIPS) | Time to Yield ( $\mu$ Sec) | Maximum Load (KIPS) | Time to Maximum ( $\mu$ Sec) | Fracture Load (KIPS) | Arrest Load (KIPS) | Yield Stress (KSI) | Flow Stress (KSI) |
|------------|------------------------------|-----------------------|--------------------------------------|--------------|-----------|-------------------|----------------------------|---------------------|------------------------------|----------------------|--------------------|--------------------|-------------------|
|            |                              |                       | Charpy Ed/A                          | Maximum Em/A | Prop Ep/A |                   |                            |                     |                              |                      |                    |                    |                   |
|            |                              |                       | ----- (FT-LB/in <sup>2</sup> ) ----- |              |           |                   |                            |                     |                              |                      |                    |                    |                   |
| H10        | -25                          | 12.0                  | 97                                   | 53           | 44        | 3.70              | 135                        | 4.00                | 180                          | 4.00                 | .30                | 122                | 127               |
| H9         | 25                           | 28.0                  | 225                                  | 113          | 113       | 3.35              | 125                        | 4.10                | 295                          | 4.15                 | 1.45               | 110                | 123               |
| H13        | 50                           | 53.0                  | 427                                  | 225          | 202       | .85               | 55                         | 5.25                | 530                          | 5.3                  | 3.80               | 27                 | 100               |
| H11        | 100                          | 87.0                  | 701                                  | 290          | 410       | 3.85              | 135                        | 4.95                | 580                          | 3.70                 | 1.50               | 128                | 146               |
| H15        | 150                          | 22.0                  | 177                                  | 107          | 71        | 3.10              | 105                        | 4.05                | 280                          | 4.05                 | .80                | 102                | 118               |
| H14        | 200                          | 81.0                  | 652                                  | 232          | 420       | 3.75              | 130                        | 4.70                | 485                          | -                    | -                  | 124                | 140               |
| H12        | 300                          | 52.0                  | 419                                  | 155          | 264       | 3.15              | 135                        | 3.95                | 400                          | -                    | -                  | 105                | 118               |
| H16        | 400                          | 110.0                 | 886                                  | 255          | 631       | 3.30              | 145                        | 4.50                | 575                          | -                    | -                  | 110                | 129               |

5-11



TABLE 5-8  
 INSTRUMENTED CHARPY IMPACT TEST RESULTS FOR SURRY UNIT 1  
 A533 GRADE B CLASS 1 CORRELATION MONITOR MATERIAL (HSST PLATE 02)

| Sample No. | Test Temp. (°F) | Charpy Energy (FT LB) | Normalized Energies                  |              |           | Yield Load (KIPS) | Time to Yield (µSec) | Maximum Load (KIPS) | Time to Maximum (µSec) | Fracture Load (KIPS) | Arrest Load (KIPS) | Yield Stress (KSI) | Flow Stress (KSI) |
|------------|-----------------|-----------------------|--------------------------------------|--------------|-----------|-------------------|----------------------|---------------------|------------------------|----------------------|--------------------|--------------------|-------------------|
|            |                 |                       | Charpy Ed/A                          | Maximum Em/A | Prop Ep/A |                   |                      |                     |                        |                      |                    |                    |                   |
|            |                 |                       | ----- (FT-LB/in <sup>2</sup> ) ----- |              |           |                   |                      |                     |                        |                      |                    |                    |                   |
| R41        | 100             | 10.0                  | 81                                   | 50           | 31        | 3.30              | 110                  | 3.60                | 160                    | 3.75                 | .65                | 109                | 114               |
| R43        | 150             | 21.0                  | 169                                  | 125          | 44        | 3.20              | 100                  | 3.90                | 325                    | 3.90                 | .25                | 106                | 117               |
| R48        | 200             | 33.0                  | 266                                  | 141          | 125       | 2.75              | 135                  | 3.75                | 405                    | 3.75                 | 1.40               | 91                 | 107               |
| R47        | 200             | 33.0                  | 266                                  | 164          | 102       | 2.90              | 135                  | 3.90                | 445                    | 3.90                 | 1.35               | 95                 | 112               |
| R46        | 250             | 73.0                  | 588                                  | 263          | 325       | 2.70              | 120                  | 4.05                | 640                    | 4.00                 | 2.75               | 89                 | 112               |
| R44        | 300             | 92.0                  | 741                                  | 265          | 476       | 2.65              | 135                  | 4.05                | 665                    | 3.30                 | 2.65               | 88                 | 111               |
| R45        | 400             | 101.0                 | 813                                  | 234          | 579       | 2.60              | 135                  | 3.90                | 610                    | -                    | -                  | 87                 | 108               |
| R42        | 450             | 98.0                  | 789                                  | 263          | 526       | 2.80              | 115                  | 4.15                | 625                    | -                    | -                  | 92                 | 115               |

5-12

TABLE 5-9  
 EFFECT OF 550°F IRRADIATION AT  $1.94 \times 10^{19}$  n/cm<sup>2</sup> (E > MeV)  
 ON THE NOTCH TOUGHNESS PROPERTIES OF THE  
 SURRY UNIT 1 REACTOR VESSEL MATERIALS

| Material                | Average<br>50 ft-lb Temp (°F) |            |     | Average 35 mil<br>Lateral Expansion Temp (°F) |            |     | Average<br>30 ft-lb Temp (°F) |            |     | Average Energy Absorption<br>at Fu <sup>11</sup> Shear (ft-lb) |            |          |
|-------------------------|-------------------------------|------------|-----|-----------------------------------------------|------------|-----|-------------------------------|------------|-----|----------------------------------------------------------------|------------|----------|
|                         | Unirradiated                  | Irradiated | ΔT  | Unirradiated                                  | Irradiated | ΔT  | Unirradiated                  | Irradiated | ΔT  | Unirradiated                                                   | Irradiated | Δ(ft-lb) |
| Plate<br>C4415-1        | 20                            | 150        | 130 | 10                                            | 130        | 120 | -10                           | 100        | 110 | 125                                                            | 116        | 9        |
| Weld<br>Metal           | 50                            | -          | -   | 0                                             | 245        | 245 | -15                           | 225        | 240 | 70                                                             | 49.5       | 20.5     |
| HAZ Metal               | -15                           | 70         | 85  | -20                                           | 70         | 90  | -50                           | 30         | 80  | 89                                                             | 81         | 8        |
| Correlation<br>Material | 75                            | 225        | 150 | 65                                            | 225        | 160 | 45                            | 190        | 145 | 123                                                            | 100        | 23       |

5-13

TABLE 5-10  
 SUMMARY OF SURRY UNIT NO. 1  
 REACTOR VESSEL SURVEILLANCE CAPSULE CHARPY IMPACT TEST RESULTS

| <u>Material</u>        | <u>Fluence</u><br>$10^{19}$ n/cm <sup>2</sup> | 68 Joule                                              | 41 Joule                                              | Decrease in<br>Upper Shelf<br>Energy<br>(ft-lb) |
|------------------------|-----------------------------------------------|-------------------------------------------------------|-------------------------------------------------------|-------------------------------------------------|
|                        |                                               | 50 ft-lb                                              | 30 ft-lb                                              |                                                 |
|                        |                                               | <u>Trans. Temp.</u><br><u>Increase</u><br><u>(°F)</u> | <u>Trans. Temp.</u><br><u>Increase</u><br><u>(°F)</u> |                                                 |
| Plate C4415-1 (Long)   | 0.281 (a)                                     | 60                                                    | 50                                                    | 5                                               |
|                        | 1.940 (b)                                     | 130                                                   | 110                                                   | 9                                               |
| Weld Metal             | 0.281                                         | 250                                                   | 165                                                   | 17                                              |
|                        | 1.94                                          | -                                                     | 240                                                   | 20.5                                            |
| HAZ Metal              | 0.281                                         | -                                                     | -                                                     | -                                               |
|                        | 1.94                                          | 85                                                    | 80                                                    | 8                                               |
| Correlation<br>Monitor | 0.281                                         | 80                                                    | 70                                                    | 18                                              |
|                        | 1.94                                          | 150                                                   | 145                                                   | 23                                              |

(a) Capsule T

(b) Capsule V



TABLE 5-11  
 COMPARISON OF  
 MEASURED  $\Delta RT_{NDT}$  VERSUS REGULATORY GUIDE 1.99 REVISION 2  
 PREDICTED  $\Delta RT_{NDT}$  <sup>(a)</sup>

| <u>Material</u>        | <u>Capsule</u> | <u>Fluence</u><br><u><math>10^{19}</math> n/cm<sup>2</sup></u> | <u><math>\Delta RT_{NDT}</math> (30 ft-lb increase)</u> |                                |
|------------------------|----------------|----------------------------------------------------------------|---------------------------------------------------------|--------------------------------|
|                        |                |                                                                | <u>RG. 1.99 Rev. 2</u><br><u>(°F)</u>                   | <u>Measured</u><br><u>(°F)</u> |
| Plate C4415-1          | T              | 0.281                                                          | 47                                                      | 50                             |
|                        | V              | 1.94                                                           | 87                                                      | 110                            |
| Weld Metal             | T              | 0.281                                                          | 121                                                     | 165                            |
|                        | V              | 1.94                                                           | 222                                                     | 240                            |
| Correlation<br>Monitor | T              | 0.281                                                          | 65                                                      | 70                             |
|                        | V              | 1.94                                                           | 120                                                     | 145                            |

(a) Based on copper and nickel contents reported in WCAP 7723 [1].

TABLE 5-12  
TENSILE PROPERTIES FOR SURRY UNIT 1  
REACTOR VESSEL MATERIAL IRRADIATED TO  $1.94 \times 10^{19}$  n/cm<sup>2</sup>

| <u>Sample No.</u> | <u>Material</u> | <u>Test Temp. (°F)</u> | <u>2% Yield Strength (ksi)</u> | <u>Ultimate Strength (ksi)</u> | <u>Fracture Load (kip)</u> | <u>Fracture Stress (ksi)</u> | <u>Fracture Strength (ksi)</u> | <u>Uniform Elongation (%)</u> | <u>Total Elongation (%)</u> | <u>Reduction in Area (%)</u> |
|-------------------|-----------------|------------------------|--------------------------------|--------------------------------|----------------------------|------------------------------|--------------------------------|-------------------------------|-----------------------------|------------------------------|
| V12               | Plate C4415-1   | 250                    | 82.5                           | 99.8                           | 3.30                       | 183.5                        | 67.2                           | 9.8                           | 20.4                        | 63                           |
| V11               | Plate C4415-1   | 550                    | 77.4                           | 100.8                          | 3.40                       | 159.4                        | 69.3                           | 9.0                           | 19.7                        | 57                           |
| W4                | WELD            | 250                    | 90.7                           | 102.3                          | 3.90                       | 180.9                        | 79.5                           | 8.8                           | 19.7                        | 56                           |
| W3                | WELD            | 550                    | 82.5                           | 101.9                          | 4.00                       | 165.2                        | 81.5                           | 9.0                           | 17.1                        | 51                           |

5-16




Figure 5-1. Irradiated Charpy V-Notch Impact Properties for Surry Unit 1 Reactor Vessel Lower Shell Plate C4415-1






Figure 5-2. Irradiated Charpy V-Notch Impact Properties for Surry Unit 1 Reactor Pressure Vessel Weld Metal




Figure 5-3. Irradiated Charpy V-Notch Impact Properties for Surry Unit 1 Reactor Pressure Vessel Weld Heat Affected Zone Metal




Figure 5-4. Irradiated Charpy V-Notch Impact Properties for Surry Unit 1 A533 Grade B Class 1 Correlation Monitor Material (HSST Plate 02)






Figure 5-5. Tensile Properties for Surry Unit 1 Reactor Vessel Lower Shell Plate C4415-1




Figure 5-6. Tensile Properties for Surry Unit 1 Reactor Vessel Weld Metal

## SECTION 6

### RADIATION ANALYSIS AND NEUTRON DOSIMETRY

#### 6-1 INTRODUCTION

Knowledge of the neutron environment within the pressure vessel-surveillance capsule geometry is required as an integral part of LWR pressure vessel surveillance programs for two reasons. First, in the interpretation of radiation-induced property changes observed in materials test specimens, the neutron environment (fluence, flux) to which the test specimens were exposed must be known. Second, in relating the changes observed in the test specimens to the present and future condition of the reactor pressure vessel, a relationship between the environment at various positions within the reactor vessel and that experienced by the test specimens must be established. The former requirement is normally met by employing a combination of rigorous analytical techniques and measurements obtained with passive neutron flux monitors contained in each of the surveillance capsules. The latter information, on the other hand, is derived solely from analysis.

This section describes a discrete ordinates  $S_n$  transport analysis performed for the Surry Unit 1 reactor to determine the fast neutron ( $E > 1.0$  Mev) flux and fluence as well as the neutron energy spectra within the reactor vessel and surveillance capsules; and, in turn, to develop data for use in relating neutron exposure of the pressure vessel to that of the surveillance capsules. Based on spectrum-averaged reaction cross sections derived from this calculation, the analysis of the neutron dosimetry contained in Capsule V is discussed and updated evaluations of dosimetry from Capsules T and W are presented.

#### 6-2 DISCRETE ORDINATES ANALYSIS

A plan view of the Surry reactor geometry at the core midplane is shown in Figure 6-1. Since the reactor exhibits 1/8th core symmetry, only a 0°-45°



sector is depicted. Eight irradiation capsules attached to the thermal shield are included in the design to constitute the reactor vessel surveillance program. The capsules are located at 45°, 55°, 65°, 165°, 245°, 285°, 295°, and 305° relative to the major axis at 0°. (Refer to Figure 4-1.)

A plan view of a single surveillance capsule attached to the thermal shield is shown in Figure 6-2. The stainless steel specimen container is 1-inch square and approximately 3 feet in height. The containers are positioned axially such that the specimens are centered on the core midplane, thus spanning the central 3 feet of the 12-foot high reactor core.

From a neutronic standpoint, the surveillance capsule structures are significant. In fact, they have a marked impact on the distributions of neutron flux and energy spectra in the water annulus between the thermal shield and the reactor vessel. Thus, in order to properly ascertain the neutron environment at the test specimen locations, the capsules themselves must be included in the analytical model. Use of at least a two-dimensional computation is, therefore, mandatory.

In the analysis of the neutron environment within the Surry Unit 1 reactor geometry, two sets of transport calculations were carried out. The first, a single computation in the conventional forward mode, was utilized primarily to obtain spectrum-averaged reaction cross sections and gradient corrections for dosimetry reactions. The second set of calculations consisted of a series of adjoint analyses relating the fast neutron ( $E > 1.0$  Mev) flux at the surveillance capsule locations and selected locations on the reactor vessel inner wall to the power distributions in the reactor core. These adjoint importance functions, when combined with cycle-specific core power distributions, yield the plant-specific fast neutron exposure at the surveillance capsule and pressure vessel locations for each operating fuel cycle. Both the forward and adjoint calculations utilized an  $S_6$  angular quadrature.

The forward transport calculation was carried out in  $R, \theta$  geometry using the DOT two dimensional discrete ordinates code<sup>[7]</sup> and the SAILOR cross-section

library<sup>[8]</sup>. The SAILOR library is a 47 group, ENDF-BIV based data set produced specifically for light water reactor applications. Anisotropic scattering is treated with a  $P_3$  expansion of the cross-sections. The energy group structure used in the analysis is listed in Table 6-1.

The design basis core power distribution utilized in the forward analysis was derived from statistical studies of long-term operation of Westinghouse 3-loop plants. Inherent in the development of this design basis core power distribution is the use of an out-in fuel management strategy; i.e., fresh fuel on the core periphery. Furthermore, for the peripheral fuel assemblies, a  $2\sigma$  uncertainty derived from the statistical evaluation of plant to plant and cycle to cycle variations in peripheral power was used. Since it is unlikely that a single reactor would have a power distribution at the nominal  $+2\sigma$  level for a large number of fuel cycles, the use of this design basis distribution is expected to yield somewhat conservative results. This is especially true in cases where low leakage fuel management has been employed.

The adjoint analyses were also carried out using the  $P_3$  cross section approximation from the SAILOR library. Adjoint source locations were chosen at the center of each of the surveillance capsules as well as at positions along the inner diameter of the pressure vessel. Again, these calculations were run in  $R,\theta$  geometry to provide power distribution importance functions for the exposure parameters of interest. Having the adjoint importance functions and appropriate core power distributions, the response of interest is calculated as

$$R_{R,\theta} = \int_R \int_\theta \int_E I(R,\theta,E) F(R,\theta,E) dE R d\theta$$

where:

$R_{R,\theta}$  = Response of interest (e.g.,  $\phi$  ( $E > 1.0$  MeV)) at radius  $R$  and azimuthal angle  $\theta$ .

$I(R,\theta,E)$  = Adjoint importance function at radius  $R$  and azimuthal angle  $\theta$  for neutron energy group  $E$

$F(R, \theta, E)$  = Full power fission density at radius R and azimuthal angle  $\theta$  for neutron energy group E

The fission density distributions used reflect the burnup-dependent inventory of fissioning actinides, including U-235, U-238, Pu-239, and Pu-241.

Core power distributions for use in the plant specific fluence evaluations for Surry Unit 1 are derived from measured assembly and cycle burnups for each operating cycle to date. The specific power distribution data used in the analysis is provided in Appendix A of WCAP 11015<sup>[9]</sup>. The data listed in Appendix A represents cycle averaged relative assembly powers. Therefore, the adjoint results are in terms of fuel cycle averaged neutron flux which when multiplied by the fuel cycle length yields the incremental fast neutron fluence.

Reactor vessel and surveillance capsule neutron fluence projections are made to several future dates. Current neutron fluences, based on past core loadings, are defined as of the end of Cycle 8. Fluence projections are made to the expiration date of the operating license. The expiration date of the operating license for Surry Unit 1 is May 25, 2012 (forty years after the operating license was issued). In addition, projections are made to 60 calendar years beyond issuance of the operating license to illustrate the effect of a 20-year life extension.

A few key assumptions are required to make the fluence projections. In particular, the cycle-averaged core power distribution for Cycle 8 and an 80% capacity factor are assumed to be representative of all future operation. Thus, all fluence projections reflect the low leakage fuel management strategies exemplified by the Cycle 8 core loading. Finally, it is assumed that the Surry Unit 1 core will be uprated from 2441 MWth to 2546 MWth at the beginning of Cycle 11.

The transport methodology, both forward and adjoint, using the SAILOR cross-section library has been benchmarked against the Oakridge National Laboratory (ORNL) Poolside Critical Assembly (PCA) facility as well as against



the Westinghouse power reactor surveillance capsule data base [10]. The benchmarking studies indicate that the use of SAILOR cross-sections and generic design basis power distributions produces flux levels that tend to be conservative by 7-22%. When plant specific power distributions are used with the adjoint importance functions, the benchmarking studies show that fluence predictions are within + 15% of measured values at surveillance capsule locations.

### 6-3 NEUTRON DOSIMETRY

The passive neutron flux monitors included in the Surry Unit 1 surveillance program are listed in Table 6-2. The first five reactions in Table 6-2 are used as fast neutron monitors to relate neutron fluence ( $E > 1.0$  Mev) to measured materials properties changes. To properly account for burnout of the product isotope generated by fast neutron reactions, it is necessary to also determine the magnitude of the thermal neutron flux at the monitor location. Therefore, bare and cadmium-covered cobalt-aluminum monitors are also included.

The relative locations of the various monitors within the surveillance capsules are shown in Figure 4-2. The nickel, copper, and cobalt-aluminum monitors, in wire form, are placed in holes drilled in spacers at several axial levels within the capsules. The iron monitors are obtained by drilling samples from selected Charpy test specimens. In "type-II" capsules such as T, V, X and Z, cadmium-shielded neptunium and uranium fission monitors are accommodated within a dosimeter block located near the center of the capsule. The "type-I" capsules, including S, U, W and Y, do not contain the neptunium and uranium fission monitors.

The use of passive monitors such as those listed in Table 6-2 does not yield a direct measure of the energy dependent flux level at the point of interest. Rather, the activation or fission process is a measure of the integrated effect that the time- and energy-dependent neutron flux has on the target material over the course of the irradiation period. An accurate assessment of the average neutron flux level incident on the various monitors may be derived

from the activation measurements only if the irradiation parameters are well known. In particular, the following variables are of interest:

- o The operating history of the reactor
- o The energy response of the monitor
- o The neutron energy spectrum at the monitor location
- o The physical characteristics of the monitor

The analysis of the passive monitors and subsequent derivation of the average neutron flux requires completion of two procedures. First, the disintegration rate of product isotope per unit mass of monitor must be determined. Second, in order to define a suitable spectrum averaged reaction cross section, the neutron energy spectrum at the monitor location must be calculated.

The specific activity of each of the monitors is determined using established ASTM procedures.<sup>[11,12,13,14,15]</sup> Following sample preparation, the activity of each monitor is determined by means of a lithium-drifted germanium, Ge(Li), gamma spectrometer. The overall standard deviation of the measured data is a function of the precision of sample weighing, the uncertainty in counting, and the acceptable error in detector calibration. For the samples removed from Surry Unit 1, the overall  $2\sigma$  deviation in the measured data is determined to be +10 percent. The neutron energy spectra are determined analytically using the method described in Section 6-1.

Having the measured activity of the monitors and the neutron energy spectra at the locations of interest, the calculation of the neutron flux proceeds as follows.

The reaction product activity in the monitor is expressed as:

$$R = \frac{N_0}{A} f_i Y \int_E \sigma(E) \phi(E) \sum_{j=1}^N \frac{P_j}{P_{\max}} C_j (1 - e^{-\lambda_j t}) e^{-\lambda_d t} \quad (6-1)$$

where:

R = induced product activity

$N_0$  = Avagadro's number

A = atomic weight of the target isotope

$f_i$  = weight fraction of the target isotope in the target material

Y = number of product atoms produced per reaction

$\sigma(E)$  = energy-dependent reaction cross section

$\phi(E)$  = time-averaged energy-dependent neutron flux at the monitor location with the reactor at full power

$P_j$  = average core power level during irradiation period j



- $P_{\max}$  = maximum or reference core power level  
 $\lambda$  = decay constant of the product isotope  
 $t_j$  = length of irradiation period j  
 $t_d$  = decay time following irradiation period j  
 $C_j$  =  $\phi(E > 1.0 \text{ MeV})$  during irradiation period j divided by the average  $\phi(E > 1.0 \text{ MeV})$  over the total irradiation period.  $C_j$  is calculated with the adjoint neutron transport method and accounts for the change in neutron monitor response caused by core power distribution variations from cycle to cycle.  $P_j/P_{\max}$ , which accounts for the month-by-month variation of power level within a cycle, is applied to the full-power-based flux ratio,  $C_j$ .

Since neutron flux distributions are calculated using multigroup transport methods and, further, since the prime interest is in the fast neutron flux above 1.0 Mev, spectrum-averaged reaction cross sections are defined such that the integral term in equation (6-1) is replaced by the following relation.

$$\int_E \sigma(E) \phi(E) dE = \bar{\sigma} \phi(E > 1.0 \text{ Mev})$$

where:

$$\bar{\sigma} = \frac{\int_0^{\infty} \sigma(E) \phi(E) dE}{\int_{1.0 \text{ Mev}}^{\infty} \phi(E) dE} = \frac{\sum_{G=1}^N \sigma_g \phi_g}{\sum_{G=G_{1.0 \text{ Mev}}}^N \phi_g}$$

Thus, equation (6-1) is rewritten

$$R = \frac{N_0}{A} f_i \gamma \bar{\sigma} \phi (E > 1.0 \text{ Mev}) \sum_{j=1}^N \frac{P_j}{P_{\max}} C_j (1 - e^{-\lambda t_j}) e^{-\lambda t_d}$$

or, solving for the neutron flux,

$$\phi (E > 1.0 \text{ Mev}) = \frac{R}{\frac{N_0}{A} f_i \gamma \bar{\sigma} \sum_{j=1}^N \frac{P_j}{P_{\max}} C_j (1 - e^{-\lambda t_j}) e^{-\lambda t_d}} \quad (6-2)$$

The total fluence above 1.0 Mev is then given by

$$\Phi (E > 1.0 \text{ Mev}) = \phi (E > 1.0 \text{ Mev}) \sum_{j=1}^N \frac{P_j}{P_{\max}} t_j \quad (6-3)$$

where:

$$\sum_{j=1}^N \frac{P_j}{P_{\max}} t_j = \text{total effective full power seconds of operation up to the time of capsule removal}$$

An assessment of the thermal neutron flux levels within the surveillance capsules is obtained from the bare and cadmium-covered  $\text{Co}^{59} (n, \gamma) \text{Co}^{60}$  data by means of cadmium ratios and the use of a 37-barn 2200 m/sec cross section. Thus,

$$\phi_{Th} = \frac{R_{bare} D^{-1}}{\frac{N_0}{A} f_i Y \sigma \sum_{j=1}^N \frac{P_j}{P_{max}} (1 - e^{-\lambda t_j}) e^{-\lambda t_d}} \quad (6-4)$$

where:

$$D \text{ is defined as } \frac{R_{bare}}{R_{Cd \text{ covered}}}$$

#### 6-4 TRANSPORT ANALYSIS RESULTS

Calculated fast neutron ( $E > 1.0 \text{ Mev}$ ) exposure results for Surry Unit 1 are presented in Tables 6-3 through 6-10 and in Figures 6-3 through 6-7. Data is presented at several azimuthal locations on the inner radius of the pressure vessel as well as the center of each surveillance capsule.

In Tables 6-3 through 6-6 cycle-specific maximum neutron flux and fluence levels at  $0^\circ$ ,  $15^\circ$ ,  $30^\circ$ , and  $45^\circ$  on the pressure vessel inner radius are listed the first eight fuel cycles as well as projected to 60 years beyond issuance of the operating license. Similar data for the center of the surveillance capsules located at  $15^\circ$ ,  $25^\circ$ ,  $35^\circ$ , and  $45^\circ$  are given in Tables 6-7 through 6-10, respectively.

Graphical presentations of the plant specific fast neutron fluence at key locations on the pressure vessel are shown in Figure 6-3 as a function of full power operating time. The pressure vessel data is presented for the  $0^\circ$  location on the circumferential weld as well as for the  $45^\circ$  longitudinal welds. Fast neutron fluence at the surveillance capsule locations is shown as a function of full power operating time in Figure 6-4.



In regard to Figure 6-3 and 6-4, the solid portions of the fluence curves are based directly on the cycle-specific core loadings as of the end of cycle 8. The dashed portions of these curves, however, involve a projection into the future. As mentioned in Section 6-3, the neutron flux average over Cycle 8 was used to project future fluence levels.

It should be noted that implementation of a more severe low leakage pattern would act to reduce the projections of fluence at key locations. On the other hand, relaxation of the current low leakage patterns or a return to out-in fuel management would increase those projections.

In Figure 6-5, the azimuthal variation of maximum fast neutron ( $E > 1.0$  MeV) fluence at the inner radius of the pressure vessel is presented as a function of azimuthal angle. Data are presented for both current and projected end-of-life conditions. In Figure 6-6, the relative radial variation of fast neutron flux and fluence within the pressure vessel wall is presented. Similar data showing the relative axial variation of fast neutron flux and fluence over the beltline region of the pressure vessel is shown in Figure 6-7. A three-dimensional description of the fast neutron exposure of the pressure vessel wall can be constructed using the data given in Figures 6-5 through 6-7 along with the relation

$$\phi(R,\theta,Z) = \phi(\theta) F(R) G(Z)$$

where:  $\phi(R,\theta,Z)$  = Fast neutron fluence at location R,  $\theta$ , Z within the pressure vessel wall

$\phi(\theta)$  = Fast neutron fluence at azimuthal location  $\theta$  on the pressure vessel inner radius from Figure 6-5

$F(R)$  = Relative fast neutron flux at depth R into the pressure vessel from Figure 6-6

$G(Z)$  = Relative fast neutron flux at axial position  $Z$   
from Figure 6-7

Analysis has shown that the radial and axial variations within the vessel wall are relatively insensitive to the implementation of low leakage fuel management schemes. Thus, the above relationship provides a vehicle for a reasonable evaluation of fluence gradients within the vessel wall.

#### 6-5 DOSIMETRY RESULTS

The irradiation history of the Surry Unit 1 reactor is given in Table 6-11. The data were obtained from several sources including Nucleonics Week<sup>[16]</sup>, a Surry semi-annual operating report<sup>[17]</sup>, NUREG C020<sup>[18]</sup> and Virginia Power<sup>[19]</sup>. Measured saturated activities of the flux monitors contained in Capsules T, W, and V are listed in Tables 6-12 through 6-14, respectively. The measured results for Capsules T and W were derived from Battelle reports<sup>[3,4]</sup>, whereas those for Capsule V were obtained by Westinghouse. The data are presented as measured at the actual monitor radial locations as well as adjusted to the capsule radial (191.15 cm) and azimuthal center where possible. Adjustment factors for each monitor were obtained from reaction rate gradients through each capsule as calculated from the forward transport calculation described in Section 6-2.

In order to derive neutron flux and fluence levels from the measured disintegration rates, suitable spectrum-averaged reaction cross sections are required. The neutron energy spectrum at the radial and azimuthal center of each surveillance capsule, shown in Table 6-15, was taken from the forward calculation. The resulting spectrum-averaged cross sections for each of the five fast neutron reactions are given in Table 6-16.

The fast neutron ( $E > 1.0$  Mev) flux levels derived for Capsules T, W, and V are presented in Tables 6-12 through 6-14, respectively. The thermal neutron flux obtained from the cobalt-aluminum monitors is summarized in Table 6-17. Due to the relatively low thermal neutron flux at the capsule locations, no

burnout correction was made to any of the measured activities. The maximum error introduced by this assumption is estimated to be less than one percent for the  $\text{Ni}^{58}(\text{n,p})\text{Co}^{58}$  reaction and even less significant for all of the other fast reactions.

A comparison of the measured and calculated fast neutron fluence for each flux monitor of Capsules T, W, and V is shown in Table 6-18. Examination of the data in Table 6-18 shows that neutron fluences corresponding to the average of the monitors at each location agree within 5% of the calculated fluences based on the plant-specific power distributions.

It should be mentioned that, in the case of Capsule V, the excellent agreement between the measured fluences derived from the individual flux monitors and the calculated fluence is due largely to the use of the flux ratio,  $C_j$ , mentioned in Section 6-3. Recall that  $C_j$  accounts for the impact of power distribution changes on neutron monitor response. For example, low leakage core power distributions in cycles 6 and 8 caused the fast neutron ( $E > 1.0$  MeV) flux at the  $15^\circ$  surveillance capsule location to be 15-16 percent lower than the lifetime-average flux at that position. The  $\text{Co}^{58}$  product from the  $\text{Ni}^{58}$  n-p reaction has a half-life of only 71 days, which implies that the nickel monitor is probably not sensitive to the irradiation history dating back more than one fuel cycle. Without the power distribution correction factor, the derived flux from the nickel monitor would have been low compared to the other monitors having significantly longer-lived reaction products. Under these circumstances, the results from the nickel monitor would have been ignored.

A similar, but not quite as severe, under-prediction would have occurred if the flux was derived from the iron monitor without use of the  $C_j$  factor ( $\text{Mn}^{54}$  half-life is 312 days). Thus, one can see that meaningful results can be obtained from the entire set of neutron dosimetry when the power distribution correction is made. This correction may be even more important or necessary in future dosimetry analyses where Type I capsules, lacking the uranium and neptunium monitors, are examined.



## 6-6 SURVEILLANCE CAPSULE WITHDRAWAL SCHEDULES

As discussed in Section 6-4, plant specific fluence evaluations for the center of surveillance capsules located at 15°, 25°, 35°, and 45° were presented in Figure 6-4 for Surry Unit 1. The data presented on those curves represent the best available information upon which to base the future withdrawal schedules for capsules remaining in the Surry Unit 1 reactor.

In the past, withdrawal schedules have been based on the assumption of a constant exposure rate at the surveillance capsule center and a constant lead factor relating capsule exposure to maximum vessel exposure. With the widespread implementation of low leakage fuel management neither of these assumptions can be assumed to be universally valid. It becomes prudent, therefore, to utilize the actual anticipated capsule exposure in conjunction with appropriate materials properties data to establish capsule withdrawal dates that will provide experimental information that is of most benefit.

In evaluating future withdrawal schedules, it must be remembered that the fluence projections shown in Figure 6-4 assume continued operation with the low leakage fuel management scheme currently in place. The validity of this assumption should be verified as each new fuel cycle evolves and if significant changes occur withdrawal schedules should be adjusted accordingly.

## 6-7 INFLUENCE OF AN ENERGY DEPENDENT DAMAGE MODEL

The use of fast neutron fluence ( $E > 1.0$  MeV) to correlate measured materials property changes to the neutron exposure of the material for light water reactor applications has traditionally been accepted for development of damage trend curves as well as for implementation of trend curve data to assess vessel condition. In recent years, however, it has been suggested that an exposure model that accounts for differences in neutron energy spectra between surveillance capsule locations and positions within the vessel wall could lead to a reduction in the uncertainties associated with damage trend curves as well as to a more accurate evaluation of damage gradients through the pressure vessel wall.

Because of this potential shift away from a threshold fluence toward an energy dependent damage function for data correlation, ASTM Standard Practice E853 "Analysis and Interpretation of Light Water Reactor Surveillance Results", recommends reporting calculated displacements per iron atom (dPa) along with fluence ( $E > 1.0$  MeV) to provide a data base for future reference. The energy dependent dPa function to be used for this evaluation is specified in ASTM Standard Practice E693 "Characterizing Neutron Exposures in Ferritic Steels in Terms of Displacements per Atom (dPa)."

For the Surry Unit 1 pressure vessel, iron atom displacement rates at each surveillance capsule location and at positions within the vessel wall have been calculated. The analysis has indicated that for a given location the ratio of  $dPa/\phi(E > 1.0 \text{ MeV})$  is insensitive to changing core power distributions. That is, while implementation of low leakage loading patterns significantly impacts the magnitude and spatial distribution of the neutron field, changes in the relative neutron energy spectrum at a given location are of second order. The  $dPa/\phi(E > 1.0 \text{ MeV})$  ratios calculated for key locations in the Surry reactor geometry are given in Table 6-19. The data in Table 6-19 may be used in conjunction with the fast neutron fluence data provided in Section 6-4 to develop distributions of dPa within the surveillance capsules and the reactor pressure vessel.

TABLE 6-1

## 47 GROUP ENERGY STRUCTURE

| <u>Group</u> | <u>Lower Energy<br/>(Mev)</u> | <u>Group</u> | <u>Lower Energy<br/>(Mev)</u> |
|--------------|-------------------------------|--------------|-------------------------------|
| 1            | 14.19*                        | 25           | 0.183                         |
| 2            | 12.21                         | 26           | 0.111                         |
| 3            | 10.00                         | 27           | 0.0674                        |
| 4            | 8.61                          | 28           | 0.0409                        |
| 5            | 7.41                          | 29           | 0.0318                        |
| 6            | 6.07                          | 30           | 0.0261                        |
| 7            | 4.97                          | 31           | 0.0242                        |
| 8            | 3.68                          | 32           | 0.0219                        |
| 9            | 3.01                          | 33           | 0.0150                        |
| 10           | 2.73                          | 34           | $7.10 \times 10^{-3}$         |
| 11           | 2.47                          | 35           | $3.36 \times 10^{-3}$         |
| 12           | 2.37                          | 36           | $1.59 \times 10^{-3}$         |
| 13           | 2.35                          | 37           | $4.54 \times 10^{-4}$         |
| 14           | 2.23                          | 38           | $2.14 \times 10^{-4}$         |
| 15           | 1.92                          | 39           | $1.01 \times 10^{-4}$         |
| 16           | 1.65                          | 40           | $3.73 \times 10^{-5}$         |
| 17           | 1.35                          | 41           | $1.07 \times 10^{-5}$         |
| 18           | 1.00                          | 42           | $5.04 \times 10^{-6}$         |
| 19           | 0.821                         | 43           | $1.86 \times 10^{-6}$         |
| 20           | 0.743                         | 44           | $8.76 \times 10^{-7}$         |
| 21           | 0.608                         | 45           | $4.14 \times 10^{-7}$         |
| 22           | 0.498                         | 46           | $1.00 \times 10^{-7}$         |
| 23           | 0.369                         | 47           | 0.00                          |
| 24           | 0.298                         |              |                               |

\*The upper energy of group 1 is 17.33 Mev.



TABLE 6-2

## NUCLEAR PARAMETERS FOR NEUTRON FLUX MONITORS

| <u>Monitor<br/>Material</u> | <u>Reaction<br/>of Interest</u>                      | <u>Target<br/>Weight<br/>Fraction</u> | <u>Response<br/>Range</u>                | <u>Product<br/>Half-Life</u> | <u>Fission<br/>Yield<br/>(%)</u> |
|-----------------------------|------------------------------------------------------|---------------------------------------|------------------------------------------|------------------------------|----------------------------------|
| Copper                      | $\text{Cu}^{63}(\text{n}, \alpha)\text{Co}^{60}$     | 0.6917                                | $E > 4.7 \text{ Mev}$                    | 5.272 years                  |                                  |
| Iron                        | $\text{Fe}^{54}(\text{n}, \text{p})\text{Mn}^{54}$   | 0.058                                 | $E > 1.0 \text{ Mev}$                    | 312.2 days                   |                                  |
| Nickel                      | $\text{Ni}^{58}(\text{n}, \text{p})\text{Co}^{58}$   | 0.6827                                | $E > 1.0 \text{ Mev}$                    | 70.91 days                   |                                  |
| Uranium-238*                | $\text{U}^{238}(\text{n}, \text{f})\text{Cs}^{137}$  | 1.0                                   | $E > 0.4 \text{ Mev}$                    | 30.17 years                  | 6.0                              |
| Neptunium-237*              | $\text{Np}^{237}(\text{n}, \text{f})\text{Cs}^{137}$ | 1.0                                   | $E > 0.08 \text{ Mev}$                   | 30.17 years                  | 6.5                              |
| Cobalt-Aluminum*            | $\text{Co}^{59}(\text{n}, \gamma)\text{Co}^{60}$     | 0.0015                                | $0.4 \text{ eV} < E < 0.015 \text{ Mev}$ | 5.272 years                  |                                  |
| Cobalt-Aluminum             | $\text{Co}^{59}(\text{n}, \gamma)\text{Co}^{60}$     | 0.0015                                | $E < 0.015 \text{ Mev}$                  | 5.272 years                  |                                  |

\*Denotes that monitor is cadmium shielded.

TABLE 6-3

SURREY UNIT 1  
CALCULATED FAST NEUTRON ( $E > 1.0$  MeV) EXPOSURE AT THE PRESSURE  
VESSEL INNER RADIUS -  $0^\circ$  AZIMUTHAL ANGLE<sup>(a)</sup>

| Irradiation<br>Interval              | Elapsed<br>Irradiation<br>Time (EFPY) | Avg. Flux<br>(n/cm <sup>2</sup> sec) | Beltline Region<br>Cumulative Fluence (n/cm <sup>2</sup> ) |
|--------------------------------------|---------------------------------------|--------------------------------------|------------------------------------------------------------|
| CY-1                                 | 1.1                                   | $5.03 \times 10^{10}$                | $1.70 \times 10^{18}$                                      |
| CY-2                                 | 1.6                                   | $5.73 \times 10^{10}$                | $2.70 \times 10^{18}$                                      |
| CY-3                                 | 2.3                                   | $5.22 \times 10^{10}$                | $3.87 \times 10^{18}$                                      |
| CY-4                                 | 3.4                                   | $4.86 \times 10^{10}$                | $5.49 \times 10^{18}$                                      |
| CY-5                                 | 4.6                                   | $4.40 \times 10^{10}$                | $7.10 \times 10^{18}$                                      |
| CY-6                                 | 5.9                                   | $3.96 \times 10^{10}$                | $8.75 \times 10^{18}$                                      |
| CY-7                                 | 6.8                                   | $5.91 \times 10^{10}$                | $1.05 \times 10^{19}$                                      |
| CY-8 <sup>(b)</sup>                  | 8.0                                   | $4.05 \times 10^{10}$                | $1.20 \times 10^{19}$                                      |
| CY-9 + CY-10 <sup>(c)</sup>          | 10.3                                  | $4.05 \times 10^{10}$                | $1.49 \times 10^{19}$                                      |
| CY-11 + 6/25/2008 <sup>(d)</sup>     | 25.6                                  | $4.22 \times 10^{10}$                | $3.54 \times 10^{19}$                                      |
| 6/25/2008 + 5/25/2012 <sup>(e)</sup> | 28.8                                  | $4.22 \times 10^{10}$                | $3.96 \times 10^{19}$                                      |
| 5/25/2012 + 5/25/2032 <sup>(f)</sup> | 44.8                                  | $4.22 \times 10^{10}$                | $6.09 \times 10^{19}$                                      |

- (a) Applicable to the peak locations ( $0^\circ$ ,  $90^\circ$ ,  $180^\circ$ ,  $270^\circ$ ) on the intermediate and lower shell plates and the intermediate to lower shell circumferential weld.
- (b) Current neutron fluences are defined at the end of CY-8.
- (c) At the beginning of CY-11, the core thermal power will be uprated to 2546 MWth. Beyond the end of CY-8 a 80% capacity factor is assumed.
- (d) Exposure period from the onset of the uprating to the original license expiration date.
- (e) 5/25/2012 corresponds to 40 calendar years beyond issuance of the operating license and is the license expiration date.
- (f) 5/25/2032 corresponds to 60 calendar years beyond issuance of the operating license, illustrating the effect of a 20 year life extension.

TABLE 6-4

SURRY UNIT 1  
CALCULATED FAST NEUTRON ( $E > 1.0$  MeV) EXPOSURE AT THE PRESSURE  
VESSEL INNER RADIUS -  $15^\circ$  AZIMUTHAL ANGLE

| Irradiation<br>Interval              | Elapsed<br>Irradiation<br>Time (EFPY) | Avg. Flux<br>( $n/cm^2$ -sec) | Beltline Region<br>Cumulative Fluence ( $n/cm^2$ ) |
|--------------------------------------|---------------------------------------|-------------------------------|----------------------------------------------------|
| CY-1                                 | 1.1                                   | $2.40 \times 10^{10}$         | $8.12 \times 10^{17}$                              |
| CY-2                                 | 1.6                                   | $2.72 \times 10^{10}$         | $1.29 \times 10^{18}$                              |
| CY-3                                 | 2.3                                   | $2.49 \times 10^{10}$         | $1.84 \times 10^{18}$                              |
| CY-4                                 | 3.4                                   | $2.34 \times 10^{10}$         | $2.62 \times 10^{18}$                              |
| CY-5                                 | 4.6                                   | $2.06 \times 10^{10}$         | $3.38 \times 10^{18}$                              |
| CY-6                                 | 5.9                                   | $1.88 \times 10^{10}$         | $4.16 \times 10^{18}$                              |
| CY-7                                 | 6.8                                   | $2.50 \times 10^{10}$         | $4.92 \times 10^{18}$                              |
| CY-8 <sup>(a)</sup>                  | 8.0                                   | $1.88 \times 10^{10}$         | $5.62 \times 10^{18}$                              |
| CY-9 + CY-10 <sup>(b)</sup>          | 10.3                                  | $1.88 \times 10^{10}$         | $6.96 \times 10^{18}$                              |
| CY-11 + 6/25/2008 <sup>(c)</sup>     | 25.6                                  | $1.97 \times 10^{10}$         | $1.65 \times 10^{19}$                              |
| 6/25/2008 + 5/25/2012 <sup>(d)</sup> | 28.8                                  | $1.97 \times 10^{10}$         | $1.84 \times 10^{19}$                              |
| 5/25/2012 + 5/25/2032 <sup>(e)</sup> | 44.8                                  | $1.97 \times 10^{10}$         | $2.84 \times 10^{19}$                              |

- (a) Current neutron fluences are defined at the end of CY-8.
- (b) At the beginning of CY-11, the core thermal power will be uprated to 2546 MWth. Beyond the end of CY-8 a 80% capacity factor is assumed.
- (c) Exposure period from the onset of the uprating to the original license expiration date.
- (d) 5/25/2012 corresponds to 40 calendar years beyond issuance of the operating license and is the license expiration date.
- (e) 5/25/2032 corresponds to 60 calendar years beyond issuance of the operating license, illustrating the effect of a 20 year life extension.



TABLE 6-5

SURRY UNIT 1  
CALCULATED FAST NEUTRON ( $E > 1.0$  MeV) EXPOSURE AT THE PRESSURE  
VESSEL INNER RADIUS - 30° AZIMUTHAL ANGLE

| Irradiation<br>Interval              | Elapsed<br>Irradiation<br>Time (EFPY) | Avg. Flux<br>(n/cm <sup>2</sup> -sec) | Beltline Region<br>Cumulative Fluence (n/cm <sup>2</sup> ) |
|--------------------------------------|---------------------------------------|---------------------------------------|------------------------------------------------------------|
| CY-1                                 | 1.1                                   | $1.30 \times 10^{10}$                 | $4.40 \times 10^{17}$                                      |
| CY-2                                 | 1.6                                   | $1.54 \times 10^{10}$                 | $7.09 \times 10^{17}$                                      |
| CY-3                                 | 2.3                                   | $1.34 \times 10^{10}$                 | $1.01 \times 10^{18}$                                      |
| CY-4                                 | 3.4                                   | $1.30 \times 10^{10}$                 | $1.44 \times 10^{18}$                                      |
| CY-5                                 | 4.6                                   | $1.09 \times 10^{10}$                 | $1.84 \times 10^{18}$                                      |
| CY-6                                 | 5.9                                   | $1.02 \times 10^{10}$                 | $2.27 \times 10^{18}$                                      |
| CY-7                                 | 6.8                                   | $9.80 \times 10^9$                    | $2.56 \times 10^{18}$                                      |
| CY-8 <sup>(a)</sup>                  | 8.0                                   | $9.86 \times 10^9$                    | $2.93 \times 10^{18}$                                      |
| CY-9 + CY-10 <sup>(b)</sup>          | 10.3                                  | $9.86 \times 10^9$                    | $3.63 \times 10^{18}$                                      |
| CY-11 + 6/25/2008 <sup>(c)</sup>     | 25.6                                  | $1.03 \times 10^{10}$                 | $8.62 \times 10^{18}$                                      |
| 6/25/2008 + 5/25/2012 <sup>(d)</sup> | 28.8                                  | $1.03 \times 10^{10}$                 | $9.63 \times 10^{18}$                                      |
| 5/25/2012 + 5/25/2032 <sup>(e)</sup> | 44.8                                  | $1.03 \times 10^{10}$                 | $1.48 \times 10^{19}$                                      |

- (a) Current neutron fluences are defined at the end of CY-8.
- (b) At the beginning of CY-11, the core thermal power will be uprated to 2546 MWth. Beyond the end of CY-8 a 80% capacity factor is assumed.
- (c) Exposure period from the onset of the uprating to the original license expiration date.
- (d) 5/25/2012 corresponds to 40 calendar years beyond issuance of the operating license and is the license expiration date.
- (e) 5/25/2032 corresponds to 60 calendar years beyond issuance of the operating license, illustrating the effect of a 20 year life extension.

TABLE 6-6

SURREY UNIT 1  
CALCULATED FAST NEUTRON ( $E > 1.0$  MeV) EXPOSURE AT THE PRESSURE  
VESSEL INNER RADIUS - 45° AZIMUTHAL ANGLE<sup>(a)</sup>

| Irradiation<br>Interval              | Elapsed<br>Irradiation<br>Time (EFPY) | Avg. Flux<br>(n/cm <sup>2</sup> -sec) | Beltline Region<br>Cumulative Fluence (n/cm <sup>2</sup> ) |
|--------------------------------------|---------------------------------------|---------------------------------------|------------------------------------------------------------|
| CY-1                                 | 1.1                                   | $8.59 \times 10^9$                    | $2.91 \times 10^{17}$                                      |
| CY-2                                 | 1.6                                   | $1.05 \times 10^{10}$                 | $4.75 \times 10^{17}$                                      |
| CY-3                                 | 2.3                                   | $9.08 \times 10^9$                    | $6.78 \times 10^{17}$                                      |
| CY-4                                 | 3.4                                   | $8.71 \times 10^9$                    | $9.68 \times 10^{17}$                                      |
| CY-5                                 | 4.6                                   | $7.11 \times 10^9$                    | $1.23 \times 10^{18}$                                      |
| CY-6                                 | 5.9                                   | $6.86 \times 10^9$                    | $1.51 \times 10^{18}$                                      |
| CY-7                                 | 6.8                                   | $6.14 \times 10^9$                    | $1.70 \times 10^{18}$                                      |
| CY-8 <sup>(b)</sup>                  | 8.0                                   | $6.54 \times 10^9$                    | $1.94 \times 10^{18}$                                      |
| CY-9 + CY-10 <sup>(c)</sup>          | 10.3                                  | $6.54 \times 10^9$                    | $2.41 \times 10^{18}$                                      |
| CY-11 + 6/25/2008 <sup>(d)</sup>     | 25.6                                  | $6.82 \times 10^9$                    | $5.71 \times 10^{18}$                                      |
| 6/25/2008 → 5/25/2012 <sup>(e)</sup> | 28.8                                  | $6.82 \times 10^9$                    | $6.39 \times 10^{18}$                                      |
| 5/25/2012 → 5/25/2032 <sup>(f)</sup> | 44.8                                  | $6.82 \times 10^9$                    | $9.83 \times 10^{18}$                                      |

- (a) Applicable to the longitudinal welds at 45°, 135°, 225°, 315° in the peak axial flux.
- (b) Current neutron fluences are defined at the end of CY-8.
- (c) At the beginning of CY-11, the core thermal power will be uprated to 2546 MWth. Beyond the end of CY-8 a 80% capacity factor is assumed.
- (d) Exposure period from the onset of the uprating to the original license expiration date.
- (e) 5/25/2012 corresponds to 40 calendar years beyond issuance of the operating license and is the license expiration date.
- (f) 5/25/2032 corresponds to 60 calendar years beyond issuance of the operating license, illustrating the effect of a 20 year life extension.

TABLE 6-7

SURRY UNIT 1  
CALCULATED FAST NEUTRON ( $E > 1.0$  MeV) EXPOSURE AT THE 15° SURVEILLANCE  
CAPSULE CENTER

| Irradiation<br>Interval              | Elapsed<br>Irradiation<br>Time (EFPY) | Avg. Flux<br>( $n/cm^2$ -sec) | Beltline Region<br>Cumulative Fluence ( $n/cm^2$ ) |
|--------------------------------------|---------------------------------------|-------------------------------|----------------------------------------------------|
| CY-1                                 | 1.1                                   | $8.31 \times 10^{10}$         | $2.81 \times 10^{18}$                              |
| CY-2                                 | 1.6                                   | $9.42 \times 10^{10}$         | $4.46 \times 10^{18}$                              |
| CY-3                                 | 2.3                                   | $8.61 \times 10^{10}$         | $6.39 \times 10^{18}$                              |
| CY-4                                 | 3.4                                   | $8.11 \times 10^{10}$         | $9.08 \times 10^{18}$                              |
| CY-5                                 | 4.6                                   | $7.08 \times 10^{10}$         | $1.17 \times 10^{19}$                              |
| CY-6                                 | 5.9                                   | $6.47 \times 10^{10}$         | $1.44 \times 10^{19}$                              |
| CY-7                                 | 6.8                                   | $8.76 \times 10^{10}$         | $1.70 \times 10^{19}$                              |
| CY-8 <sup>(a)</sup>                  | 8.0                                   | $6.46 \times 10^{10}$         | $1.94 \times 10^{19}$                              |
| CY-9 + CY-10 <sup>(b)</sup>          | 10.3                                  | $6.46 \times 10^{10}$         | $2.40 \times 10^{19}$                              |
| CY-11 + 6/25/2008 <sup>(c)</sup>     | 25.6                                  | $6.74 \times 10^{10}$         | $5.67 \times 10^{19}$                              |
| 6/25/2008 + 5/25/2012 <sup>(d)</sup> | 28.8                                  | $6.74 \times 10^{10}$         | $6.34 \times 10^{19}$                              |
| 5/25/2012 + 5/25/2032 <sup>(e)</sup> | 44.8                                  | $6.74 \times 10^{10}$         | $9.74 \times 10^{19}$                              |

- (a) Current neutron fluences are defined at the end of CY-8.
- (b) At the beginning of CY-11, the core thermal power will be uprated to 2546 MWth. Beyond the end of CY-8 a 80% capacity factor is assumed.
- (c) Exposure period from the onset of the uprating to the original license expiration date.
- (d) 5/25/2012 corresponds to 40 calendar years beyond issuance of the operating license and is the license expiration date.
- (e) 5/25/2032 corresponds to 60 calendar years beyond issuance of the operating license, illustrating the effect of a 20 year life extension.



TABLE 6-8

SURRY UNIT 1  
CALCULATED FAST NEUTRON ( $E > 1.0$  MeV) EXPOSURE AT THE 25° SURVEILLANCE  
CAPSULE CENTER

| Irradiation<br>Interval              | Elapsed<br>Irradiation<br>Time (EFPY) | Avg. Flux<br>( $n/cm^2$ -sec) | Beltline Region<br>Cumulative Fluence ( $n/cm^2$ ) |
|--------------------------------------|---------------------------------------|-------------------------------|----------------------------------------------------|
| CY-1                                 | 1.1                                   | $5.26 \times 10^{10}$         | $1.78 \times 10^{18}$                              |
| CY-2                                 | 1.6                                   | $6.14 \times 10^{10}$         | $2.85 \times 10^{18}$                              |
| CY-3                                 | 2.3                                   | $5.40 \times 10^{10}$         | $4.06 \times 10^{18}$                              |
| CY-4                                 | 3.4                                   | $5.24 \times 10^{10}$         | $5.81 \times 10^{18}$                              |
| CY-5                                 | 4.6                                   | $4.48 \times 10^{10}$         | $7.44 \times 10^{18}$                              |
| CY-6                                 | 5.9                                   | $4.15 \times 10^{10}$         | $9.17 \times 10^{18}$                              |
| CY-7                                 | 6.8                                   | $4.17 \times 10^{10}$         | $1.04 \times 10^{19}$                              |
| CY-8 <sup>(a)</sup>                  | 8.0                                   | $4.02 \times 10^{10}$         | $1.19 \times 10^{19}$                              |
| CY-9 + CY-10 <sup>(b)</sup>          | 10.3                                  | $4.02 \times 10^{10}$         | $1.48 \times 10^{19}$                              |
| CY-11 + 6/25/2008 <sup>(c)</sup>     | 25.6                                  | $4.20 \times 10^{10}$         | $3.52 \times 10^{19}$                              |
| 6/25/2008 + 5/25/2012 <sup>(d)</sup> | 28.8                                  | $4.20 \times 10^{10}$         | $3.93 \times 10^{19}$                              |
| 5/25/2012 + 5/25/2032 <sup>(e)</sup> | 44.8                                  | $4.20 \times 10^{10}$         | $6.05 \times 10^{19}$                              |

(a) Current neutron fluences are defined at the end of CY-8.

(b) At the beginning of CY-11, the core thermal power will be uprated to 2546 MWth. Beyond the end of CY-8 a 80% capacity factor is assumed.

(c) Exposure period from the onset of the uprating to the original license expiration date.

(d) 5/25/2012 corresponds to 40 calendar years beyond issuance of the operating license and is the license expiration date.

(e) 5/25/2032 corresponds to 60 calendar years beyond issuance of the operating license, illustrating the effect of a 20 year life extension.

TABLE 6-9

SURRY UNIT 1  
CALCULATED FAST NEUTRON ( $E > 1.0$  MeV) EXPOSURE AT THE 35° SURVEILLANCE  
CAPSULE CENTER

| Irradiation<br>Interval              | Elapsed<br>Irradiation<br>Time (EFPY) | Avg. Flux<br>( $n/cm^2$ -sec) | Beltline Region<br>Cumulative Fluence ( $n/cm^2$ ) |
|--------------------------------------|---------------------------------------|-------------------------------|----------------------------------------------------|
| CY-1                                 | 1.1                                   | $3.56 \times 10^{10}$         | $1.21 \times 10^{18}$                              |
| CY-2                                 | 1.6                                   | $4.28 \times 10^{10}$         | $1.95 \times 10^{18}$                              |
| CY-3                                 | 2.3                                   | $3.71 \times 10^{10}$         | $2.78 \times 10^{18}$                              |
| CY-4                                 | 3.4                                   | $3.58 \times 10^{10}$         | $3.97 \times 10^{18}$                              |
| CY-5                                 | 4.6                                   | $2.93 \times 10^{10}$         | $5.05 \times 10^{18}$                              |
| CY-6                                 | 5.9                                   | $2.78 \times 10^{10}$         | $6.21 \times 10^{18}$                              |
| CY-7                                 | 6.8                                   | $2.58 \times 10^{10}$         | $6.99 \times 10^{18}$                              |
| CY-8 <sup>(a)</sup>                  | 8.0                                   | $2.68 \times 10^{10}$         | $7.99 \times 10^{18}$                              |
| CY-9 + CY-10 <sup>(b)</sup>          | 10.3                                  | $2.68 \times 10^{10}$         | $9.90 \times 10^{18}$                              |
| CY-11 → 6/25/2008 <sup>(c)</sup>     | 25.6                                  | $2.80 \times 10^{10}$         | $2.35 \times 10^{19}$                              |
| 6/25/2008 → 5/25/2012 <sup>(d)</sup> | 28.8                                  | $2.80 \times 10^{10}$         | $2.62 \times 10^{19}$                              |
| 5/25/2012 → 5/25/2032 <sup>(e)</sup> | 44.8                                  | $2.80 \times 10^{10}$         | $4.04 \times 10^{19}$                              |

- (a) Current neutron fluences are defined at the end of CY-8.
- (b) At the beginning of CY-11, the core thermal power will be uprated to 2546 MWth. Beyond the end of CY-8 a 80% capacity factor is assumed.
- (c) Exposure period from the onset of the uprating to the original license expiration date.
- (d) 5/25/2012 corresponds to 40 calendar years beyond issuance of the operating license and is the license expiration date.
- (e) 5/25/2032 corresponds to 60 calendar years beyond issuance of the operating license, illustrating the effect of a 20 year life extension.

TABLE 6-10

SURRY UNIT 1  
CALCULATED FAST NEUTRON ( $E > 1.0$  MeV) EXPOSURE AT THE 45° SURVEILLANCE  
CAPSULE CENTER

| Irradiation<br>Interval              | Elapsed<br>Irradiation<br>Time (EFPY) | Avg. Flux<br>(n/cm <sup>2</sup> -sec) | Beltline Region<br>Cumulative Fluence (n/cm <sup>2</sup> ) |
|--------------------------------------|---------------------------------------|---------------------------------------|------------------------------------------------------------|
| CY-1                                 | 1.1                                   | $2.79 \times 10^{10}$                 | $9.45 \times 10^{17}$                                      |
| CY-2                                 | 1.6                                   | $3.43 \times 10^{10}$                 | $1.55 \times 10^{18}$                                      |
| CY-3                                 | 2.3                                   | $2.95 \times 10^{10}$                 | $2.21 \times 10^{18}$                                      |
| CY-4                                 | 3.4                                   | $2.83 \times 10^{10}$                 | $3.15 \times 10^{18}$                                      |
| CY-5                                 | 4.6                                   | $2.29 \times 10^{10}$                 | $3.98 \times 10^{18}$                                      |
| CY-6                                 | 5.9                                   | $2.21 \times 10^{10}$                 | $4.91 \times 10^{18}$                                      |
| CY-7                                 | 6.8                                   | $1.97 \times 10^{10}$                 | $5.50 \times 10^{18}$                                      |
| CY-8 <sup>(a)</sup>                  | 8.0                                   | $2.10 \times 10^{10}$                 | $6.28 \times 10^{18}$                                      |
| CY-9 + CY-10 <sup>(b)</sup>          | 10.3                                  | $2.10 \times 10^{10}$                 | $7.78 \times 10^{18}$                                      |
| CY-11 → 6/25/2008 <sup>(c)</sup>     | 25.6                                  | $2.19 \times 10^{10}$                 | $1.84 \times 10^{19}$                                      |
| 6/25/2008 → 5/25/2012 <sup>(d)</sup> | 28.8                                  | $2.19 \times 10^{10}$                 | $2.06 \times 10^{19}$                                      |
| 5/25/2012 → 5/25/2032 <sup>(e)</sup> | 44.8                                  | $2.19 \times 10^{10}$                 | $3.16 \times 10^{19}$                                      |

(a) Current neutron fluences are defined at the end of CY-8.

(b) At the beginning of CY-11, the core thermal power will be uprated to 2546 MWth. Beyond the end of CY-8 a 80% capacity factor is assumed.

(c) Exposure period from the onset of the uprating to the original license expiration date.

(d) 5/25/2012 corresponds to 40 calendar years beyond issuance of the operating license and is the license expiration date.

(e) 5/25/2032 corresponds to 60 calendar years beyond issuance of the operating license, illustrating the effect of a 20 year life extension.



TABLE 6-11

IRRADIATION HISTORY OF SURRY UNIT 1  
REACTOR VESSEL SURVEILLANCE CAPSULE V

| <u>MONTH</u> | <u>YEAR</u> | <u>P<sub>J</sub></u><br><u>(MW)</u> | <u>P<sub>MAX</sub></u><br><u>(MW)</u> | <u>P<sub>J</sub>/P<sub>MAX</sub></u> | <u>IRRADIATION</u><br><u>TIME (DAY)</u> | <u>DECAY</u><br><u>TIME (DAY)</u> |
|--------------|-------------|-------------------------------------|---------------------------------------|--------------------------------------|-----------------------------------------|-----------------------------------|
| 7            | 1972        | 83                                  | 2441                                  | 0.034                                | 31                                      | 5202                              |
| 8            | 1972        | 83                                  | 2441                                  | 0.034                                | 31                                      | 5171                              |
| 9            | 1972        | 436                                 | 2441                                  | 0.178                                | 30                                      | 5141                              |
| 10           | 1972        | 0                                   | 2441                                  | 0.000                                | 31                                      | 5110                              |
| 11           | 1972        | 1                                   | 2441                                  | 0.000                                | 30                                      | 5080                              |
| 12           | 1972        | 1129                                | 2441                                  | 0.463                                | 31                                      | 5049                              |
| 1            | 1973        | 285                                 | 2441                                  | 0.117                                | 31                                      | 5018                              |
| 2            | 1973        | 1649                                | 2441                                  | 0.676                                | 28                                      | 4990                              |
| 3            | 1973        | 1416                                | 2441                                  | 0.580                                | 31                                      | 4959                              |
| 4            | 1973        | 1371                                | 2441                                  | 0.562                                | 30                                      | 4929                              |
| 5            | 1973        | 1361                                | 2441                                  | 0.557                                | 31                                      | 4898                              |
| 6            | 1973        | 1181                                | 2441                                  | 0.484                                | 30                                      | 4868                              |
| 7            | 1973        | 1838                                | 2441                                  | 0.753                                | 31                                      | 4837                              |
| 8            | 1973        | 1777                                | 2441                                  | 0.728                                | 31                                      | 4806                              |
| 9            | 1973        | 1250                                | 2441                                  | 0.512                                | 30                                      | 4776                              |
| 10           | 1973        | 674                                 | 2441                                  | 0.276                                | 31                                      | 4745                              |
| 11           | 1973        | 2073                                | 2441                                  | 0.849                                | 30                                      | 4715                              |
| 12           | 1973        | 0                                   | 2441                                  | 0.000                                | 31                                      | 4684                              |
| 1            | 1974        | 0                                   | 2441                                  | 0.000                                | 31                                      | 4653                              |
| 2            | 1974        | 0                                   | 2441                                  | 0.000                                | 28                                      | 4625                              |
| 3            | 1974        | 1047                                | 2441                                  | 0.429                                | 31                                      | 4594                              |
| 4            | 1974        | 2192                                | 2441                                  | 0.898                                | 30                                      | 4564                              |
| 5            | 1974        | 2073                                | 2441                                  | 0.849                                | 31                                      | 4533                              |
| 6            | 1974        | 2224                                | 2441                                  | 0.911                                | 30                                      | 4503                              |
| 7            | 1974        | 1400                                | 2441                                  | 0.574                                | 31                                      | 4472                              |
| 8            | 1974        | 2384                                | 2441                                  | 0.977                                | 31                                      | 4441                              |
| 9            | 1974        | 2095                                | 2441                                  | 0.858                                | 30                                      | 4411                              |
| 10           | 1974        | 1129                                | 2441                                  | 0.462                                | 31                                      | 4380 Capsule T Removed            |
| 11           | 1974        | 0                                   | 2441                                  | 0.000                                | 30                                      | 4350                              |
| 12           | 1974        | 0                                   | 2441                                  | 0.000                                | 31                                      | 4319                              |
| 1            | 1975        | 1                                   | 2441                                  | 0.000                                | 31                                      | 4288                              |
| 2            | 1975        | 1979                                | 2441                                  | 0.811                                | 28                                      | 4260                              |
| 3            | 1975        | 1853                                | 2441                                  | 0.751                                | 31                                      | 4229                              |
| 4            | 1975        | 2049                                | 2441                                  | 0.839                                | 30                                      | 4199                              |
| 5            | 1975        | 2302                                | 2441                                  | 0.943                                | 31                                      | 4168                              |
| 6            | 1975        | 2176                                | 2441                                  | 0.891                                | 30                                      | 4138                              |
| 7            | 1975        | 1799                                | 2441                                  | 0.737                                | 31                                      | 4107                              |
| 8            | 1975        | 2180                                | 2441                                  | 0.893                                | 31                                      | 4076                              |
| 9            | 1975        | 1971                                | 2441                                  | 0.807                                | 30                                      | 4046                              |
| 10           | 1975        | 0                                   | 2441                                  | 0.000                                | 31                                      | 4015                              |
| 11           | 1975        | 0                                   | 2441                                  | 0.000                                | 30                                      | 3985                              |
| 12           | 1975        | 1209                                | 2441                                  | 0.495                                | 31                                      | 3954                              |

TABLE 6-11 (Continued)

IRRADIATION HISTORY OF SURRY UNIT 1  
 REACTOR VESSEL SURVEILLANCE CAPSULE V

| <u>MONTH</u> | <u>YEAR</u> | <u>P<sub>J</sub></u><br><u>(MW)</u> | <u>P<sub>MAX</sub></u><br><u>(MW)</u> | <u>P<sub>J</sub>/P<sub>MAX</sub></u> | <u>IRRADIATION</u><br><u>TIME (DAY)</u> | <u>DECAY</u><br><u>TIME (DAY)</u> |
|--------------|-------------|-------------------------------------|---------------------------------------|--------------------------------------|-----------------------------------------|-----------------------------------|
| 1            | 1976        | 2430                                | 2441                                  | 0.995                                | 31                                      | 3923                              |
| 2            | 1976        | 2399                                | 2441                                  | 0.983                                | 29                                      | 3894                              |
| 3            | 1976        | 1634                                | 2441                                  | 0.669                                | 31                                      | 3863                              |
| 4            | 1976        | 1894                                | 2441                                  | 0.776                                | 30                                      | 3833                              |
| 5            | 1976        | 2022                                | 2441                                  | 0.828                                | 31                                      | 3802                              |
| 6            | 1976        | 2423                                | 2441                                  | 0.992                                | 30                                      | 3772                              |
| 7            | 1976        | 1777                                | 2441                                  | 0.728                                | 31                                      | 3741                              |
| 8            | 1976        | 1834                                | 2441                                  | 0.751                                | 31                                      | 3710                              |
| 9            | 1976        | 1914                                | 2441                                  | 0.784                                | 30                                      | 3680                              |
| 10           | 1976        | 1258                                | 2441                                  | 0.516                                | 31                                      | 3649                              |
| 11           | 1976        | 0                                   | 2441                                  | 0.000                                | 30                                      | 3619                              |
| 12           | 1976        | 0                                   | 2441                                  | 0.000                                | 31                                      | 3588                              |
| 1            | 1977        | 600                                 | 2441                                  | 0.246                                | 31                                      | 3557                              |
| 2            | 1977        | 2143                                | 2441                                  | 0.878                                | 28                                      | 3529                              |
| 3            | 1977        | 2414                                | 2441                                  | 0.989                                | 31                                      | 3498                              |
| 4            | 1977        | 861                                 | 2441                                  | 0.353                                | 30                                      | 3468                              |
| 5            | 1977        | 1319                                | 2441                                  | 0.540                                | 31                                      | 3437                              |
| 6            | 1977        | 2441                                | 2441                                  | 1.000                                | 30                                      | 3407                              |
| 7            | 1977        | 2389                                | 2441                                  | 0.979                                | 31                                      | 3376                              |
| 8            | 1977        | 2213                                | 2441                                  | 0.906                                | 31                                      | 3345                              |
| 9            | 1977        | 2402                                | 2441                                  | 0.984                                | 30                                      | 3315                              |
| 10           | 1977        | 2441                                | 2441                                  | 1.000                                | 31                                      | 3284                              |
| 11           | 1977        | 1623                                | 2441                                  | 0.665                                | 30                                      | 3254                              |
| 12           | 1977        | 1906                                | 2441                                  | 0.781                                | 31                                      | 3223                              |
| 1            | 1978        | 2436                                | 2441                                  | 0.998                                | 31                                      | 3192                              |
| 2            | 1978        | 2434                                | 2441                                  | 0.997                                | 28                                      | 3164                              |
| 3            | 1978        | 2437                                | 2441                                  | 0.998                                | 31                                      | 3133                              |
| 4            | 1978        | 1703                                | 2441                                  | 0.698                                | 30                                      | 3103 Capsule W Removed            |
| 5            | 1978        | 0                                   | 2441                                  | 0.000                                | 31                                      | 3072                              |
| 6            | 1978        | 0                                   | 2441                                  | 0.000                                | 30                                      | 3042                              |
| 7            | 1978        | 1708                                | 2441                                  | 0.700                                | 31                                      | 3011                              |
| 8            | 1978        | 2383                                | 2441                                  | 0.976                                | 31                                      | 2980                              |
| 9            | 1978        | 2148                                | 2441                                  | 0.880                                | 30                                      | 2950                              |
| 10           | 1978        | 2430                                | 2441                                  | 0.996                                | 31                                      | 2919                              |
| 11           | 1978        | 2425                                | 2441                                  | 0.993                                | 30                                      | 2889                              |
| 12           | 1978        | 785                                 | 2441                                  | 0.322                                | 31                                      | 2858                              |
| 1            | 1979        | 2287                                | 2441                                  | 0.937                                | 31                                      | 2827                              |
| 2            | 1979        | 2443                                | 2441                                  | 1.001                                | 28                                      | 2799                              |
| 3            | 1979        | 1097                                | 2441                                  | 0.450                                | 31                                      | 2768                              |
| 4            | 1979        | 0                                   | 2441                                  | 0.000                                | 30                                      | 2738                              |
| 5            | 1979        | 0                                   | 2441                                  | 0.000                                | 31                                      | 2707                              |
| 6            | 1979        | 0                                   | 2441                                  | 0.000                                | 30                                      | 2677                              |

TABLE 6-11 (Continued)

IRRADIATION HISTORY OF SURRY UNIT 1  
REACTOR VESSEL SURVEILLANCE CAPSULE V

| <u>MONTH</u> | <u>YEAR</u> | <u>P<sub>J</sub></u><br><u>(MW)</u> | <u>P<sub>MAX</sub></u><br><u>(MW)</u> | <u>P<sub>J</sub>/P<sub>MAX</sub></u> | <u>IRRADIATION</u><br><u>TIME (DAY)</u> | <u>DECAY</u><br><u>TIME (DAY)</u> |
|--------------|-------------|-------------------------------------|---------------------------------------|--------------------------------------|-----------------------------------------|-----------------------------------|
| 7            | 1979        | 0                                   | 2441                                  | 0.000                                | 31                                      | 2646                              |
| 8            | 1979        | 0                                   | 2441                                  | 0.000                                | 31                                      | 2615                              |
| 9            | 1979        | 0                                   | 2441                                  | 0.000                                | 30                                      | 2585                              |
| 10           | 1979        | 488                                 | 2441                                  | 0.200                                | 31                                      | 2554                              |
| 11           | 1979        | 2428                                | 2441                                  | 0.995                                | 30                                      | 2524                              |
| 12           | 1979        | 1463                                | 2441                                  | 0.599                                | 31                                      | 2493                              |
| 1            | 1980        | 1798                                | 2441                                  | 0.736                                | 31                                      | 2462                              |
| 2            | 1980        | 1582                                | 2441                                  | 0.648                                | 29                                      | 2433                              |
| 3            | 1980        | 0                                   | 2441                                  | 0.000                                | 31                                      | 2402                              |
| 4            | 1980        | 0                                   | 2441                                  | 0.000                                | 30                                      | 2372                              |
| 5            | 1980        | 1520                                | 2441                                  | 0.623                                | 31                                      | 2341                              |
| 6            | 1980        | 2361                                | 2441                                  | 0.967                                | 30                                      | 2311                              |
| 7            | 1980        | 2341                                | 2441                                  | 0.959                                | 31                                      | 2280                              |
| 8            | 1980        | 1405                                | 2441                                  | 0.576                                | 31                                      | 2249                              |
| 9            | 1980        | 859                                 | 2441                                  | 0.352                                | 30                                      | 2219                              |
| 10           | 1980        | 0                                   | 2441                                  | 0.000                                | 31                                      | 2188                              |
| 11           | 1980        | 0                                   | 2441                                  | 0.000                                | 30                                      | 2158                              |
| 12           | 1980        | 0                                   | 2441                                  | 0.000                                | 31                                      | 2127                              |
| 1            | 1981        | 0                                   | 2441                                  | 0.000                                | 31                                      | 2096                              |
| 2            | 1981        | 0                                   | 2441                                  | 0.000                                | 28                                      | 2068                              |
| 3            | 1981        | 0                                   | 2441                                  | 0.000                                | 31                                      | 2037                              |
| 4            | 1981        | 0                                   | 2441                                  | 0.000                                | 30                                      | 2007                              |
| 5            | 1981        | 0                                   | 2441                                  | 0.000                                | 31                                      | 1976                              |
| 6            | 1981        | 0                                   | 2441                                  | 0.000                                | 30                                      | 1946                              |
| 7            | 1981        | 1427                                | 2441                                  | 0.584                                | 31                                      | 1915                              |
| 8            | 1981        | 2340                                | 2441                                  | 0.959                                | 31                                      | 1884                              |
| 9            | 1981        | 1391                                | 2441                                  | 0.570                                | 30                                      | 1854                              |
| 10           | 1981        | 1981                                | 2441                                  | 0.812                                | 31                                      | 1823                              |
| 11           | 1981        | 2214                                | 2441                                  | 0.907                                | 30                                      | 1793                              |
| 12           | 1981        | 1441                                | 2441                                  | 0.590                                | 31                                      | 1762                              |
| 1            | 1982        | 2141                                | 2441                                  | 0.877                                | 31                                      | 1731                              |
| 2            | 1982        | 1120                                | 2441                                  | 0.459                                | 28                                      | 1703                              |
| 3            | 1982        | 2332                                | 2441                                  | 0.955                                | 31                                      | 1672                              |
| 4            | 1982        | 2021                                | 2441                                  | 0.828                                | 30                                      | 1642                              |
| 5            | 1982        | 2441                                | 2441                                  | 1.000                                | 31                                      | 1611                              |
| 6            | 1982        | 2437                                | 2441                                  | 0.998                                | 30                                      | 1581                              |
| 7            | 1982        | 2354                                | 2441                                  | 0.964                                | 31                                      | 1550                              |
| 8            | 1982        | 2311                                | 2441                                  | 0.947                                | 31                                      | 1519                              |
| 9            | 1982        | 2426                                | 2441                                  | 0.994                                | 30                                      | 1489                              |
| 10           | 1982        | 997                                 | 2441                                  | 0.408                                | 31                                      | 1458                              |
| 11           | 1982        | 2104                                | 2441                                  | 0.862                                | 30                                      | 1428                              |
| 12           | 1982        | 2374                                | 2441                                  | 0.973                                | 31                                      | 1397                              |



TABLE 6-11 (Continued)

IRRADIATION HISTORY OF SURRY UNIT 1  
REACTOR VESSEL SURVEILLANCE CAPSULE V

| <u>MONTH</u> | <u>YEAR</u> | <u>P<sub>J</sub></u><br><u>(MW)</u> | <u>P<sub>MAX</sub></u><br><u>(MW)</u> | <u>P<sub>J</sub>/P<sub>MAX</sub></u> | <u>IRRADIATION</u><br><u>TIME (DAY)</u> | <u>DECAY</u><br><u>TIME (DAY)</u> |
|--------------|-------------|-------------------------------------|---------------------------------------|--------------------------------------|-----------------------------------------|-----------------------------------|
| 1            | 1983        | 2373                                | 2441                                  | 0.972                                | 31                                      | 1366                              |
| 2            | 1983        | 510                                 | 2441                                  | 0.209                                | 28                                      | 1338                              |
| 3            | 1983        | 0                                   | 2441                                  | 0.000                                | 31                                      | 1307                              |
| 4            | 1983        | 0                                   | 2441                                  | 0.000                                | 30                                      | 1277                              |
| 5            | 1983        | 0                                   | 2441                                  | 0.000                                | 31                                      | 1246                              |
| 6            | 1983        | 554                                 | 2441                                  | 0.227                                | 30                                      | 1216                              |
| 7            | 1983        | 2370                                | 2441                                  | 0.971                                | 31                                      | 1185                              |
| 8            | 1983        | 2430                                | 2441                                  | 0.996                                | 31                                      | 1154                              |
| 9            | 1983        | 1574                                | 2441                                  | 0.645                                | 30                                      | 1124                              |
| 10           | 1983        | 1950                                | 2441                                  | 0.799                                | 31                                      | 1093                              |
| 11           | 1983        | 2330                                | 2441                                  | 0.955                                | 30                                      | 1063                              |
| 12           | 1983        | 2561                                | 2441                                  | 1.049                                | 31                                      | 1032                              |
| 1            | 1984        | 2264                                | 2441                                  | 0.927                                | 31                                      | 1001                              |
| 2            | 1984        | 1928                                | 2441                                  | 0.790                                | 29                                      | 972                               |
| 3            | 1984        | 1595                                | 2441                                  | 0.654                                | 31                                      | 941                               |
| 4            | 1984        | 1047                                | 2441                                  | 0.429                                | 30                                      | 911                               |
| 5            | 1984        | 1956                                | 2441                                  | 0.801                                | 31                                      | 880                               |
| 6            | 1984        | 1335                                | 2441                                  | 0.547                                | 30                                      | 850                               |
| 7            | 1984        | 1387                                | 2441                                  | 0.568                                | 31                                      | 819                               |
| 8            | 1984        | 1910                                | 2441                                  | 0.783                                | 31                                      | 788                               |
| 9            | 1984        | 1672                                | 2441                                  | 0.685                                | 30                                      | 758                               |
| 10           | 1984        | 0                                   | 2441                                  | 0.000                                | 31                                      | 727                               |
| 11           | 1984        | 0                                   | 2441                                  | 0.000                                | 30                                      | 697                               |
| 12           | 1984        | 62                                  | 2441                                  | 0.025                                | 31                                      | 666                               |
| 1            | 1985        | 1737                                | 2441                                  | 0.711                                | 31                                      | 635                               |
| 2            | 1985        | 2426                                | 2441                                  | 0.994                                | 28                                      | 607                               |
| 3            | 1985        | 2440                                | 2441                                  | 1.000                                | 31                                      | 576                               |
| 4            | 1985        | 2169                                | 2441                                  | 0.888                                | 30                                      | 546                               |
| 5            | 1985        | 1248                                | 2441                                  | 0.511                                | 31                                      | 515                               |
| 6            | 1985        | 2441                                | 2441                                  | 1.000                                | 30                                      | 485                               |
| 7            | 1985        | 2325                                | 2441                                  | 0.952                                | 31                                      | 454                               |
| 8            | 1985        | 860                                 | 2441                                  | 0.352                                | 31                                      | 423                               |
| 9            | 1985        | 2017                                | 2441                                  | 0.826                                | 30                                      | 393                               |
| 10           | 1985        | 2232                                | 2441                                  | 0.914                                | 31                                      | 362                               |
| 11           | 1985        | 2321                                | 2441                                  | 0.951                                | 30                                      | 332                               |
| 12           | 1985        | 2325                                | 2441                                  | 0.952                                | 31                                      | 301                               |
| 1            | 1986        | 1579                                | 2441                                  | 0.647                                | 31                                      | 270                               |
| 2            | 1986        | 1704                                | 2441                                  | 0.698                                | 28                                      | 242                               |
| 3            | 1986        | 2439                                | 2441                                  | 0.999                                | 31                                      | 211                               |
| 4            | 1986        | 2394                                | 2441                                  | 0.981                                | 30                                      | 181                               |
| 5            | 1986        | 1947                                | 2441                                  | 0.798                                | 10                                      | 171                               |

Decay time is referenced to 10/28/86.

TABLE 6-12

MEASURED FLUX MONITOR ACTIVITIES FROM  
SURRY UNIT 1, CAPSULE T<sup>+</sup>

| Reaction and Axial Location | Radial Location (cm) | Saturated Activity (DPS/gm) | Adjusted Saturated Activity (DPS/gm) | Measured $\phi$ ( $E > 1.0$ Mev) ( $n/cm^2$ -sec) |
|-----------------------------|----------------------|-----------------------------|--------------------------------------|---------------------------------------------------|
| $Fe^{54}(n,p)Mn^{54}$       |                      |                             |                                      |                                                   |
| Top                         |                      | $4.44 \times 10^6$          |                                      | $9.63 \times 10^{10}$                             |
| Middle                      |                      | $3.71 \times 10^6$          |                                      | $8.01 \times 10^{10}$                             |
| Bottom                      |                      | $3.45 \times 10^6$          |                                      | $7.45 \times 10^{10}$                             |
| Average                     |                      |                             |                                      | $8.36 \times 10^{10}$                             |
| $Ni^{58}(n,p)Co^{58}$       |                      |                             |                                      |                                                   |
| Middle                      | 190.92               | $6.11 \times 10^7$          | $5.84 \times 10^7$                   | $8.24 \times 10^{10}$                             |
| $Cu^{63}(n,\alpha)Co^{60}$  |                      |                             |                                      |                                                   |
| Top                         | 190.92               | $4.15 \times 10^5$          | $3.98 \times 10^5$                   | $8.84 \times 10^{10}$                             |
| Bottom                      | 190.92               | $4.24 \times 10^5$          | $4.06 \times 10^5$                   | $9.03 \times 10^{10}$                             |
| Average                     |                      |                             |                                      | $8.94 \times 10^{10}$                             |
| $Np^{237}(n,f)Cs^{137}$     |                      |                             |                                      |                                                   |
| Middle                      | 191.15               | $3.23 \times 10^7$          |                                      | $7.01 \times 10^{10}$                             |
| $U^{238}(n,f)Cs^{137*}$     |                      |                             |                                      |                                                   |
| Middle                      | 191.15               | $4.40 \times 10^6$          |                                      | $8.19 \times 10^{10}$                             |

\* $U^{238}(n,f)Cs^{137}$  activities corrected by a factor of 0.89 for 300 ppm U-235 impurity and Pu-239 buildup.

+ Neither measured activities nor radial locations were reported in Reference 3. Saturated activities were determined from the reported nuclear constants and resultant flux levels. Adjusted saturated activities are not given for the iron monitors because the radial and azimuthal position of the charpy chips is uncertain.

TABLE 6-13

MEASURED FLUX MONITOR ACTIVITIES FROM  
SURRY UNIT 1, CAPSULE W<sup>(a)</sup>

| Reaction and Axial Location | Radial Location (cm) | Saturated Activity (DPS/gm) | Adjusted Saturated Activity (DPS/gm) | Measured $\phi$ ( $E > 1.0$ Mev) ( $n/cm^2$ -sec) |
|-----------------------------|----------------------|-----------------------------|--------------------------------------|---------------------------------------------------|
| $Fe^{54}(n,p)Mn^{54}$       |                      |                             |                                      |                                                   |
| Mid Top                     |                      | $1.99 \times 10^6$          |                                      | $3.69 \times 10^{10}$                             |
| Mid Bottom                  |                      | $1.94 \times 10^6$          |                                      | $3.60 \times 10^{10}$                             |
| Average                     |                      |                             |                                      | $3.64 \times 10^{10}$                             |
| $Ni^{58}(n,p)Co^{58}$       |                      |                             |                                      |                                                   |
| Middle                      | 190.92               | $3.47 \times 10^7$          | $3.31 \times 10^7$                   | $4.10 \times 10^{10}$                             |
| $Cu^{53}(n,\alpha)Co^{60}$  |                      |                             |                                      |                                                   |
| Top                         | 190.92               | $2.38 \times 10^5$          | $2.28 \times 10^5$                   | $3.92 \times 10^{10}$                             |
| Bottom                      | 190.92               | $2.42 \times 10^5$          | $2.32 \times 10^5$                   | $3.98 \times 10^{10}$                             |
| Average                     |                      |                             |                                      | $3.95 \times 10^{10}$                             |

a) Neither measured activities nor radial locations were reported in Reference 4. Saturated activities were determined from the reported nuclear constants and resultant flux levels. Adjusted saturated activities are not given for the iron monitors because the radial and azimuthal position of the tensile specimen chips is uncertain.



TABLE 6-14

MEASURED FLUX MONITOR ACTIVITIES FROM  
SURREY UNIT 1, CAPSULE V

| <u>Reaction and<br/>Axial Location</u>   | <u>Radial<br/>Location<br/>(cm)</u> | <u>Saturated<br/>Activity<br/>(DPS/gm)</u> | <u>Adjusted<br/>Saturated<br/>Activity<br/>(DPS/gm)</u> | <u>Measured<br/><math>\phi</math> (<math>E &gt; 1.0</math> Mev)<br/>(n/cm<sup>2</sup>-sec)</u> |
|------------------------------------------|-------------------------------------|--------------------------------------------|---------------------------------------------------------|------------------------------------------------------------------------------------------------|
| $\text{Fe}^{54}(n,p)\text{Mn}^{54}$      |                                     |                                            |                                                         |                                                                                                |
| R-41                                     | 191.92                              | $3.13 \times 10^6$                         | $3.54 \times 10^6$                                      | $7.49 \times 10^{10}$                                                                          |
| H-10                                     | 191.92                              | $3.16 \times 10^6$                         | $3.74 \times 10^6$                                      | $7.89 \times 10^{10}$                                                                          |
| V-50                                     | 190.92                              | $3.86 \times 10^6$                         | $3.77 \times 10^6$                                      | $7.95 \times 10^{10}$                                                                          |
| Average                                  |                                     |                                            |                                                         | $7.78 \times 10^{10}$                                                                          |
| $\text{Ni}^{58}(n,p)\text{Co}^{58}$      |                                     |                                            |                                                         |                                                                                                |
| Middle                                   | 190.92                              | $5.45 \times 10^7$                         | $5.21 \times 10^7$                                      | $7.30 \times 10^{10}$                                                                          |
| $\text{Cu}^{63}(n,\alpha)\text{Co}^{60}$ |                                     |                                            |                                                         |                                                                                                |
| Top                                      | 190.92                              | $3.84 \times 10^5$                         | $3.68 \times 10^5$                                      | $8.17 \times 10^{10}$                                                                          |
| $\text{Np}^{237}(n,f)\text{Cs}^{137}$    |                                     |                                            |                                                         |                                                                                                |
| Middle                                   | 191.15                              | $3.22 \times 10^7$                         | $3.22 \times 10^7$                                      | $7.02 \times 10^{10}$                                                                          |
| $\text{U}^{238}(n,f)\text{Cs}^{137*}$    |                                     |                                            |                                                         |                                                                                                |
| Middle                                   | 191.15                              | $4.13 \times 10^6$                         | $4.13 \times 10^6$                                      | $7.69 \times 10^{10}$                                                                          |

\* $\text{U}^{238}(n,f)\text{Cs}^{137}$  activities corrected by a factor of 0.84 for 300 ppm U-235 impurity and Pu-239 buildup.

TABLE 6-15

CALCULATED NEUTRON ENERGY SPECTRA AT THE CENTER OF  
SURRY UNIT 1 SURVEILLANCE CAPSULESNeutron Flux (n/cm<sup>2</sup>-sec)

| <u>Group No.</u> | <u>15° Capsules T &amp; V</u> | <u>35° Capsule W</u>    |
|------------------|-------------------------------|-------------------------|
| 1                | 2.64 x 10 <sup>7</sup>        | 1.62 x 10 <sup>7</sup>  |
| 2                | 9.64 x 10 <sup>7</sup>        | 5.85 x 10 <sup>7</sup>  |
| 3                | 3.34 x 10 <sup>8</sup>        | 1.95 x 10 <sup>8</sup>  |
| 4                | 6.08 x 10 <sup>8</sup>        | 3.48 x 10 <sup>8</sup>  |
| 5                | 1.01 x 10 <sup>9</sup>        | 5.62 x 10 <sup>8</sup>  |
| 6                | 2.26 x 10 <sup>9</sup>        | 1.23 x 10 <sup>9</sup>  |
| 7                | 3.11 x 10 <sup>9</sup>        | 1.63 x 10 <sup>9</sup>  |
| 8                | 6.17 x 10 <sup>9</sup>        | 3.01 x 10 <sup>9</sup>  |
| 9                | 5.40 x 10 <sup>9</sup>        | 2.48 x 10 <sup>9</sup>  |
| 10               | 6.97 x 10 <sup>9</sup>        | 1.99 x 10 <sup>9</sup>  |
| 11               | 5.16 x 10 <sup>9</sup>        | 2.30 x 10 <sup>9</sup>  |
| 12               | 2.57 x 10 <sup>9</sup>        | 1.14 x 10 <sup>9</sup>  |
| 13               | 7.81 x 10 <sup>8</sup>        | 3.45 x 10 <sup>8</sup>  |
| 14               | 3.82 x 10 <sup>9</sup>        | 1.68 x 10 <sup>9</sup>  |
| 15               | 9.81 x 10 <sup>9</sup>        | 4.29 x 10 <sup>9</sup>  |
| 16               | 1.25 x 10 <sup>10</sup>       | 5.30 x 10 <sup>9</sup>  |
| 17               | 1.18 x 10 <sup>10</sup>       | 7.73 x 10 <sup>9</sup>  |
| 18               | 3.52 x 10 <sup>10</sup>       | 1.43 x 10 <sup>10</sup> |
| 19               | 2.52 x 10 <sup>10</sup>       | 9.97 x 10 <sup>9</sup>  |
| 20               | 1.22 x 10 <sup>10</sup>       | 4.82 x 10 <sup>9</sup>  |
| 21               | 3.78 x 10 <sup>10</sup>       | 1.44 x 10 <sup>10</sup> |

Note: These spectra were obtained from the forward DOT calculation using a design basis core power distribution with a core thermal power rating of 2900 MWt.

TABLE 6-15 (Continued)

CALCULATED NEUTRON ENERGY SPECTRA AT THE CENTER OF  
SURRY UNIT 1 SURVEILLANCE CAPSULESNeutron Flux (n/cm<sup>2</sup>-sec)

| <u>Group No.</u> | <u>15° Capsules T &amp; V</u> | <u>35° Capsule W</u>    |
|------------------|-------------------------------|-------------------------|
| 22               | 2.90 x 10 <sup>10</sup>       | 1.09 x 10 <sup>10</sup> |
| 23               | 3.40 x 10 <sup>10</sup>       | 1.29 x 10 <sup>10</sup> |
| 24               | 3.09 x 10 <sup>10</sup>       | 1.16 x 10 <sup>10</sup> |
| 25               | 3.99 x 10 <sup>10</sup>       | 1.50 x 10 <sup>10</sup> |
| 26               | 3.87 x 10 <sup>10</sup>       | 1.44 x 10 <sup>10</sup> |
| 27               | 3.07 x 10 <sup>10</sup>       | 1.14 x 10 <sup>10</sup> |
| 28               | 2.27 x 10 <sup>10</sup>       | 8.37 x 10 <sup>9</sup>  |
| 29               | 7.49 x 10 <sup>9</sup>        | 2.77 x 10 <sup>9</sup>  |
| 30               | 4.19 x 10 <sup>9</sup>        | 1.55 x 10 <sup>9</sup>  |
| 31               | 9.18 x 10 <sup>9</sup>        | 3.36 x 10 <sup>9</sup>  |
| 32               | 5.52 x 10 <sup>9</sup>        | 2.01 x 10 <sup>9</sup>  |
| 33               | 1.29 x 10 <sup>10</sup>       | 4.74 x 10 <sup>9</sup>  |
| 34               | 1.97 x 10 <sup>10</sup>       | 7.24 x 10 <sup>9</sup>  |
| 35               | 3.03 x 10 <sup>10</sup>       | 1.04 x 10 <sup>10</sup> |
| 36               | 2.52 x 10 <sup>10</sup>       | 9.21 x 10 <sup>9</sup>  |
| 37               | 3.81 x 10 <sup>10</sup>       | 1.39 x 10 <sup>10</sup> |
| 38               | 2.18 x 10 <sup>10</sup>       | 7.94 x 10 <sup>9</sup>  |
| 39               | 2.35 x 10 <sup>10</sup>       | 8.52 x 10 <sup>9</sup>  |
| 40               | 3.17 x 10 <sup>10</sup>       | 1.15 x 10 <sup>10</sup> |
| 41               | 3.87 x 10 <sup>10</sup>       | 1.39 x 10 <sup>10</sup> |
| 42               | 2.22 x 10 <sup>10</sup>       | 7.95 x 10 <sup>9</sup>  |
| 43               | 2.69 x 10 <sup>10</sup>       | 9.63 x 10 <sup>9</sup>  |
| 44               | 1.78 x 10 <sup>10</sup>       | 6.37 x 10 <sup>9</sup>  |
| 45               | 1.50 x 10 <sup>10</sup>       | 5.37 x 10 <sup>9</sup>  |
| 46               | 2.88 x 10 <sup>10</sup>       | 1.03 x 10 <sup>10</sup> |
| 47               | 5.30 x 10 <sup>10</sup>       | 1.91 x 10 <sup>10</sup> |



TABLE 6-16

SPECTRUM AVERAGED REACTION CROSS-SECTIONS AT THE  
CENTER OF SURRY UNIT 1 SURVEILLANCE CAPSULES

| <u>Reaction</u>                          | <u><math>\bar{\sigma}</math> (barns)</u>  |                                  |
|------------------------------------------|-------------------------------------------|----------------------------------|
|                                          | <u>Capsules T &amp; V</u><br><u>(15°)</u> | <u>Capsule W</u><br><u>(35°)</u> |
| $\text{Cu}^{63}(n,\alpha)\text{Co}^{60}$ | 0.00068                                   | 0.00088                          |
| $\text{Fe}^{54}(n,p)\text{Mn}^{54}$      | 0.074                                     | 0.086                            |
| $\text{Ni}^{58}(n,p)\text{Co}^{58}$      | 0.100                                     | 0.114                            |
| $\text{U}^{238}(n,f)$                    | 0.354                                     |                                  |
| $\text{Np}^{237}(n,f)$                   | 2.79                                      |                                  |

$$\bar{\sigma} = \frac{\int_0^{\infty} \sigma(E) \phi(E) dE}{\int_{1.0 \text{ Mev}}^{\infty} \phi(E) dE}$$

TABLE 6-17

## THERMAL NEUTRON FLUX DATA FROM CAPSULES T, W, AND V

| Capsule | Axial Location | Saturated Activity (DPS/gm) |                    | $\phi_{th}$<br>(n/cm <sup>2</sup> -sec) | Adjusted $\phi_{th}$<br>(n/cm <sup>2</sup> -sec) |
|---------|----------------|-----------------------------|--------------------|-----------------------------------------|--------------------------------------------------|
|         |                | Bare                        | Cd-Covered         |                                         |                                                  |
| T       | Top            | $7.32 \times 10^7$          | $2.76 \times 10^7$ | $8.04 \times 10^{10}$                   | $6.47 \times 10^{10}$                            |
|         | Middle         | $6.34 \times 10^7$          | $2.27 \times 10^7$ | $7.18 \times 10^{10}$                   | $5.77 \times 10^{10}$                            |
|         | Bottom         | $6.87 \times 10^7$          | $2.57 \times 10^7$ | $7.59 \times 10^{10}$                   | $6.10 \times 10^{10}$                            |
| W       | Top            | $2.35 \times 10^7$          | $1.05 \times 10^7$ | $2.29 \times 10^{10}$                   | $1.83 \times 10^{10}$                            |
|         | Middle         | $2.35 \times 10^7$          | $7.56 \times 10^6$ | $2.81 \times 10^{10}$                   | $2.24 \times 10^{10}$                            |
|         | Bottom         | $2.63 \times 10^7$          | $9.60 \times 10^6$ | $2.95 \times 10^{10}$                   | $2.34 \times 10^{10}$                            |
| V       | Top            | $5.30 \times 10^7$          | $2.42 \times 10^7$ | $5.08 \times 10^{10}$                   | $4.08 \times 10^{10}$                            |
|         | Middle         | $4.33 \times 10^7$          | $1.66 \times 10^7$ | $4.71 \times 10^{10}$                   | $3.78 \times 10^{10}$                            |
|         | Bottom         | $4.47 \times 10^7$          | $1.70 \times 10^7$ | $4.89 \times 10^{10}$                   | $3.93 \times 10^{10}$                            |

TABLE 6-18

COMPARISON OF MEASURED AND CALCULATED FAST NEUTRON  
FLUENCES FOR CAPSULES T, W, AND V\*

| <u>Capsule</u> | <u>Reaction</u>                          | <u>Irradiation<br/>Time<br/>(EFPS)</u> | <u>φ (E&gt;1.0 MeV)<br/>(n/cm<sup>2</sup>)</u> |                         |
|----------------|------------------------------------------|----------------------------------------|------------------------------------------------|-------------------------|
|                |                                          |                                        | <u>Measured</u>                                | <u>Calculated</u>       |
| T              | Fe <sup>54</sup> (n,p)Mn <sup>54</sup>   | 3.39 x 10 <sup>7</sup>                 | 2.83 x 10 <sup>18</sup>                        |                         |
|                | Ni <sup>58</sup> (n,p)Co <sup>58</sup>   |                                        | 2.79 x 10 <sup>18</sup>                        |                         |
|                | Cu <sup>63</sup> (n,α)Co <sup>60</sup>   |                                        | 3.03 x 10 <sup>18</sup>                        |                         |
|                | Np <sup>237</sup> (n,f)Cs <sup>137</sup> |                                        | 2.38 x 10 <sup>18</sup>                        |                         |
|                | U <sup>238</sup> (n,f)Cs <sup>137</sup>  |                                        | 2.78 x 10 <sup>18</sup>                        |                         |
|                | Average                                  |                                        | 2.76 x 10 <sup>18</sup>                        | 2.81 x 10 <sup>18</sup> |
| W              | Fe <sup>54</sup> (n,p)Mn <sup>54</sup>   | 1.07 x 10 <sup>8</sup>                 | 3.89 x 10 <sup>18</sup>                        |                         |
|                | Ni <sup>58</sup> (n,p)Co <sup>58</sup>   |                                        | 4.39 x 10 <sup>18</sup>                        |                         |
|                | Cu <sup>63</sup> (n,α)Co <sup>60</sup>   |                                        | 4.23 x 10 <sup>18</sup>                        |                         |
|                | Average                                  |                                        | 4.17 x 10 <sup>18</sup>                        | 3.97 x 10 <sup>18</sup> |
| V              | Fe <sup>54</sup> (n,p)Mn <sup>54</sup>   | 2.53 x 10 <sup>8</sup>                 | 1.97 x 10 <sup>19</sup>                        |                         |
|                | Ni <sup>58</sup> (n,p)Co <sup>58</sup>   |                                        | 1.85 x 10 <sup>19</sup>                        |                         |
|                | Cu <sup>63</sup> (n,α)Co <sup>60</sup>   |                                        | 2.07 x 10 <sup>19</sup>                        |                         |
|                | Np <sup>237</sup> (n,f)Cs <sup>137</sup> |                                        | 1.78 x 10 <sup>19</sup>                        |                         |
|                | U <sup>238</sup> (n,f)Cs <sup>137</sup>  |                                        | 1.94 x 10 <sup>19</sup>                        |                         |
|                | Average                                  |                                        | 1.92 x 10 <sup>19</sup>                        | 1.94 x 10 <sup>19</sup> |

\* Measured data have been adjusted to the radial and azimuthal center of the capsule where possible. In addition, corrections were made to the U<sup>238</sup> monitor activities to account for the U<sup>235</sup> impurity and build-in of Pu<sup>239</sup>.



TABLE 6-19

dPa/ $\phi$ (E > 1.0 MeV) RATIOS FOR SURRY UNIT 1

| <u>Location</u>            | <u>dPa/<math>\phi</math>(E &gt; 1.0 MeV)</u> |
|----------------------------|----------------------------------------------|
| 15° CAPSULE                | $1.69 \times 10^{-21}$                       |
| 25° CAPSULE                | $1.65 \times 10^{-21}$                       |
| 35° CAPSULE                | $1.63 \times 10^{-21}$                       |
| 45° CAPSULE                | $1.62 \times 10^{-21}$                       |
| VESSEL INNER RADIUS (0°)   | $1.62 \times 10^{-21}$                       |
| VESSEL 1/4 THICKNESS (0°)  | $1.87 \times 10^{-21}$                       |
| VESSEL 3/4 THICKNESS (0°)  | $2.95 \times 10^{-21}$                       |
| VESSEL INNER RADIUS (45°)  | $1.66 \times 10^{-21}$                       |
| VESSEL 1/4 THICKNESS (45°) | $1.92 \times 10^{-21}$                       |
| VESSEL 3/4 THICKNESS (45°) | $3.08 \times 10^{-21}$                       |

NOTE: RATIOS ARE IN UNITS OF  
 [DISPLACEMENTS PER ATOM]/[n/cm<sup>2</sup>]




Figure 6-1 Surry Unit 1 Reactor Geometry




Figure 6-2. Reactor Vessel Surveillance Capsule






Figure 6-3 Surry Unit 1 Maximum Fast Neutron (E > 1.0 MeV) Fluence at the Beltline Weld Locations as a Function of Full Power Operating Time




Figure 6-4 Surry Unit 1 Maximum Fast Neutron ( $E > 1.0$  MeV) Fluence at the Center of the Surveillance Capsules as a Function of Full Power Operating Time




Figure 6-5 Surry Unit 1 Maximum Fast Neutron ( $E > 1.0$  MeV) Fluence at the Pressure Vessel Inner Radius as a Function of Azimuthal Angle






Figure 6-6 Surry Unit 1 Relative Radial Distribution of Fast Neutron ( $E > 1.0$  MeV) Flux and Fluence within the Pressure Vessel Wall




Figure 6-7 Surry Unit 1 Relative Axial Variation of Fast Neutron ( $E > 1.0$  MeV) Flux and Fluence within the Pressure Vessel Wall

SECTION 7  
SURVEILLANCE CAPSULE WITHDRAWAL SCHEDULE

The following withdrawal schedule per ASTM E185-82 is recommended for future capsules to be removed from the Surry Unit 1 reactor vessel.

| <u>Capsule</u> | <u>Vessel Location (deg)</u> | <u>Withdrawal Time<sup>[a]</sup></u> | <u>Estimated Fluence (n/cm<sup>2</sup>)</u> |
|----------------|------------------------------|--------------------------------------|---------------------------------------------|
| T              | 285°                         | 1.07 (removed)                       | $2.81 \times 10^{18}$ [b]                   |
| W              | 55°                          | 3.39 (removed)                       | $3.97 \times 10^{18}$ [b]                   |
| V              | 165°                         | 8.02 (removed)                       | $1.94 \times 10^{19}$ [b]                   |
| X              | 65°                          | 21.2                                 | $2.78 \times 10^{19}$                       |
| Z              | 245°                         | 28.8                                 | $3.78 \times 10^{19}$ [c]                   |
| S              | 295°                         | standby (d)                          | --                                          |
| Y              | 305°                         | standby (d)                          | --                                          |
| U              | 45°                          | standby (d)                          | --                                          |

- a. Effective full power years from plant startup
- b. Actual Fluence
- c. Approximate maximum neutron fluence on vessel inner wall at 32 EFPY.
- d. During 20 year inservice inspection capsules should possibly be transferred to higher flux capsule location.

The surveillance weld represents the Surry Unit 1 reactor vessel lower shell vertical weld seam (L2) which is located at 45° azimuthal position where the maximum neutron fluence after long operating times (30 to 40 EFPY) will be approximately  $6$  to  $8 \times 10^{18}$  n/cm<sup>2</sup>. The data obtained for capsule V therefore represents a fluence for seam (L2) which will be well beyond any fluence experienced by seam (L2). Since the surveillance weld is typical of other welds in the beltline region because it was fabricated with Linde 80 flux, data from this weld to be obtained at 21.2 and 28.8 EFPY will be useful in further assessing this type of weld for normal operating life and plant life extension.



It should be noted that the Point Beach Unit 1 vessel surveillance program contains a surveillance weld which was fabricated with the same heat of weld wire (72445) and type of flux (Linde 80) as the Surry Unit 1 intermediate to lower shell girth weld. Data from this weld<sup>[20]</sup> shows a  $\Delta RT_{NDT}$  of 165 to 180°F at a neutron fluence of approximately  $2.1 \times 10^{19}$  n/cm<sup>2</sup> and an upper shelf energy of approximately 55 ft-lbs. It is recommended that future weld test results from the Point Beach Unit 1 surveillance program be considered when evaluating the Surry Unit 1 reactor vessel at later times in life.

SECTION 8  
REFERENCES

1. Yanichko, S. E., "Virginia Electric and Power Company Surry Unit No. 1 Reactor Vessel Radiation Surveillance Program" WCAP-7723, July 1971.
2. ASTM E185-73 "Practice for Surveillance Tests for Nuclear Reactor Vessels" in ASTM Standards, Part 10 (1973), American Society for Testing and Materials, Philadelphia, Pa., 1973.
3. Perrin, J. S., etal, "Surry Unit No. 1 Pressure Vessel Irradiation Capsule Program: Examination and Analysis of Capsule T," Battelle Columbus Laboratories, June 24, 1975.
4. Perrin, J. S., etal, "Surry Unit No. 1 Nuclear Plant Reactor Pressure Vessel Surveillance Program: Examination and Analysis of Capsule W," Battelle Columbus Laboratories Report BCL-585-8R, March 30, 1979.
5. Lowe, A. L. "Reactor Pressure Vessel and Surveillance Program Materials Licensing Information for Surry Units 1 and 2," Babcock and Wilcox Report BAW-1909, March, 1986.
6. Proposed Revision 2 to Regulatory Guide 1.99 "Radiation Damage to Reactor Vessel Materials," U.S. Nuclear Regulatory Commission, February, 1986.
7. Soltesz, R. G., Disney, R. K., Jedruch, J., and Zeigler, S. L., "Nuclear Rocket Shielding Methods, Modification, Updating and Input Data Preparation. Vol. 5 - Two-Dimensional Discrete Ordinates Transport Technique," WANL-PR(LL)034, Vol. 5, August 1970.
8. SAILOR RSIC Data Library Collection "DLC-76, Coupled, Self-shielded, 47 Neutron, 20 Gamma-ray, P3, Cross Section Library for Light Water Reactors."

9. Furchi, E. L., Perone, V. A., Weaver, M., and Wrights, G. N., "Surry Units 1 and 2 Reactor Vessel Fluence and  $RT_{PTS}$  Evaluations," WCAP-11015, December 1985.
10. Benchmark Testing of Westinghouse Neutron Transport Analysis Methodology - to be published.
11. ASTM Designation E261-77, "Standard Method for Determining Neutron Flux, Fluence, and Spectra by Radioactivation Techniques," in ASTM Standards (1983), Section 12, Nuclear Standards, pp. 76-87, American Society for Testing and Materials, Philadelphia, Pa., 1983.
12. ASTM Designation E262-77, "Standard Method for Measuring Thermal Neutron Flux by Radioactivation Techniques," in ASTM Standards (1983), Section 12, Nuclear Standards, pp. 88-96, American Society for Testing and Materials, Philadelphia, Pa., 1983.
13. ASTM Designation E263-82, "Standard Method for Determining Fast-Neutron Flux Density by Radioactivation of Iron," in ASTM Standards (1983), Section 12, Nuclear Standards, pp. 97-102, American Society for Testing and Materials, Philadelphia, Pa., 1983.
14. ASTM Designation 481-78, "Standard Method of Measuring Neutron-Flux Density by Radioactivation of Cobalt and Silver," in ASTM Standards (1983), Section 12, Nuclear Standards, pp. 228-235, American Society for Testing and Materials, Philadelphia, Pa., 1983.
15. ASTM Designation E264-82, "Standard Method for Determining Fast-Neutron Flux Density by Radioactivation of Nickel," in ASTM Standards (1983), Section 12, Nuclear Standards, pp. 103-107, American Society for Testing and Materials, Philadelphia, Pa., 1983.
16. Nucleonics Week, October 1972 and November 1972 issues.
17. Docket 50280-160, "Surry Power Station Units 1 and 2 Semi-Annual Operating Report, SOR-2, for the period January 1, 1973 - June 30, 1973" (Virginia Electric and Power Company, Richmond).



18. "Licensed Operating Reactors Status Summary Report," NUREG 0020, May 1974 through June 1986.
19. Private communication from Vivian Jones of Virginia Electric and Power Company to V. A. Perone of Westinghouse (December 18, 1986).
20. Yanichko, S. E., et al, "Analysis of Capsule T from the Wisconsin Electric Power Company Point Beach Nuclear Plant Unit No. 1 Reactor Vessel Radiation Surveillance Program," WCAP-10736, December 1984.