

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-I-87-46

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region I staff on this date.

Facility: Philadelphia Electric Co.	Licensee Emergency Classification:
Peach Bottom Unit 3	<input type="checkbox"/> Notification of Unusual Event
DN 50-278	<input type="checkbox"/> Alert
Delta, Pennsylvania	<input type="checkbox"/> Site Area Emergency
	<input type="checkbox"/> General Emergency
	<input checked="" type="checkbox"/> Not Applicable

Subject: WATCHMAN ASLEEP

A plant auxiliary operator and the Shift Superintendent found a security watchman asleep at the Unit 3 drywell access at 3:45 a.m. on May 29, 1987. The watchman was escorted offsite by the sargeant of the guards, and his employment was terminated. A search of the Unit 3 drywell area found no abnormalities. The licensee is investigating the incident and the residents are reviewing their actions.

The State of Maryland and the Commonwealth of Pennsylvania have been informed.

CONTACTS:	J. Linville	R. Gallo
	488-1122	488-1225

DISTRIBUTION:

H. St.	MNBB	Phillips	E/W	Willste	Mail: ADM:DMB
Chairman Zech EDO	NRR	IE	NMSS	DOT:Trans only	
Comm. Bernthal PA		OIA	RES		
Comm. Roberts	ELD		AEOD	NRC Ops Crt	
Comm. Asselstine					
Comm. Carr					

ACRS	Air Rights	INPO----
SECY	SP	NSAC----
CA		
PDR	Regional Offices _____	TMI Resident Section _____
		RI Resident Office _____
		Licensee: _____
		(Reactor Licensees)

Region I Form 83
(Rev. July 1986)

B706040208 B70529
PDR I&E
PNO-I-87-046 PDR

1.30
di K-34