

**THE
B&W OWNERS GROUP**
**Transient Assessment
Committee**

**BASIS FOR RAISING ARMING THRESHOLD
FOR ANTICIPATORY REACTOR
TRIP ON TURBINE TRIP**

Babcock & Wilcox
a McDermott company

8609240144 860910
PDR TOPRP EMVBW
C PDR

BAW-1893A

77-1159289-01

AUGUST 1986

BASIS FOR RAISING ARMING THRESHOLD
FOR ANTICIPATORY REACTOR
TRIP ON TURBINE TRIP

BABCOCK & WILCOX
Nuclear Power Division
P. O. Box 10935
Lynchburg, Virginia 24506-0935

Babcock & Wilcox
a McDermott company

BAW-1893A
77-1159289-01
AUGUST 1986

BASIS FOR RAISING ARMING THRESHOLD
FOR ANTICIPATORY REACTOR
TRIP ON TURBINE TRIP

by
C. W. Tally
J. A. Weimer



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

April 25, 1986

J. H. Taylor
MAY 10 1986

Mr. J. H. Taylor, Manager, Licensing
Babcock & Wilcox Company
3315 Old Forest Road
Post Office Box 1260
Lynchburg, Virginia 24505-1260

Dear Mr. Taylor:

SUBJECT: ACCEPTANCE FOR REFERENCING OF LICENSING TOPICAL REPORT BAW-1893,
"BASIS FOR RAISING ARMING THRESHOLD FOR ANTICIPATORY REACTOR TRIP
ON TURBINE TRIP"

The Nuclear Regulatory Commission (NRC) staff has completed its review of the Babcock & Wilcox Licensing Topical Report BAW-1893 entitled, "Basis For Raising Arming Threshold For Anticipatory Reactor Trip On Turbine Trip," that was prepared for the B&W Owners Group. The report discusses the effect of the power threshold for the anticipatory reactor trip (ART) on turbine trips and power runbacks in B&W reactors. The report describes the impact of the turbine trip ART power level threshold on reactor trip frequency, the plant transient data, the analysis methodology, and the results that were obtained.

The staff finds the report to be acceptable for referencing in license applications to the extent specified and under the limitations delineated in the report and the associated NRC evaluation, which is enclosed. The evaluation defines the basis for acceptance of the report.

The staff does not intend to repeat its review of the matters described in the report and found acceptable when the report appears as a reference in license applications, except to assure that the material presented is applicable to the specific plant involved. The staff's acceptance applies only to the matters described in the report.

In accordance with procedures established in NUREG-0390, it is requested that B&W publish an accepted version of this report within three months of receipt of this letter. The accepted version shall incorporate this letter and the enclosed evaluation after the title page. The accepted version shall include an -A (designating accepted) following the report identification symbol.

Should the staff's criteria or regulations change such that its conclusions as to the acceptability of the report are invalidated, B&W and/or the applicants

CONTACT:
Daniel Fieno
RSB/DPL-B
x27742


J. H. Taylor

- 2 -

April 26, 1986

referencing the topical report will be expected to revise and resubmit their respective documentation, or submit justification for the continued effective applicability of the topical report without revision of their respective documentation.

Sincerely,


Dennis M. Crutchfield, Assistant Director
for Technical Support
Division of PWR Licensing-B

Enclosure:
Safety Evaluation

cc: C. Rossi
G. Lainas

ENCLOSURE

SAFETY EVALUATION OF TOPICAL REPORT BAW-1893, "BASIS FOR RAISING ARMING THRESHOLD FOR ANTICIPATORY TRIP ON TURBINE TRIP"

I. INTRODUCTION

This Babcock & Wilcox (B&W) report was submitted on behalf of the B&W Owners Group to justify increasing the anticipatory reactor trip (ART) setpoint on turbine trip from its current value of 20% power to 45% power. The current value of the 20% power ART setpoint on turbine trip was based on changes required by the staff (Ref. 1) subsequent to the TMI accident to reduce challenges to and opening of the power operated relief valve (PORV). Two other changes that are pertinent to this report were required: (1) raising the PORV setpoint from 2255 psig to 2450 psig and (2) lowering the high pressure reactor trip setpoint from 2355 psig to 2300 psig. These modifications have met the NRC requirements that (1) the PORV will open less than 5% of the time for all anticipated overpressure transients (Ref. 2, Item II.K.3.7) and (2) the probability of a small-break LOCA (SBLOCA), caused by a stuck-open PORV, will be less than 0.001 per reactor-year (Ref. 2, Item II.K.3.2) which is based on the WASH-1400 (Ref. 3) median probability of a SBLOCA (Sequence S₂). Although these TMI required modifications have met the objectives of reducing challenges to and opening of the PORV during anticipated high pressure transients, they have increased the frequency of reactor trips. Each reactor trip results in a challenge to plant safety systems and any reduction in reactor trip frequency will contribute to overall plant safety as well as plant availability.

The report states that a number of turbine trips would not have resulted in a reactor trip if more margin had been available in the ART power level setpoint. The report further states that the present analysis demonstrates that the NRC requirements would be met with the ART power level setpoint at 45% power rather than at 20% power. In fact, the report states that these requirements on PORV openings would be met regardless of whether or not ART is implemented. Moreover, if the high pressure reactor trip setpoint is increased from 2300 psig to 2355 psig, an additional reduction in reactor trip frequency would be possible. The total reduction in reactor trip frequency is estimated to be about 10%. The B&W report (Ref. 4) on raising the high pressure reactor trip setpoint has been evaluated by the staff (Ref. 5). This staff safety evaluation report concluded that it was acceptable to raise this high pressure reactor trip setpoint from 2300 psig to 2355 psig. This increased high pressure reactor trip setpoint is assumed in the analyses performed in support of raising the turbine trip ART power level threshold to 45%.

The report discusses the post-TMI turbine trip/reactor trip data base and the impact on the reactor trip frequency. A discussion is presented of the analysis methodology. The results of the present study are used to justify the turbine trip ART proposed threshold power level of 45%.

The staff evaluation of this licensing topical report follows.

II. EVALUATION.

A. Impact of Previous and Proposed Turbine Trip ART Power Threshold

The report discusses the response of B&W plants to turbine trips. Prior to the TMI accident, a turbine trip caused a reactor power runback. For some plants successful runbacks were demonstrated for power levels as high as 100%. However, these runbacks were dependent, to some degree, on the PORV opening. Since the TMI accident, the turbine trip ART, among other changes, was instituted to reduce challenges to the PORV. This turbine trip ART now results in a reactor trip whenever the turbine trips and the reactor power level is 20% or higher. Although the NRC requirements on PORV challenges are met by the various post-TMI changes, an undesired side-effect of increased frequency of reactor trip and consequent challenges to the plant safety system has occurred. The data presented in the report show that 52 turbine trips occurred in the period from January 1, 1980 to January 1, 1985. Twelve of these trips occurred between power levels of 20% to 40%. Raising the turbine trip ART power level threshold has the potential for reducing the reactor trip frequency without affecting PORV opening frequency. Based on our review, we concur with the applicant that the analysis of plant data on reactor trips caused by turbine trips demonstrates that reactor trip frequency increased as a result of TMI modifications.

B&W evaluated the potential for reactor trip reduction for (1) increasing the high pressure reactor trip setpoint by 55 psi back to the original FSAR value of 2355 psig (Ref. 4) and (2) increasing the power level threshold for the turbine trip ART from 20% to 45%. The first change would provide more margin to the reactor trip setpoint and would allow some minor plant upsets to either avoid reactor trip or provide the operator sufficient time to perform an action which would not result in a reactor trip. The second change, in conjunction with an increased high pressure reactor trip setpoint, would not require a reactor trip for some additional low power turbine trips. We find that the analysis of potential reactor trip frequency reduction is reasonable and demonstrates from the data in the report and Reference 4 that a number of high pressure and anticipatory reactor trips could be avoided. That is, a potential 10% reduction in reactor trip frequency may be possible.

B. Results of Analysis of Turbine Trip ART

The POWERTRAIN (Ref. 6) program was used by B&W to evaluate the factors which are important in power runback on turbine trips without a reactor trip. These factors lead to the determination of the highest initial power level or threshold for the turbine trip ART. Factors evaluated

included (1) the total bypass steam flow, (2) the moderator temperature coefficient, (3) the initial power level, (4) the power runback rate, and (5) the pressurizer spray flow rate. The cases evaluated were turbine trips with runbacks modeled with a reactor closely resembling Rancho Seco. A successful runback case was defined by B&W to have the following desirable performance characteristics: (1) no reactor trip on high reactor system pressure, (2) no auxiliary feedwater actuation on low steam generator level, (3) no steam generator overfill affecting steam quality, and (4) no loss of subcooled margin as affected by reactor system pressure and temperature. Since the modeling, assumptions, and criteria used in the analysis considers the principal factors in a turbine trip with runback, the staff concludes that the methodology used is, therefore, acceptable. In addition, since the POWERTRAIN program has been reviewed and approved by the staff (approval letter dated November 28, 1983) the staff concludes that its use is, therefore, acceptable.

From the POWERTRAIN analyses it was determined that the total steam bypass flow was one of the most important factors in determining whether or not a reactor power runback on turbine trip was successful. The total steam bypass flow included turbine bypass flow, atmospheric vent flow and flow through at least one bank of Main Steam Safety Valves (MSSV). At least one bank of MSSVs will open at the high pressure reactor trip setpoint of 2355 psig (Ref. 5). In the analyses,

if the core power decreases because of control rod insertions and negative moderator temperature coefficient, to the total steam bypass flow before the high pressure reactor trip setpoint is reached, sufficient primary to secondary heat transfer exists to stop the reactor system pressure from increasing. These results presented show that the larger the total steam bypass flow the higher the power threshold that can be tolerated by the turbine trip ART.

The reactor coolant temperature and pressure increases during the early stages of a turbine trip. The moderator (and Doppler) reactivity coefficient are negative throughout a reactor cycle. These negative coefficients, therefore, help to reduce the reactor power and thus help the reactor power runback process caused by control rod insertion. POWERTRAIN results were obtained for near beginning-of-cycle (BOC) and end-of-cycle (EOC) cases which demonstrates this effect. Therefore, for the same total steam bypass flow and control rod insertion rate, successful reactor power runbacks are more probable the more negative the moderator temperature coefficient becomes.

The initial power level is a factor in determining a successful power runback along with the total steam bypass flow and moderator temperature coefficient. POWERTRAIN results established, as expected, that successful reactor power runbacks from higher initial reactor power would require higher total steam bypass flow. POWERTRAIN results were also obtained for two other factors. These were the Integrated Control

System (ICS) runback rate on control rod insertion and the pressurizer spray flow rates. The ICS runback rate was changed from 20% per minute to 50% per minute but this did not change the overall control rod insertion rate during the important early stages of a turbine trip transient where the moderator temperature coefficient is also important. Therefore, the indicated ICS runback rate had negligible influence on the reactor power runback on a turbine trip event. Similarly, the pressurizer spray rate was found to have very little effect in turning around the reactor coolant pressure in the time period of interest.

The conclusions of this POWERTRAIN analysis were that, for a given control rod reactivity insertion rate and high pressure reactor trip setpoint, the most important factors, in determining whether or not a reactor power runback, on turbine trip is successful, are the initial power level and the total steam bypass flow. The study also concluded that the negative moderator temperature coefficient helped the reactor power runback especially at EOC when it is more negative than say, for example, near BOC. The report concluded that other factors had negligible impact on reactor power runbacks. Since the results in the report were obtained with the approved POWERTRAIN program and since the principal effects were evaluated, the staff concludes that the POWERTRAIN results are, therefore, acceptable.

The report states that the results are applicable to all the B&W 177 fuel assembly (FA) plants. Based on the review of the analyses presented, we concur on the applicability of these results to the 177 FA B&W plants. The report concludes that, for the total steam bypass flow credited in the analysis, the reactor trip on turbine trip power level threshold could be increased from 20% to 45% with a high pressure reactor trip setpoint of 2355 psig. Based on the review of the plant data presented in the report and the POWERTRAIN results, the staff concludes that the B&W assessment regarding the raising of the turbine trip ART power level threshold to 45% is, therefore, acceptable.

C. Effect of Turbine Trip ART Proposed Power Level Threshold
On PORV Openings and NRC Requirements

Although the results presented in the report are applicable to all B&W 177 FA plants, differences in a number of plant parameters may not lead to successful reactor power runbacks on turbine trips with a turbine trip ART power level threshold of 45% and a high pressure reactor trip setpoint of 2355 psig. An unsuccessful power runback will lead to a high pressure trip. Therefore, it is essential to evaluate the effect of these potential additional high pressure trips on the frequency of PORV openings and to determine whether or not NRC requirements on PORV openings are met.

The report assumes that 30% of the reactor power runbacks will be unsuccessful. Assuming the same turbine trip frequency at power levels equal to or below 45% as occurred in the post-TMI period, the report finds the following:

$$\frac{12 \text{ (turbine trips)} * .30 \text{ (reactor trip/turbine trip)}}{5 \text{ (years)} * 7 \text{ (reactors)}}$$
$$= 0.10 \frac{\text{high pressure trips}}{\text{reactor year}}$$

Then the high pressure trip frequency would increase from 1.86 per reactor-year (Ref. 4) to (1.86 + .10) or 1.96 per reactor-year. The number of PORV openings from high pressure trip events would now be:

$$\frac{1.96 \text{ events}}{\text{year}} * 1.0 * 10^{-5} \frac{\text{PORV opens}}{\text{event}} = 1.96 * 10^{-5} \frac{\text{PORV openings}}{\text{year}}$$

The total number of PORV openings per reactor-year for all events, as given in Reference 4, is 8.06×10^{-2} and is negligibly affected by this change. The results of Reference 4 on PORV openings and the probability of a SBLOCA (Sequence S₂) remain applicable. Therefore, the staff concludes that the requirements of Item II.K.3.2 and Item II.K.3.7 of NUREG-0737 (Ref. 2) are met even if a number of reactor power runbacks are unsuccessful at the proposed turbine trip ART power threshold of 45%.

III. CONCLUSION

The staff has reviewed the Babcock & Wilcox licensing topical report on the turbine trip ART power level threshold and concludes that it is

acceptable to increase the turbine trip ART power level threshold for B&W plants from 20% to 45%. The staff concludes that this power level threshold change meets the NRC requirements of NUREG-0737, Items II.K.3.2 and II.K.3.7 regarding PORV openings and PORV caused SBLOCA while benefitting plants by potentially reducing the reactor trip frequency. Similarly, the requirements on this matter embodied in IE Bulletin 79-05B are also met.

Accordingly, the staff concludes that the licensing topical report may be referenced in licensing submittals by the B&W Owners Group members.

Due to the modeling, assumptions made, and data used, the results presented in the report, as is the case for any analysis, may contain uncertainties. Therefore, as plant experience is accumulated with the proposed turbine trip ART power threshold, the staff should be kept informed of any significant deviations from the results presented in the report.

IV. REFERENCES

1. "Nuclear Incident at Three Mile Island - Supplement," IE Bulletin 79-05B, April 21, 1979.
2. "Clarification of TMI Action Plan Requirements," NUREG-0737, November 1980.
3. "Reactor Safety Study - An Assessment of Accident Risks in U. S. Commercial Nuclear Power Plant," WASH-1400, 1975.

4. "Justification For Raising Setpoint For Reactor Trips on High Pressure," BAW-1890, September 1985.
5. Letter from D. M. Crutchfield (NRC) to J. H. Taylor (B&W) on "Acceptance For Referencing of Licensing Topical Report BAW-1890, 'Justification For Raising Setpoint For Reactor Trip on High Pressure,'" April 1986.
6. "POWERTRAIN: Hybrid Computer Simulation of a Babcock & Wilcox Nuclear Power Plant," N. S. Yee and J. A. Weimar, BAW-10149, Rev. 1, November 1981.

CONTENTS

	Page
1. BACKGROUND	1-1
2. POTENTIAL BENEFITS	2-1
3. ANALYSIS	3-1
3.1. Analysis Objectives	3-1
3.2. Performance Criteria	3-1
3.3. Analysis Summary Description	3-2
3.4. Analysis Results	3-2
3.4.1. Total Bypass Flow	3-2
3.4.2. Moderator Coefficient	3-4
3.4.3. Initial Power Level	3-4
3.4.4. RCS Runback Rate	3-5
3.4.5. Pressurizer Spray	3-5
4. CONCLUSIONS FROM ANALYSIS	4-1
5. APPLICATION OF RESULTS	5-1
5.1. Plant Specific Application	5-1
5.2. Analysis Limitations	5-2
6. RECOMMENDATIONS	6-1
7. REFERENCES	7-1

List of Tables

Table

3-1. Tabulation of Power Train Cases	3-7
5-1. Turbine Bypass Capacities	5-4
5-2. Main Steam Safety Valve Arrangements	5-4
5-3. Available Total Bypass Capacities Prior to Reaching 2355 psig Trip	5-5
5-4. Estimated Initial Power Levels for Runbacks on Turbine Trip	5-5

CONTENTS (CONT'D)

List of Figures

Figure	Page
1-1. Anticipatory Reactor Trips on Turbine Trip for B&W Plants	1-3
3-1. POWER TRAIN Results Turbine Trip With Runback - Case #6 (15% Bypass, 59% Power EOC)	3-8
3-2. POWER TRAIN Results - Case #6 (15% Bypass, 59% Power, EOC) vs. Case #7 (25% Bypass, 70% Power, EOC)	3-9
3-3. POWER TRAIN Results - Case #5 (15% Bypass, 59% Power, MOC) vs. Case #6 (15% Bypass, 59% Power, EOC)	3-10
3-4. POWER TRAIN Results - Case #1 (15% Bypass, 30% Power, BOC) vs. Case #2 (15% Bypass, 40% Power, BOC)	3-11
3-5. POWER TRAIN Results - Case #3 (15% BP, 40% PWR, 191 GPM PZR Spray) vs. Case #4 (15% BP, 40% PWR, 382 GPM PZR Spray)	3-12

1. Background

Prior to the TMI-2 accident, B&W plants responded to a turbine trip by initiating a plant runback. Successful runbacks from power levels as high as 100% were demonstrated for some B&W plants. After TMI-2, the NRC required that B&W plants implement an automatic reactor trip on turbine trip for the purpose of reducing challenges to the PORV. This Anticipatory Reactor Trip (ART) was installed in all B&W plants and set to function for power levels above 20%. This value was selected because it was anticipated that with a high pressure trip setpoint of 2300 psig and PORV setpoint of 2450 psig, runbacks attempted from higher initial power levels would result in reactor trips on high pressure.

A consequence of implementing the turbine trip ART is that all turbine trips which occur at initial power levels above 20% now result in reactor trips. The B&W Owners Group Transient Assessment Program (TAP) records show that during the period January 1, 1980 through January 1, 1985, anticipatory trips due to turbine trips occurred 52 times. Twelve of these trips occurred with the initial reactor power at or below 40% (see Figure 1-1). Operating experience and a recent study addressing the setpoint for reactor trip on high pressure (reference 1) indicate that tripping the reactor for all turbine trips which occur at power levels greater than 20 percent results in unnecessary challenges to plant safety systems. These challenges are considered unnecessary because:

1. It is possible for B&W plants to accommodate a turbine trip from some power levels higher than 20 percent without a reactor trip on high pressure. Therefore, tripping the


reactor for those turbine trips which would not otherwise cause a reactor trip results in unnecessary challenges to safety systems.

2. The probability of opening the PORV as a consequence of a turbine trip from any power level is very small whether the ART is implemented or not. Therefore, tripping the reactor on every turbine trip for the purpose of reducing challenges to the PORV is unnecessary.

The B&WOG is committed to reducing reactor trips for the purpose of improving plant availability and safety. Raising the arming threshold for the turbine trip ART to a power level consistent with a plant's runback capability would result in fewer reactor trips. For this reason, the B&WOG initiated this study to determine the initial power level from which a successful runback on turbine trip could be accomplished.

Figure 1-1.

ANTICIPATORY REACTOR TRIPS ON TURBINE TRIP FOR B&W PLANTS 1980-1984



2. POTENTIAL BENEFITS

As noted in the previous section, raising the arming threshold for the turbine trip ART to a power level consistent with a plant's runback capability would result in a reduction in reactor trips. Section five of this report discusses the potential reduction in reactor trips which could be achieved. Based on assumptions of an ART arming threshold of 45 percent power and turbine trip frequency similar to previous years (1980-84), it is estimated that a reduction of .24 trips per reactor year could be achieved. This represents a reduction in average trip frequency for B&W plants of approximately five percent when compared to the 1980-84 average of 5.3 trips per reactor year.

3. ANALYSIS

3.1. Analysis Objectives

The primary purpose of this generic study was to determine an upper limit for initial power level from which a successful plant runback on turbine trip could be accomplished. The analysis was performed using the digital code POWER TRAIN configured to model a plant closely resembling Rancho Seco. In addition to investigating different power levels, cases were run with changes in various plant parameters. The objectives of this parameterization effort were to:

- a. Determine which plant parameters are vital to a successful runback
- b. Provide guidance relative to potential modifications which could enhance successful runback probability
- c. Develop guidance for plant specific application of the results

3.2. Performance Criteria

The following criteria were established to define a successful runback on turbine trip:

<u>Desired Performance</u>	<u>Limiting Parameter for runback transient</u>
No reactor trip	High RC pressure
No AFW actuation	Low Steam Generator level
No OTSG overflow	Steam Quality
No loss of subcooled margin	RC pressure and temperature

3.3. Analysis Summary Description

A number of cases were investigated to predict maximum RC pressure during a turbine trip with reactor runback using the POWER TRAIN code. The parameters varied for these cases were:

- a. Total bypass steam flow
- b. Moderator coefficient (a function of burnup)
- c. Initial power level
- d. Runback rate
- e. Pressurizer spray flow rate.

The cases analyzed are identified in Table 3-1. In all cases, the transient analyzed was a turbine trip with runback. Case numbers six and seven demonstrate the effect of variation in total bypass steam flow. Case number seven was also used to investigate the effect of ICS runback rate. Case numbers five and six demonstrate the effect of moderator coefficient. Case numbers one and two show the effect of initial power level. Case numbers three and four were run to investigate the effect of pressurizer spray.

3.4. Analysis Results

3.4.1. Total Bypass Flow

For this analysis, total bypass flow was defined as the sum of flow through all the open steam paths available prior to reaching the high pressure trip setpoint. Total bypass flow for the 2300 psig trip setpoint condition was the sum of turbine bypass plus atmospheric vent flow. When the RCS pressure was allowed to increase above 2300 psig (up to 2355 psig), steam pressure rose above 1050 psig and at least one bank of Main Steam Safety Valves (MSSVs) was open. Thus, at a 2355 psig trip setpoint, total bypass flow included at least one bank of MSSVs in addition to the turbine bypass and atmospheric vents.

The analysis showed that total bypass flow was one of the dominating parameters affecting successful runback. A typical RC pressure profile for the runback transient shows that pressure

levels out and begins to decrease when the percent core thermal power is approximately equal to the total percent bypass flow. (See Figure 3-1). Thus, the higher the bypass flow prior to reaching the high pressure trip setpoint the higher the initial power level that can be tolerated.

For the cases analyzed, when the RCS pressure reached 2300 psig, the total rated bypass flow* was 15% (or 25%).** To avoid a high pressure trip at a 2300 psig trip setpoint, thermal power had to decrease to a value corresponding to the actual bypass flow before 2300 psig was reached. At a 2355 psig trip setpoint the total bypass included an additional 28% flow due to the opening of the first bank of MSSVs. This allowed for a much higher power level for a successful runback.

In this analysis, when the core thermal power decreased to a value corresponding to this total bypass (i.e., -43% or -53%) prior to reaching a 2355 psig RCS pressure, a sufficient primary to secondary heat balance existed and the RC pressure stopped increasing. Should a second bank of MSSVs open before a 2355 psig RCS pressure is reached, a higher initial power runback could be tolerated. In fact, any increase in bypass steam flow would increase the allowable initial power level.

Case numbers six and seven were analyzed to support the above conclusions. Case number six (59% power, 43%) resulted in a successful runback (at a 2355 psig setpoint) with RC pressure approaching 2350 psig about the same time the thermal power decreased below 46%. Case number seven was run to confirm that increasing the bypass flow would allow a higher initial power level. In case number seven, both the initial power level and bypass flow were increased by approximately 10%. The results for case numbers six and seven were similar, with RC pressure in

- - - - -
*Rated bypass flow is based on 900 psig. At higher steam pressure the actual bypass flow will be somewhat higher.
**Cases were run at 25% bypass since some B&W plants have 25% turbine bypass capacity.

both cases starting to decrease when the core thermal power and total bypass flow were approximately equal. Figure 3-2 shows a comparison of the RC pressure responses for case numbers six and seven.

3.4.2. Moderator Coefficient

As discussed in section 3.4.1, a successful runback requires that the percent core thermal power be reduced to the equivalent bypass capacity prior to reaching the high pressure trip setpoint. The reduction in core power is accomplished by negative reactivity insertion due to control rod movement and moderator temperature increase. The more negative the moderator temperature coefficient (as burnup increases) the faster the core thermal power decreases. Thus, for the same control rod insertion rate, a more rapid core thermal power decrease will occur at core End of Cycle (EOC), than at Beginning of Cycle (BOC).

Case numbers five and six illustrate the effect of moderator temperature coefficient. In case number six (EOC) thermal power decreased to 45% in the same time that thermal power decreased to 50% for case number five (MOC). The difference was enough to result in a high pressure trip (at 2355 psig) in case number five but not in case number six (EOC). Figure 3-3 compares the RC pressure response for case numbers five and six.

3.4.3. Initial Power Level

Initial power level was treated as an independent variable in the bypass capacity and moderator temperature coefficient discussions (sections 3.4.1 and 3.4.2). To confirm the conclusions drawn from those four cases, two additional cases were analyzed at lower power levels (case numbers one and two). Case number one (30% power, 15% turbine bypass, BOC) resulted in a peak RC pressure of 2256 psig. Thus, a successful runback was achieved without reaching the 2300 psig high pressure trip setpoint. It should be noted that the first bank of MSSVs did not open for this transient. Case number two (40% power, 15%

turbine bypass, BOC) resulted in a peak RC pressure of 2335 psig. Thus, a successful runback would not have been achieved at the 2300 psig trip setpoint but was achieved at a 2355 psig setpoint. The first bank of MSSVs did open for case number two demonstrating that as initial power is increased, more total bypass capacity is required to achieve a successful runback. Figure 3-4 compares the RC pressure responses for case numbers one and two.

3.4.4. ICS Runback Rate

This study included an effort to determine whether changes in Integrated Control System (ICS) runback rates could enhance the probability of successful runbacks.

In all cases analyzed, a maximum rod insertion rate was observed within a few seconds after the turbine trip and continued for 30 to 40 seconds. This rod movement started when the ICS put the unit into track (20% per minute runback rate) and continued (regardless of the power level) due to the ICS response to the increase in core average temperature (T_{ave}). Continuous rod insertion was observed for all cases until the core T_{ave} returned to the 582° setpoint, which was at least 30 to 40 seconds into the transients. Since the maximum transient RC pressure occurred well within this time frame, it follows that an increased runback rate should not affect the peak RC pressure. Case number eight was analyzed to confirm this. When the runback rate was increased to 50% per minute the overall rod insertion rate did not change (in the first 30 seconds) and consequently the rate of core thermal power decrease did not change. Thus, increasing the ICS runback above 20% per minute would not improve the probability for a successful runback.

3.4.5. Pressurizer Spray

The influence of pressurizer spray on the runback transient was investigated to determine whether changes in spray flow or setpoint could contribute to successful runback.

Case numbers three and four were run to show the effect of a variation in pressurizer spray flow. The expected spray flow (of 191 gpm) was arbitrarily doubled in case number four to 382 gpm. Both cases reached 2275 psig RCS pressure at the same time (about eight seconds into the transient) indicating that the doubled spray had not yet affected the RCS pressure significantly. Case number three reached a 2327 psig pressure at 15 seconds into the transient. The same time in case number four (double spray flow) predicted a 2316 psig pressure. These results suggest that increasing the pressurizer spray flow would not significantly enhance the probability of a successful runback. This comparison is shown on Figure 3-5.

The pressurizer spray is initiated at 2200 psig RCS pressure which occurs about three seconds into the transient. Should this setpoint be reduced, the spray would come on one or two seconds sooner. Based on the previous results, this additional spray time would have an insignificant effect on the peak transient pressures.

Table 3-1. Tabulation of Power Train Cases

<u>Case No</u>	<u>Burnup</u>	<u>Max. Pressurizer Spray flow (gpm)</u>	<u>Bypass Flow %</u>	<u>MSSV Flow (1st Bank) %</u>	<u>Runback Rate %/min</u>	<u>Initial Power %</u>
1	BOC	191	15%	28%	20	30
2	BOC	191	15%	28%	20	40
3	EOC	191	15%	28%	20	40
4	EOC	382	15%	28%	20	40
5	MOC (100) EFPD	191	15%	28%	20	59
6	EOC	191	15%	28%	20	59
7	EOC	191	25%	28%	50	70

Figure 3-1.

POWERTRAIN RESULTS TURBINE TRIP WITH RUNBACK CASE #6 (15%BYPASS,59%POWER,EOC)




Figure 3-2.

POWERTRAIN RESULTS
CASE #6 (15%BYPASS,59%POWER,EOC)
VS
CASE #7 (25%BYPASS,70%POWER,EOC)





Figure 3-3.

POWERTRAIN RESULTS
CASE #5 (15%BYPASS,59%POWER,MOC)
VS
CASE #6 (15%BYPASS,59%POWER,EOC)



*CASE #5 REACHED THE 2355PSIG TRIP SETPOINT AT 8 SECONDS

Figure 3-4.

POWERTRAIN RESULTS
CASE #1 (15%BYPASS,30%POWER,BOC)
VS
CASE #2 (15%BYPASS,40%POWER,BOC)





Figure 3-5.

POWERTRAIN RESULTS
CASE #3 (15%BP,40%PWR,191GPM PZR SPRAY)
VS
CASE #4 (15%BP,40%PWR,382GPM PZR SPRAY)



4. CONCLUSIONS FROM ANALYSIS

The power level from which a turbine trip can be followed by a successful reactor runback can be raised from its present level (20% power) to a higher power. This maximum power level from which a plant can successfully runback (without a high RC pressure trip and without the use of the PORV) varies for each plant depending on four plant parameters. These parameters are:

- a. Total steam bypass capacity (including turbine bypass and atmospheric dumps)
- b. Main steam safety valve (MSSV) setpoints and flow rates.
- c. RPS high pressure trip setpoint
- d. Moderator coefficient (burn-up)

In general, all B&W 177 FA plants should be capable of a successful turbine trip runback from 45% power at BOC (assuming a 2355 psig high pressure trip setpoint). This is based on all plants having at least 40% total bypass capacity and an approximately 5% power reduction prior to reaching the trip setpoint. At the current 2300 psig high pressure trip setpoint, all plants should be capable of a successful turbine trip runback from 30% power at BOC. This is based on analysis predictions showing successful runback from 30% power with 15% turbine bypass and no MSSVs opening. Any additional flow capabilities (in turbine bypass or MSSVs) will allow a higher initial power level for successful runback. This is discussed further in section 5.2.

The ICS controlled runback rate has little effect on this transient. This is because the maximum RC pressure occurs typically within 10 to 15 seconds. During this period the moderator coefficient dominates the core power decrease and core T_{ave}

dominates rod movement. These two effects override any "demand" from the ULD runback rate in the first 30 to 40 seconds.

Increasing the pressurizer spray flow rate or reducing the spray setpoint will have no effect on the peak RC pressure with a 2300 psig high pressure trip setpoint and only a very small effect (10 psi) assuming a 2355 psig setpoint.

5. APPLICATION OF RESULTS

5.1. Plant Specific Application

This study concluded that, for a given time in core life (moderator coefficient), the maximum initial power level for successful runback is constrained mainly by the total bypass flow available. It is important to note that only the flow that occurs prior to reaching the high pressure trip setpoint will affect the runback. This will include the flow through turbine bypass valves, atmospheric dump valves, and at least the first bank of MSSVs at a 2355 psig trip setpoint.

The total bypass flow available prior to trip is a plant specific parameter dependent on the configuration of turbine bypass, atmospheric dump and main steam safety valves (number, capacity and setpoints) and the main steam line volume. Tables 5-1 and 5-2 show the various bypass capacities and MSSV arrangements for B&W plants. The information in these tables indicates that the maximum initial power level from which a successful runback could be achieved will not be the same for all plants.

Table 5-3 is a compilation of the total bypass capacity available (prior to reaching a high pressure trip setpoint of 2355 psig) for all B&W plants.

Table 5-4 shows the estimated initial power levels for successful runback on turbine trip for each plant. These initial power levels are based on the total bypass capacities for the turbine bypass and MSSVs as shown in Table 5-3 and an approximately 5% power reduction prior to reaching the 2355 psig trip setpoint. These estimates are considered conservative in that no credit is taken for:

1. Bypass flow through the atmospheric dump valves
2. Power reduction due to moderator coefficient

5.2. Analysis Limitations

The analysis on which the conclusions of this study are based was performed using a model representing a typical B&W plant (similar to Rancho Seco). It is recognized that differences between the model and actual plants may exist (in addition to total bypass flow) which could cause plant performance to differ from analysis predictions. Examples of such differences are ICS tuning, feedwater pump speed response and feedwater valve response. Because of such differences, successful runbacks from initial power levels shown in Table 5-4 may not be achieved for every turbine trip. The consequence of an unsuccessful runback is a reactor trip on high pressure.

We believe that the possibility of unsuccessful runback for some turbine trips which could result if the turbine ART arming threshold were raised as described above is warranted for the following reasons:

- a. The probability of opening the PORV would not be significantly increased. The turbine ART was implemented for the purpose of reducing challenges to the PORV. For successful runbacks, no challenge to the PORV would occur. For unsuccessful runbacks, a high pressure reactor trip would occur. Reference 1 showed that the probability of opening the PORV on a high pressure trip was small ($\sim 10^{-5}$ per event). Unsuccessful runbacks would result in an increased number of high pressure trips but no significant change in probability of opening the PORV. For example:

Assuming that turbine trip frequency remains at 1980-84 levels (Figure 1-1), the ART arming point is set at 45% power, and 30% of the runbacks are unsuccessful, the average number of high pressure trips/reactor year due to this cause would be:

$$\frac{12 \text{ Turbine Trips*} \times .30}{5 \text{ years} \times 7 \text{ reactors}} = 0.10 \quad \frac{\text{High Pressure Trips}}{\text{reactor year}}$$

This would increase the high pressure trip frequency average from 1.86/reactor year (reference 1) to $(1.86 + .10) = 1.96$ trip/reactor year. PORV opening probability would change from:

$$(1.86 \frac{\text{Trips}}{\text{Reactor Year}}) \times (10^{-5} \frac{\text{Opening}}{\text{Trip}}) = 1.86 \times 10^{-5}$$

to:

$$(1.96 \frac{\text{Trips}}{\text{Reactor Year}}) \times (10^{-5} \frac{\text{Opening}}{\text{Trip}}) = 1.96 \times 10^{-5}$$

- b. A net reduction in reactor trips would result. Figure 1-1 indicates the potential for reactor trip reduction which could be achieved by raising the ART arming point. Again, assuming turbine trip frequency to remain at the 1980-84 levels, an ART arming point of 45% power and successful runbacks for 70% of turbine trips at power $\leq 45\%$, the reduction in reactor trips due to this cause would be:

$$\frac{12 \text{ Turbine Trips*} \times .70}{5 \text{ years} \times 7 \text{ Reactors}} = \frac{.24 \text{ Trips}}{\text{Reactor year}}$$

*at power $\leq 45\%$

Table 5-1. Turbine Bypass Capacities

177 FA Plants

<u>Unit</u>	<u>Steam flow at 100% FP (lb/hr)</u>	<u>Condenser dump capacity (% FP Stm. flow)</u>	<u>Modulating atmospheric dump capacity (% FP Stm. Flow)</u>
ANO-1	10.5x10 ⁶	15.8	6.2
CR-3	10.6x10 ⁶	15.0	7.5
DB-1	11.8x10 ⁶	25.0	15.0
ON-1	10.5x10 ⁶	25.0	-
ON-2	10.5x10 ⁶	25.0	-
ON-3	10.5x10 ⁶	25.0	-
RS-1	11.7x10 ⁶	15.7	7.5
TMI-1	10.6x10 ⁶	22.5	6.4

Table 5-2. Main Steam Safety Valve Arrangements

177 FA Plants

<u>Pressure (psig)</u>	<u>Number of valves set to lift at listed pressure</u>								
	<u>1040</u>	<u>1050</u>	<u>1060</u>	<u>1065</u>	<u>1070</u>	<u>1080</u>	<u>1090</u>	<u>1100</u>	<u>1104</u>
<u>Unit</u>									
ANO-1	-	4	-	-	4	-	4	4	-
CR-3	-	4	-	-	4	-	4	4	-
DB-1	-	4	-	-	4	-	6	4	-
ON-1	-	2	-	2	-	2	2	4	4
ON-2	-	2	-	2	-	2	2	4	4
ON-3	-	2	-	2	-	2	2	4	4
RS-1	-	4	-	-	4	-	6	4	-
TMI-1	2	6	4	-	-	4	2	-	-

Table 5-3. Available Total Bypass Capacities Prior to Reaching 2355 psig Trip

<u>Unit</u>	<u>Turbine bypass (% FP Stm. flow)</u>	<u>Atmospheric dump (% FP Stm. flow)</u>	<u>First bank MSSVs (% FP Stm. Flow)</u>
ANO-1	15.8	6.2	28
CR-3	15.0	7.5	28
DB-1	25.0	15.0	25
ON-1	25.0	-	14
ON-2	25.0	-	14
ON-3	25.0	-	14
RS-1	15.7	7.5	25
TMI-1	22.5	6.4	48*

*Includes valves set at 1040 and 1050 psig

Table 5-4. Estimated Initial Power Levels for Runbacks on Turbine Trip

<u>Unit</u>	<u>Initial Power Level</u>
ANO-1	48
CR-3	48
DB-1	55
ON-1	45
ON-2	45
ON-3	45
RS-1	45
TMI-1	75

6. RECOMMENDATIONS

It is recommended that the Anticipatory Reactor Trip on Turbine Trip arming point be changed from its current setting of 20% power to a higher level based on the guidance provided in Section five above.

7. REFERENCES

1. "Justification for Raising Setpoint for Reactor Trip on High Pressure," BAW-1890, September 1980.