

APPENDIX

U.S. NUCLEAR REGULATORY COMMISSION
REGION IV

NRC Inspection Report: 50-382/87-09

License: NPF-38

Docket: 50-382

Licensee: Louisiana Power & Light Company (LP&L)
N-80
317 Baronne Street
New Orleans, Louisiana 70160

Facility Name: Waterford 3

Inspection At: Taft, Louisiana

Inspection Conducted: May 11-15, 1987

Inspector: Charles A. Hackney
C. A. Hackney, Emergency Preparedness Analyst

5-28-87
Date

Approved: William L. Fisher
W. L. Fisher, Chief, Nuclear Materials and
Emergency Preparedness Branch

5/29/87
Date

Inspection Summary

Inspection Conducted May 11-15, 1987 (Report 50-382/87-09)

Areas Inspected: Routine, announced inspection of notifications and communications, changes to the emergency preparedness program, shift staffing and augmentation, and licensee audits and quality assurance.

Results: Within the areas inspected, no violations, deviations, or deficiencies were identified.

DETAILS

1. Persons Contacted

Licensee

- *R. Barkhurst, Vice President, Nuclear
- *N. Carns, Plant Manger
- *R. Azzarello, Emergency Preparedness Manager
- *P. Backes, Nuclear Quality Assurance Manager
- *S. Alleman, Assistant Plant Manager, Technical Services
- *F. Englebracht, Manager, Nuclear Operations Administration

*Denotes attendance at exit interview.

The NRC inspector also held discussions with other station personnel in the areas of emergency detection and classifications, protective action recommendations, notification and communications, staffing and augmentation, health physics, operations, and emergency response organization.

2. Program Areas Inspected

The following program areas were inspected. The inspection included interviews with cognizant individuals, observation of activities, and record reviews. The depth and scope of these activities were consistent with past findings and with the current status of the facility.

Except as noted, the inspection revealed no violations, deviations, deficiencies, unresolved items, or open items. Notations after a specific inspection team identify the following: I = item not inspected or only partially inspected, V = violation, D = deviation, H = deficiency, U = unresolved item, and O = open item.

<u>Inspection Procedure</u>	<u>Functional Area and Inspection Requirements</u>
82203	Notifications and Communications
82204	Changes to Emergency Preparedness Program
82205	Shift Staffing and Augmentation
82210	Licensee Audits and Quality Assurance

3. Exit Interview

The NRC inspector met with the licensee representatives denoted in paragraph 1 on May 15, 1987, and summarized the scope and findings of the inspection as presented in this report.

The NRC inspector questioned the availability of a control room communicator for offsite notification in the event of a fire. The person

designated as the control room communicator was also assigned as a member of the fire brigade. Additionally, the NRC inspector determined from training record reviews that emergency preparedness training for the shift technical advisors (STA) had been terminated. The STA may be used in special cases to perform as a communicator. Mr. N. Carns, Plant Manager, stated that both the communicator and the STA training concern would be reviewed and a response given to the NRC during the week of May 18, 1987.

On May 19, 1987, Mr. N. Carns contacted the NRC inspector and committed to designate one operator as a communicator and to replace the operator position on the fire brigade with a security guard. Additionally, all STA personnel will receive additional training as emergency communicators. Both commitments are to be completed by July 1, 1987.