

Public Service  
Electric and Gas  
Company

**Corbin A. McNeill, Jr.**  
Senior Vice President -  
Nuclear

Public Service Electric and Gas Company P.O. Box 236, Hancocks Bridge, NJ 08038 609 339-4800

June 4, 1987  
NLR-N87108

United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Gentlemen:

REQUEST FOR AMENDMENT - ADDITIONAL INFORMATION  
FACILITY OPERATING LICENSE NPF-57  
HOPE CREEK GENERATING STATION  
DOCKET NOS. 50-354

Public Service Electric and Gas Company (PSE&G) hereby provides additional information in support of the emergency request for amendment submitted on June 1, 1987 and supplemented in a transmittal dated June 2, 1987. The referenced request revised Technical Specification Table 3.3.7.5-1, Accident Monitoring Instrumentation, and would permit Hope Creek Generating Station (HCGS) to avert an unnecessary plant shutdown as a result of an inoperable acoustic monitor for Safety Relief Valve (SRV) #F013H.

PSE&G commits to restore the inoperable acoustic monitor to OPERABILITY if HCGS experiences a forced outage of sufficient duration to effect repairs prior to our presently scheduled September 21, 1987, outage. Otherwise, the acoustic monitor for F013H SRV may be inoperable until September 21, 1987, without applying the shutdown requirement of ACTION 80(a). Attached please find a revised copy of the subject Technical Specification with this commitment appropriately noted.

Sincerely,



Attachment

8706100313 870604  
PDR ADOCK 05000354  
P PDR

Adal  
1/1

C Mr. G. W. Rivenbark  
USNRC Licensing Project Manager

Mr. R. W. Borchardt  
USNRC Senior Resident Inspector

Mr. D. M. Scott, Chief  
Bureau of Nuclear Engineering  
Department of Environmental Protection  
380 Scotch Road  
Trenton, NJ 08628