



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

December 2, 1986

Docket No. 50-267

MEMORANDUM FOR: Herbert N. Berkow, Director
Standardization and Special
Projects Directorate
Division of PWR Licensing-B, NRR

THRU: Oliver D. T. Lynch, Jr., Section Leader
Standardization and Special
Projects Directorate
Division of PWR Licensing-B, NRR

FROM: Kenneth L. Heitner, Project Manager
Standardization and Special
Projects Directorate
Division of PWR Licensing-B, NRR

SUBJECT: SUMMARY OF NOVEMBER 20, 1986 MEETING WITH PUBLIC SERVICE
COMPANY OF COLORADO (PSC) TO DISCUSS FORT ST. VRAIN (FSV)
TEMPERATURE PROFILES FOR EQUIPMENT QUALIFICATION

This meeting was requested by PSC in response to the October 30, 1986 letter from the NRC to PSC concerning FSV temperature profiles for equipment qualification. In this letter, the NRC had concluded that the calculational methods used by PSC were not conservative. The purpose of this meeting was to review PSC's calculations and methodologies, and find a potential basis for NRC approval of the FSV temperature profiles. Attendees at this meeting are listed in Enclosure 1.

PSC presented a summary of their basis for concluding that their temperature profile calculations were conservative (see Enclosure 2). PSC stated that the different computer codes used by the staff's consultant and PSC were not the cause of the different temperature profiles. However, the lower heat transfer coefficients used by the staff's consultant were the primary cause of the differences. PSC noted the higher heat transfer coefficients that they had used were derived from original licensing calculations, and were accepted by the staff when the plant was originally licensed. PSC felt these heat transfer coefficients were still conservative.

PSC had investigated the possibility of taking credit for potential limitations in plant power level. However, preliminary calculations for scenario HRH-2 at 75 percent of full power still exceeded the design temperature profile.

PSC further noted that large conservatisms existed in the restricted volumes they had used for their evaluations in the reactor and turbine buildings. The actual building volumes were considerably higher. However, preliminary calculations with less conservative building volumes gave much lower temperature profiles. PSC maintained that the temperature profiles used for equipment qualification could not easily be modified, since most of the equipment qualification files were complete. For certain critical components, such as cables, the margin in temperature for equipment qualification was small.


The staff held a separate caucus. The staff then directed PSC to redo the sample temperature profiles with the following guidance:

- Use heat transfer coefficients similar in value to the staff's consultants (approximately one in English units),
- Use revised building volume and surface area parameters to reflect additional volumes where steam could easily penetrate, and
- Do the sample calculations for a large break (i.e., HRH-2), small break (i.e., CRH-19), and operator-isolated break. Three revised calculations should be done for each building.

The staff also recommended that PSC provide a separate evaluation of other factors which provided additional conservatisms in these calculations, such as the blowdown orifice coefficient and thermal radiation from the hot gas to colder surfaces.

PSC stated that additional time would be needed to perform these new analyses. They estimated that analyses for the first building could be submitted by mid-December 1986, and for the second building by the end of December 1986.

The staff noted that this could potentially impact the schedule for the field inspection and would advise PSC if a schedule change was needed. (Subsequent to the meeting, the staff advised PSC that the current schedule for the field inspection would be maintained).



Kenneth L. Heitner, Project Manager
Standardization and Special
Projects Directorate
Division of PWR Licensing-B, NRR

Enclosures:
As stated

cc w/enclosures:
See next page

PSC further noted that large conservatisms existed in the restricted volumes they had used for their evaluations in the reactor and turbine buildings. The actual building volumes were considerably higher. However, preliminary calculations with less conservative building volumes gave much lower temperature profiles. PSC maintained that the temperature profiles used for equipment qualification could not easily be modified, since most of the equipment qualification files were complete. For certain critical components, such as cables, the margin in temperature for equipment qualification was small.

The staff held a separate caucus. The staff then directed PSC to redo the sample temperature profiles with the following guidance:

- Use heat transfer coefficients similar in value to the staff's consultants (approximately one in English units),
- Use revised building volume and surface area parameters to reflect additional volumes where steam could easily penetrate, and
- Do the sample calculations for a large break (i.e., HRH-2), small break (i.e., CRH-19), and operator isolated break. Three revised calculations should be done for each building.

The staff also recommended that PSC provide a separate evaluation of other factors which provided additional conservatisms in these calculations, such as the blowdown orifice coefficient and thermal radiation from the hot gas to colder surfaces.

PSC stated that additional time would be needed to perform these new analyses. They estimated that analyses for the first building could be submitted by mid December 1986, and for the second building by the end of December 1986.

The staff noted that this could potentially impact the schedule for the field inspection and would advise PSC if a schedule change was needed. (Subsequent to the meeting, the staff advised PSC that the current schedule for the field inspection would be maintained).

Kenneth L. Heitner, Project Manager
Standardization and Special
Projects Directorate
Division of PWR Licensing-B, NRR

Enclosures:
As stated

cc w/enclosures:
See next page

DISTRIBUTION:

<u>Docket File</u>	KHeitner
NRC PDR	OGC-Bethesda
Local PDR	EJordan
PBSS Reading	BGrimes
JPartlow	ACRS (10)
HBerkow	NRC Participants

PH
PNoonan
11/24/86

PBSS *KH*
KHeitner:ac
11/1/86

PBSS *OL*
OLynch
11/1/86

PBSS *HB*
HBerkow
11/2/86

FSV Temperature Profile Meeting

LIST OF ATTENDEES

<u>Name</u>	<u>Affiliation</u>
J. C. Conklin	Oak Ridge National Laboratory
Charles Hinson	NRC/NRR/DPLB/PBSS
Robert Jones	NRC/NRR/DPLB/RSB
J. S. Wermiel	NRC/NRR/DPLB/PEICB
Paul Shemanski	NRC/NRR/DPLB/PEICB
Jose A. Calvo	NRC/NRR/DPLB/PEICS
Richard E. Ireland	NRC/RIV/RSB-ES
K. L. Heitner	NRC/NRR/DPLB/PBSS
Mark White	Battelle/PNL
Carl Wheeler	PNL
Don Warembourg	PSC
M. L. Holmes	PSC/Nucl. Licensing
M. E. Niehoff	PSC/Nucl. Design Mgr.
Carmels Rodriguez	GA Technologies-Engineering
F. W. Tilson	PSC/Nucl. Engineering
Ken Dvorak	PSC/Nucl. Engineering
Art Barsell	GA Technologies
F. C. Dahms	GA Technologies
Johr C. McKinley	NRC/ACRS Staff
Julio Landoni	GA Technologies
Max Yost	EG&G, Idaho
Norman Wagner	NRC/NRR/DPLB/PEICSB
John Ridgely	NRC/NRR/DPLB/RSB
O. D. T. Lynch, Jr.	NRC/NRR/DPLB/PBSS
Herb Berkow	NRC/NRR/DPLB/PBSS
Dennis Crutchfield	NRC/NRR/DPLB
Chang Li	NRC/NRR/PWR-A/PSB

DISCUSSION ITEMS

- 0 THE ISSUE
- 0 HRH-2 BLOWDOWN ANALYSIS
- 0 COMPARISON OF CVTR TEST DATA
TO FSV ANALYSIS
- 0 LITERATURE SUPPORTING PREVAILING
HEAT TRANSFER COEFFICIENTS
- 0 CONSERVATISMS IN ANALYSIS

THE ISSUE: APPROPRIATE VALUES FOR
HEAT TRANSFER COEFFICIENTS FOR
FORT ST. VRAIN STEAM LINE BREAKS

0.01

0.1

1.0

10.0

100

0.001

500

400

TEMP
(°F)


300

200

100

0

- △ HRH-2 (h=1) 100% power
- HRH-2 (h=1) 75% power
- ◊ MS-3 (h=1) 100% power
- S & L composite
- HRH-2 (variable h) 100% power



CONSERVATISMS

- THE UCHIDA HEAT TRANSFER COEFFICIENT UTILIZED FOR THE CONDENSING REGIME OF THE FSV BLOW-DOWN ARE RECOGNIZED AS CONSERVATIVE.
- THE CONVECTIVE HEAT TRANSFER COEFFICIENT IS CONSERVATIVE BASED ON ACTUAL TEST DATA.
- TOTAL HEAT REMOVAL IS LOW FROM GAS MIXTURE (TAGAMI CORRELATION)
- BOUNDING BLOWDOWN ORIFICE COEFFICIENT (1.0) IS CONSERVATIVE.
- VOLUMES AND HEAT SINKS UTILIZED IN DEVELOPMENT OF FSV TEMPERATURE PROFILES ARE CONSERVATIVELY LOW.

17

□

□

HRH-2 BLOWDOWN ANALYSIS

0 DURING BLOWDOWN


- H_{CONV} VARIES LINEARLY FROM 5 AT START TO 7.5 BTU/FT²-H-°F AT END OF BLOWDOWN
- H_{COND} IS BASED ON UCHIDA
- H_{TOTAL} IS ABOUT 15 BTU/FT²-H-°F AT END OF BLOWDOWN

HRH-2 BLOWDOWN ANALYSIS (CONT)

0 AFTER BLOWDOWN

- H_{CONV} IS EQUAL TO 5 BTU/FT²-H-°F
- H_{CONVD} IS BASED ON UCHIDA

REACTOR BUILDING TEMPERATURE RESPONSE TO
HOT REHEAT OFFSET RUPTURE, HRH-2



**COMPARISON OF CVTR TEST 3 WITH FSV HOT REHEAT HEADER
BLOWDOWN (REACTOR BUILDING) - HRH-2**

<u>PARAMETER</u>	<u>CVTR TEST 3</u>	<u>HRH-2</u>
BLOWDOWN TIME, SEC.	170	13
TOTAL STEAM ENERGY RELEASE, BTU	1.9×10^7	1.2×10^7
ANALYSIS VOLUME, FT ³	227,000	534,730
HEAT SINK AREA, FT ²	37,120	282,550
STEAM RELEASE RATE AT 10 SEC, LB/H	3.2×10^5	2.3×10^6
SPECIFIC ENTHALPY AT 10 SEC, BTU/LB	1264	1535
TOTAL STEAM RELEASE, LB	1.5×10^4	7.9×10^3
PEAK GAS TEMPERATURE, °F	209	371

COMPARISON OF CVTR TEST DATA WITH CONTEMPT-G MODEL RESULTS

CASE	HEAT TRANSFER COEFF. * BTU/FT ² -H-°F		TOTAL VOLUME PEAK PRESSURE PSIG	TOTAL VOLUME PEAK TEMPERATURE °F
	CONVECTION	CONDENSATION		
CONTEMPT-G MODEL RUNS				
1	2	UCHIDA	27.3	361
2	5	UCHIDA	23.5	281
3	10	UCHIDA	20.9	224
4	20	UCHIDA	19.4	215
5	20	2 x UCHIDA	16.5	209
CVTR TEST 3 DATA ⁺			18.0	209


* DURING BLOWDOWN

+ TEST 4 AND 5 CONDITIONS AND BLOWDOWN RESULTS WERE SIMILAR



GA Technologies

COMPARISON OF CVTR TEST TEMPERATURE DATA WITH CONTEMP-G TOTAL VOLUME MODEL




ST1215 11/15/86

$h_{conv} = 5 \text{ TO } 7.5/5$ DURING/AFTER BLOWDOWN; UCHIDA CONDENSATION



COMPARISON OF CVTR TEST TEMPERATURE DATA WITH CONTEMPT-G TOTAL VOLUME MODEL



$h_{conv} = 20/5$ DURING/AFTER BLOWDOWN; UCHIDA CONDENSATION

ST9760 11/13/86

LITERATURE SUPPORTING PREVAILING HEAT TRANSFER COEFFICIENTS BY CONVECTION (HTCV) DURING STEAM BLOWDOWNS

- 0 SLAUGHTERBECK'S RECOMMENDATION FOR AN INITIAL HTC_V IS 5 BTU/(FT²-H-°F)
- 0 BENHAM, ET AL, ADOPTED SLAUGHTERBECK'S RECOMMENDATION FOR PREVIOUS FSV EQ WORK
- 0 ALMENAS'S METHODOLOGY BASED ON MATCHING CVTR, LEADS TO HTC_V OF ABOUT 10 BTU/(FT²-H-°F)
- 0 FRANK, ET AL, METHODOLOGY, BASED ON MATCHING CVTR, GENERATES AN ALL CONVECTIVE HTC_V OF 20 BTU/(FT²-H-°F)
- 0 JUBB'S METHODOLOGY BASED ON BOILER LEAK TESTS LEADS TO AN HTC_V OF 5 BTU/(FT²-H-°F)

CONSERVATISMS IN ANALYSIS


1. RELATIVE TO CVTR, CONVECTIVE HEAT TRANSFER COEFFICIENT IS CONSERVATIVE BY FACTOR OF 3.

CONSERVATISMS IN ANALYSIS (CONT)

2. RELATIVE TO TAGAMI, HEAT
REMOVAL FROM ATMOSPHERE IS
CONSERVATIVE BY A FACTOR OF 4.



GA Technologies



CONSERVATISMS IN ANALYSIS (CONT)

3. ALL BLOWDOWNS ASSUMED TO EXIT PIPES WITH AN EFFECTIVE FLOW ORIFICE COEFFICIENT OF 1.0.

CONSERVATISMS IN ANALYSIS (CONT)

4. VOLUMES AND HEAT SINK AREAS UTILIZED IN THE CONTEMPT-G CALCULATIONS ARE CONSERVATIVELY LOW.




Figure 1.2-2 Plan View of Reactor Building and Turbine Building




Figure 1.2-3 Section Through Reactor Building and Turbine Building

REACTOR BUILDING

SURFACE AREAS AND VOLUMES

	<u>Area ft²</u>	<u>Volume ft³</u>
* Around PCRV	282,550	534,730
Region east of 4A wall	157,470	327,310
Above Refueling floor	68,420	711,160

TURBINE BUILDING

SURFACE AREAS AND VOLUMES

	<u>Area ft²</u>	<u>Volume ft³</u>
* Below Operating floor	296,990	750,000
Above Operating floor	68,780	920,000
Aux. Bay Area	Not calculated	Not calculated

- - -

* Used in CONTEMPT-G profile calculation

CONCLUSIONS

1. HEAT TRANSFER COEFFICIENTS USED ARE CONSERVATIVE.
2. ANALYTICAL APPROACH HAS OTHER MAJOR CONSERVATISMS IN ADDITION TO HTC CONSERVATISMS.
3. COMPOSITE TEMPERATURE PROFILE IS CONSERVATIVE AND APPROPRIATE FOR FORT ST. VRAIN EQUIPMENT QUALIFICATION.

Mr. R. O. Williams
Public Service Company of Colorado

Fort St. Vrain

cc:

Mr. D. W. Warembourg, Manager
Nuclear Engineering Division
Public Service Company
of Colorado
P. O. Box 840
Denver, Colorado 80201

Albert J. Hazle, Director
Radiation Control Division
Department of Health
4210 East 11th Avenue
Denver, Colorado 80220

Mr. David Alberstein, 14/159A
GA Technologies, Inc.
Post Office Box 85608
San Diego, California 92138

Mr. J. W. Gahm, Manager
Nuclear Production Division
Public Service Company of Colorado
16805 Weld County Road 19-1/2
Platteville, Colorado 80651

Mr. H. L. Brey, Manager
Nuclear Licensing and Fuel Division
Public Service Company of Colorado
P. O. Box 840
Denver, Colorado 80201

Mr. P. F. Tomlinson, Manager
Quality Assurance Division
Public Service Company of Colorado
16805 Weld County Road 19-1/2
Platteville, Colorado 80651

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 840
Platteville, Colorado 80651

Mr. R. F. Walker
Public Service Company of Colorado
Post Office Box 840
Denver, Colorado 92138

Kelley, Stansfield & O'Donnell
Public Service Company Building
Room 900
550 15th Street
Denver, Colorado 80202

Commitment Control Program
Coordinator
Public Service Company of Colorado
2420 W. 26th Ave. Suite 100-D
Denver, Colorado 80211

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Chairman, Board of County Commissioners
of Weld County, Colorado
Greeley, Colorado 80631

Regional Representative
Radiation Programs
Environmental Protection Agency
1 Denver Place
999 18th Street, Suite 1300
Denver, Colorado 80202-2413