

Docket No. 50-266

LICENSEE: Wisconsin Electric Power Company

FACILITY: Point Beach Unit 1

SUBJECT: SUMMARY OF MEETING WITH WISCONSIN ELECTRIC POWER COMPANY REGARDING
FRACTURE MECHANICS ANALYSIS OF A FLAW INDICATION IN POINT BEACH
UNIT 1

An emergency meeting was held with Wisconsin Electric Power Company (WEPCo) in Bethesda, Maryland, on May 30, 1987. A list of those attending the meeting is enclosed as Enclosure 1. Point Beach Unit 1 was scheduled for startup the afternoon of Friday, May 29, 1987. However, as a result of ultrasonic testing a flaw indication was observed in a reactor vessel nozzle-to-shell weld for the safety injection system. The flaw size was greater than code allowable. Consequently, startup of Point Beach Unit 1 was delayed pending a review by the staff of the licensee's assessment of the flaw indication.

WEPCo (Steve Pullins) reviewed data concerning the flaw size with the staff. No indication was detected in this particular location in the preoperational inspection. An indication appeared in an inspection conducted in 1976. In 1976, however, there was insufficient data to size the indication. The most recent inspection, conducted in 1987, utilized equipment more sensitive than that previously used and showed one indication 1.44" x 2.25" (all other indications were within the code). The 1987 indication was detected by two transducers. Three different peaks were found when traversing the flaw. WEPCo stated that this was an indication that the flaw may not be continuous but broken up into three smaller segments. The analyses were performed, however, assuming the flaw was continuous.

Mr. Warren Bamford (Westinghouse) discussed the Westinghouse fracture mechanics analysis of the flaw. The analyses assumed the flaw was in the worst location (involved peak stress). The analysis evaluated all the design basis transients. It did not include an LTOP faulted transient condition. For all transients evaluated, the flaw met the fracture mechanics criteria of ASME Code Section XI. Mr. Barry Elliot of the staff indicated that, based on the information provided by Mr. Bamford, he had done a very quick hand calculation and concluded that the flaw indication would meet the fracture mechanics criteria of ASME Code Section XI if an LTOP event, similar to that occurring in November 1981 at Turkey Point, had been analyzed.

The staff concluded, based on the the information presented, that the flaw indication satisfied the fracture mechanics criteria in ASME Code Section XI and Point Beach Unit 1 could restart. However, WEPCo was requested to submit on the docket information presented at the meeting which the NRC staff used to

870615011B E70405
PDR ADOCK 05000266
P PDR


reach this conclusion. This information is to include:


1. LTOP analyses (using Turkey Point);
 - a. probability of exceeding LTOP setpoints; and
 - b. fracture mechanics evaluation assuming a Turkey Point type transient;
2. Flaw characterization based on welding procedure, and inspection test results;
3. Description of the methods of compensating for beam spread;
4. Codes and addenda used and referenced in the inspection and flaw sizing; and
5. UT examination information presented at the meeting.

The above information must be sent via express service so that NRC will have it at the start of business Wednesday morning and will be able to produce a safety evaluation by the end of the week.

151

Theodore R. Quay, Project Manager
Project Directorate III-3
Division of Reactor Projects

Office:  PM/PDIII-3
Surname: TQuay/tg
Date: 06/5 /87

 PD/PDIII-3
DWigginton
06/5 /87

Mr. C. W. Fay
Wisconsin Electric Power Company

Point Beach Nuclear Plant
Units 1 and 2

cc:
Mr. Bruce Churchill, Esq.
Shaw, Pittman, Potts and Trowbridge
2300 N Street, N.W.
Washington, DC 20037

Mr. James J. Zach, Manager
Point Beach Nuclear Plant
Wisconsin Electric Power Company
6610 Nuclear Road
Two Rivers, Wisconsin 54241

Town Chairman
Town of Two Creeks
Route 3
Two Rivers, Wisconsin 54241

Chairman
Public Service Commission
of Wisconsin
Hills Farms State Office Building
Madison, Wisconsin 53702

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
Office of Executive Director
for Operations
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Resident Inspector's Office
U.S. Nuclear Regulatory Commission
6612 Nuclear Road
Two Rivers, Wisconsin 54241

MEETING ON FRACTURE MECHANICS ANALYSIS FOR POINT BEACH UNIT 1

ATTENDANCE LIST

<u>NAME</u>	<u>ORGANIZATION</u>
C. Y. Cheng	NRC/NRR/EMTB
Warren Hazelton	"
Keith Wichman	"
Barry Elliot	"
Ted Quay	NRC/NRR/PD3-3
Steve Pullins	Wisconsin Electric Power Company
Chuck Krause	" " " "
Mike Moylan	" " " "
Warren Bamford	Westinghouse GISD
Steve Richter	SWRI
Hector Diaz	SWRI

Distribution

Docket Files

NRC PDR

Local PDR

PDIII-3 r/f

PDIII-3 s/f

DWigginton

TQuay

CYCheng

WHazelton

KWichman

Belliot

OGC-Bethesda

EJordan

JPartlow

ACRS (10)

NRC Participants

(cc: Licensee and Plant Service List)