

**VIRGINIA POWER  
SURRY POWER STATION  
EMERGENCY PLAN IMPLEMENTING PROCEDURE**

| NUMBER    | PROCEDURE TITLE  | REVISION       |
|-----------|--|----------------|
| EPIP-1.01 | EMERGENCY MANAGER CONTROLLING PROCEDURE<br><br>(With 1 Attachment) | 16             |
|           |  | PAGE<br>1 of 8 |

**PURPOSE**

To initially assess a potential emergency condition and initiate corrective actions.

**USER**

Shift Supervisor or Station Emergency Manager

**ENTRY CONDITIONS**

Any one of the following:

1. Another station procedure directs initiation of this procedure
2. A potential emergency condition is reported to the Shift Supervisor.

8610230091 861017  
PDR ADOCK 05000230  
F PDR

**REVISION RECORD**

|         |  |                   |
|---------|--|-------------------|
| REV. 10 | PAGE(S): 1, 6; Att. 1, pgs. 6, 7, 8 and 9        | DATE: 02-02-84    |
| REV. 11 | PAGE(S): 1 of 8 and 5 of 8                       | DATE: 03-01-84    |
| REV. 12 | PAGE(S): 1, 2, 3, 4, 5, 6 and 7 of 7             | DATE: 05-21-85    |
| REV. 13 | PAGE(S): Entire Procedure and Attachment 1       | DATE: 05-27-86    |
| REV. 14 | PAGE(S): Att. 1, pgs 2,10,11,22 thru 25, 27 & 28 | DATE: 06-25-86    |
| REV. 15 | PAGE(S): 1,4;Att. 1, pgs 2 thru 24,26,28 thru 41 | DATE: 07-24-86    |
| REV. 16 | PAGE(S): Entire Procedure and Attachment 1       | DATE: SEP 29 1986 |

**APPROVAL RECOMMENDED**

*John B. Costello*

**SNSQC REVIEW**

*H L Miller*

**DATE**

*9/29/86*

**QC REVIEW**

*W. J. Jody*

**STATION MANAGER APPROVAL**

*RT Saur*

**DATE**

*9-29-86*

|                                |   |  |
|--------------------------------|---|--|
| <b>NUMBER</b><br><br>EPIP-1.01 | <b>PROCEDURE TITLE</b><br><br>EMERGENCY MANAGER CONTROLLING PROCEDURE | <b>REVISION</b><br>16<br><br><b>PAGE</b><br>2 of 8 |
|--------------------------------|---|--|

| STEP                                   | ACTION/EXPECTED RESPONSE  | RESPONSE NOT OBTAINED            |
|--|---|----------------------------------|
| 1.                                     | <b>INITIAL ASSESSMENT:</b><br><br>a) Perform initial assessment from EAL tables<br><br>b) <u>IF</u> EAL exceeded, initiate EPIP-1.01:<br><br>1) BY: _____<br><br>DATE: _____<br><br>TIME: _____   | b) Return to procedure in effect |
| <b>NOTE:</b>                           | Continue through this and all further instructions unless otherwise directed to hold.   |                                  |
| 2.                                     | <b>IDENTIFY EVENT:</b><br><br>a) Event-TRANSPORT OF CONTAMINATED INJURED PERSONNEL<br><br>1) Initiate EPIP-5.01, <u>Transport of Contaminated Injured Personnel</u><br><br>2) Verify initiation of EPIP-4.20, <u>H.P. Actions for Transport of Injured Contaminated Personnel</u><br><br>3) Continue this instruction | a) <u>GO TO</u> Step <u>2.b</u>  |
| [Step <u>2</u> continued on next page] |   |                                  |

|                                |   |                       |
|--------------------------------|---|-----------------------|
| <b>NUMBER</b><br><br>EPIP-1.01 | <b>PROCEDURE TITLE</b><br><br>EMERGENCY MANAGER CONTROLLING PROCEDURE | <b>REVISION</b><br>16 |
|                                |   | <b>PAGE</b><br>3 of 8 |

| STEP | ACTION/EXPECTED RESPONSE  | RESPONSE NOT OBTAINED                |
|------|---|--------------------------------------|
| 2.   | <p>IDENTIFY EVENT: [continued]</p> <p>b) Event-Any of the following;</p> <ul style="list-style-type: none"><li>* Radiation Release</li><li>* Fuel Handling Incident</li><li>* Secondary Release</li><li>* S/G Tube Rupture</li><li>* LOCA</li></ul> <p>1) Request Health Physics initiate EPIP-4.01, <u>Radiological Assessment Director Controlling Procedure</u>, and continue this instruction</p> | <p>b) <u>GO TO</u> Step <u>3</u></p> |

|                                |   |  |
|--------------------------------|---|--|
| <b>NUMBER</b><br><br>EPIP-1.01 | <b>PROCEDURE TITLE</b><br><br>EMERGENCY MANAGER CONTROLLING PROCEDURE | <b>REVISION</b><br>16<br><br><b>PAGE</b><br>4 of 8 |
|--------------------------------|---|--|

| STEP  | ACTION/EXPECTED RESPONSE   | RESPONSE NOT OBTAINED                   |
|---|--|---|
| * * * * *<br><br>*<br><br>* <u>CAUTION:</u><br><br>*<br><br>* * * * * | Declaration of the highest emergency class for which an<br>Emergency Action Level is exceeded shall be made.   | *<br><br>*<br><br>*                     |
| * * * * *<br><br>* * * * *  | <p><u>NOTE:</u> The SPDS is potentially unreliable in the event of an earthquake. Therefore, the SPDS should be evaluated for reliability of accident assessment should this situation occur.</p>  |   |
| 3.  | <p>ASSESSMENT AND CLASSIFICATION:</p> <p>a) Use the SPDS to obtain indications of emergency conditions listed in the EAL Table, as necessary.</p> <p>b) Use EPIP 1.01, Attachment <u>1</u>, <u>Emergency Action Level Table Index</u> to determine event category</p> <p style="text-align: center;"><u>AND</u></p> <p><u>GO TO</u> proper EAL tab</p> <p>c) Evaluate event to determine classification,</p> <p style="text-align: center;"><u>AND</u></p> <p><u>GO TO</u> Step <u>4</u> of this procedure</p> | <p>a) <u>GO TO</u> Step <u>3.b</u>.</p> |



|                                |   |  |
|--------------------------------|---|--|
| <b>NUMBER</b><br><br>EPIP-1.01 | <b>PROCEDURE TITLE</b><br><br>EMERGENCY MANAGER CONTROLLING PROCEDURE | <b>REVISION</b><br>16<br><br><b>PAGE</b><br>5 of 8 |
|--------------------------------|---|--|

| STEP | ACTION/EXPECTED RESPONSE  | RESPONSE NOT OBTAINED   |  |
|------|---|---|--|
| 4.   | NOTIFICATION AND VERIFICATION:  |   |  |
|      | a) LEOF - <u>NOT</u> ACTIVATED  | a) Announce transfer of command from TSC to LEOF and proceed to step 4.b. |  |
|      | b) TSC - <u>NOT</u> ACTIVATED   | b) <u>GO TO</u> Step 6.   |  |
|      | c) Notify SRO-On-Call or Superintendent of Operations   | c) Notify Station Manager or Asst. Station Manager.                       |  |
|      | d) Verify emergency classification  |   |  |
|      | e) If required by ALERT, SITE AREA, or GENERAL emergency, request initiation of the Operations Department, Directive for augmenting staff resources during Emergency Plan activation. |   |  |
|      | <b>NOTE:</b> Return to Step 2 of this instruction as necessary to consider additional events and reclassification.  |   |  |
| 5.   | VERIFY EALS EXCEEDED:   |   |  |
|      | a) Assure EALS - EXCEEDED   | a) <u>DO NOT</u> declare an emergency classification,                     |  |
|      |   | <u>AND</u>  |  |
|      |   | <u>GO TO</u> Step 7.  |  |
|      | b) <u>IF</u> required, assign appropriate individual as Emergency Communicator  |   |  |
|      | [Step 5 continued on next page]   |   |  |

| NUMBER    | PROCEDURE TITLE                         | REVISION<br>16 |
|-----------|---|----------------|
| EPIP-1.01 | EMERGENCY MANAGER CONTROLLING PROCEDURE | PAGE<br>6 of 8 |

| STEP | ACTION/EXPECTED RESPONSE   | RESPONSE NOT OBTAINED  |
|------|--|--|
| 5.   | VERIFY EALS EXCEEDED:<br>[continued]<br><br>c) <u>IF required, direct senior HP personnel on site to initiate EPIP-4.01, Radiological Assessment Director Controlling Procedure</u>  |  |
| 6.   | DETERMINE EPIPS:<br><br>a) Event classification - NOTIFICATION OF UNUSUAL EVENT<br>1) <u>GO TO EPIP-1.02, Response to Notification of Unusual Event</u><br><br>b) Event classification - ALERT<br>1) <u>GO TO EPIP-1.03, Response to Alert</u><br><br>c) Event classification - SITE AREA EMERGENCY<br>1) <u>GO TO EPIP-1.04, Response to Site Area Emergency</u><br><br>d) Event classification - GENERAL EMERGENCY<br>1) <u>GO TO EPIP-1.05, Response to General Emergency</u> | a) <u>GO TO Step 6.b.</u><br><br><br><br><br><br><br><br><br><br>b) <u>GO TO Step 6.c.</u><br><br><br><br><br><br><br><br><br><br>c) <u>GO TO Step 6.d.</u><br><br><br><br><br><br><br><br><br><br>d) <u>GO TO Step 6.d.</u> |
| 7.   | SECURE FROM EVENT:<br><br>a) Notify involved station personnel that emergency condition does not exist<br><br>b) <u>GO TO Step 11.</u>   |  |

| NUMBER    | PROCEDURE TITLE                         | REVISION<br>16 |
|-----------|---|----------------|
| EPIP-1.01 | EMERGENCY MANAGER CONTROLLING PROCEDURE | PAGE<br>7 of 8 |

| STEP | ACTION/EXPECTED RESPONSE   | RESPONSE NOT OBTAINED   |
|------|--|---|
| 8.   | <p>TERMINATION NOTIFICATIONS:</p> <p>a) Initiate termination notification to state and local governments IAW EPIP-2.01, <u>Notification of State and Local Governments</u></p> <p>b) Initiate termination notification to NRC IAW EPIP-2.02, <u>Notification of NRC</u></p>        |   |
| 9.   | <p>REPORTING:</p> <p>a) Verify required reports and notifications IAW EPIP-2.03, <u>Reports to Offsite Agencies</u></p>  |   |
| 10.  | <p>RECOVERY ACTIONS:</p> <p>a) Notify involved station personnel of emergency termination</p> <p>b) Initiate recovery actions IAW established station procedures and capabilities</p> <p>c) <u>IF</u> required, deactivate station emergency response facilities and personnel</p> | <p>b) <u>GO TO EPIP-6.01, Reentry/Recovery Guidelines</u></p> |

|                                |   |  |
|--------------------------------|---|--|
| <b>NUMBER</b><br><br>EPIP-1.01 | <b>PROCEDURE TITLE</b><br><br>EMERGENCY MANAGER CONTROLLING PROCEDURE | <b>REVISION</b><br>16<br><br><b>PAGE</b><br>8 of 8 |
|--------------------------------|---|--|

| STEP | ACTION/EXPECTED RESPONSE   | RESPONSE NOT OBTAINED |
|------|--|-----------------------|
| 11.  | <p>TERMINATE EPIP-1.01:</p> <p>a) COMPLETED BY: _____</p> <p>DATE: _____</p> <p>TIME: _____</p> <p>b) Forward completed EPIP-1.01,<br/>forms and other applicable<br/>records to Secretary SNSOC</p> |                       |
|      | END  |                       |



|                     |   |                 |
|---------------------|---|-----------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br><br>EMERGENCY ACTION LEVEL TABLE<br><br>INDEX | REVISION<br>16  |
| ATTACHMENT<br>1     |   | PAGE<br>1 of 41 |

\*\*\*\*\*

CAUTION: Declaration of the highest emergency class for which an EAL is exceeded shall be made.

\*\*\*\*\*

| <u>IF EVENT CATEGORY IS:</u> |  | <u>GO TO</u><br><u>TAB</u> |
|------------------------------|--|----------------------------|
| 1.                           | Safety, Shutdown, or Assessment System Event ..... | A                          |
| 2.                           | Reactor Coolant System Event .....                 | B                          |
| 3.                           | Fuel Failure or Fuel Handling Accident.....        | C                          |
| 4.                           | Containment Event.....                             | D                          |
| 5.                           | Radioactivity Event.....                           | E                          |
| 6.                           | Contaminated Personnel .....                       | F                          |
| 7.                           | Loss of Secondary Cooling.....                     | G                          |
| 8.                           | Electrical Failure.....                            | H                          |
| 9.                           | Fire.....  | I                          |
| 10.                          | Security Event.....                                | J                          |
| 11.                          | Hazard to Station Operation.....                   | K                          |
| 12.                          | Natural Events.....                                | L                          |
| 13.                          | Miscellaneous Abnormal Events.....                 | M                          |

|                            |  |                        |
|----------------------------|--|------------------------|
| <u>NUMBER</u><br>EPIP-1.01 | <u>ATTACHMENT TITLE</u><br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB A)<br>SAFETY, SHUTDOWN, OR ASSESSMENT SYSTEM EVENT | <u>REVISION</u><br>16  |
| <u>ATTACHMENT</u><br>1     |  | <u>PAGE</u><br>2 of 41 |

| <u>CONDITION/APPLICABILITY</u>  | <u>INDICATION</u>   | <u>CLASSIFICATION</u>         |
|---|---|-------------------------------|
| 1. Non-spurious ECCS initiation<br><br>ABOVE CSD CONDITION                                    | Non-spurious ECCS initiation as validated by Emergency Procedures   | NOTIFICATION OF UNUSUAL EVENT |
| 2. Mode reduction required by Tech. Spec. Limiting Condition for Operation<br><br>POWER & HSB | Intentional reduction in Power, Load or Temperature because the unit has entered an Action Statement or will exceed a Limiting Condition for Operation.<br><u>NOTE:</u> In the event that other plant conditions require a shutdown, NOTIFICATION OF UNUSUAL EVENT must still be declared on the basis that a shutdown would have been required by the Tech Spec. | NOTIFICATION OF UNUSUAL EVENT |
| 3. Loss of Function needed for unit HSD condition<br><br>ABOVE CSD CONDITION                  | Total loss of:<br>a) Charging/SI System<br><br><u>OR</u><br>b) Main feedwater <u>AND</u> Auxiliary Feedwater Systems  | SITE AREA EMERGENCY           |

|                     |   |                    |
|---------------------|---|--------------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB A) | REVISION<br><br>16 |
| ATTACHMENT<br>1     | SAFETY, SHUTDOWN, OR ASSESSMENT SYSTEM EVENT                    | PAGE<br>3 of 41    |

| <u>CONDITION/APPLICABILITY</u>   | <u>INDICATION</u>   | <u>CLASSIFICATION</u>         |
|--|---|-------------------------------|
| 4. Loss of function needed for unit CSD condition<br><br>CSD                                   | Loss of heat removal capability due to total loss of any of the following systems:<br><br>a) Service Water<br><br><u>OR</u><br><br>b) Component Cooling<br><br><u>OR</u><br><br>c) Residual Heat Removal  | ALERT                         |
| 5. Failure of a safety or relief valve to close after pressure reduction<br><br>ALL CONDITIONS | Condition a) or b) exists:<br><br>a) Pressurizer safety or PORV flow as indicated by accoustical or temperature monitoring equipment<br><br><u>AND</u><br><br>RCS subcooling - LESS THAN 30°F<br><br>b) Excessive flow through Steam Generator Safety, PORV, or Decay Heat Release valve indicated by RCS cooldown rate > 50°F per hour | NOTIFICATION OF UNUSUAL EVENT |



|                     |   |                 |
|---------------------|---|-----------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br>EMERGENCY ACTION LEVEL TABLE<br>(TAB A) | REVISION<br>16  |
| ATTACHMENT<br>1     | SAFETY, SHUTDOWN, OR ASSESSMENT SYSTEM EVENT                | PAGE<br>4 of 41 |

| CONDITION/APPLICABILITY   | INDICATION  | CLASSIFICATION                   |
|---|---|----------------------------------|
| 6. Failure of the Reactor to trip (ATWT)<br><br>POWER & HSB   | Condition a) and b) exists with c)<br><br>a) RX trip setpoint and coincidences - EXCEEDED<br><br><u>AND</u><br><br>b) Manual Rx trip - INITIATED<br><br><u>AND</u><br><br>c) Rx power indication-NOT DECREASING   | SITE AREA<br>EMERGENCY           |
| 7. Trip following ATWT that takes the Rx Subcritical<br><br>POWER & HSB   | a) ATWT - Manual Reactor Trip following failure of Auto Trip Circuit<br><br><u>AND</u><br><br>b) Reactor power - DECREASING   | ALERT                            |
| 8. Indications or alarms on process or effluent parameters required for incident assessment <u>NOT</u> available<br><br>ABOVE CSD CONDITION | Intentional reduction in Power, Load or Temperature because the unit has entered an Action Statement or will exceed a Limiting Condition for Operation.<br><br><u>NOTE:</u> In the event that other plant conditions require a shutdown, NOTIFICATION OF UNUSUAL EVENT must still be declared on the basis that a shutdown would have been required by the Tech Spec. | NOTIFICATION OF<br>UNUSUAL EVENT |



|                     |   |                 |
|---------------------|---|-----------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB A)<br>SAFETY, SHUTDOWN, OR ASSESSMENT SYSTEM EVENT | REVISION<br>16  |
| ATTACHMENT<br>1     |   | PAGE<br>5 of 41 |

|     | <u>CONDITION/APPLICABILITY</u>   | <u>INDICATION</u>  | <u>CLASSIFICATION</u>         |
|-----|--|--|-------------------------------|
| 9.  | Failure of meteorological instrumentation required to perform offsite dose calculations.<br><br>ALL CONDITIONS               | Loss of all onsite and off-site meteorological monitoring capability   | NOTIFICATION OF UNUSUAL EVENT |
| 10. | Loss of plant communications capability<br><br>ALL CONDITIONS  | Complete failure of:<br><br>a) Station Gai-Tronics system<br><br><u>AND</u><br><br>b) Station UHF radio system   | NOTIFICATION OF UNUSUAL EVENT |
| 11. | All main board annunciator alarms and unit computer lost for more than 15 minutes during a unit transient<br><br>POWER & HSB | a) Complete loss of all annunciator alarms on panels "A" to "K"<br><br><u>AND</u><br><br>b) Loss of unit computer for GREATER THAN 15 minutes<br><br><u>AND</u><br><br>c) Unit operational transient - IN PROGRESS | SITE AREA EMERGENCY           |
| 12. | All main board annunciator alarms and unit computer lost<br><br>POWER & HSB  | a) Simultaneous loss of all annunciator alarms on panels "A" to "K"<br><br><u>AND</u><br><br>b) Loss of unit computer  | ALERT                         |

|                            |  |                        |
|----------------------------|--|------------------------|
| <i>NUMBER</i><br>EPIP-1.01 | <i>ATTACHMENT TITLE</i><br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB A)<br>SAFETY, SHUTDOWN, OR ASSESSMENT SYSTEM EVENT | <i>REVISION</i><br>16  |
| <i>ATTACHMENT</i><br>1     |  | <i>PAGE</i><br>6 of 41 |

|     | <u>CONDITION/APPLICABILITY</u>  | <u>INDICATION</u>  | <u>CLASSIFICATION</u>  |
|-----|---|--|------------------------|
| 13. | Evacuation of Main Control Room with control <u>NOT</u> established within 15 minutes<br><br>ALL CONDITIONS | Evacuation of the Control Room with stable shutdown control <u>NOT</u> established within 15 minutes | SITE AREA<br>EMERGENCY |
| 14. | Evacuation of Main Control Room required<br><br>ALL CONDITIONS  | Evacuation of the Control Room with stable shutdown control established within 15 minutes            | ALERT                  |

|                     |   |                 |
|---------------------|---|-----------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB B)<br>REACTOR COOLANT SYSTEM EVENT | REVISION<br>16  |
| ATTACHMENT<br>1     |   | PAGE<br>7 of 41 |

| CONDITION/APPLICABILITY   | INDICATION   | CLASSIFICATION                |
|---|--|-------------------------------|
| 1. Tech. Spec. Safety Limits for RCS exceeded<br><br>POWER & HSB    | Verification of any Tech. Spec. Safety limit for RCS   | NOTIFICATION OF UNUSUAL EVENT |
| 2. RCS leak rate exceeds makeup capacity<br><br>ABOVE CSD CONDITION | EP-2.00, <u>Loss of Reactor or Secondary Coolant - IMPLEMENTED</u><br><br><u>AND</u><br><br>Pressurizer level cannot be maintained with two (2) Charging/SI Pumps in operation   | SITE AREA EMERGENCY           |
| 3. RCS leak rate exceeds 50 gpm<br><br>ABOVE CSD CONDITION          | Intentional reduction in Power, Load or Temperature because the unit has entered an Action State-ment or will exceed a Limiting Condition for Operation.<br><br><u>NOTE:</u> In the event that other plant conditions require a shutdown, NOTIFICATION OF UNUSUAL EVENT must still be declared on the basis that a shutdown would have been required by the Tech Spec.<br><br>a) Actions required IAW AP-16, <u>Excessive Primary Plant Leakage</u><br><br><u>AND</u><br><br>b) RCS inventory balance indicates leakage - GREATER THAN <u>50</u> gpm | ALERT                         |



|                     |   |                 |
|---------------------|---|-----------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB B) | REVISION<br>16  |
| ATTACHMENT<br>1     | REACTOR COOLANT SYSTEM EVENT                                    | PAGE<br>8 of 41 |

| CONDITION/APPLICABILITY   | INDICATION  | CLASSIFICATION                   |
|---|---|----------------------------------|
| 4. RCS leak rate requiring<br>plant shutdown IAW<br>T.S. 3.1.C<br><br>POWER & HSB | Intentional reduction in<br>Power, Load or Temperature<br>because the unit has<br>entered an Action State-<br>ment or will exceed a<br>Limiting Condition for<br>Operation.<br><br>NOTE: In the event that<br>other plant conditions<br>require a shutdown, NOTI-<br>FICATION OF UNUSUAL EVENT<br>must still be declared on<br>the basis that a shutdown<br>would have been required<br>by the Tech Spec. | NOTIFICATION OF<br>UNUSUAL EVENT |
|   | a) Unidentified RCS<br>leakage - GREATER<br>THAN <u>1</u> gpm   |                                  |
|   | <u>OR</u>   |                                  |
|   | b) Identified leakage -<br>GREATER THAN <u>10</u> gpm   |                                  |
|   | <u>OR</u>   |                                  |
|   | c) Non-isolatable fault<br>of RCS pressure boundary   |                                  |



|                             |  |                                |
|-----------------------------|--|--------------------------------|
| <p>NUMBER<br/>EPIP-1.01</p> | <p>ATTACHMENT TITLE</p>  | <p>REVISION</p>                |
| <p>ATTACHMENT<br/>1</p>     | <p>EMERGENCY ACTION LEVEL TABLE<br/>(TAB B)<br/>REACTOR COOLANT SYSTEM EVENT</p> | <p>16<br/>PAGE<br/>9 of 41</p> |

| CONDITION/APPLICABILITY  | INDICATION   | CLASSIFICATION                 |
|--|--|--------------------------------|
| <p>5. RCP locked rotor<br/>leading to fuel damage<br/><br/>POWER</p>   | <p>a) Flow in one or more<br/>RC loops - LESS THAN<br/><u>90%</u><br/><br/><u>AND</u><br/><br/>b) RCP trip caused by Phase<br/>Overcurrent Relay -<br/>ACTUATION<br/><br/><u>AND</u><br/><br/>c) High Range Letdown Rad-<br/>iation Monitor (RM-CH-118,<br/>-218) indication increases<br/>to - GREATER THAN <u><math>5 \times 10^5</math></u><br/>cpm</p> | <p>ALERT</p>                   |
| <p>6. Gross Primary to Second-<br/>ary leakage with loss of<br/>offsite power<br/><br/>ABOVE CSD CONDITION</p> | <p>EP-4.00, <u>Steam Generator</u><br/><u>Tube Rupture</u> - IMPLEMENTED<br/><br/><u>AND</u><br/><br/>Loss of offsite power indi-<br/>cated by zero volts for 4160V<br/>Buses D, E &amp; F</p>   | <p>SITE AREA<br/>EMERGENCY</p> |

|                     |   |                  |
|---------------------|---|------------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br>EMERGENCY ACTION LEVEL TABLE<br>(TAB B)<br>REACTOR COOLANT SYSTEM EVENT | REVISION<br>16   |
| ATTACHMENT<br>1     |   | PAGE<br>10 of 41 |

| <u>CONDITION/APPLICABILITY</u>  | <u>INDICATION</u>   | <u>CLASSIFICATION</u> |
|---|---|-----------------------|
| 7. Excessive Primary to Secondary leakage with loss of offsite power<br><br>ABOVE CSD CONDITION | Intentional reduction in Power, Load or Temperature because the unit has entered an Action Statement or will exceed a Limiting Condition for Operation.<br><br>a) Primary to Secondary leakage - GREATER THAN <u>1</u> gpm<br><br><u>OR</u><br><br>GREATER THAN <u>500</u> gal. per day per generator<br><br><u>AND</u><br><br>b) zero volts for 4160V busses D, E & F. | ALERT                 |
| 8. Gross Primary to Secondary leakage<br><br>ABOVE CSD CONDITION                                | EP-4.00, <u>Steam Generator Tube Rupture</u> - IMPLEMENTED  | ALERT                 |

|                            |  |                         |
|----------------------------|--|-------------------------|
| <u>NUMBER</u><br>EPIP-1.01 | <u>ATTACHMENT TITLE</u><br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB B)<br>REACTOR COOLANT SYSTEM EVENT | <u>REVISION</u><br>16   |
| <u>ATTACHMENT</u><br>1     |  | <u>PAGE</u><br>11 of 41 |

CONDITION/APPLICABILITYINDICATIONCLASSIFICATION

9. Primary to Secondary  
leakage - GREATER THAN  
1 gpm

ABOVE CSD CONDITION

Intentional reduction in  
Power, Load or Temperature  
because the unit has  
entered an Action State-  
ment or will exceed a  
Limiting Condition for  
Operation.

NOTIFICATION OF  
UNUSUAL EVENT

NOTE: In the event that  
other plant conditions  
require a shutdown, NOTI-  
FICATION OF UNUSUAL EVENT  
must still be declared on  
the basis that a shutdown  
would have been required  
by the Tech Spec.

- a) Primary to Secondary  
leakage - GREATER THAN  
1 gpm

OR

GREATER THAN 500 gal.  
per day per generator.

|                     |   |                  |
|---------------------|---|------------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB B)<br>REACTOR COOLANT SYSTEM EVENT | REVISION<br>16   |
| ATTACHMENT<br>1     |   | PAGE<br>12 of 41 |

| CONDITION/APPLICABILITY  | INDICATION   | CLASSIFICATION       |
|--|--|----------------------|
| 10. Loss of 2 of 3 fission product barriers with potential loss of 3rd barrier<br><br>ALL CONDITIONS | Any two of a), b) or c) exist and the third is imminent<br><br>a) Fuel clad integrity failure as indicated by any of the following:<br><br>1) RCS specific activity - GREATER THAN OR EQUAL TO <u>300</u> $\mu$ Ci/gram dose equivalent I-131.<br><br>2) 5 or more core exit thermocouples reading - GREATER THAN <u>1200°F</u><br><br>b) Loss of RCS integrity as indicated by any of the following:<br><br>1) PORV failed open<br><br>2) Loss of Reactor Coolant<br><br>3) Outside Containment High Range Gamma Radiation Monitor (RM-RMS-161, -261) reading - GREATER THAN <u><math>2 \times 10^1</math></u> mR/hr<br><br>c) Loss of containment integrity as indicated by any of the following:<br><br>1) Containment pressure - GREATER THAN <u>60</u> psia AND NOT DECREASING<br><br>2) OP-1E, <u>Containment Integrity Checklist.</u> | GENERAL<br>EMERGENCY |



|                     |   |                    |
|---------------------|---|--------------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB B)<br>REACTOR COOLANT SYSTEM EVENT | REVISION<br><br>16 |
| ATTACHMENT<br>1     |   | PAGE<br>13 of 41   |

| <u>CONDITION/APPLICABILITY</u>   | <u>INDICATION</u>  | <u>CLASSIFICATION</u> |
|--|--|-----------------------|
| 11. Fuel failure with steam generator tube rupture<br><br>ALL CONDITIONS | Any two of a), b) or c) exists and the third is imminent<br><br>a) Fuel clad integrity failure as indicated by any of the following:<br><br>1) RCS specific activity - GREATER THAN 300 $\mu$ Ci/gram dose equivalent I-131<br><br>2) 5 or more core exit thermocouples indicate - GREATER THAN 1200 °F<br><br>b) S/G tube rupture as indicated by both of the following:<br><br>1) RCS Low Pressure SI - INITIATED<br><br>2) EP-4.00, <u>Steam Generator Tube Rupture</u> , - IMPLEMENTED<br><br>c) Loss of Secondary integrity as indicated by:<br><br>1) Steam discharge to atmosphere<br><br>2) Faulted steam generator as indicated by EP-2.00, <u>Loss of Reactor or Secondary Coolant</u> | GENERAL<br>EMERGENCY  |

|                     |   |                  |
|---------------------|---|------------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br>EMERGENCY ACTION LEVEL TABLE<br>(TAB C)<br>FUEL FAILURE OR FUEL HANDLING ACCIDENT | REVISION<br>16   |
| ATTACHMENT<br>1     |   | PAGE<br>14 of 41 |

| CONDITION/APPLICABILITY   | INDICATION  | CLASSIFICATION         |
|---|---|------------------------|
| 1. Core damage with possible loss of coolable geometry<br><br>ABOVE CSD CONDITION | Condition a) exists with<br>b)<br>a) Fuel clad failure as indicated by any of the following:<br>1) RCS Specific activity - GREATER THAN <u>60</u> $\mu\text{Ci}/\text{gram}$ dose equivalent I-131<br>2) High Range Letdown Radiation Monitor (RM-CH-118, -218) indication - GREATER THAN <u><math>1 \times 10^6</math></u> cpm<br><u>AND</u><br>b) Loss of cooling as indicated by any of the following:<br>1) 5 confirmed core exit thermocouples - GREATER THAN <u>1200</u> °F<br>2) Core $\Delta T$ - ZERO<br>3) Core $\Delta T$ - RAPIDLY INCREASING | SITE AREA<br>EMERGENCY |

|                     |   |                  |
|---------------------|---|------------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB C)<br>FUEL FAILURE OR FUEL HANDLING ACCIDENT | REVISION<br>16   |
| ATTACHMENT<br>1     |   | PAGE<br>15 of 41 |

| CONDITION/APPLICABILITY                                   | INDICATION  | CLASSIFICATION                |
|---|---|-------------------------------|
| 2. Severe Fuel Clad Damage<br><br>ABOVE CSD CONDITION     | a) RCS specific activity -<br>GREATER THAN <u>300</u> $\mu$ Ci/gram<br>dose equivalent I-131<br><br><u>OR</u><br><br>High Range Letdown Radiation Monitor (RM-CH-118, -218) indication increases<br>GREATER THAN <u><math>5 \times 10^5</math></u> cpm<br>within <u>30</u> minutes AND<br>remains for at least <u>15</u> minutes  | ALERT                         |
| 3. Fuel clad damage indication<br><br>ABOVE CSD CONDITION | Intentional reduction in Power, Load or Temperature because the unit has entered an Action State-ment or will exceed a Limiting Condition for Operation.<br><br><u>NOTE:</u> In the event that other plant conditions require a shutdown, NOTIFICATION OF UNUSUAL EVENT must still be declared on the basis that a shutdown would have been required by the Tech Spec.<br><br><u>OR</u><br><br>a) High Range Letdown Radiation Monitor indication increases -<br>GREATER THAN <u><math>10^5</math></u> cpm<br>within <u>30</u> minutes AND<br>remains for at least <u>15</u> minutes. | NOTIFICATION OF UNUSUAL EVENT |



|                     |   |                  |
|---------------------|---|------------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br>EMERGENCY ACTION LEVEL TABLE<br>(TAB C)<br>FUEL FAILURE OR FUEL HANDLING ACCIDENT | REVISION<br>16   |
| ATTACHMENT<br>1     |   | PAGE<br>16 of 41 |

| CONDITION/APPLICABILITY  | INDICATION  | CLASSIFICATION       |
|--|---|----------------------|
| 4. Probable large radio-activity release initiated by LOCA with ECSS failure leading to core degradation<br><br>ABOVE CSD CONDITION                                | a) EP-2.00, <u>Loss of Reactor or Secondary Coolant</u> , - IMPLEMENTED,<br><br><u>AND</u><br><br>RCS specific activity - GREATER THAN <u>300</u> $\mu$ Ci/gram dose equivalent I-131<br><br><u>AND</u><br><br>b) High or Low Head ECCS flow - <u>NOT</u> being delivered to the core | GENERAL<br>EMERGENCY |
| 5. Probable large radio-activity release initiated by loss of heat sink leading to core degradation<br><br>ABOVE CSD CONDITION                                     | a) Loss of Main FW system and Condensate System<br><br><u>AND</u><br><br>b) Loss of Auxiliary FW System<br><br><u>AND</u><br><br>c) RHR System - <u>NOT</u> OPERABLE  | GENERAL<br>EMERGENCY |
| 6. Probable large radio-activity release initiated by failure of protection system to bring Rx subcritical and causing core degradation<br><br>ABOVE CSD CONDITION | a) Rx nuclear power after a trip remains - GREATER THAN <u>5%</u><br><br><u>AND</u><br><br>b) RCS pressure - GREATER THAN <u>2485</u> psig <u>AND NOT</u> decreasing<br><br><u>OR</u><br><br>Containment pressure and temperature are RAPIDLY INCREASING                              | GENERAL<br>EMERGENCY |



|                     |   |                  |
|---------------------|---|------------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br>EMERGENCY ACTION LEVEL TABLE<br>(TAB C)<br>FUEL FAILURE OR FUEL HANDLING ACCIDENT | REVISION<br>16   |
| ATTACHMENT<br>1     |   | PAGE<br>17 of 41 |

| CONDITION/APPLICABILITY   | INDICATION  | CLASSIFICATION       |
|---|---|----------------------|
| 7. Probable large radio-activity release initiated by loss of AC and all feedwater<br><br>ABOVE CSD CONDITION                   | a) ECA-1.00, <u>Loss of All AC Power</u> - IMPLEMENTED<br><br><u>AND</u><br><br>b) Turbine Driven Auxiliary Feedwater Pump <u>NOT</u> OPERABLE<br><br><u>AND</u><br><br>c) Restoration of a) or b) above not likely within <u>2</u> hours   | GENERAL<br>EMERGENCY |
| 8. Probable large radio-activity release initiated by LOCA with loss of ECCS and containment cooling<br><br>ABOVE CSD CONDITION | a) EP-2.00, <u>Loss of Reactor or Secondary Coolant</u> - IMPLEMENTED<br><br><u>AND</u><br><br>b) High <u>OR</u> Low Head ECCS flow <u>NOT</u> being delivered to the core<br><br><u>AND</u><br><br>c) Containment RS sump temperature-GREATER THAN <u>190°F</u> <u>AND NOT</u> DECREASING<br><br><u>OR</u><br><br>Containment Spray and Recirculation Spray Systems- <u>NOT</u> OPERABLE | GENERAL<br>EMERGENCY |

|                     |   |                  |
|---------------------|---|------------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB C)<br>FUEL FAILURE OR FUEL HANDLING ACCIDENT | REVISION<br>16   |
| ATTACHMENT<br>1     |   | PAGE<br>18 of 41 |

| CONDITION/APPLICABILITY  | INDICATION  | CLASSIFICATION         |
|--|---|------------------------|
| 9. Major fuel damage accident with radio-activity release to containment or fuel buildings | a) Water level in Rx vessel during refueling - BELOW TOP OF CORE<br><br><u>OR</u><br><br>Water level in Spent Fuel Pit verified - BELOW TOP OF SPENT FUEL<br><br><u>AND</u> | SITE AREA<br>EMERGENCY |
| ALL CONDITIONS   | b) Verified damage to irradiated fuel resulting in readings on Ventilation Vent Gaseous Monitor - GREATER THAN $1 \times 10^6$ cpm  |                        |
| 10. Fuel damage accident with release of radio-activity to containment or fuel buildings   | a) Verified accident involving damage to irradiated fuel<br><br><u>AND</u>  | ALERT                  |
| ALL CONDITIONS   | b) Health Physics confirms fission product release from fuel<br><br><u>OR</u>   |                        |
|  | c) Readings on the Ventilation Vent Gaseous Monitor (RM-VG-110) - GREATER THAN $1 \times 10^6$ cpm  |                        |
| 11. Spent Fuel Storage Facility accident with release of radioactivity                     | a) Verified loss of all cask/ fuel containment barriers<br><br><u>AND</u>   | ALERT                  |
| ALL CONDITIONS   | b) Health Physics confirms fission product release  |                        |

|                            |  |                         |
|----------------------------|--|-------------------------|
| <i>NUMBER</i><br>EPIP-1.01 | <i>ATTACHMENT TITLE</i><br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB C)<br>FUEL FAILURE OR FUEL HANDLING ACCIDENT | <i>REVISION</i><br>16   |
| <i>ATTACHMENT</i><br>1     |  | <i>PAGE</i><br>19 of 41 |

| <u>CONDITION/APPLICABILITY</u>              | <u>INDICATION</u>                                   | <u>CLASSIFICATION</u>            |
|---|---|----------------------------------|
| 12. Spent Fuel Storage<br>Facility accident | a) Verified SSSC seal leak-<br>age                  | NOTIFICATION OF<br>UNUSUAL EVENT |
| ALL CONDITIONS                              | <u>OR</u>   |                                  |
|   | b) Spent Fuel Storage Cask<br>dropped or mishandled |                                  |

|                     |  |                    |
|---------------------|--|--------------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB D)<br>CONTAINMENT EVENT | REVISION<br><br>16 |
| ATTACHMENT<br>1     |  | PAGE<br>20 of 41   |

| <u>CONDITION/APPLICABILITY</u>   | <u>INDICATION</u>  | <u>CLASSIFICATION</u>  |
|--|--|------------------------|
| 1. Extremely high Containment radiation, pressure and temperature<br><br>ABOVE CSD CONDITION | a) Outside Containment High Range Radiation Monitor (RM-RMS-161, -261) - GREATER THAN <u>5x10<sup>2</sup></u> mR/hr<br><br><u>AND</u><br><br>b) Containment pressure - GREATER THAN <u>45</u> psia <u>AND</u> is <u>NOT</u> decreasing<br><br><u>OR</u><br><br>Containment temperature - GREATER THAN <u>280°F</u> | GENERAL<br>EMERGENCY   |
| 2. High Containment radiation, pressure, and temperature<br><br>ABOVE CSD CONDITION          | a) Outside Containment High Range Radiation Monitor (RM-RMS-161, -261) - GREATER THAN <u>2x10<sup>1</sup></u> mR/hr<br><br><u>AND</u><br><br>b) Containment pressure - GREATER THAN <u>23</u> psia and is <u>NOT</u> decreasing<br><br><u>OR</u><br><br>Containment temperature - GREATER THAN <u>200°F</u>        | SITE AREA<br>EMERGENCY |



|                     |  |                  |
|---------------------|--|------------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB D)<br>CONTAINMENT EVENT | REVISION<br>16   |
| ATTACHMENT<br>1     |  | PAGE<br>21 of 41 |

| <u>CONDITION/APPLICABILITY</u>   | <u>INDICATION</u>   | <u>CLASSIFICATION</u>         |
|--|---|-------------------------------|
| 3. High Containment radiation, pressure and temperature<br><br>ABOVE CSD CONDITION | a) Outside Containment High Range Radiation Monitor (RM-RMS-161, -261) - GREATER THAN <u>10</u> mR/hr<br><br><u>AND</u><br><br>b) Containment pressure - GREATER THAN <u>17.7</u> psia<br><br><u>OR</u><br><br>Containment temperature - GREATER THAN <u>150</u> °F   | ALERT                         |
| 4. Loss of Containment integrity<br><br>ABOVE CSD CONDITION                        | Intentional reduction in Power, Load or Temperature because the unit has entered an Action Statement or will exceed a Limiting Condition for Operations.<br><br><u>NOTE:</u> In the event that other plant conditions require a shutdown, NOTIFICATION OF UNUSUAL EVENT must still be declared on the basis that a shutdown would have been required by the Tech Spec.<br><br>a) Loss of Containment integrity as indicated by OP-1E, <u>Containment Integrity Checklist.</u> | NOTIFICATION OF UNUSUAL EVENT |

|                     |  |                  |
|---------------------|--|------------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB E)<br>RADIOACTIVITY EVENT | REVISION<br>16   |
| ATTACHMENT<br>1     |  | PAGE<br>22 of 41 |

| <u>CONDITION/APPLICABILITY</u>  | <u>INDICATION</u>   | <u>CLASSIFICATION</u>  |
|---|---|------------------------|
| 1. Projected or actual site boundary doses exceed <u>2</u> Rem W.B. or <u>12</u> Rem thyroid exposure<br><br>ALL CONDITIONS                               | a) Confirmed actual or projected site boundary doses - GREATER THAN <u>2.0</u> Rem Whole Body OR <u>12.0</u> Rem Thyroid exposure as determined from EPIP-4.01. | GENERAL<br>EMERGENCY   |
| 2. Projected or actual site boundary doses of <u>0.5</u> Rem to <u>2</u> Rem W.B. or <u>1</u> Rem to <u>12</u> Rem thyroid exposure<br><br>ALL CONDITIONS | a) Confirmed actual or projected site boundary doses - GREATER THAN <u>0.5</u> Rem Whole Body or <u>1.0</u> Rem Thyroid exposure as determined from EPIP-4.01.  | SITE AREA<br>EMERGENCY |

|                            |   |                         |
|----------------------------|---|-------------------------|
| <b>NUMBER</b><br>EPIP-1.01 | <b>ATTACHMENT TITLE</b><br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB E)<br>RADIOACTIVITY EVENT | <b>REVISION</b><br>16   |
| <b>ATTACHMENT</b><br>1     |   | <b>PAGE</b><br>23 of 41 |

| <u>CONDITION/APPLICABILITY</u>   | <u>INDICATION</u>  | <u>CLASSIFICATION</u> |
|--|--|-----------------------|
| 3. High radiation or air-borne contamination levels indicate a severe degradation in control of radioactive material<br><br>ALL CONDITIONS | Valid unexpected readings on any of the following monitors have increased by a factor of 1000<br><br>a) Control Room Area Monitor (RM-RMS-157)<br><br>b) Auxiliary Building Control Area Monitor (RM-RMS-154)<br><br>c) Auxiliary Building Drumming Area Monitor (RM-RMS-155)<br><br>d) Decontamination Building Area Monitor (RM-RMS-151)<br><br>e) Fuel Pit Bridge Area Monitor (RM-RMS-153)<br><br>f) New Fuel Storage Area Monitor (RM-RMS-152)<br><br>g) Laboratory Area Monitor (RM-RMS-158)<br><br>h) Sample Room Area Monitor (RM-RMS-156) | ALERT                 |

|                     |  |                  |
|---------------------|--|------------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB E)<br>RADIOACTIVITY EVENT | REVISION<br>16   |
| ATTACHMENT<br>1     |  | PAGE<br>24 of 41 |

| <u>CONDITION/APPLICABILITY</u>  | <u>INDICATION</u>  | <u>CLASSIFICATION</u> |
|---|--|-----------------------|
| 4. Effluent Release GREATER THAN 10 TIMES T.S. instantaneous allowable limits<br><br>ALL CONDITIONS | <p>a) Ventilation Vent Gaseous Monitor (RM-VG-110 <u>or</u> RM-VG-131) - GREATER THAN 1000% T.S. value as determined from Attachment 1, AP-5.20</p> <p><u>OR</u></p> <p>b) Process Vent Gaseous Monitor (RM-GW-102 <u>or</u> RM-GW-130) - GREATER THAN 1000% T.S. value as determined from Attachment 1, AP-5.01</p> <p><u>OR</u></p> <p>c) Air Ejector Monitor (RM-SV-111, -211) - GREATER THAN <math>1 \times 10^6</math> cpm</p> <p><u>AND</u></p> <p>Air ejector exhaust - <u>NOT</u> diverted to containment.</p> <p><u>OR</u></p> <p>d) Discharge Tunnel Monitor (RM-SW-120, -220) - GREATER THAN <math>1.3 \times 10^5</math> cpm</p> <p><u>OR</u></p> <p>e) Sampling and Analysis Team confirms effluent release GREATER THAN 1000% T.S. value as determined from EPIP-4.01.</p> | ALERT                 |



|                     |  |                  |
|---------------------|--|------------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br>EMERGENCY ACTION LEVEL TABLE<br>(TAB E)<br>RADIOACTIVITY EVENT | REVISION<br>16   |
| ATTACHMENT<br>1     |  | PAGE<br>25 of 41 |

| CONDITION/APPLICABILITY   | INDICATION   | CLASSIFICATION                |
|---|--|-------------------------------|
| 5. Effluent release GREATER THAN T.S. allowable Limit<br><br>ALL CONDITIONS | <p>a) Ventilation Vent Gaseous Monitor (RM-VG-110 <u>or</u> RM-VG-131) - GREATER THAN 100% T.S. value as determined from Attachment 1, AP-5.20</p> <p><u>OR</u></p> <p>b) Process Vent Gaseous Monitor (RM-GW-102 <u>or</u> RM-GW-130) - GREATER THAN 100% T.S. value as determined from Attachment 1, AP-5.01</p> <p><u>OR</u></p> <p>c) Air Ejector Monitor (RM-SV-111, -211) - GREATER THAN <math>1.99 \times 10^5</math> cpm</p> <p><u>AND</u></p> <p>Air Ejector Exhaust - <u>NOT</u> diverted to containment.</p> <p><u>OR</u></p> <p>d) Discharge Canal Monitor (RM-SW-120, -220) - GREATER THAN <math>1.3 \times 10^4</math> cpm</p> <p>e) Sampling and Analysis Team confirms effluent release GREATER THAN 100% T.S. value as determined from EPIP-4.01.</p> | NOTIFICATION OF UNUSUAL EVENT |

|                            |  |                         |
|----------------------------|--|-------------------------|
| <i>NUMBER</i><br>EPIP-1.01 | <i>ATTACHMENT TITLE</i><br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB F)<br>CONTAMINATED PERSONNEL | <i>REVISION</i><br>16   |
| <i>ATTACHMENT</i><br>1     |  | <i>PAGE</i><br>26 of 41 |

| <u>CONDITION/APPLICABILITY</u>   | <u>INDICATION</u>  | <u>CLASSIFICATION</u>            |
|--|--|----------------------------------|
| 1. Transportation of<br>contaminated injured<br>individual to off-site<br>facility<br><br>ALL CONDITIONS | Contaminated injured indi-<br>vidual enroute to off-site<br>facility for treatment | NOTIFICATION OF<br>UNUSUAL EVENT |

|                     |  |                  |
|---------------------|--|------------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br>EMERGENCY ACTION LEVEL TABLE<br>(TAB G)<br>LOSS OF SECONDARY COOLANT | REVISION<br>16   |
| ATTACHMENT<br>1     |  | PAGE<br>27 of 41 |

| <u>CONDITION/APPLICABILITY</u>  | <u>INDICATION</u>   | <u>CLASSIFICATION</u>  |
|---|---|------------------------|
| 1. Major Secondary line break with Primary to Secondary leakage<br>GREATER THAN 50 gpm and fuel damage indicated<br><br>ABOVE CSD CONDITION | <p>a) Faulted steam generator indicated by EP-2. Loss of Reactor or Secondary Coolant</p> <p><u>AND</u></p> <p>b) RCS specific activity - GREATER THAN <u>300</u> <math>\mu</math>Ci/gram</p> <p><u>OR</u></p> <p>Letdown High Range Radiation Monitor (RM-CH-118<sub>5</sub>-218) - GREATER THAN <u>10</u><sup>5</sup> cpm</p> <p><u>AND</u></p> <p>c) Condenser Air Ejector Radiation Monitor (RM-SV-111, -211) - GREATER THAN <u>10</u><sup>6</sup> cpm</p> <p><u>OR</u></p> <p>Steam Generator Blowdown Radiation Monitor (RM-SS-112, -113, -212, -213) - GREATER THAN <u>10</u><sup>6</sup> cpm</p> <p><u>OR</u></p> <p>MS Line High Range Radiation Monitor (RM-RI-MS-124, -125, -126, -224, -225, -226) - GREATER THAN <u>2.55x10<sup>-1</sup></u> mR/hr</p> | SITE AREA<br>EMERGENCY |

|                     |  |                  |
|---------------------|--|------------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br>EMERGENCY ACTION LEVEL TABLE<br>(TAB G)<br>LOSS OF SECONDARY COOLANT | REVISION<br>16   |
| ATTACHMENT<br>1     |  | PAGE<br>28 of 41 |

| <u>CONDITION/APPLICABILITY</u>   | <u>INDICATION</u>   | <u>CLASSIFICATION</u>         |
|--|---|-------------------------------|
| 2. Major Secondary line break with Primary to Secondary leakage greater than 10 GPM<br><br>ABOVE CSD CONDITION | a) Faulted steam generator as indicated by EP-2.00, <u>Loss of Reactor or Secondary Coolant</u><br><br><u>AND</u><br><br>b) Condenser Air Ejector Radiation Monitor (RM-SV-111, -211) <sub>6</sub> - GREATER THAN <u>1x10</u> cpm<br><br><u>OR</u><br><br>Steam Generator Blowdown Radiation Monitor (RM-SS-112, -113, -212 <sub>5</sub> -213) - GREATER THAN <u>10</u> cpm | ALERT                         |
| 3. Major Secondary line break<br><br>ABOVE CSD CONDITION   | Faulted steam generator as indicated by EP-2.00, <u>Loss of Reactor or Secondary Coolant</u>  | NOTIFICATION OF UNUSUAL EVENT |



|                     |   |                    |
|---------------------|---|--------------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB H)<br>ELECTRICAL FAILURE | REVISION<br><br>16 |
| ATTACHMENT<br>1     |   | PAGE<br>29 of 41   |

| <u>CONDITION/APPLICABILITY</u>  | <u>INDICATION</u>   | <u>CLASSIFICATION</u>         |
|---|---|-------------------------------|
| 1. Loss of off-site power or on-site AC power capability<br><br>ALL CONDITIONS          | a) Unit Main Generator <u>AND</u> both Emergency Diesel Generators out of service<br><br><u>OR</u><br>b) Loss of all 34.5KV Reserve Station Service Buses   | NOTIFICATION OF UNUSUAL EVENT |
| 2. Loss of off-site and on-site AC power for more than 15 minutes<br><br>ALL CONDITIONS | The following conditions exist for a period - GREATER THAN <u>15</u> minutes<br><br>a) Ammeters for 4160V Reserve Station Service Buses D,E, & F all - ZERO AMPS<br><br><u>AND</u><br>b) Ammeters for 4160V Station Service Buses A,B & C all ZERO AMPS<br><br><u>AND</u><br>c) Ammeters for 4160V Emergency Buses H & J both - ZERO AMPS | SITE AREA EMERGENCY           |

|                     |   |                  |
|---------------------|---|------------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br>EMERGENCY ACTION LEVEL TABLE<br>(TAB H)<br>ELECTRICAL FAILURE | REVISION<br>16   |
| ATTACHMENT<br>1     |   | PAGE<br>30 of 41 |

| <u>CONDITION/APPLICABILITY</u>  | <u>INDICATION</u>  | <u>CLASSIFICATION</u>  |
|---|--|------------------------|
| 3. Loss of all off-site and on-site AC power<br><br>ALL CONDITIONS                | a) Ammeters for 4160V Reserve Station Service Buses D, E, & F all - ZERO AMPS<br><br><u>AND</u><br>b) Ammeters for 4160V Station Service Buses A, B, & C all - ZERO AMPS<br><br><u>AND</u><br>c) Ammeters for 4160V Emergency Buses H and J both - ZERO AMPS | ALERT                  |
| 4. Loss of all on-site DC power for-GREATER THAN 15 minutes<br><br>ALL CONDITIONS | The following conditions exist for a period - GREATER THAN <u>15</u> minutes<br><br>a) All Station Battery voltmeters - ZERO VOLTS<br><br><u>AND</u><br>b) No light indication available to Reserve Station Service Breakers 15D1, 15E1 and 15F1             | SITE AREA<br>EMERGENCY |
| 5. Loss of all on-site DC power<br><br>ALL CONDITIONS                             | a) All Station Battery voltmeters - ZERO VOLTS<br><br><u>AND</u><br>b) No light indication available to Reserve Station Service Breakers 15D1, 15E1 and 15F1   | ALERT                  |

|                     |   |                    |
|---------------------|---|--------------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB 1)<br>FIRE | REVISION<br><br>16 |
| ATTACHMENT<br>1     |   | PAGE<br>31 of 41   |

| <u>CONDITION/APPLICABILITY</u>  | <u>INDICATION</u>  | <u>CLASSIFICATION</u>            |
|---|--|----------------------------------|
| 1. Fire resulting in degradation of safety systems<br><br>ABOVE CSD CONDITION   | a) Fire within the Station which causes major degradation of a safety system function required for protection of the public<br><br><u>AND</u><br><br>b) Affected systems are caused <u>NOT</u> to be operable as defined by T.S.1.0.D and 3.02 | SITE AREA<br>EMERGENCY           |
| 2. Fire potentially affecting station safety systems<br><br>ABOVE CSD CONDITION | Fire within the Station which has potential for causing a safety system <u>NOT</u> to be operable as defined by T.S.1.0.D and 3.0.2  | ALERT                            |
| 3. Fire lasting-GREATER THAN 10 minutes<br><br>ALL CONDITIONS                   | Fire within the Station which is not under control within <u>10</u> minutes after fire fighting efforts begin  | NOTIFICATION OF<br>UNUSUAL EVENT |

|                            |  |                         |
|----------------------------|--|-------------------------|
| <u>NUMBER</u><br>EPIP-1.01 | <u>ATTACHMENT TITLE</u><br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB J)<br>SECURITY EVENT | <u>REVISION</u><br>16   |
| <u>ATTACHMENT</u><br>1     |  | <u>PAGE</u><br>32 of 41 |

| <u>CONDITION/APPLICABILITY</u>   | <u>INDICATION</u>   | <u>CLASSIFICATION</u>  |
|--|---|------------------------|
| 1. Loss of Station physical control<br><br>ALL CONDITIONS                  | a) Shift Supervisor has been informed that the security force has been neutralized by attack, resulting in loss of physical control of station<br><br><u>OR</u><br>b) Shift Supervisor has been informed of intrusion into one or more Vital Areas which are occupied or controlled by an aggressor | GENERAL<br>EMERGENCY   |
| 2. Imminent loss of physical Station control<br><br>ALL CONDITIONS         | Supervisor Security Shift has notified the Shift Supervisor of imminent intrusion into a Vital Area   | SITE AREA<br>EMERGENCY |
| 3. Ongoing Security compromise<br><br>ALL CONDITIONS                       | Supervisor Security Shift has notified the Shift Supervisor of a confirmed unneutralized intrusion into the Protected Area  | ALERT                  |
| 4. Bomb potentially affecting station safety systems<br><br>ALL CONDITIONS | Shift Supervisor notification of a verified bomb discovered on <u>OR</u> near a safety related system   | ALERT                  |



|                            |  |                         |
|----------------------------|--|-------------------------|
| <b>NUMBER</b><br>EPIP-1.01 | <b>ATTACHMENT TITLE</b><br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB J)<br>SECURITY EVENT | <b>REVISION</b><br>16   |
| <b>ATTACHMENT</b><br>1     |  | <b>PAGE</b><br>33 of 41 |

| <u>CONDITION/APPLICABILITY</u>  | <u>INDICATION</u>   | <u>CLASSIFICATION</u>         |
|---|---|-------------------------------|
| 5. Security threat, unauthorized attempted entry, or attempted sabotage<br><br>ALL CONDITIONS | Supervisor Security Shift has initiated SPIP-29, <u>Response to Security Contingency Events</u>   | NOTIFICATION OF UNUSUAL EVENT |
| 6. Bomb threat or discovery<br><br>ALL CONDITIONS   | a) Shift Supervisor notification of a bonafide bomb threat<br><br><u>OR</u><br>b) Shift Supervisor notification of bomb discovery within the Protected Area | NOTIFICATION OF UNUSUAL EVENT |

|                            |   |                         |
|----------------------------|---|-------------------------|
| <u>NUMBER</u><br>EPIP-1.01 | <u>ATTACHMENT TITLE</u><br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB K)<br>HAZARD TO STATION OPERATION | <u>REVISION</u><br>16   |
| <u>ATTACHMENT</u><br>1     |   | <u>PAGE</u><br>34 of 41 |

| <u>CONDITION/APPLICABILITY</u>                                       | <u>INDICATION</u>  | <u>CLASSIFICATION</u>            |
|--|--|----------------------------------|
| 1. Aircraft damage to vital plant systems<br><br>ABOVE CSD CONDITION | Aircraft crash adversely affects vital structures by impact or fire  | SITE AREA<br>EMERGENCY           |
| 2. Aircraft crash on the facility<br><br>ALL CONDITIONS              | a) Aircraft crash within the Protected Area<br><br><u>OR</u><br>b) Aircraft crash in Station Switchyard  | ALERT                            |
| 3. Aircraft crash or unusual aircraft activity<br><br>ALL CONDITIONS | a) Confirmed notification of aircraft crash within the site boundary<br><br><u>OR</u><br>b) Unusual aircraft activity in the vicinity of the site as determined by the Shift Supervisor or Supervisor Security Shift | NOTIFICATION OF<br>UNUSUAL EVENT |
| 4. Severe explosive damage<br><br>ABOVE CSD CONDITION                | Explosion which results in severe degradation of any systems required for safe shutdown  | SITE AREA<br>EMERGENCY           |

|                     |  |                  |
|---------------------|--|------------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br>EMERGENCY ACTION LEVEL TABLE<br>(TAB K)<br>HAZARD TO STATION OPERATION | REVISION<br>16   |
| ATTACHMENT<br>1     |  | PAGE<br>35 of 41 |

| <u>CONDITION/APPLICABILITY</u>  | <u>INDICATION</u>   | <u>CLASSIFICATION</u>         |
|---|---|-------------------------------|
| 5. Explosion damage to facility<br><br>ALL CONDITIONS                                     | Unplanned explosion resulting in damage to plant structure or equipment   | ALERT                         |
| 6. Onsite explosion<br><br>ALL CONDITIONS   | Confirmed report of unplanned explosion onsite  | NOTIFICATION OF UNUSUAL EVENT |
| 7. Entry of toxic or flammable gases into plant vital areas<br><br>ABOVE CSD CONDITION    | a) Uncontrolled release of toxic <u>OR</u> flammable agents into Vital Areas<br><br><u>AND</u><br>b) Evacuation of Vital Area required<br><br><u>OR</u><br>Loss of a safety system function required for protection of the public | SITE AREA EMERGENCY           |
| 8. Entry of toxic or flammable gases or liquids into plant facility<br><br>ALL CONDITIONS | Uncontrolled release of toxic <u>OR</u> flammable agent which cause:<br><br>a) Evacuation of personnel from plant areas<br><br><u>AND</u><br>b) Safety related equipment to be rendered inoperable                                | ALERT                         |

|                            |   |                         |
|----------------------------|---|-------------------------|
| <u>NUMBER</u><br>EPIP-1.01 | <u>ATTACHMENT TITLE</u><br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB K)<br>HAZARD TO STATION OPERATION | <u>REVISION</u><br>16   |
| <u>ATTACHMENT</u><br>1     |   | <u>PAGE</u><br>36 of 41 |

|     | <u>CONDITION/APPLICABILITY</u>   | <u>INDICATION</u>  | <u>CLASSIFICATION</u>         |
|-----|--|--|-------------------------------|
| 9.  | On or nearsite release of toxic or flammable liquids or gases<br><br>ALL CONDITIONS    | Unplanned release of toxic <u>OR</u> flammable agents which may affect safety of station personnel <u>OR</u> equipment | NOTIFICATION OF UNUSUAL EVENT |
| 10. | Severe missile damage to safety systems<br><br>ABOVE CSD CONDITION                     | Missile impact causing severe degradation of safety systems required for unit shutdown                                 | SITE AREA EMERGENCY           |
| 11. | Missile damage to safety related equipment or structures<br><br>ABOVE CSD CONDITION    | Notification of missile impact causing damage to safety related equipment or structures                                | ALERT                         |
| 12. | Turbine failure with penetration<br><br>POWER  | Failure of Turbine/Generator rotating equipment resulting in casing penetration  | ALERT                         |
| 13. | Turbine rotating component failure without casing penetration<br><br>POWER AND STARTUP | Failure of Turbine/Generator rotating component resulting in unit trip   | NOTIFICATION OF UNUSUAL EVENT |



|                            |  |                         |
|----------------------------|--|-------------------------|
| <u>NUMBER</u><br>EPIP-1.01 | <u>ATTACHMENT TITLE</u><br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB L)<br>NATURAL EVENTS | <u>REVISION</u><br>16   |
| <u>ATTACHMENT</u><br>1     |  | <u>PAGE</u><br>37 of 41 |

| <u>CONDITION/APPLICABILITY</u>                                   | <u>INDICATION</u>   | <u>CLASSIFICATION</u>            |
|--|---|----------------------------------|
| 1. Earthquake greater than DBE levels<br><br>ABOVE CSD CONDITION | a) Earthquake which activates the Event Alarm on the Strong Motion Accelerograph<br><br><u>AND</u><br><br>b) AP-37, <u>Seismic Event</u> , calculations indicate horizontal motion of <u>0.15g OR GREATER</u><br><br><u>OR</u><br><br>Safety related systems are significantly degraded by earthquake     | SITE AREA<br>EMERGENCY           |
| 2. Earthquake greater than OBE levels<br><br>ALL CONDITIONS      | a) Confirmed earthquake which activates Event Alarm on the Strong Motion Accelerograph<br><br><u>AND</u><br><br>b) AP-37, <u>Seismic Event</u> , calculations indicate horizontal motion of <u>0.07g OR GREATER</u><br><br><u>OR</u><br><br>Safety related equipment is rendered inoperable by earthquake | ALERT                            |
| 3. Earthquake detected<br><br>ALL CONDITIONS                     | Confirmed earthquake which activates the Event Alarm on the Strong Motion Accelerograph   | NOTIFICATION OF<br>UNUSUAL EVENT |

|                     |   |                    |
|---------------------|---|--------------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB L)<br>NATURAL EVENTS | REVISION<br><br>16 |
| ATTACHMENT<br>1     |   | PAGE<br>38 of 41   |

|    | <u>CONDITION/APPLICABILITY</u>                  | <u>INDICATION</u>   | <u>CLASSIFICATION</u>         |
|----|---|---|-------------------------------|
| 4. | Tornado striking facility<br><br>ALL CONDITIONS | Tornado visually detected striking within the Protected Area or Switchyard  | ALERT                         |
| 5. | Tornado onsite<br><br>ALL CONDITIONS            | Tornado visually detected onsite  | NOTIFICATION OF UNUSUAL EVENT |
| 6. | Severe winds<br><br>ABOVE CSD CONDITION         | Sustained severe winds in excess of <u>100</u> mph caused by Hurricane, Tornado or other severe weather condition | SITE AREA EMERGENCY           |
| 7. | Extreme winds<br><br>ABOVE CSD CONDITION        | Sustained extreme winds between <u>80</u> and <u>100</u> mph Hurricane or other severe weather conditions         | ALERT                         |
| 8. | High winds<br><br>ALL CONDITIONS                | Sustained wind speed onsite measured or projected to be between <u>73</u> and <u>80</u> mph                       | NOTIFICATION OF UNUSUAL EVENT |
|    |   | <u>OR</u><br><br>System Operator notification of hurricane watch for Surry County                                 |                               |

|                     |   |                    |
|---------------------|---|--------------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB L)<br>NATURAL EVENTS | REVISION<br><br>16 |
| ATTACHMENT<br>1     |   | PAGE<br>39 of 41   |

| <u>CONDITION/APPLICABILITY</u>  | <u>INDICATION</u>  | <u>CLASSIFICATION</u>            |
|---|--|----------------------------------|
| 9. Flood or low water level above design levels<br><br>ALL CONDITIONS | Flood in the James River -<br>GREATER THAN <u>+27</u> feet MSL<br><br><u>OR</u><br><br>Water level in the James River - LESS THAN <u>-9</u> feet MSL as indicated by loss of Emergency SW Pump suction                   | SITE AREA<br>EMERGENCY           |
| 10. Flood or low water level near design levels<br><br>ALL CONDITIONS | Flood in the James River -<br>GREATER THAN <u>+21</u> but LESS THAN <u>+27</u> feet MSL<br><br><u>OR</u><br><br>Water level in the Surry Power Station Intake Canal - LESS THAN <u>18</u> feet <u>AND</u> DECREASING     | ALERT                            |
| 11. Flood or low water level<br><br>ALL CONDITIONS                    | Flood in the James River -<br>GREATER THAN <u>+12</u> but LESS THAN <u>+21</u> feet MSL<br><br><u>OR</u><br><br>Water level in the Surry Power Station Intake Canal - LESS THAN <u>18</u> feet <u>AND NOT</u> INCREASING | NOTIFICATION OF<br>UNUSUAL EVENT |

|                            |   |                         |
|----------------------------|---|-------------------------|
| <u>NUMBER</u><br>EPIP-1.01 | <u>ATTACHMENT TITLE</u><br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB M)<br>MISCELLANEOUS ABNORMAL EVENTS | <u>REVISION</u><br>16   |
| <u>ATTACHMENT</u><br>1     |   | <u>PAGE</u><br>40 of 41 |

| <u>CONDITION/APPLICABILITY</u>  | <u>INDICATION</u>                                       | <u>CLASSIFICATION</u>  |
|---|---|------------------------|
| 1. Any major internal or external events which singly or in combination cause massive damage to station facilities<br><br>ALL CONDITIONS                          | Shift Supervisor/Station<br>Emergency Manager judgement | GENERAL<br>EMERGENCY   |
| 2. Station conditions which warrant activation of emergency facilities monitoring teams and precautionary Protection Action Recommendations<br><br>ALL CONDITIONS | Shift Supervisor/Station<br>Emergency Manager judgement | SITE AREA<br>EMERGENCY |
| 3. Station conditions which warrant precautionary Protection Action Recommendations<br><br>ALL CONDITIONS   | Shift Supervisor/Station<br>Emergency Manager judgement | ALERT                  |



|                     |   |                  |
|---------------------|---|------------------|
| NUMBER<br>EPIP-1.01 | ATTACHMENT TITLE<br><br>EMERGENCY ACTION LEVEL TABLE<br>(TAB M) | REVISION<br>16   |
| ATTACHMENT<br>1     | MISCELLANEOUS ABNORMAL EVENTS                                   | PAGE<br>41 of 41 |

| <u>CONDITION/APPLICABILITY</u>  | <u>INDICATION</u>  | <u>CLASSIFICATION</u>         |
|---|--|-------------------------------|
| 4. Station conditions which warrant increased awareness of state and/or local authorities<br><br>ALL CONDITIONS | <p>Shift supervisor judgement that any of the following exist:</p> <p>a) Intentional reduction in Power, Load or Temperature because the unit has entered an Action Statement or will exceed a Limiting Condition for Operation.</p> <p>NOTE: In the event that other plant conditions require a shutdown, NOTIFICATION OF UNUSUAL EVENT must still be declared on the basis that a shutdown would have been required by the Tech Spec.</p> <p><u>OR</u></p> <p>b) Unit shutdown is other than a controlled shutdown</p> <p><u>OR</u></p> <p>c) Unit is in an uncontrolled condition during operation</p> <p><u>OR</u></p> <p>d) A condition exists that has the potential for escalation and, therefore, warrants notification.</p> | NOTIFICATION OF UNUSUAL EVENT |