



Log # TXX-6423
File # 10110
903.8
Ref # 10CFR50.55(e)

William G. Council
Executive Vice President

May 1, 1987

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446
PROXIMITY PLACEMENT - RICHMOND INSERTS TO EMBEDDED
PLATES AND WELDED ATTACHMENTS TO EMBEDDED PLATES
SDAR: CP-86-04 (INTERIM REPORT)

Gentlemen:

On February 13, 1987, we notified you by our letter logged TXX-6260, of a deficiency involving the placement of Richmond inserts in the proximity of loaded embedded plates which could compromise the integrity of adjacent shear cones. This is an interim report of a deficiency which is reportable under the provisions of 10CFR50.55(e). By our telephone request of April 29, 1987, received by your Mr. Cliff Hale, the due date for this report was extended until May 13, 1987.

Our corrective actions previously specified for Unit 1 are continuing as planned. Based on the current project schedule, it is anticipated that the Unit 1 corrective actions will be completed by December 31, 1987. New work for Unit 2 is being done in accordance with the revised design specification and the related construction/quality control procedures. The Unit 2 field verification of existing installations will be conducted following the completion of the Unit 1 verification.

We anticipate submitting our next report no later than August 1, 1987.

Very truly yours,

W. G. Council

8705070003 870501
PDR ADOCK 05000445
S PDR

By:
G. S. Keeley
Manager, Nuclear Licensing

BSD:amb

c - Mr. E. H. Johnson, Region IV
Mr. D. L. Kelley, RI - Region IV
Mr. H. S. Phillips, RI - Region IV

IF27
10