



Public Service™

Public Service
Company of Colorado

2420 W. 26th Avenue, Suite 100D, Denver, Colorado 80211

May 4, 1987
Fort St. Vrain
Unit No. 1
P-87171

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Attention: Mr. Jose A. Calvo
Director, Project Directorate IV

Docket No. 50-267

SUBJECT: Additional Information for
Analysis of Firewater Cooldown
for 82% Power Operation

REFERENCE: PSC letter, Brey to Berkow,
dated March 20, 1987 (P-87110)

Dear Mr. Calvo:

PSC has completed the special test that was discussed in PSC's Response 7 in Attachment 1 of the above Reference. The results of this test are evaluated in "Evaluation of Test Data for the Confirmation of Fire Water Flow Rate to the Circulator Water Turbine During EES Cooldown for Safe Shutdown Cooling," EE-EQ-0057, Rev. A.

One copy of EE-EQ-0057, Rev. A is enclosed for your information in accordance with PSC's Response 7 in Attachment 1 of the above Reference.

If you have any questions about this evaluation, please contact Mr. M. H. Holmes at (303) 480-6960.

Very truly yours,

Lawrence Brey

H. L. Brey, Manager
Nuclear Licensing and
Fuels Division

8705080288 870504
PDR ADOCK 05000267
F PDR

HLB/AW:jmt

Enclosure

cc: Regional Administrator, Region IV
Attn. Mr. J. E. Gagliardo, Chief
Reactor Projects Branch

Mr. R. E. Farrell
Senior Resident Inspector
Fort St. Vrain

*A006
1/1*