WCAP-11410 Revision 1

> TECHNICAL BASES FOR ELIMINATING LARGE PRIMARY LOOP PIPE RUPTURE AS THE STRUCTURAL DESIGN BASIS FOR KEWAUNEE

> > February 1987 Revision 1: April 1987

D. H. Roarty S. R. Nelson Y. S. Lee D. A. Lindgren

VERIFIED: Found itt

APPROVED ; S. Palusamy, Manager Structural Materials

Engineering

APPROVED:

Manager G. Antak' Structural and Seismic

Development

APPROVED:

C. W. Hirst, Manager

Mechanical Equipment and Systems Licensing

WESTINGHOUSE ELECTRIC CORPORATION Nuclear Energy Systems P. D. Box 2728 Pittsburgh, Pennsylvania 15230-2728

8706260181 870622 PDR ADOCK 05000305 PDR

## FOREWORD

The revisions are identified by vertical lines in the column.

# TABLE OF CONTENTS

Sect	ion	Title	Page
1.0	SUMM 1.1 1.2	ARY AND INTRODUCTION Summary Introduction 1.2.1 Purpose 1.2.2 Scope 1.2.3 Objectives 1.2.4 Background Information	1-1 1-1 1-1 1-1 1-2 1-2 1-2
2.0	OPER 2.1 2.2 2.3	ATION AND STABILITY OF THE PRIMARY SYSTEM Stress Corrosion Cracking Water Hammer Low Cycle and High Cycle Fatigue	2-1 2-1 2-2 2-3
3.0	PIPE	GEOMETRY AND LOADING	3-1
4.0	FRAC 4.1 4.2 4.3 4.4	TURE MECHANICS EVALUATION Global Failure Mechanism Local Failure Mechanism Material Properties Results of Crack Stability Evaluation	4-1 4-1 4-2 4-3 4-6
5.0	LEAK 5.1 5.2 5.3 5.4	RATE PREDICTIONS Introduction General Considerations Calculation Method Leak Rate Calculations	5-1 5-1 5-1 5-1 5-2
6.0	FATI	GUE CRACK GROWTH ANALYSIS	6-1
7.0	ASSE	SSMENT OF MARGINS	7-1
8.0	CONC	LUSIONS	8-1
9.0	REFE	RENCES	9-1
APPEN	IDIX A	- Limit Moment	A-1
APPEN	DIX B	- Alternate Toughness Criteria for the Kewaunee Cast Primary Loop Components	B-1
		<ul> <li>B.1 Introduction</li> <li>B.2 Chemistry and KCU Toughness</li> <li>B.3 The As-Built Kewaunee Loops</li> <li>B.4 Alternate Toughness Criteria for the Kewaunee Cast Primary Loop Material on a Component-by-Component Basis</li> </ul>	B-1 B-1 B-1 B-2

## LIST OF TABLES

Table	Title	Page
3-1	Kewaunee Primary Loop Data Including Faulted Loading Conditions	3-3
3-2	Normal Condition (Dead Weight + Pressure + Thermal) Loads for Kewaunee	3-4
4-1	Fracture Toughness Criteria Used in the Leak-Before- Break Evaluation	4-9
6-1	Fatigue Crack Growth at [ ]a,c,e (40 Years)	6-3
7-1	Summary of J and Leak Rate Results as a Function of Crack Length at the Four Critical Locations	7-3
B-1	Chemical and Physical Properties of Kewaunee Cast Primary Loop Material - SA 351/CF8M	B-4
B-2	Fracture Toughness Criteria for the Cast Primary Piping Components of the Kewaunee Nuclear Plant	B-5

LIST OF FIGURES

Figure	Title	Page
3-1	Reactor Coolant Pipe	3-5
3-2	Schematic Diagram of Primary Loop Showing Weld Locations - Kewaunee	3-6
4-1	[ ] <sup>a,c,e</sup> Stress Distribution	4-10
4-2	J vs ∆a for SA351 CF8M Cast Stainless Steel at 600°F	4-11
4-3	J-da Curves at Different Temperatures, Aged Material	4-12
4-4	"Critical" Flaw Size Prediction - Hot Leg at Load Critical Location 1	4-13
4-5	"Critical" Flaw Size Prediction - Crossover Leg at Toughness Critical Location 8	4-14
4-6	"Critical" Flaw Size Prediction - Crossover Leg at Toughness Critical Location 9	4-15
4-7	"Critical" Flaw Size Prediction - Cold Leg at Toughness Critical Location 10	4-15
5-1	Analytical Predictions of Critical Flow Rates of Steam-Water Mixtures	5-4
5-2	[ ] <sup>a,c,e</sup> Pressure Ratio as a Function of L/D	5-5
5-3	Idealized Pressure Drop Profile Through a Postulated Crack	5-6
6-1	Typical Cross-Section of [ ]a,c,e	6-4
6-2	Reference Fatigue Crack Growth Curves for ja, c, e	6-5
6-3	Reference Fatigue Crack Growth Law for [ ] <sup>a,c,e</sup> in a Water Environment at 600°F	6-6

vi

LIST OF FIGURES (Cont'd.)

Figure	Title	Page
A-1	Pipe with a Through-Wall Crack in Bending	A-2
B-1	Typical Layout of the Primary Loops for a Westinghouse Two-Loop Plant Without Isolation Valves	B-6
B-2	Identification of Heats with Location for Cold Leg	B-7
B-3	Identification of Heats with Location for Hot Leg	B-8
B-4	Identification of Heats with Location for Crossover Leg	B-9

#### 1.1 Summary

The original structural design basis for the Kewaunee reactor coolant system primary loop required that the effects of pipe breaks be considered. However such breaks have been shown to be highly unlikely on a generic basis and the Nuclear Regulatory Commission has revised criteria which allow exclusion of dynamic effects from the design basis.

In this report the applicability of the generic evaluations to the Kewaunee piping system is demonstrated by presenting a fracture mechanics evaluation, a determination of leak rates from a through-wall crack, a fatigue crack growth evaluation and an assessment of margins. Major emphasis is on the cast piping components which are limiting. Geometries, loadings and heat chemistries are summarized. Fracture toughness values are established for each part using the alternate toughness criteria approach. Fracture mechanics and leak rate calculations showed that acceptable margins exist between cracks which are stable and those for which detectable leak rates are demonstrated.

This report demonstrates that the reactor coolant system primary loop pipe breaks need not be considered in the structural design basis of the Kewaunee plant, in accordance with the revised General Design Criterion 4.

#### 1.2 Introduction

#### 1.2.1 Purpose

This report applies to the Kewaunee Reactor Coolant System (RCS) primary loop piping. It is intended to demonstrate that for the specific parameters of the Kewaunee plant, RCS primary loop pipe breaks need not be considered in the structural design basis. The approach taken has been accepted by the Nuclear Regulatory Commission (NRC) (Reference 1).

1-1

#### 1.2.2 Scope

The existing structural design basis for the RCS primary loop requires that dynamic effects of pipe breaks be evaluated. In addition, protective measures for the dynamic effects associated with RCS primary loop pipe breaks have been incorporated in the Kewaunee plant design. However, Westinghouse has demonstrated on a generic basis that RCS primary loop pipe breaks are highly unlikely and should not be included in the structural design basis of Westinghouse plants (see Reference 2). In order to demonstrate this applicability of the generic evaluations to the Kewaunee plant, Westinghouse has performed a fracture mechanics evaluation, a determination of leak rates from a through-wall crack, a fatigue crack growth evaluation, and an assessment of margins.

#### 1.2.3 Objectives

In order to validate the elimination of RCS primary loop pipe breaks for the Kewaunee plant, the following objectives must be achieved:

- a. Demonstrate that margin exists between the "critical" crack size and a postulated crack which yields a detectable leak rate.
- b. Demonstrate that there is sufficient margin between the leakage through a postulated crack and the leak detection capability of the Kewaunee plant.
- c. Demonstrate that fatigue crack growth is negligible.

#### 1.2.4 Background Information

Westinghouse has performed considerable testing and analysis to demonstrate that RCS primary loop pipe breaks can be eliminated from the structural design basis of all Westinghouse plants. The concept of eliminating pipe breaks in the RCS primary loop was first presented to the NRC in 1978 in WCAP-9283 (Reference 3). That Topical Report employed a deterministic fracture mechanics evaluation and a probabilistic analysis to support the elimination of RCS primary loop pipe breaks. That approach was then used as a means of addressing Generic Issue A-2 and Asymmetric LOCA Loads. Westinghouse performed additional testing and analysis to justify the elimination of RCS primary loop pipe breaks. This material was provided to the NRC along with Letter Report NS-EPR-2519 (Reference 4).

The NRC funded research through Lawrence Livermore National Laboratory (LLNL) to address this same issue using a probabilistic approach. As part of the LLNL research effort, Westinghouse performed extensive evaluations of specific plant loads, material properties, transients, and system geometries to demonstrate that the analysis and testing previously performed by Westinghouse and the research performed by LLNL applied to all Westinghouse plants including Kewaunee (References 5 and 6). The results from the LLNL study were released at a March 28, 1983 ACRS Subcommittee meeting. These studies which are applicable to all Westinghouse plants east of the Rocky Mountains determined the mean probability of a direct LOCA (RCS primary loop pipe break) to be  $10^{-70}$  per reactor year and the mean probability of an indirect LOCA to be  $10^{-7}$  per reactor year. Thus, the results previously obtained by Westinghouse (Reference 3) were confirmed by an independent NRC research study.

Based on the studies by Westinghouse, LLNL, the ACRS, and the AIF, the NRC completed a safety review of the Westinghouse reports submitted to address asymmetric blowdown loads that result from a number of discrete break locations on the PWR primary systems. The NRC Staff evaluation (Reference 1) concludes that an acceptable technical basis has been provided so that asymmetric blowdown loads need not be considered for those plants that can demonstrate the applicability of the modeling and conclusions contained in the Westinghouse response or can provide an equivalent fracture mechanics demonstration of the primary coolant loop integrity. In a more formal recognition of LBB methodology applicability for PWRs, the NRC appropriately modified 10CFR50, General Design Criterion 4, "Requirements for Protection Against Dynamic Effects for Postulated Pipe Rupture" (Federal Register/Volume 51, Number 70/April 11, 1986/Rules and Regulations, pp. 12502-12505).

This report provides a fracture mechanics demonstration of primary loop integrity for the Kewaunee plant consistent with the NRC position for exemption from consideration of dynamic effects.

#### 2.0 OPERATION AND STABILITY OF THE REACTOR COOLANT SYSTEM

The Westinghouse reactor coolant system primary loop has an operating history which demonstrates the inherent stability characteristics of the design. This includes a low susceptibility to cracking failure from the effects of corrosion (e.g., intergranular stress corrosion cracking), water hammer, or fatigue (low and high cycle). This operating history totals over 450 reactor-years, including five plants each having over 16 years of operation and 15 other plants each with over 11 years of operation.

#### 2.1 Stress Corrosion Cracking

For the Westinghouse plants, there is no history of cracking failure in the reactor coolant system loop piping. For stress corrosion cracking (SCC) to occur in piping, the following three conditions must exist simultaneously: high tensile stresses, a susceptible material, and a corrosive environment (Reference 7). Since some residual stresses and some degree of material susceptibility exist in any stainless steel piping, the potential for stress corrosion is minimized by proper material selection immune to SCC as well as preventing the occurrence of a corrosive environment. The material specifications consider compatibility with the system's operating environment (both internal and external) as well as other materials in the system, applicable ASME Code rules, fracture toughness, welding, fabrication, and processing.

The environments known to increase the susceptibility of austenitic stainless steel to stress corrosion are (Reference 7): oxygen, fluorides, chlorides, hydroxides, hydrogen peroxide, and reduced forms of sulfur (e.g., sulfides, sulfites, and thionates). Strict pipe cleaning standards prior to operation and careful control of water chemistry during plant operation are used to prevent the occurrence of a corrosive environment. Prior to being put into service, the piping is cleaned internally and externally. During flushes and preoperational testing, water chemistry is controlled in accordance with written specifications. External cleaning for Class 1 stainless steel piping includes patch tests to monitor and control chloride and fluoride levels. For

2-1

preoperational flushes, influent water chemistry is controlled. Requirements on chlorides, fluorides, conductivity, and pH are included in the acceptance criteria for the piping.

During plant operation, the reactor coolant water chemistry is monitored and maintained within very specific limits. Contaminant concentrations are kept below the thresholds known to be conducive to stress corrosion cracking with the major water chemistry control standards being included in the plant operating procedures as a condition for plant operation. For example, during normal power operation, oxygen concentration in the RCS is expected to be less than 0.005 ppm by controlling charging flow chemistry and maintaining hydrogen in the reactor coolant at specified concentrations. Halogen concentrations are also stringently controlled by maintaining concentrations of chlorides and fluorides within the specified limits. This is assured by controlling charging flow chemistry and specifying proper wetted surface materials.

#### 2.2 Water Hammer

Overall, there is a low potential for water hammer in the RCS since it is designed and operated to preclude the voiding condition in normally filled lines. The reactor coolant system, including piping and primary components, is designed for normal, upset, emergency, and faulted condition transients. The design requirements are conservative relative to both the number of transients and their severity. Relief valve actuation and the associated hydraulic transients following valve opening are considered in the system design. Other valve and pump actuations are relatively slow transients with no significant effect on the system dynamic loads. To ensure dynamic system stability, reactor coolant parameters are stringently controlled. Temperature during normal operation is maintained within a narrow range by control rod position; pressure is controlled by pressurizer heaters and pressurizer spray also within a narrow range for steady-state conditions. The flow characteristics of the system remain constant during a fuel cycle because the only governing parameters, namely system resistance and the reactor coolant pump characteristics, are controlled in the design process. Additionally, Westinghouse has instrumented typical reactor coolant systems to verify the

flow and vibration characteristics of the system. Preoperational testing and operating experience have verified the Westinghouse approach. The operating transients of the RCS primary piping are such that no significant water hammer can occur.

#### 2.3 Low Cycle and High Cycle Fatigue

Low cycle fatigue considerations are accounted for in the design of the piping system through the fatigue usage factor evaluation to show compliance with the rules of Section III of the ASME Code. A further evaluation of the low cycle fatigue loadings was carried out as part of this study in the form of a fatigue crack growth analysis, as discussed in Section 6.

High cycle fatigue loads in the system would result primarily from pump vibrations. These are minimized by restrictions placed on shaft vibrations during hot functional testing and operation. During operation, an alarm signals the exceedance of the vibration limits. Field measurements have been made on a number of plants during hot functional testing, including plants similar to Kewaunee. Stresses in the elbow below the reactor coolant pump have been found to be very small, between 2 and 3 ksi at the highest. These stresses are well below the fatigue endurance limit for the material and would also result in an applied stress intensity factor below the threshold for fatigue crack growth.

2-3

#### 3.0 PIPE GEOMETRY AND LOADING

The general analytical approach is discussed first. A segment of the primary coolant hot leg pipe shown below to be limiting in terms of stresses is sketched in Figure 3-1. This segment is postulated to contain a circumferential through-wall flaw. The inside diameter and wall thickness of the pipe are 29.2 and 2.69 inches, respectively. The pipe is subjected to a normal operating pressure of 2235 psi. Figure 3-2 identifies the loop weld locations. The material properties and the loads at these locations resulting from deadweight, thermal expansion, and Safe Shutdown Earthquake are indicated in Table 3-1. As seen from this table, the junction of the hot leg and the reactor vessel outlet nozzle is the worst location for crack stability analysis based on the highest stress due to combined pressure, dead weight, thermal expansion, and SSE (Safe Shutdown Earthquake) loadings. At this location, the axial load (F,) and the bending moment ( $M_{\rm b}$ ) are 1514 kips (including axial force due to pressure) and 25,683 in-kips, respectively. This location will be referred to as the load critical location. However, as seen later, significant degradation of end-of-service life fracture toughnesses due to thermal aging occurs in several pipe heats and fittings. The highest stresses and lowest toughness locations for which pipes fittings suffer such degradation will be referred to as toughness critical locations. The associated heats of material or welds with low toughness will be called the toughness critical materials. As seen in Table 3-1, the toughness critical locations are 8, 9, and 10 (see Figure 3-2). Location 1 is also a toughness critical location.

The loads of Table 3-1 are calculated as follows: The axial force F and transverse bending moments,  $M_y$  and  $M_z$ , are chosen for each static load (pressure, deadweight, and thermal) based on elastic-static analyses for each of these load cases. These pipe load components are combined algebraically to define the equivalent pipe static loads  $F_s$ ,  $M_{ys}$ , and  $M_{zs}$ . Based on elastic SSE response spectra analyses, amplified pipe seismic loads,  $F_d$ ,  $M_{yd}$ ,  $M_{zd}$ , are obtained. The maximum pipe loads are obtained by combining the static and dynamic load components as follows:

$$F_{x} = |F_{s}| + |F_{d}|$$
$$M_{b} = \sqrt{M_{y}^{2} + M_{z}^{2}}$$

where:

$$M_{y} = |M_{ys}| + |M_{yd}|$$
$$M_{z} = |M_{zs}| + |M_{zd}|$$

The normal operating loads (i.e., algebraic sum of pressure, deadweight, and 100 percent power thermal expansion loading) at the locations identified in Figure 3-2 are given in Table 3-2. The loads were determined as described above.

The calculated and allowable stresses for ASME III NB-3600 equation 9F (faulted i.e., pressure, deadweight, and SSE) and equation 12 (normal operating thermal stress) at load critical location 1 are as follows:

	Calculated	Allowable	Ratio of
Equation	Stress	Stress	Calculated/
Number	<u>(ksi)</u>	(ksi)	Allowable
9F	8.5	50.1	0.17
12	12.02	50.1	0.24

At the other locations, the calculated stresses and ratios are even less.

TABLE 3-1

KEWAUNEE PRIMARY LOOP DATA INCLUDING FAULTED LOADING CONDITIONS

Direct Stress (ksi) $\sigma_a = \frac{F}{A} + \frac{W}{2}$	18.4	9.2	9.6	7.0	6.6	6.0	7.8	9.6	11.2	9.5	8.5	8.5
Loads <sup>a</sup> Bending Moment (in-Kips) M <sub>b</sub>	25683	7219	12568	3874	2815	1497	5165	9557	12959	5974	4334	4286
Faulted   Axial Load (Kips) F <sub>x</sub>	1514	1513	1376	1680	1676	1669	1739	1739	1800	1457	1458	1448
Flow Stress ]a.c.e (ksi)	42.9	42.9	42.9	43.3	43.3	43.3	43.3	43.3	43.3	43.3	43.3	43.3
Ultimate Stress <sup>a</sup> u [ (ksi)	67.0	67.0	67.0	67.0	67.0	67.0	67.0	67.0	67.0	67.0	67.0	67.0
Yield Stress <sup>a</sup> y (ksi)	18.8	18.8	18.8	19.5	19.5	19.5	19.5	19.5	19.5	19.5	19.5	19.5
Wall Thickness (in)	2.69	2.69	2.88	2.88	2.88	2.88	2.88	2.88	2.88	2.55	2.55	2.55
Inside Radius (in)	14.6	14.6	15.6	15.6	15.6	15.6	15.6	15.6	15.6	13.85	13.85	13.85
Weld	1 <sup>b,c</sup>	2	e	4	5	9	7	80	90	10 <sup>c</sup>	11	12

<sup>a</sup>Includes internal pressure

bload critical location for the entire system

<sup>c</sup>Toughness critical location

3-3

## TABLE 3-2

# NORMAL CONDITION (DEAD WEIGHT + PRESSURE + THERMAL) LOADS FOR KEWAUNEE

Weld	Axial Load	Bending Moment
Location	Fx (Kips) <sup>a</sup>	M <sub>b</sub> (in-Kips)
l <sup>b,c</sup>	1452	25080
2	1452	6774
3	1333	12371
4	1666	2811
5	1669	2096
6	1662	1161
7	1729	4882
8 <sup>c</sup>	1729	9173
9c	1792	12007
10 <sup>C</sup>	1426	4482
11	1426	3938
12	1422	3734

<sup>a</sup>Includes internal pressure <sup>b</sup>Load critical location <sup>c</sup>Toughness critical locations





M = 25,683 in-kips

F = 1514 kips

P = 2,235 psi

.







## HOT LEG

Temperature: 599°F; Pressure: 2235 psi

### CROSSOVER LEG

Temperature: 536°F; Pressure: 2190 psi

### COLD LEG

Temperature: 536°F; Pressure: 2290 psi

Figure 3-2 Schematic Diagram of Kewaunee RCL Showing Weld Identifications

#### 4.0 FRACTURE MECHANICS EVALUATION

#### 4.1 Global Failure Mechanism

Determination of the conditions which lead to failure in stainless steel should be done with plastic fracture methodology because of the large amount of deformation accompanying fracture. One method for predicting the failure of ductile material is the plastic instability method, based on traditional plastic limit load concepts, but accounting for strain hardening and taking into account the presence of a flaw. The flawed pipe is predicted to fail when the remaining net section reaches a stress level at which a plastic hinge is formed. The stress level at which this occurs is termed as the flow stress. The flow stress is generally taken as the average of the yield and ultimate tensile strength of the material at the temperature of interest. This methodology has been shown to be applicable to ductile piping through a large number of experiments and will be used here to predict the critical flaw size in the primary coolant piping. The failure criterion has been obtained by requiring equilibrium of the section containing the flaw (Figure 4-1) when loads are applied. The detailed development is provided in Appendix A for a through-wall circumferential flaw in a pipe with internal pressure, axial force, and imposed bending moments. The limit moment for such a pipe is given by:

a,c,e

1

where:

[

[

la,c,e

]<sup>a,c,e</sup>

The analytical model described above accurately accounts for the piping internal pressure as well as imposed axial force as they affect the limit moment. Good agreement was found between the analytical predictions and the experimental results (Reference 8).

#### 4.2 Local Failure Mechanism

The local mechanism of failure is primarily dominated by the crack tip behavior in terms of crack-tip blunting, initiation, extension and finally crack instability. Depending on the material properties and geometry of the pipe, flaw size, shape and loading, the local failure mechanisms may or may not govern the ultimate failure.

The stability will be assumed if the crack does not initiate at all. It has been accepted that the initiation toughness measured in terms of  $J_{Ic}$  from a J-integral resistance curve is a material parameter defining the crack initiation. If, for a given load, the calculated J-integral value is shown to be less than the  $J_{Ic}$  of the material, then the crack will not initiate. If the initiation criterion is not met, one can calculate the tearing modulus as defined by the following relation:

$$T_{app} = \frac{dJ}{da} = \frac{E}{\sigma_{f}^{2}}$$

where:

ja,c,e

In summary, the local crack stability will be established by the two-step criteria:

J < JIC

or

```
T_{app} < T_{mat} if J \ge J_{Ic}
```

#### 4.3 Material Properties

The primary loop piping and fittings material for Kewaunee is SA351-CF8M, a cast product form. Welds exist as indicated in Figure 3-2.

The tensile and flow properties of the load critical location and the toughness critical locations are given in Table 3-1.

The pre-service fracture toughness of cast materials in terms of J have been found to be very high at 600°F. Typical results are given in Figure 4-2 taken from Reference 9.  $J_{IC}$  is observed to be over 5000 in-lbs/in<sup>2</sup>. However, cast stainless steels are subject to thermal aging during service. This thermal aging causes an elevation in the yield strength of the material and a degradation of the fracture toughness, the degree of degradation being proportional to the level of ferrite in the material.

To determine the effects of thermal aging on piping integrity, a detailed study was carried out in Reference 10. In that report, fracture toughness results were presented for a material representative of [ j<sup>a,c,e</sup> Toughness results were provided for the material in the full service life condition and these properties are also presented in Figure 4-3 of this report for information. The  $J_{Ic}$  value for this material at operating temperature was approximately [  $J^{a,c,e}$  and the maximum value<sup>a</sup> of J obtained in the tests was in excess of [  $J^{a,c,e}$  The tests of this material were conducted on small specimens and therefore rather short crack extensions occurred, (maximum extension 4.3 mm) so it is expected that higher J values would be sustained for larger specimens.  $T_{mat}$  was [

]<sup>a,c,e</sup> at operating temperature. The effects of the aging process on the end-of-service life fracture toughness is discussed in Appendix B.

End-of-service life toughnesses for the heats are established using the alternate toughness criteria methodology described in Appendix B. By that methodology a heat of material is said to be as good as  $[]^{a,c,e}$  if it can be demonstrated that its end-of-service fracture toughnesses equal or exceed those of  $[]^{a,c,e}$ . Of the twenty-three heats examined in Appendix B, nine are below the initial governing criterion. The lowest toughness occurs in the horizontal run on the crossover leg in loop A only (locations 7 and 8).

The piping spool pieces which required evaluation using the alternate toughness criteria are summarized in Table B-2. To select points for the detailed colculations, three basic criteria were considered, the minimum toughness and the maximum faulted loads, for the stability calculations, and the minimum normal loads for the leak rate calculation. Because of the thermal aging embrittlement, each run of piping and fittings are evaluated individually for leak-before-break. In the hot leg, point 1 was a clear choice having the least toughness material (toughness critical) and highest faulted loads (load critical). In the crossover leg two points were selected

An additional supplementary criterion applied here is that  $J \leq J_{max}$ where  $J_{max}$  is the maximum value of J obtained from J tests for the material in question.

for evaluation. Point 8 was selected as the toughness critical location and point 9 as the load critical location. Finally, in the cold leg two points were evaluated. Point 11 was selected as the toughness critical location but loads from point 10, which had somewhat higher loads, were used at point 11. For leak rate, the lower normal loads at point 11 were conservatively used. Results will be reported as point 10 in this report.

The fracture toughness criteria to be used in the fracture mechanics evaluation, based on the alternate toughness methodology of Appendix B, are given in Table 4-1. These toughness values are the lowest of all heats occurring at that location.

Available data on aged stainless steel welds (References 10 and 11) indicate the  $J_{Ic}$  values for the worst case welds are of the same order as the aged  $[ ]^{a,c,e}$  material. However, the slope of the J-R curve is steeper, and higher J-values have been obtained from fracture tests (in excess of 3000 in-1b/in<sup>2</sup>). The applied value of the J-integral for a flaw in the weld regions will be lower than that in the base metal because the yield stress for the weld materials is much higher at temperature<sup>a</sup>. Therefore, weld regions are less limiting than the cast material.

It is thus conservative to choose the end-of-service life toughness properties of  $[ ]^{a,c,e}$  as representative of those of the welds. Also, such cast pipe and fittings having an end-of-service life room temperature Charpy U-notch energy (KCU) greater than that of  $[ ]^{a,c,e}$  are also conservatively assumed to have the properties of  $[ ]^{a,c,e}$ .

In the fracture mechanics analyses that follow, the fracture toughness properties given in Table 4-1 will be used as the criteria against which the applied fracture toughness values will be compared.

a In this report all applied J values were conservatively determined by using base metal strength properties.

#### 4.4 Results of Crack Stability Evaluation

Figure 4-4 shows a plot of the plastic limit moment as a function of throughwall circumferential flaw length in the hot leg of the main coolant piping (load critical location 1). This limit moment was calculated for Kewaunee from data for a pressurized pipe at 2235 psi with an axial force of 1514 kips, operating at 599°F with ASME Code minimum tensile properties. The maximum applied bending moment of 25683 in-kips can be plotted on this figure and used to determine a critical flaw length, which is shown to be []<sup>a,c,e</sup> inches.

In Figures 4-5 through 4-7 plots of the plastic limit moment as a function of through-wall circumferential flaw length at the toughness critical locations of the main coolant pipe are given. These limit moments were calculated as above using the appropriate pressure, forces, and dimensions as given either in Table 3-1 or Figure 3-2 with bending moment as a parameter. The ASME Code minimum properties at 536°F were used. Critical flaw lengths were determined as in Figure 4-5 by use of the maximum applied bending moment. The critical flaw length in Figures 4-5 through 4-7 are all seen to exceed the []<sup>a,c,e</sup> inches established for load critical location 1.

For fracture mechanics evaluations the toughness and load critical locations were evaluated as follows. In Table 3-1, the outer surface axial stress  $(\sigma_a)$  at load critical location 1 (highest loads) is 18.4 ksi. The remaining stresses due to the internal pressure of 2235 psi are as follows (see Reference 12):

or (circumferential stress): 11.1 ksi

```
o, radial stress: 0
```

The von Mises effective stress,  $\sigma_{eff}$ , (see Reference 13) is given by

$$\sigma_{eff} = \sqrt{\frac{1}{2}} \left[ (\sigma_a - \sigma_r)^2 + (\sigma_c - \sigma_r)^2 + (\sigma_a - \sigma_c)^2 \right]^{0.5}$$

and is 16.0 ksi.

Thus the effective stress is less than the yield stress and by the Von Mises plasticity theory yielding does not occur. Also, similar consideration at the other toughness critical locations confirms that yielding does not occur there. Hence, linear elastic fracture mechanics is applicable for analyzing the pipes with hypothesized flaws at the critical locations. The analytical method used for the local stability evaluation at these locations is summarized below.

The stress intensity factors corresponding to tension and bending are expressed, respectively, by (see Reference 14)

K <sub>t</sub>	=	°t	5	πa	$F_t(\alpha)$
Kb	=	ap	5	πa	$F_b(\alpha)$

where  $F_t(\alpha)$  and  $F_b(\alpha)$  are stress intensity calibration factors corresponding to tension and bending, respectively, a is the half-crack length,  $\alpha$  is the half-crack angle,  $\sigma_t$  is the remote uniform tensile stress, and  $\sigma_b$  is the remote fiber stress due to pure bending. Data for  $F_t(\alpha)$  and  $F_b(\alpha)$  are given in Reference 14. The effect of the yielding near the crack tip can be incorporated by Irwin's plastic zone correction method (see Reference 15) in which the half-crack length, a, in these formulas is replaced by the effective crack length,  $a_{eff}$ , defined by

$$a_{eff} = a + \frac{1}{2\pi} \frac{K^2}{\sigma_v^2}$$

for plane stress plastic corrections, where  $\sigma_y$  is the yield strength of the material and K is the total stress intensity factor due to combined tensile and bending loads (i.e., K = K<sub>t</sub> + K<sub>b</sub>). Finally, the J<sub>app</sub> value is determined by the relation J<sub>app</sub> = K<sup>2</sup>/E, where E is Young's Modulus.

 $J_{app}$  was calculated for the four load and toughness critical locations using crack length as a parameter. The results are presented in Table 7-1 of Chapter 7 wherein  $J_{app}$  values and leak rates are examined in assessing margin.

For J<sub>app</sub> less than the local crack stability criterion given in Section 4.2, the critical circumferential flaw lengths exceed 7.5 inches, at load and toughness critical location 1 and toughness critical locations 8, 9, and 10, respectively.

In summary, the critical flaw size has been shown to exceed 7.5 inches at all locations with size exceeding  $[]^{a,c,e}$  inches, at load critical location 1.

TABLE 4-1



<sup>a</sup>The lowest of the values for all heats are given here. <sup>b</sup>Properties for the worst of the two halves of the fitting.

¥,

e S

R



Figure 4-2 J vs &a for SA351-CF8M Cast Stainless Steel at 600°F

b,c,e

Figure 4-3 J-Da Curves at Different Temperatures for Aged Material [ ]<sup>a,c,e</sup> (7500 Hours at 400°C)

ų.

b,c,e





Figure 4-5 "Critical" Flaw Size Prediction Based on Limit Load Methodology - Crossover Leg at Toughness Critical Location 8





#### 5.1 Introduction

Fracture mechanics analysis has shown that postulated through-wall cracks in the primary loop would remain stable and not cause a gross failure of this component. If such a through-wall crack did exist, it would be desirable to detect the leakage such that the plant could be brought to a safe shutdown condition. The purpose of this section is to discuss the method which will be used to predict the flow through such a postulated crack and present the leak rate calculation results for through-wall circumferential cracks.

#### 5.2 General Considerations

The flow of hot pressurized water through an opening to a lower back pressure causes flashing which can result in choking. For long channels where the ratio of the channel length, L, to hydraulic diameter,  $D_H$ ,  $(L/D_H)$  is greater than [ $1^{a,C,e}$ , both [ $1^{a,C,e}$ , both [ $1^{a,C,e}$ , must be considered. In this situation the flow can be described as being single-phase through the channel until the local pressure equals the saturation pressure of the fluid. At this point, the flow begins to flash and choking occurs. Pressure losses due to momentum changes will dominate for [ $1^{a,C,e}$ ]<sup>a,c,e</sup> However, for large L/D<sub>H</sub> values, friction pressure drop will become important and must be considered along with the momentum losses due to flashing.

#### 5.3 Calculation Method

The basic method used in the leak rate calculations is the method developed by [

1ª, c, e

The flow rate through a crack was calculated in the following manner. Figure 5-1 from Reference 16 was used to estimate the critical pressure, Pc, for the primary loop enthalpy condition and an assumed flow. Once Pc was found for a given mass flow, the [

was found from Figure 5-2 taken from Reference 16. For all cases considered, since [ ]<sup>a,c,e</sup> Therefore, this method will yield the two-phase pressure drop due to momentum effects as illustrated in Figure 5-3. Now using the assumed flow rate, G, the frictional pressure drop can be calculated using

 $\Delta P_{f} = [ ]^{a,c,e}$  (5-1)

where the friction factor f is determined using the [  $]^{a,c,e}$ The crack relative roughness,  $\varepsilon$ , was obtained from fatigue crack data on stainless steel samples. The relative roughness value used in these calculations was [  $]^{a,c,e}$  RMS.

The frictional pressure drop using Equation 5-1 is then calculated for the assumed flow and added to the [

]<sup>a,c,e</sup> to obtain the total pressure drop from the primary system to the atmosphere. That is, for the primary loop

(5-2)

18, C, e

Absolute Pressure - 14.7 = [

for a given assumed flow G. If the right-hand side of Equation 5-2 does not agree with the pressure difference between the primary loop and the atmosphere, then the procedure is repeated until Equation 5-2 is satisfied to within an acceptable tolerance and this results in the flow value through the crack. This calculational procedure has been recommended by [

]<sup>a,c,e</sup> for this type of [ ]<sup>a,c,e</sup> calculation.

5.4 Leak Rate Calculations

Leak rate calculations were made as a function of crack length for all the critical locations previously identified. The normal operating loads of Table 3-2 were applied in these calculations. The crack opening area was estimated

using the method of Reference 14 and the leak rate was calculated using the two-phase flow formulation described above. The results are tabulated in Table 7-1 of Chapter 7 wherein  $J_{\rm app}$  values and leak rates are examined in assessing margin.

The Kewaunee plant has an RCS pressure boundary leak detection system which is consistent with the guidelines of Regulatory Guide 1.45 for detecting leakage of 1 gpm in one hour. For the critical flaw size at load critical location 1 in the hot-leg, a factor in excess of 120 exists between the calculated leak rate and the 1 gpm criteria of Regulatory Guide 1.45.

For the worst toughness critical location (8), the largest stable flaw has a factor of over 100 above the 1 gpm criteria of Regulatory Guide 1.45. For the other toughness critical locations, the leak rate factors are also large.

MASS VELOCITY (Ib/(sec)(ft2))

## STAGNATION ENTHALPY (102 Btu/Ib)

8,0,8

Figure 5-1 Analytical Predictions of Critical Flow Rates of Steam-Water Mixtures



8,c,e

## LENGTH/DIAMETER RATIO (L/D)

Figure 5-2 [

]<sup>a,c,e</sup> Pressure Ratio as a Function of L/D





#### 6.0 FATIGUE CRACK GROWTH ANALYSIS

To determine the servitivity of the primary coolant system to the presence of small cracks, classify us crack growth analysis was carried out for the [ ]<sup>a, c, e</sup> region of a typical system (see Location

[ ]<sup>a,c,e</sup> of Figure 3-2). This region was selected because crack growth calculated here will be typical of that in the entire primary loop. Crack growths calculated at other locations can be expected to show less than 10% variation. Thermal aging has been shown not to impact fatigue crack growth (References 10 and 11).

#### A [

]<sup>a,c,e</sup> of a plant typical in geometry and operational characteristics to any Westinghouse PWR System. [

All normal, upset, and test conditions were considered and circumferentially oriented surface flaws were postulated in the region, assuming the flaw was located in three different locations, as shown in Figure 6-1. Specifically, these were:

18, C, e

Cross Section A: [	] <sup>a,c,e</sup>	
Cross Section B: [		] <sup>a,c,</sup>
Cross Section C: [	] <sup>a,c,e</sup>	

Fatigue crack growth rate laws were used [

j<sup>a,c,e</sup> The law for stainless steel was derived from Reference 18, with a very conservative correction for the R ratio, which is the ratio of minimum to maximum stress during a transient. For stainless steel, the fatigue crack growth formula is:

$$\frac{da}{dn} = (5.4 \times 10^{-12}) K_{eff}^{4.48} inches/cycle$$

where  $K_{eff} = K_{max} (1-R)^{0.5}$ 

 $R = K_{min}/K_{max}$ 

1

[

]a,c,e

where: [

ja,c,e

The calculated fatigue crack growth for semi-elliptic surface flaws of circumferential orientation and various depths is summarized in Table 6-1, and shows that the crack growth is very small, regardless [ ]a,c,e

a,c,e

14		10		-		
	Ω	ж	10	34		1
10	$\sim$	$\omega$	he i	he .	0	

FATIGUE CRACK GROWTH AT [

]<sup>a,c,e</sup> (40 YEARS)

-		FINAL FLAW (in)	
INITIAL FLAW (in)	[ ] <sup>a,c,e</sup> [ ] <sup>a,c,e</sup>	[ ]a,c,e	[ ] <sup>a,c,e</sup>
0.292	0.31097	0.30107	0.30698
0.300	0.31949	0.30953	0.31626
0.375	0.39940	0.38948	0.40763
0.425	0.45271	0.4435	0.47421

Figure 6-1 Typical Cross-Section of [

a,c,e



Figure 6-2 Reference Fatigue Crack Growth Curves for [ ]<sup>a,c,e</sup>

.....



#### 7.0 ASSESSMENT OF MARGINS

The results of the toughness and leak rate calculations for the four critical locations examined are summarized in Table 7-1. Margins for these critical locations are discussed below.

At load and toughness critical location 1 a flaw size of 3.5 inches yields a leak rate of 10 gpm. This is a factor of 10 greater than the leak rate required by Regulatory Guide 1.45. Twice this flaw size, 7.0 inches, which will be referred to as the critical flaw size, results in a  $J_{app}$  of  $[]^{b,c,e}$  in-lb/in<sup>2</sup>. This value is less than  $J_{Ic}$  ([] $^{b,c,epp}$  in-lb/in<sup>2</sup>) for the worst case heat of loops A and B at this location.

At toughness critical location 8, the flaw size which results in 10 gpm leakage is 6.4 inches. Twice this flaw size, 12.8 inches, results in a  $J_{app}$  of [ ]<sup>b,c,e</sup> in-lb/in<sup>2</sup> which is less than the minimum  $J_{Ic}$  at this location ([ ]<sup>b,c,e</sup>in-lb/in<sup>2</sup>).

The critical flaw sizes for the other toughness critical locations, 11.2 inches at location 9 and 13.2 inches at location 10, result in  $J_{app}$  values very much less than the  $J_{Ic}$  at these locations, [ ]<sup>b,c,e</sup> versus [ ]<sup>b,c,e</sup> versus [ ]<sup>b,c,e</sup> in-1b/in<sup>2</sup>, respectively.

As shown in Section 3.0, a margin of a factor of not less than 4 exists between calculated stress and ASME Code allowable stresses for normal and faulted loadings.

In Section 4.4, the "maximum" flaw sizes at load critical location 1 and the toughness critical locations are calculated using the limit load method and shown to be at least [ ]<sup>b,c,e</sup> inches. Thus, based on the above, the "maximum" flaw sizes at these locations will, of course, exceed the stable crack lengths at their respective locations.

7-1

In summary, relative to:

#### 1. Loads

- a. The J<sub>app</sub> values for Kewaunee are enveloped by the J values established from testing of highly aged material.
- b. Margins at the critical location of at least 4 on faulted and thermal loadings exist relative to ASME Code allowable values.

#### 2. Flaw Size

- a. Margins of [ ]<sup>b,c,e</sup> or greater on flaw size exist for stable flaw sizes with flow rates well in excess of a leak rate of 1 gal/min.
- b. If limit load is used as the basis for critical flaw size, the margin for global stability well exceeds that based upon fracture mechanics.

#### 3. Leak Rate

At all locations, a margin in excess of 50 for the 1 gpm criterion of Regulatory Guide 1.45 exists for the flaw sizes which result in a  $J_{\rm app}$  less than  $J_{\rm Lc}$ .





a. J values have units of in-1b/in<sup>2</sup>.

- b. Location 1 is the load critical location, the remaining locations are toughness critical locations.
- c. Values are lowest of all heats in indicated coolant loops.

#### 8.0 CONCLUSIONS

This report justifies the elimination of evaluation of dynamic effects of RCS primary loop pipe breaks for the Kewaunee plant as follows:

- a. Stress corrosion cracking is precluded by use of fracture resistant materials in the piping system and controls on reactor coolant chemistry, temperature, pressure, and flow during normal operation.
- b. Water hammer should not occur in the RCS piping because of system design, testing, and operational considerations.
- c. The effects of low and high cycle fatigue on the integrity of the primary piping are negligible.
- d. Adequate margins exist for ASME code allowable faulted and thermal loads.
- e. Adequate margin exists between the leak rate of small stable flaws and the criterion of Reg. Guide 1.45.
- Ample margin exists between the small stable flaw sizes of item e and larger stable flaws.
- g. Ample margin exists in the material properties used to demonstrate end-of-service life (relative to aging) stability of the critical flaws.

For each critical location a flaw is identified (see Table 7-1) that will be stable throughout reactor life because of the ample margins in e, f, and g above and will leak at a detectable rate which will assure a safe plant shutdown.

Based on the above, it is concluded that dynamic effects of RCS primary loop pipe breaks need not be considered in the structural design basis of the Kewaunee plant.

8-1

#### 9.0 REFERENCES

- USNRC Generic letter 84-04, Subject: "Safety Evaluation of Westinghouse Topical Reports Dealing with Elimination of Postulated Pipe Breaks in PWR Primary Main Loops", February 1, 1984.
- Letter from Westinghouse (E. P. Rahe) to NRC (R. H. Vollmer), NS-EPR-2768, ciated May 11, 1983.
- WCAP-9283, "The Integrity of Primary Piping Systems of Westinghouse Nuclear Power Plants During Postulated Seismic Events," March, 1978.
- Letter Report NS-EPR-2519, Westinghouse (E. P. Rahe) to NRC (D. G. Eisenhut), Westinghouse Proprietary Class 2, November 10, 1981.
- Letter from Westinghouse (E. P. Rahe) to NRC (W. V. Johnston) dated April 25, 1983.
- Letter from Westinghouse (E. P. Rahe) to NRC (W. V. Johnston) dated July 25, 1983.
- NUREG-0691, "Investigation and Evaluation of Cracking Incidents in Piping in Pressurized Water Reactors", USNRC, September 1980.
- Kanninen, M. F., et. al., "Mechanical Fracture Predictions for Sensitized Stainless Steel Piping with Circumferential Cracks", EPRI NP-192, September 1976.
- 9. Palusamy, S. S. and Hartmann, "Mechanistic Fracture Evaluation of Reactor Coolant Pipe Containing a Postulated Circumferential Through-Wall Crack, WCAP-9558, Rev. 2. W Proprietary Class 2, May 1981, p K-12.
- WCAP-10456, "The Effects of Thermal Aging on the Structural Integrity of Cast Stainless Steel Piping For <u>W</u> NSSS," <u>W</u> Proprietary Class 2, November 1983.

9-1

- 11. Slama, G., Petreguin, P., Masson, S. H., and Mager, T. R., "Effect of Aging on Mechanical Properties of Austenitic Stainless Steel Casting and Welds", presented at SMIRT 7 Post Conference Seminar 6 - Assuring Structural Integrity of Steel Reactor Pressure Boundary Components, August 29/30, 1983, Monterey, CA.
- 12. Durelli, A. J., et. al., Introduction to the Theoretical and Experimental Analysis of Stress and Strain, McGraw Hill Book Company, New York, (1958), pp 233-236.
- 13. Johnson, W. and Mellor, P. B., Engineering Plasticity, Van Nostrand Relmhold Company, New York, (1973), pp 83-86.
- 14. Tada, H., "The Effects of Shell Corrections on Stress Intensity Factors and the Crack Opening Area of Circumferential and a Longitudinal Through-Crack in a Pipe," Section II-1, NUREG/CR-3464, September 1983.
- 15. Irwin, G. R., "Plastic Zone Near a Crack and Fracture Toughness," Proc. 7th Sagamore Conference, P. IV-63 (1960).

16. [

ja,c,e

17. : j<sup>a,c,e</sup>

18. Bamford, W. H., "Fatigue Crack Growth of Stainless Steel Piping in a Pressurized Water Reactor Environment," Trans. ASME Journal of Pressure Vessel Technology, Vol. 101, Feb. 1979.

19. [

ja,c,e

20. [

ja,c,e

- 21. Witt, F. J. and Kim, C. C., Toughness Criteria for Thermally Aged Cast Stainless Steel, Westinghouse Proprietary Class 2 Report WCAP 10931, Revision 1, July 1986.
- 22. Letter: Dominic C. Dilanni, NRC to D. M. Musolf, Northern States Power Company, dated December 22, 1986, Docket Nos. 50-282 and 50-306.

APPENDIX A

LIMIT MOMENT

[

] a,c,e

and service and



#### APPENDIX B

## ALTERNATE TOUGHNESS CRITERIA FOR THE KEWAUNEE CAST PRIMARY LOOP COMPONENTS

### B.1 INTRODUCTION

Not all of the individual cast piping components of the Kewaunee primary loop piping satisfy the original [ ]<sup>a,C,e</sup> criteria (Reference 10). In this appendix, the alternate toughness criteria for thermally aged cast stainless steel developed in Reference 21 will be used to categorize the various individual cast piping components thus establishing criteria based upon which the mechanistic pipe break evaluation may be performed. Reference 21 has been reviewed by the NRC wherein the NRC concluded that Reference 21 may be utilized for establishing the fracture criteria for thermally aged cast stainless piping applicable for the leak-before-break analyses (Reference 22). First the chemistry and calculated room temperature charpy U-notch energy (KCU), values are given followed by an identification of each of the heats of material with a specific loop and location. The criteria for the various individual loop components are tabulated.

### B.2 CHEMISTRY AND KCU TOUGHNESS

The correlation of Reference 11 which is based on the chemistry of the cast stainless steel piping was used to calculate the associated KCU value. The chemistry and end-of-service life KCU toughness values are given in Table B-1. Of the twenty-three heats of cast stainless steel, nine fail to meet the current [ ]<sup>a,c,e</sup> criteria. These heats occur in the fittings and pipe of the hot, cold and crossover legs in each of the two reactor loops.

#### B.3 THE AS-BUILT KEWAUNEE LOOPS

Kewaunee is a two-loop Westinghouse type pressurized water reactor plant. A typical two-loop primary system is sketched in Figure B-1. The two loops are identified as Loops A and B. Sketches for associating piping component with

specific locations and loop are given in Figures B-2 through B-4. The individual components are identified by heat numbers. The components which have toughnesses less than that of  $[]^{a,c,e}$  are identified (see Figures B-2 to B-4).

## B.4 ALTERNATE TOUGHNESS CRITERIA FOR THE KEWAUNEE CAST PRIMARY LOOP MATERIAL ON A COMPONENT-BY-COMPONENT BASIS

The alternate toughness criteria for the Kewaunee cast primary loop material may be obtained by applying the methodology of Reference 21 to Table B-1. First, it is observed that fourteen of the twenty-three heats fall into Category 1, i.e., they are as tough as  $[ ]^{a,c,e}$ . The remaining heats fall into Category 2 with one in Category 3. The toughness criteria for all twenty-three heats are given in Table B-2. Typical toughness calculations using the methodology of Reference 21 are given below.

Loop A crossover leg Heat No. [ $]^{a,c,e}$  has the lowest calculated end-of-service life KCU at room temperature of [ $]^{a,c,e}$  daJ/cm<sup>2</sup> which falls below that of [ $]^{a,c,e}$ . The  $\delta$ -ferrite content is [ $]^{a,c,e}$ . By Reference 21, the [

la'c'e

Thus, for full-embrittlement

J<sub>Ic</sub> = [ ]<sup>a,c,e</sup> T<sub>mat</sub> = [ ]<sup>a,c,e</sup> J<sub>max</sub> = [ ]<sup>a,c,e</sup>

and

KCU < [ ]a,c,e

Since the end-of-service life KCU value is less than the full-embrittlement KCU value, Heat No. [ $]^{a,c,e}$  is a Category 3 material as defined in Reference 21 and the end-of-service life fracture toughness is [ $]^{a,c,e}$ . These results are

given in Table B-2 for Category 3.

An example calculation for a Category 2 heat is given below. Similar calculations for the remaining seven Category 2 heats were made.

The example calculation will be made for Heat  $[ ]^{a,c,e}$ . The ferrite content is  $[ ]^{a,c,e}$  and the end-of-service life KCU is  $[ ]^{a,c,e}$  daJ/cm<sup>2</sup>. The [

]<sup>a,c,e</sup>. Since the end-of-service life KCU exceeds the fully aged KCU, the heat falls into Category 2. Thus:

J<sub>Ic</sub> = [

ja,c,e

T<sub>mat</sub> = [

1ª, ¢, e

and

 $J_{max} = [$ 

la,c,e



# CHEMISTRY AND CALCULATED KCU VALUES FOR EACH PRIMARY LOOP PIPING OF THE KEWAUNEE NUCLEAR PLANT



### TABLE B-2

## FRACTURE TOUGHNESS CRITERIA FOR THE CAST PRIMARY PIPING COMPONENTS OF THE KEWAUNEE NUCLEAR PLANT

a,c,e

b. Given in the same order as Table B-1



Figure B-2 Identification of Heats with Location for Cold Leg

a,c,e

Figure B-3 Identification of Heats with Location for Hot Leg

4

a,c,e

Figure B-4 Identification of Heats with Location for Crossover Leg

a,c,e