

MAY 06 1987

Docket Nos. 50-277  
50-278

License Nos. DPR-45  
DPR-56

Philadelphia Electric Company  
ATTN: Mr. J. W. Gallagher  
Vice President  
Nuclear Operations  
2301 Market Street  
Philadelphia, Pennsylvania 19101

Gentlemen:

Subject: Inspection Report Nos. 50-277/87-11 and 50-278/87-11

This refers to the special safety inspection conducted by Messrs. A. Krasopoulos and S. Pullani of this office on April 9, 1987 at the Philadelphia Electric Company Headquarters of activities authorized by NRC License Nos. DPR-45 and DPR-56 and to the discussions of our findings held by Mr. A. Krasopoulos with Mr. W. Boyer of your staff at the conclusion of the inspection. The inspection was conducted to review, and determine the status of, numerous examples of a violation of fire protection requirements (10 CFR 50, Appendix R) identified by your staff during a confirmatory review of the Fire Protection Program. This review was committed to in Confirmatory Action Letter 86-07 dated April 11, 1986 following a previous NRC inspection of the fire protection program. (Reference: Inspection Nos. 50-277/86-08; 50-278/86-08). The examples identified by your staff were described in your letters dated May 22, 1986, September 17, 1986 and October 31, 1986.

During the inspection, the inspector evaluated the circumstances associated with five of the examples. Based on this review, the NRC has determined that you do not currently satisfy all of the applicable requirements of 10 CFR 50 Appendix R. We are considering the violation for appropriate enforcement action and will schedule an enforcement conference with you to discuss the examples of the violation, their causes and your corrective actions.

No reply to this letter is required. Your cooperation with us in this matter is appreciated.

Sincerely,

8705120405 870506  
PDR ADOCK 05000277  
Q PDR

Original Signed By:

William V. Johnston, Acting Director  
Division of Reactor Safety

Enclosure: Combined NRC Region I Inspection Report  
Nos. 50-277/87-11 and 50-278/87-11

OFFICIAL RECORD COPY

CIR PB 87-11 - 0001.0.0  
04/30/87

*IEOZ* //

cc w/encl:

R. S. Fleischmann, Manager, Peach Bottom Atomic Power Station  
 John S. Kemper, Senior Vice President, Engineering and Production  
 Troy B. Conner, Jr., Esquire  
 W. H. Hirst, Director, Joint Generation Projects Department,  
 Atlantic Electric  
 G. Leitch, Nuclear Generation Manager  
 Eugene J. Bradley, Esquire, Assistant General Counsel (Without Report)  
 Raymond L. Hovis, Esquire  
 Thomas Magette, Power Plant Siting, Nuclear Evaluations  
 W. M. Alden, Engineer in Charge, Licensing Section  
 Public Document Room (PDR)  
 Local Public Document Room (LPDR)  
 Nuclear Safety Information Center (NSIC)  
 NRC Resident Inspector  
 Commonwealth of Pennsylvania

bcc w/encl:

Region I Docket Room (with concurrences)  
 Management Assistant, DRMA (w/o encl)  
 Section Chief, DRP  
 Robert J. Bores, DRSS

RI:DRS  
 Krasopoulos/ms  
 4/30/87 *AK*

*c/a*  
 RI:DRS  
 Anderson  
*S*  
 4/11/87

*c/a for*  
 RI:DRS  
 Durr  
*S/1*  
 4/11/87

*MD*  
 Haloby  
 5/1

*DRP*  
 Linnilla  
 5/4

OFFICIAL RECORD COPY

CIR PB 87-11 - 0002.0.0  
04/30/87