YANKEE ATOMIC ELECTRIC COMPANY



1671 Worcester Road, Framingham, Massachusetts 01701

June 22, 1987

FYR 87--66

United States Nuclear Regulatory Commission Washington, D. C. 20555

Attention: Document Control Desk

References: (a) License No. DPR-3 (Docket No. 50-29)

Subject: Steam Generator Inspection Results

Dear Sir:

In accordance with Technical Specifications 4.4.10.5.a, this letter provides notification on the number of tubes plugged following the inservice inspection of steam generator tubes.

As a result of the May 1987 inservice inspection of Steam Generator #2, twenty six tubes were plugged. In addition, eighteen tubes were plugged in Steam Generator #3 and sixteen tubes in Steam Generator #4.

Complete results of the inservice inspection of Steam Generator #2 will follow within twelve months in accordance with Technical Specification 4.4.10.5.b. Also, a special report will be forwarded pertaining to the plugging of Steam Generators #3 and #4.

If you have any questions, please contact us.

Very truly yours,

YANKEE ATOMIC ELECTRIC COMPANY

In 2 Waseltine for

George Papanic, Jr.

Senior Project Engineer - Licensing

Yankee Project

/gbc

cc: (1) USNRC, Region I

(1) Resident Inspector