

Docket No. 50-313

October 20, 1986

*DCR  
016*

Mr. Gene Campbell  
Vice President, Nuclear  
Operations  
Arkansas Power and Light Company  
P. O. Box 551  
Little Rock, Arkansas 72203

Dear Mr. Campbell:

Arkansas Power and Light (AP&L) was required by Generic Letter 83-28, Item 4.4 to confirm that safety-related maintenance and test procedures are applied to the diverse trip feature provided by interrupting power to the control rods through the silicon controlled rectifiers (SCRs) for Arkansas Nuclear One, Unit 1 (ANO-1). Your responses to these requirements, dated November 5, 1983 and April 24, 1985, and our review of these responses as documented in the enclosed contractor's report (EG&G NTA 7910) finds your responses to Generic Letter 83-28, Item 4.4 to be acceptable (with the exception of the requested Technical Specification (TS) changes, which are being handled as a separate issue). The enclosed Safety Evaluation Report (SER) documents our concurrence with the contractor's findings and also finds your responses to be acceptable. Therefore, except as noted above, we consider Item 4.4 of Generic Letter 83-28 to be complete.

Sincerely,

/s/

John F. Stolz, Director  
PWR Project Directorate #6  
Division of PWR Licensing-B

Enclosures:  
As stated

cc w/enclosures:  
See next page

DISTRIBUTION

Docket File      BGrimes  
NRC & LPDRs     JPartlow  
GVissing         JRamsey  
PBD-6 Rdg        RIngram  
FMiraqlia        Gray File  
OGC-MNBB 9604   NThompson  
EJordan           ACRS 10

PBD-6 *DER*  
JRamsey  
10/17/86

PBD-6 *GV*  
GVissing  
11/12/86

PBD-6 *Ch*  
CMcCracken  
10/12/86

PBD-6 *J*  
JStolz  
10/12/86

8610300123 861020  
PDR ADOCK 05000313  
P PDR

Mr. G. Campbell  
Arkansas Power & Light Company

Arkansas Nuclear One, Unit 1

cc:

Mr. J. Ted Enos, Manager  
Nuclear Engineering and Licensing  
Arkansas Power & Light Company  
P. O. Box 551  
Little Rock, Arkansas 72203

Mr. James M. Levine, Director  
Site Nuclear Operations  
Arkansas Nuclear One  
P. O. Box 608  
Russellville, Arkansas 72801

Mr. Nicholas S. Reynolds  
Bishop, Liberman, Cook, Purcell & Reynolds  
1200 Seventeenth Street, N.W.  
Washington, D.C. 20036

Mr. Robert B. Borsum  
Babcock & Wilcox  
Nuclear Power Generation Division  
Suite 220, 7910 Woodmont Avenue  
Bethesda, Maryland 20814

Resident Inspector  
U.S. Nuclear Regulatory Commission  
P. O. Box 2090  
Russellville, Arkansas 72801

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
Office of Executive Director  
for Operations  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

Mr. Frank Wilson, Director  
Division of Environmental Health  
Protection  
Department of Health  
Arkansas Department of Health  
4815 West Markham Street  
Little Rock, Arkansas 72201

Honorable William Abernathy  
County Judge of Pope County  
Pope County Courthouse  
Russellville, Arkansas 72801