



Point Beach Nuclear Plant
6610 Nuclear Rd., Two Rivers, WI 54241

(920) 755-2321

NPL 98-0358

May 3, 1998

Document Control Desk
U.S. NUCLEAR REGULATORY COMMISSION
Mail Station P1-137
Washington, D.C. 20555

Ladies/Gentlemen:

DOCKET 50-301
LICENSEE EVENT REPORT 1998-003-00
MISSED ASME SECTION XI PRESSURE TEST PROGRAM SURVEILLANCE
POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

Enclosed is Licensee Event Report 1998-003-00 for Point Beach Nuclear Plant, Unit 2. This report is provided in accordance with 10 CFR 50.73(a)(2)(i)(B), an "operation prohibited by the plant's Technical Specifications." This report describes the discovery that a vent valve from the reactor coolant drain tank which had been placed on an increased frequency surveillance for stroke time was not tested within the time frame required by ASME Section XI requirements.

New commitments within this report are indicated in italics.

Please contact us if you require additional information.

Sincerely,

A handwritten signature in dark ink, appearing to read 'Douglas F. Johnson'.

Douglas F. Johnson
Manager,
Regulatory Services & Licensing

Enclosure

CWK/lad

cc: NRC Resident Inspector
NRC Regional Administrator
NRC Project Manager
PSCW
INPO Support Services

9805140274 980508
PDR ADDCK 05000301
S PDR

IE221