



Duquesne Light

Beaver Valley No. 2 Unit Project Organization
S.E.G. Building
P.O. Box 328
Shippingport, PA 15077

2NRC-7-163
(412) 643-5200
Teletype (412) 643-5200 Ext. 160

June 23, 1987

United States Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

SUBJECT: Beaver Valley Power Station Unit No. 2
Docket No. 50-412
Duquesne Light Company Comments on the Safety Evaluation Report
(NUREG-1057)

Gentlemen:

Attachment 1 provides additional Duquesne Light Company comments on the Beaver Valley Power Station Unit No. 2 (BVPS-2) Safety Evaluation Report (SER) (NUREG-1057).

DLC will continue to work with the NRC staff to appropriately resolve these comments.

DUQUESNE LIGHT COMPANY

J. J. Carey
Senior Vice President

RWR/ijr
NR/RWR/SER/LTR
Attachments
AR/NAR

cc: Mr. P. Tam, Project Manager (w/a/s)
Mr. J. Beall, NRC Sr. Resident Inspector (w/a/s)
Mr. L. Privity, NRC Resident Inspector (w/a/s)
INPO Records Center (w/a/s)

8706300415 870623
PDR ADDCK 05000412
P PDR

Boo1
1/0

ATTACHMENT 1
SAFETY EVALUATION REPORT
DLC COMMENTS

<u>DLC TRACKING NO.</u>	<u>PAGE</u>	<u>SECTION</u>	<u>COMMENT</u>
197	11-8	11.4.1	The third sentence of the first paragraph of Section 11.4.1 should read as follows: "Dry solid waste consisting of ventilation air filters, contaminated clothing, rags, and paper will be compacted in the waste compaction area."
198	7-14	7.3.2.2	The first sentence of the second paragraph of Section 7.3.2.2 should read as follows: (See FSAR Section 6.2.2.2.2.) "The four recirculation spray pumps start automatically in approximately 628 seconds following receipt of a CIB signal and take suction from the containment sump".