

Attachment 7

Westinghouse Electric Corporation Topical Report WCAP-10868,
Duke Power Company Catawba Unit 2 Reactor Vessel Radiation
Surveillance Program.

9709220008 970915
PDR ADDCK 05000413
P PDR

APPROVED
 DUKE POWER CO.
 DATE: MAR 03 1986
 T. F. WYKE
 CHIEF ENGINEER
 By: MECHANICAL DIVISION

DUKE POWER COMPANY
 CATAWBA UNIT NO. 2
 REACTOR VESSEL RADIATION
 SURVEILLANCE PROGRAM

Lib copy 1

DOCUMENT CONTROL DATE
 FEB 24 1986
 DUKE POWER COMPANY
 DESIGN ENGINEERING

L. R. Singer

November 1985

APPROVED: *T. A. Meyer*
 T. A. Meyer, Manager
 Structural Materials and Reliability Technology


Work Performed Under DDPJ-106

RECEIVED
 MAR 18 1986
 DAVID NASH
 DUKE POWER COMPANY

WESTINGHOUSE ELECTRIC CORPORATION
 Nuclear Energy Systems
 P. O. Box 355
 Pittsburgh, Pennsylvania 15230

PREFACE

This report has been technically reviewed and checked by S. E. Yanichko of Structural Materials and Reliability Technology.



S. E. Yanichko

Date: November 5, 1985

ABSTRACT

A pressure vessel steel surveillance program per ASTM E-185-82 has been developed for the Duke Power Company, Catawba Unit No.2 to obtain information on the effects of radiation on reactor pressure vessel material under operating conditions. The radiation surveillance program for the Catawba Unit No. 2 is designed to, and in compliance with, federal government regulations identified in appendix H to 10CFR, part 50 entitled "Reactor Vessel Material Surveillance Program Requirements."

Following is a description of the program, a description of the material involved, the specimen and capsule design and fabrication, and the preirradiation test results.

TABLE OF CONTENTS

Section	Title	Page
1	PURPOSE AND SCOPE	1-1
2	CAPSULE PREPARATION	2-1
	2-1. Pressure Vessel Material	2-1
	2-2. Machining	2-1
	2-3. Charpy V-notch Impact Specimens	2-3
	2-4. Tensile Specimens	2-3
	2-5. 1/2T Compact Specimens	2-3
	2-6. Dosimeters	2-3
	2-7. Thermal Monitors	2-3
	2-8. Capsule Loading	2-9
3	PREIRRADIATION TESTING	3-1
	3-1. Charpy V-notch Tests	3-1
	3-2. Tensile Tests	3-1
	3-3. Dropweight Tests	3-2
4	POSTIRRADIATION TESTING	4-1
	4-1. Capsule Removal	4-1
	4-2. Charpy V-notch Impact Tests	4-2
	4-3. Tensile Tests	4-2
	4-4. Fracture Toughness Tests on 1/2T Compact Specimens	4-2
	4-5. Postirradiation Test Equipment	4-3
Appendix A	DESCRIPTION AND CHARACTERIZATION OF THE CATAWBA UNIT NO. 2 REACTOR VESSEL BELTLINE AND SURVEILLANCE MATERIALS	A-1

LIST OF ILLUSTRATIONS

Figure	Title	Page
1-1	Location of the Irradiation Test Capsules in the Catawba Unit No. 2 Reactor Vessel	1-4
2-1	Charpy V-notch Impact Specimen	2-2
2-2	Tensile Specimen	2-4
2-3	Compact Specimen	2-5
2-4	Irradiation Capsule Assembly	2-7/2-8
2-5	Djsimeter Block Assembly	2-10
2-6	Specimen Locations in the Catawba Unit No. 2 Reactor Surveillance Test Capsules	2-13/2-14
3-1	Preirradiation Charpy V-notch Impact Energy for the Catawba Unit No. 2 Reactor Pressure Vessel Intermediate Shell Plate B8605-1 (Longitudinal Orientation)	3-9
3-2	Preirradiation Charpy V-notch Impact Energy for the Catawba Unit No. 2 Reactor Pressure Vessel Intermediate Shell Plate B8605-1 (Transverse Orientation)	3-9
3-3	Preirradiation Charpy V-notch Impact Energy for the Catawba Unit No. 2 Reactor Pressure Vessel Core Region Weld Metal	3-10
3-4	Preirradiation Charpy V-notch Impact Energy for the Catawba Unit No. 2 Reactor Pressure Vessel Core Region Weld Heat-Affected-Zone Material	3-10
3-5	Preirradiation Tensile Properties for the Catawba Unit No. 2 Reactor Pressure Vessel Intermediate Shell Plate B8605-1 (Longitudinal Orientation)	3-11
3-6	Preirradiation Tensile Properties for the Catawba Unit No. 2 Reactor Pressure Vessel Intermediate Shell Plate B8605-1 (Transverse Orientation)	3-12
3-7	Preirradiation Tensile Properties for the Catawba Unit No. 2 Reactor Pressure Vessel Core Region Weld Metal	3-13
3-8	Typical Stress-Strain Curve for Tensile Test	3-14

LIST OF TABLES

Table	Title	Page
2-1	Type and Number of Specimens in the Catawba Unit No. 2 Surveillance Test Capsules	2-9
2-2	Quantity of Isotopes Contained in the Dosimeter Blocks	2-11
3-1	Preirradiation Charpy V-notch Impact Data for the Catawba Unit No. 2 Reactor Pressure Vessel Intermediate Shell Plate B8605-1 (Longitudinal Orientation)	3-3
3-2	Preirradiation Charpy V-notch Impact Data for the Catawba Unit No. 2 Reactor Pressure Vessel intermediate Shell Plate B8605-1 (Transverse Orientation)	3-4
3-3	Preirradiation Charpy V-notch Impact Data for the Catawba Unit No. 2 Reactor Pressure Vessel Core Region Weld Metal	3-5
3-4	Preirradiation Charpy V-notch Impact Data for the Catawba Unit No. 2 Reactor Pressure Vessel Core Region Weld Heat-Affected-Zone Material	3-6
3-5	Summary of the Catawba Unit No. 2 Reactor Pressure Vessel Impact Test Results for Intermediate Shell Plate B8605-1 and Core Region Weld and Heat-Affected-Zone Material	3-7
3-6	Preirradiation Tensile Properties for the Catawba Unit No. 2 Reactor Pressure Vessel Intermediate Shell Plate B8605-1 and Core Region Weld Metal	3-8
4-1	Surveillance Capsule Removal Schedule	4-1
A-1	Chemical Analysis of the Intermediate Shell Plates used in the Core Region of the Catawba Unit No. 2 Reactor Pressure Vessel	A-2
A-2	Chemical Analysis of the Lower Shell Plates used in the Core Region of the Catawba Unit No. 2 Reactor Pressure Vessel	A-3
A-3	Chemical Analysis of the Weld Metal used in the Core Region Weld Seams of the Catawba Unit No. 2 Reactor Pressure Vessel	A-4
A-4	T _{NDT} , RT _{NDT} and Upper Shelf Energy for the Catawba Unit No. 2 Reactor Pressure Vessel Core Region Shell Plates and Weld Metal	A-5
A-5	Heat Treatment History of the Catawba Unit No. 2 Reactor Pressure Vessel Core Region Shell Plates and Weld Seams	A-6

SECTION 1

PURPOSE AND SCOPE

The purpose of this program is to monitor radiation effects under actual operating conditions of the core region reactor vessel materials in the Duke Power Company, Catawba Unit No. 2, a four-loop, nuclear power plant with a thermal output rating of 3427-megawatts. Evaluation of the radiation effects is based on preirradiation testing of Charpy V-notch, tensile, and dropweight specimens, and postirradiation testing of Charpy V-notch, tensile, and compact specimens.

Current reactor pressure vessel material test requirements and acceptance standards utilize the reference nil-ductility temperature, RT_{NDT} , as a basis. RT_{NDT} is determined from the dropweight nil-ductility transition temperature (T_{NDT}) per ASTM E208 and the weak⁽¹⁾ direction 50 ft lb Charpy V-notch temperature (or the 35-mil lateral expansion temperature if it is greater). RT_{NDT} is defined as the dropweight T_{NDT} or the temperature 60°F less than the 50 ft lb (or 35-mil) Charpy V-notch temperature, whichever is greater.

Therefore

$$RT_{NDT} = T_{NDT}, \text{ if } T_{NDT} \geq T_{50(35)} - 60^{\circ}\text{F}$$

and

$$RT_{NDT} = T_{50(35)} - 60^{\circ}\text{F}, \text{ if } T_{50(35)} - 60^{\circ}\text{F} > T_{NDT}$$

where

R_{NDT} = Reference nil-ductility temperature

T_{NDT} = Nil-ductility transition temperature per ASTM E208

$T_{50(35)}$ = 50 ft lb temperature from Charpy V-notch specimens oriented in the weak direction (or the 35-mil temperature if it is greater)

1. Longitudinal axis of the specimen oriented normal to the major working direction of the plate.

An empirical relationship between RT_{NDT} and fracture toughness for reactor vessel steels has been developed in Appendix G, "Protection Against Non-ductile Failure," to Section III of the ASME Boiler and Pressure Vessel Code. This relationship can be employed to set allowable pressure-temperature limitations for normal operation of reactors which are based on fracture mechanics concepts. Appendix G defines an acceptable method for calculating these limitations.

It is known that radiation can shift the Charpy V-notch impact energy curve to higher temperatures,^[1,2] and thus cause the RT_{NDT} to increase with radiation exposure. The extent of the shift in the impact energy curve, that is, radiation embrittlement, is enhanced by certain chemical elements (such as copper) present in reactor vessel steels.^[3,4]

The adjustment in RT_{NDT} with service can be monitored by a surveillance program involving periodic checking of irradiated reactor vessel surveillance specimens. The surveillance program is based on ASTM E185-82 (Standard Practice for Conducting Surveillance Tests for Light-Water Cooled Nuclear Power Reactor Vessels). Compact fracture mechanics specimens will be used in addition to Charpy V-notch specimens to evaluate the effects of radiation on the fracture toughness of reactor vessel materials.

Postirradiation testing of the Charpy V-notch impact specimens will provide a guide for determining pressure-temperature limits on the plant. Charpy impact test data will determine the shift of the reference temperature^[a] with radiation exposure at plant temperatures.

- a. The reference temperature as defined by 10CFR Part 50, Appendix G, Section II-E is as follows:

"Adjusted reference temperature" means the reference temperature as adjusted for irradiation effects by adding to RT_{NDT} the temperature shift, measured at the 30 ft lb (41 J) level.

1. Porter, L. F., "Radiation Effects in Steel," in *Materials in Nuclear Applications*, ASTM-STP-276, pp. 147-195, American Society for Testing and Materials, Philadelphia, 1960.
2. Steele, L. E. and Hawthorne, J. R., "New Information on Neutron Embrittlement and Embrittlement Relief of Reactor Pressure Vessel Steels," NRL-6160, August 1964.
3. Potapovs, U. and Hawthorne, J. R., "The Effect of Residual Elements on 550°F Irradiation Response of Selected Pressure Vessel Steels and Weldments," NRL-6803, September 1968.
4. Steele, L. E., "Structure and Composition Effects on Irradiation Sensitivity of Pressure Vessel Steels," in *Irradiation Effects on Structural Alloys for Nuclear Reactor Applications*, ASTM-STP-484, pp. 164-175, American Society for Testing and Materials, Philadelphia, 1970.

These data can then be reviewed to verify or revise pressure-temperature limits of the vessel during heatup and cooldown and will allow a check of the predicted shift in the reference temperature. The postirradiation test results of the compact specimens will provide actual fracture toughness properties of the vessel material. These properties may be used to establish allowable stress intensity factors for subsequent analyses.

Six material test capsules are fabricated containing specimens from the reactor vessel shell plate identified as being most likely to limit the operation of the reactor vessel.

The specimens contained in the Catawba Unit No. 2 test capsules are from the intermediate shell plate of the reactor vessel and representative weld metal and heat-affected-zone (HAZ) metal.

The thermal history or heat treatment given these specimens is similar to the thermal history of the reactor vessel material with the exception that the postweld heat treatment received by the specimens has been simulated (Appendix A).

The six material test capsules are then installed in the reactor in guide tubes attached to the neutron shield pads which are located in the reactor between the core barrel and the reactor vessel wall opposite the center of the core as shown in Figure 1-1.





FIGURE 1-1. LOCATION OF THE IRRADIATION TEST CAPSULES IN THE CATAWBA UNIT NO. 2 REAC. VESSEL

SECTION 2

CAPSULE PREPARATION

2-1. PRESSURE VESSEL MATERIAL

Reactor vessel material was supplied by Combustion Engineering, Inc. from intermediate shell plate B8605-1, Heat No. C0543-1. Combustion Engineering, Inc., also furnished a weldment which joined sections of material of the intermediate shell plate B8605-2 (See Note) and the adjacent lower shell plate B8806-1, Heat No. C2288-1. Data on the limiting core region plate (B8605-1), weld, and weld-heat-affected-zone material are provided in Appendix A.

Note: The limiting material for the Catawba Unit No. 2 reactor vessel beltline region is intermediate shell plate B8605-1. This is based on the highest ΔRT_{NDT} shift (94°F) as calculated using the latest ASTM revisions.

The original material selected in 1978 was intermediate shell plate B8605-2. This selection was based at the time on the highest initial RT_{NDT} . Therefore weld test plate "D" furnished to Westinghouse at that time was made up of plates B8605-2 and B8806-1.

2-2. MACHINING

Test material obtained from the intermediate shell plate (after the thermal heat treatment and forming of the plate) was taken at least one plate thickness from the quenched ends of the plate. All test specimens were machined from the $\frac{1}{4}$ and $\frac{3}{4}$ -thickness location of the plate after performing a simulated postweld, stress-relieving treatment on the test material and also from weld and heat-affected-zone metal of a stress-relieved weldment joining intermediate shell plate B8605-2 and adjacent lower shell plate B8806-1. All heat-affected-zone specimens were obtained from the weld heat-affected-zone of intermediate shell plate B8605-2.




Figure 2-1. Charpy V-notch Impact Specimen

2.3 Charpy V-notch Impact Specimens

Charpy V-notch impact specimens corresponding to ASTM A370 Type A (Figure 2-1) were machined from intermediate shell plate B8605-1 in both the longitudinal orientation (longitudinal axis of specimen parallel to major rolling direction) and transverse orientation (longitudinal axis of specimen normal to major rolling direction). The core region weld Charpy impact specimens were machined from the weldment such that the long dimension of the Charpy specimen was normal to the weld direction. The notch was machined such that the direction of crack propagation in the specimen was in the welding direction.

2-4. Tensile Specimens

Tensile specimens (Figure 2-2) from shell plate B8605-1 were machined in both the longitudinal and transverse orientation. Tensile specimens from the weld were oriented normal to the welding direction.

2-5. 1/2T Compact Specimens

Compact test specimens (Figure 2-3) from shell plate B8605-1 were machined in both the longitudinal and transverse orientations. Compact test specimens from the weld metal were machined with the notch oriented in the direction of welding. All specimens were fatigue precracked according to ASTM E399.

2-6. DOSIMETERS

Each of the six test capsules of the type shown in Figure 2-4 contain dosimeters of copper, iron, nickel and aluminum 0.15 weight percent cobalt wire (cadmium-shielded and unshielded) and cadmium-shielded Np^{237} and U^{238} which will measure the integrated flux at specific neutron energy levels.

2-7. THERMAL MONITORS

The capsules contain two low-melting-point eutectic alloys to more accurately define the maximum temperature attained by test specimens during irradiation. The thermal monitors are sealed in Pyrex tubes and then inserted in spacers located as shown in Figure 2-4. The two eutectic alloys and their melting points are the following:

2.5 percent Ag, 97.5 percent Pb

Melting point: 304°C (579°F)

1.5 percent Ag, 1.0 percent Sn, 97.5 percent Pb

Melting point: 310°C (590°F)








Figure 2-3. Compact Specimen




MACHINE IT D1 TO OBTAIN A .015 GAP BETWEEN SPACER (IT 5) AND TOP SUPPORT PLUS IT D1 WHEN IT D1 IS SEATED.


STAMP CAPSULE IDENTIFICATION WITH .250 HIGH LETTERS ON IT D1 TO BE ALIGNED WITH LETTER ON IT D3. POSITION CAPSULE ASSEMBLES IN REACTOR WITH LETTERS ADJACENT TO CORE. STAMP .125 HIGH SLEETER PLANT SYMBOLS.




LOCATION OF CAPSULES
3 LOOP PLANTS
SEE ITEM 5 FOR ORIENTATION




LOCATION OF CAPSULES
2 LOOP PLANTS
SEE ITEM 6 FOR ORIENTATION




LOCATION OF CAPSULES
4 LOOP PLANTS
SEE ITEM 7 FOR ORIENTATION



SECTION
TENSILE SPEC
SCALE



SECTION
COMPACT ITEM
SCALE



ITEM NO.	DESCRIPTION	QUANTITY	UNIT	REMARKS
01	TOP SUPPORT PLUG	1	PC	
02	PLUG	1	PC	
03	BOTTOM END PLUG	1	PC	
04	ENCLOSURE HALF	2	PC	
05	IMPACT SPECIMEN	1	PC	
06	TENSILE SPECIMEN	1	PC	
07	IMPACT COVER	1	PC	
08	IMPACT COVER PLUG	1	PC	
09	IMPACT TENSILE SPECIMEN	1	PC	
10	IMPACT TENSILE SPECIMEN	1	PC	
11	DOSE-METER BLOCK	1	PC	
12	SPACER	1	PC	
13	SPACER	1	PC	
14	SPACER	1	PC	
15	SPACER	1	PC	
16	DOSE-METER WIRE	1	PC	
17	WHEEL DOSE-METER WIRE	1	PC	
18	COPPER DOSE-METER WIRE	1	PC	
19	COBALT DOSE-METER WIRE	1	PC	
20	IMPACT COBALT DOSE-METER WIRE	1	PC	
21	IMPACT THERMAL MONITOR	1	PC	
22	IMPACT THERMAL MONITOR	1	PC	
23	IMPACT THERMAL MONITOR	1	PC	

A ALUMINUM COBALT WIRE DISK COBALT
 B ALUMINUM COBALT WIRE DISK COBALT (SHIELDED WITH CADMIUM TUBING)

NOTES: ASSEMBLY (TEST PROCEDURE)

- CLEAN ALL PARTS WITH ACETONE AND VISUALLY EXAMINE TO ASSURE FREEDOM FROM GREASE, DIRT, AND OTHER FOREIGN SUBSTANCES PRIOR TO ASSEMBLY.
- INSERT ITEM 12 INTO ITEM 11 AS REQUIRED AND PRESS FIT PLUGS (ITEMS).
- INSTALL ITEM 20 AND U-235 CAPSULES INTO DOSE-METER BLOCK (ITEM 11) AND WELD COVERS PER WPS B2148 PA KEY C.
- INSTALL SPECIMENS, SPACERS, ETC. (ITEMS 05 THRU 15) IN ENCLOSURE HALF (ITEM 04).
- WELD ENCLOSURE HALVES (ITEM 04) TOGETHER.
- WELD END PLUGS (ITEMS 01, 02) TO ENCLOSURE HALVES. ORIENT END PLUGS AS SHOWN ON DRAWING. (SEE WELD).
- TEMPORARILY INSTALL PLUG (ITEM 02) IN PLACE. DO NOT WELD PLUG. PLACE ASSEMBLY IN WELD BOX.
- EVALUATE ENCLOSURE (BANK 21) WITH HELIUM AT ONE ATM. PRESSURE. WELD PLUG (ITEM 02) TO SUPPORT PLUG (ITEM 01) IN HELIUM ATMOSPHERE. (SEE NOTE 12).
- HELIUM LEAK TEST SEALED ENCLOSURE. MAXIMUM ALLOWABLE LEAK RATE 1X10⁻⁶ CC/SEC. AT ONE ATM. PRESSURE.
- AUTOClave ENCLOSURES IN DEMINERALIZED WATER AT 2800 PSI MAXIMUM OR 550°F FOR A PERIOD NOT TO EXCEED 24 HOURS AT TEMPERATURE / PRESSURE.
- HELIUM LEAK TEST ENCLOSURES AS IN STEP 9 ABOVE AFTER PRESSURIZATION WITH HELIUM FOR 15 MINUTES AT 40 PSI.
- NOTES 5, 6, 13 TO BE WELDED PER WPS 276413-1.
- FLUID PENETRANT TEST WELDS MADE IN NOTE 6 ABOVE PER WPS 588130 LEVEL B.

ANSTEC APERTURE CARD

Also Available on Aperture Card

Figure 2-4. Irradiation Capsule Assembly
 From Westinghouse Dwg 1453E10

9709220008-01


2-8. CAPSULE LOADING

The six test capsules coded U, V, W, X, Y, and Z are positioned in the reactor between the neutron shielding pads and vessel wall at the locations shown in Figure 2-4. Each capsule contains 60 Charpy V-notch specimens, 9 tensile specimens and 12 compact specimens. The relationship of the test material to the type and number of specimens in each capsule is shown in Table 2-1.

TABLE 2-1
TYPE AND NUMBER OF SPECIMENS IN THE CATAWBA
UNIT NO. 2 SURVEILLANCE TEST CAPSULES

Material	Capsules U, V, W, X, Y, and Z		
	Charpy	Tensile	Compact
Plate B8605-1 Longitudinal	15 (Specimens Each Capsule)	3	4
Transverse	15	3	4
Weld Metal	15	3	4
HAZ	15	—	—

Dosimeters of copper, iron, nickel, aluminum 0.15 weight percent cobalt, and cadmium-shielded aluminum-cobalt wires are secured in holes drilled in spacers located at capsule positions shown in Figure 2-4. Each capsule also contains a dosimeter block (Figure 2-5) located at the center of the capsule. Two cadmium-oxide-shielded tubes, one containing an isotope of U^{238} and the other an isotope of Np^{237} , are located in the dosimeter block. The double containment afforded by the dosimeter assembly prevents loss and contamination by the U^{238} and Np^{237} and their activation products. Each dosimeter block contains approximately 12 milligrams of U^{238} and 17 milligrams of Np^{237} (Table 2-2) held in a $3/8$ -inch-long by $1/4$ -inch outside diameter sealed stainless steel tube, respectively. Each tube was placed in a $1/2$ -inch-diameter hole in the dosimeter block (one U^{238} and one Np^{237} tube per block), and the space around the tube was



ITEM	TITLE	MATERIAL SPECIFICATION	NO REQ'D.
1	BLOCK	CARBON STEEL	1
2	COVER	CARBON STEEL	2
3	SPACER	ALUMINUM	4
4	NEPTUNIUM ²³⁷ SEALED CAPSULE (0.250 OD x 0.375 LG)	STAINLESS STEEL	1
5	URANIUM ²³⁸ SEALED CAPSULE (0.250 OD x 0.375 LG)	STAINLESS STEEL	1
6	CADMIUM OXIDE		AS REQ'D

Figure 2-5. Dosimeter Block Assembly

filled with cadmium oxide. After placement of this material, each hole was blocked with two $\frac{1}{16}$ -inch-thick aluminum spacer discs and an outer $\frac{1}{8}$ -inch-thick steel cover disc welded in place.

The numbering system for the capsule specimens and their locations is shown in Figure 2-6. The specimens are seal-welded into a square capsule of austenitic stainless steel to prevent corrosion of specimen surfaces during irradiation. The capsules are hydrostatically compressed in demineralized water to collapse the capsule on the specimens so that optimum thermal conductivity between the specimens and the reactor coolant is obtained. The capsules are then leak-tested with helium after pressurization and then dye penetrant tested as a final inspection procedure. Fabrication details and testing procedures are listed in Figure 2-4.

TABLE 2-2
QUANTITY OF ISOTOPES CONTAINED IN THE DOSIMETER BLOCKS

Isotope	Weight (mg)	Compound	Weight (mg)
Np ²³⁷	17 ± 1	NpO ₂	20 ± 1
U ²³⁸	12.0	U ₃ O ₈	14.25

DDP
CAPSULES

	LONGI SPACERS	TRANSVERS	COMPACTS	COMPACTS	CHARPTS	CHARPTS	CHARPTS	COMPACTS	COMPACTS	TRANS
Z	DDP Z	DW18 DZ17 DW16	DW24 DW23	DW22 DW21	DW30 DH30 DW38 DH38 DW36 DH36	DW57 DH57 DW56 DH56 DW55 DH55	DW64 DH64 DW63 DH63 DW62 DH62	DL24 DL23	DL22 DL21	DY31 DY30 DY29
Y	DDP Y	DW15 DW14 DW13	DW20 DW19	DW18 DW17	DW75 DH75 DW74 DH74 DW73 DH73	DW72 DH72 DW71 DH71 DW70 DH70	DW80 DH80 DW88 DH88 DW87 DH87	DL27 DL19	DL18 DL17	DY88 DY86 DY84
X	DDP X	DW12 DW11 DW10	DW16 DW15	DW14 DW13	DW60 DH60 DW59 DH59 DW58 DH58	DW57 DH57 DW56 DH56 DW55 DH55	DW54 DH54 DW53 DH53 DW52 DH52	DL16 DL15	DL14 DL13	DY51 DY50 DY49
W	DDP W	DW9 DW8 DW7	DW12 DW11	DW10 DW9	DW45 DH45 DW44 DH44 DW43 DH43	DW42 DH42 DW41 DH41 DW40 DH40	DW39 DH39 DW38 DH38 DW37 DH37	DL12 DL11	DL10 DL9	DW35 DW34 DW34
V	DDP V	DW6 DW5 DW4	DW8 DW7	DW6 DW5	DW30 DH30 DW29 DH29 DW28 DH28	DW27 DH27 DW26 DH26 DW25 DH25	DW24 DH24 DW23 DH23 DW22 DH22	DL8 DL7	DL6 DL5	DW21 DW20 DW19
U	DDP U	DW3 DW2 DW1	DW4 DW3	DW2 DW1	DW15 DH15 DW14 DH14 DW13 DH13	DW12 DH12 DW11 DH11 DW10 DH10	DW9 DH9 DW8 DH8 DW7 DH7	DL4 DL3	DL2 DL1	DW3 DW2 DW4

LEGEND: DL - INTERMEDIATE SHELL PLATE B8605-1 (LONGITUDINAL)
 DT - INTERMEDIATE SHELL PLATE B8605-1 (TRANSVERSE)
 DW - WELD METAL
 DH - HEAT-AFFECTED-ZONE MATERIAL

	DIAPHRAGMS		DIAPHRAGMS	THERMISTORS		DIAPHRAGMS		DIAPHRAGMS		DIAPHRAGMS		DIAPHRAGMS		COMPACTS		COMPACTS		THERMISTORS					
481	DW76	DH76	530	DL16	DT90	DL80	DT97	DL87	DT84	DL84	DT81	DL81	DT79	DL79					DT16				
480	DW77	DH77		DL17	DT86	DL86	DT86	DL86	DT80	DL80	DT80	DL80	DT77	DL77					DT27	DT26	DT25	DT24	DT17
479	DW76	DH76		DL16	DT86	DL86	DT85	DL85	DT80	DL80	DT79	DL79	DT76	DL76									DT16
488	DW60	DH60	530	DL15	DT75	DL75	DT72	DL72	DT80	DL80	DT86	DL86	DT83	DL83					DT16				
480	DW62	DH62		DL14	DT74	DL74	DT71	DL71	DT86	DL86	DT86	DL86	DT62	DL62					DT29	DT29	DT21	DT17	DT14
484	DW61	DH61		DL13	DT73	DL73	DT70	DL70	DT87	DL87	DT84	DL84	DT61	DL61									DT13
481	DW46	DH46	534	DL12	DT80	DL80	DT87	DL87	DT84	DL84	DT81	DL81	DT48	DL48					DT12				
480	DW47	DH47		DL11	DT86	DL86	DT86	DL86	DT73	DL83	DT80	DL80	DT47	DL47					DT16	DT15	DT14	DT13	DT11
480	DW48	DH48		DL10	DT86	DL86	DT85	DL85	DT82	DL82	DT49	DL49	DT46	DL46									DT10
486	DW33	DH33	530	DL9	DT45	DL45	DT42	DL42	DT39	DL39	DT36	DL36	DT33	DL33					DT9				
485	DW32	DH32		DL8	DT44	DL44	DT41	DL41	DT38	DL38	DT35	DL35	DT32	DL32					DT12	DT11	DT10	DT9	DT8
484	DW31	DH31		DL7	DT43	DL43	DT40	DL40	DT37	DL37	DT34	DL34	DT31	DL31									DT7
481	DW18	DH18	530	DL6	DT30	DL30	DT27	DL27	DT24	DL24	DT21	DL21	DT18	DL18					DT6				
480	DW17	DH17		DL5	DT29	DL29	DT26	DL26	DT23	DL23	DT20	DL20	DT17	DL17					DT8	DT7	DT6	DT5	DT5
479	DW16	DH16		DL4	DT28	DL28	DT25	DL25	DT22	DL22	DT19	DL19	DT16	DL16									DT4
486	DW3	DH3	531	DL3	DT15	DL15	DT12	DL12	DT9	DL9	DT6	DL6	DT3	DL3					DT3				
485	DW2	DH2		DL2	DT14	DL14	DT11	DL11	DT8	DL8	DT5	DL5	DT2	DL2					DT4	DT3	DT2	DT1	DT2
484	DW1	DH1		DL1	DT13	DL13	DT10	DL10	DT7	DL7	DT4	DL4	DT1	DL1									DT1

Figure 2-6. Specimen Location in the
Catawba Unit No. 2
Reactor Surveillance Test Capsules

ANSTEC
APERTURE
CARD

2-13/2-14

Also Available on
Aperture Card

9709220008-02

SECTION 3

PREIRRADIATION TESTING

3-1. CHARPY V-NOTCH TESTS

Charpy V-notch impact tests were performed according to ASTM E23 with specimens from the vessel intermediate shell plate B8605-1. Specimens of both longitudinal and transverse orientations were tested at various test temperatures in the range from -62°C to 160°C (-80°F to 320°F), yielding a full Charpy V-notch transition temperature curve in both orientations (Tables 3-1 and 3-2 and Figures 3-1 and 3-2). Tests were also performed on the weld metal and HAZ metal at various temperatures from -118°C to 160°C (-180°F to 320°F) and are shown in Tables 3-3 and 3-4 and Figures 3-3 and 3-4.

A summary of the Charpy V-notch impact tests results including upper shelf energy (USE), 41-joule (30 ft lb), 68-joule (50 ft lb), and 35 mils (0.89mm) lateral expansion index temperatures are presented in Table 3-5.

The specimens were tested on a Sontag Universal Model Number SI-1 impact machine with a hammer energy capacity of 240 foot pounds and a striking velocity of 17 feet per second. The machine is calibrated every 6 months using Charpy V-notch impact specimens of known energy values supplied by Watertown Arsenal. Specimen conditioning for high temperature testing is maintained using a Fisher ISO Temperature Oven, Model 350. For low temperature specimen conditioning either liquid nitrogen or dry ice in isopropanol is used. The specimen temperatures are monitored by use of a "J" type thermocouple or a thermometer.

3-2. TENSILE TESTS

Table 3-6 and Figures 3-5, 3-6, and 3-7 show the results of tensile tests (per ASTM E8 and E-21 test criteria) from vessel intermediate shell plate B8605-1 and from the weld metal. Specimens from plate B8605-1 and the weldment were tested at 24°C (75°F), 149°C (300°F) and 288°C (550°F) in both the longitudinal and transverse directions.

An Instron Universal tensile testing machine Model TTD (20K-50K) was used with an Instron load cell (Serial number 059SN and 044SN) which is calibrated daily and verified annually to the National Bureau of Standards. The gripping mechanism utilizes threaded adapters to pull rods attached to the cross head/load cell and frame. The recording device utilizes an Instron Model 3124 strip chart in console calibrated to the Instron Class B-1 extensometer, Model 4929. The extensometer is calibrated by test equipment which has been certified by the National Bureau of Standards. The measurement and control of speeds in the tests conform to ASTM A370-77 (Mechanical Testing of Steel Products). A typical stress-strain curve is shown in Figure 3-8.

3-3. DROPWEIGHT TESTS

The nil ductility transition temperature (T_{NDT}) was determined for plate B8605-1 and the core region weld metal and heat-affected-zone by dropweight tests (ASTM E-208) performed at Combustion Engineering, Inc. From this test data the RT_{NDT} was calculated using the methods as described in Section 1. The T_{NDT} and RT_{NDT} for intermediate shell plate B8605-1, weld metal and heat-affected-zone (HAZ) are as follows:

Note: T_{NDT} and RT_{NDT} for all the beltline shell plates is given in Appendix A.

Material	T_{NDT} (°F)	RT_{NDT} (°F)
Plate B8605-1	- 10 ^[a]	+ 15
Weld Metal (Intermediate and Lower Shell Longitudinal Seams and closing Girth Seam)	- 80 ^[b]	- 80
HAZ	- 80 ^[c]	- 80

- a. Combustion Engineering Materials Certification Report.
- b. Combustion Engineering Welding Material Qualification Test.
- c. Combustion Engineering Surveillance Weld Test Plate "C" Materials Test Report

TABLE 3-1
PREIRRADIATION CHARPY V-NOTCH IMPACT DATA
FOR THE CATAWBA UNIT NO. 2 REACTOR
PRESSURE VESSEL INTERMEDIATE SHELL
PLATE B8605-1 (LONGITUDINAL ORIENTATION)

Temperature		Impact Energy		Lateral Expansion		Shear (%)
(°C)	(°F)	(J)	(ft lb)	(mm)	(mils)	
- 62	- 80	5.5	4.0	0.03	1.0	3
- 62	- 80	8.0	6.0	0.08	3.0	3
- 40	- 40	18.0	13.0	0.20	8.0	9
- 40	- 40	26.0	19.0	0.36	14.0	9
- 40	- 40	37.0	27.0	0.51	20.0	14
- 18	0	43.0	32.0	0.46	18.0	25
- 18	0	51.5	38.0	0.79	31.0	30
- 18	0	57.0	42.0	0.69	27.0	25
- 7	20	69.0	51.0	1.12	44.0	34
- 7	20	69.0	51.0	0.97	38.0	29
- 7	20	95.0	70.0	1.22	48.0	23
4	40	91.0	67.0	1.09	43.0	40
4	40	111.0	82.0	1.45	57.0	48
4	40	111.0	82.0	1.52	60.0	45
27	80	104.0	77.0	1.35	53.0	56
27	80	117.0	86.0	1.45	57.0	50
27	80	123.0	91.0	1.52	60.0	54
49	120	115.0	85.0	2.01	79.0	81
49	120	118.0	87.0	1.80	71.0	75
49	120	142.0	112.0	1.83	72.0	77
66	150	159.0	117.0	2.01	79.0	94
66	150	182.0	134.0	2.13	84.0	100
82	180	180.0	133.0	2.13	84.0	100
82	190	183.0	135.0	2.24	88.0	100
82	180	192.5	142.0	2.24	88.0	100
116	240	183.0	135.0	2.24	86.0	100
116	240	188.5	139.0	2.18	86.0	100
160	320	188.5	139.0	2.16	85.0	100
160	320	197.0	145.0	2.18	86.0	100

TABLE 3-2
PREIRRADIATION CHARPY V-NOTCH IMPACT DATA
FOR THE CATAWBA UNIT NO. 2 REACTOR
PRESSURE VESSEL INTERMEDIATE
SHELL PLATE B8605-1 (TRANSVERSE ORIENTATION)

Temperature		Impact Energy		Lateral Expansion		Shear (%)
(°C)	(°F)	(J)	(ft lb)	(mm)	(mils)	
- 62	- 80	7.0	5.0	0.05	2.0	3
- 62	- 80	8.0	6.0	0.13	5.0	3
- 40	- 40	12.0	9.0	0.15	6.0	13
- 40	- 40	22.0	16.0	0.25	10.0	18
- 40	- 40	24.5	18.0	0.33	13.0	9
- 18	0	46.0	34.0	0.53	21.0	29
- 18	0	47.5	35.0	0.69	27.0	25
- 18	0	56.0	41.0	0.89	35.0	29
4	40	47.5	35.0	0.69	27.0	38
4	40	70.5	52.0	1.04	41.0	43
4	40	73.0	54.0	1.02	40.0	34
27	80	80.0	59.0	1.19	47.0	41
27	80	87.0	64.0	1.22	48.0	44
27	80	96.0	71.0	1.27	50.0	45
38	100	72.0	53.0	1.09	43.0	47
38	100	89.5	66.0	1.27	50.0	55
38	100	104.5	77.0	1.37	54.0	59
49	120	89.5	66.0	1.19	47.0	62
49	120	114.0	84.0	1.55	61.0	68
49	120	127.5	94.0	1.78	70.0	100
82	180	125.0	92.0	1.63	64.0	100
82	180	130.0	96.0	1.83	72.0	100
82	180	134.0	99.0	1.80	71.0	100
116	240	136.0	100.0	1.80	71.0	100
116	240	138.0	102.0	1.98	78.0	100
160	320	114.0	84.0	1.65	65.0	100
160	320	136.0	100.0	1.90	75.0	100

TABLE 3-3
PREIRRADIATION CHARPY V-NOTCH IMPACT DATA
FOR THE CATAWBA UNIT NO. 2 REACTOR
PRESSURE VESSEL CORE REGION
WELD METAL

Temperature		Impact Energy		Lateral Expansion		Shear (%)
(°C)	(°F)	(J)	(ft lb)	(mm)	(mils)	
- 96	- 140	5.5	4.0	0.03	1.0	9
- 96	- 140	7.0	5.0	0.05	2.0	13
- 62	- 80	8.0	6.0	0.03	1.0	13
- 62	- 80	11.0	8.0	0.08	3.0	18
- 62	- 80	35.0	26.0	0.28	11.0	18
- 51	- 60	15.0	11.0	0.15	6.0	28
- 51	- 60	20.0	15.0	0.25	10.0	33
- 51	- 60	20.0	15.0	0.15	6.0	28
- 40	- 40	62.0	46.0	0.79	31.0	47
- 40	- 40	79.0	58.0	1.04	41.0	40
- 40	- 40	99.0	73.0	1.30	51.0	52
- 18	0	79.0	58.0	1.14	45.0	65
- 18	0	130.0	96.0	1.52	60.0	73
- 18	0	137.0	101.0	1.83	72.0	71
4	40	164.0	121.0	2.01	79.0	96
4	40	169.5	125.0	1.98	78.0	93
4	40	183.0	135.0	2.03	80.0	84
27	80	178.0	131.0	2.01	79.0	93
27	80	187.0	138.0	2.24	88.0	96
27	80	199.0	147.0	2.18	86.0	94
49	120	192.5	142.0	2.24	88.0	100
49	120	198.0	146.0	2.24	88.0	100
49	120	205.0	151.0	2.21	87.0	100
104	220	188.5	139.0	2.18	86.0	100
104	220	201.0	148.0	2.31	91.0	100
160	320	206.0	152.0	2.29	90.0	100
160	320	222.0	164.0	2.18	86.0	100

TABLE 3-4
PREIRRADIATION CHAPPY V-NOTCH IMPACT DATA
FOR THE CATAWBA UNIT NO. 2 REACTOR PRESSURE
VESSEL CORE REGION WELD
HEAT-AFFECTED-ZONE MATERIAL

Temperature		Impact Energy		Lateral Expansion		Shear (%)
(°C)	(°F)	(J)	(ft lb)	(mm)	(mils)	
-118	-180	9.5	7.0	0.08	3.0	3
-118	-180	12.0	9.0	0.05	2.0	3
-118	-180	15.0	11.0	0.05	2.0	9
-84	-120	20.0	15.0	0.05	2.0	10
-84	-120	31.0	23.0	0.18	7.0	29
-84	-120	38.0	28.0	0.25	10.0	25
-62	-80	12.0	9.0	0.13	5.0	29
-62	-80	38.0	28.0	0.36	14.0	29
-62	-80	84.0	62.0	0.74	29.0	43
-51	-60	37.0	27.0	0.43	17.0	32
-51	-60	79.0	58.0	0.86	34.0	50
-51	-60	90.0	66.0	0.86	34.0	47
-40	-40	72.0	53.0	0.79	31.0	56
-40	-40	108.5	80.0	1.19	47.0	59
-40	-40	127.5	94.0	1.37	54.0	68
-18	0	138.0	102.0	1.55	61.0	73
-18	0	142.0	105.0	1.42	56.0	90
-18	0	183.0	135.0	1.78	70.0	100
4	40	167.0	123.0	2.06	81.0	100
4	40	186.0	138.0	1.98	78.0	100
4	40	201.0	148.0	2.03	80.0	100
27	80	163.0	120.0	1.78	70.0	100
27	80	174.0	128.0	1.80	71.0	100
27	80	197.0	145.0	1.90	75.0	100
60	140	184.5	136.0	2.08	82.0	100
60	140	207.5	153.0	1.98	78.0	100
93	200	176.0	130.0	2.03	80.0	100
93	200	199.0	147.0	2.01	79.0	100

TABLE 3-5
SUMMARY OF CATAWBA UNIT NO. 2
REACTOR PRESSURE VESSEL IMPACT TEST RESULTS FOR
INTERMEDIATE SHELL PLATE B8605-1 AND
CORE REGION WELD AND HEAT-AFFECTED-ZONE MATERIAL

Material	Upper Shelf Energy (USE)		41-J (30-ft lb) Index Temp		68-J (50-ft lb) Index Temp		0.89 mm (35 mils) Index Temp	
	(J)	(ft lb)	(°C)	(°F)	(°C)	(°F)	(°C)	(°F)
Plate B8605-1 (Longitudinal Orientation)	187	138	-26	-15	-7	20	-9	15
Plate B8605-1 (Transverse Orientation)	130	96	-21	-5	4	40	4	40
Weld Metal	202	149	-46	-50	-40	-40	-34	-30
Heat Affected Zone	184.5	136	-71	-95	-54	-65	-43	-45

TABLE 3-6
 PREIRRADIATION TENSILE PROPERTIES FOR THE
 CATAWBA UNIT NO. 2 REACTOR PRESSURE
 VESSEL INTERMEDIATE SHELL PLATE B8605-1
 AND CORE REGION WELD METAL

Material	Test Temperature		0.2% Yield Strength		Ultimate Tensile Strength		Fracture Load		Fracture Stress		Fracture Strength		Uniform Elongation (%)	Total Elongation (%)	Reduction in Area (%)
	°C	°F	(ksi)	(MPa)	(ksi)	(MPa)	(klp)	(N)	(ksi)	(MPa)	(ksi)	(MPa)			
Plate B8605-1 (Longitudinal Orientation)	24	75	68.0	469.0	90.0	620.5	2.8	12,454	189.0	1303.0	56.0	386.0	16.0	31.0	71.0
	24	75	71.0	489.5	89.0	614.0	2.8	12,454	193.0	1331.0	57.0	393.0	16.0	30.0	71.0
	149	300	62.0	427.5	83.0	572.0	2.7	12,010	184.0	1289.0	54.0	372.0	13.0	24.0	69.0
	149	300	62.0	427.5	83.0	572.0	2.7	12,010	180.0	1241.0	55.0	379.0	13.0	24.0	68.0
	288	550	61.0	421.0	88.0	607.0	3.0	13,344	176.0	1213.0	61.0	421.0	13.0	23.0	66.0
	288	550	52.0	358.5	88.0	607.0	3.0	13,344	176.0	1213.0	58.0	407.0	14.0	24.0	67.0
Plate B8605-1 (Transverse Orientation)	24	75	67.0	462.0	90.0	620.5	3.0	13,344	167.0	1151.0	60.0	414.0	16.0	27.0	64.0
	24	75	67.0	462.0	88.0	607.0	3.0	13,344	170.0	1172.0	64.0	441.0	16.0	26.0	62.0
	149	300	61.0	421.0	82.0	565.0	2.9	12,899	153.0	1054.0	58.0	400.0	13.0	23.0	62.0
	149	300	61.0	421.0	82.0	565.0	2.9	12,899	159.0	1096.0	59.0	407.0	14.0	24.0	63.0
	288	550	60.0	414.0	86.0	593.0	3.3	14,678	167.0	1151.0	67.0	462.0	15.0	22.0	60.0
	288	550	60.0	414.0	87.0	600.0	3.3	14,678	150.0	1034.0	67.0	462.0	14.0	21.0	56.0
Weld Metal	24	75	75.0	517.0	87.0	600.0	2.5	11,120	196.0	1365.0	53.0	365.0	15.0	28.0	74.0
	24	75	73.0	503.0	88.0	607.0	2.5	11,120	194.0	1338.0	51.0	352.0	15.0	30.0	74.0
	149	300	68.0	469.0	82.0	565.0	2.5	11,120	177.0	1220.0	51.0	352.0	13.0	26.0	71.0
	149	300	69.0	476.0	82.0	565.0	2.6	11,565	182.0	1255.0	53.0	365.0	12.0	24.0	71.0
	288	550	66.0	455.0	87.0	600.0	2.9	12,899	163.0	1124.0	58.0	400.0	13.0	24.0	64.0
	288	550	65.0	448.0	87.0	600.0	2.8	12,454	179.0	1234.0	57.0	393.0	12.0	23.0	68.0




FIGURE 3-1. PREIRRADIATION CHARPY V-NOTCH IMPACT ENERGY FOR THE CATAWBA UNIT NO. 2 REACTOR PRESSURE VESSEL INTERMEDIATE SHELL PLATE B8605-1 (LONGITUDINAL ORIENTATION)




FIGURE 3-2. PREIRRADIATION CHARPY V-NOTCH IMPACT ENERGY FOR THE CATAWBA UNIT NO. 2 REACTOR PRESSURE VESSEL INTERMEDIATE SHELL PLATE B8605-1 (TRANSVERSE ORIENTATION)




FIGURE 3-3. PREIRRADIATION CHARPY V-NOTCH IMPACT ENERGY FOR THE CATAWBA UNIT NO. 2 REACTOR PRESSURE VESSEL CORE REGION WELD METAL




FIGURE 3-4. PREIRRADIATION CHARPY V-NOTCH IMPACT ENERGY FOR THE CATAWBA UNIT NO. 2 REACTOR PRESSURE VESSEL WELD HEAT-AFFECTED-ZONE MATERIAL





FIGURE 3-5. PREIRRADIATION TENSILE PROPERTIES FOR THE CATAWBA UNIT NO. 2 REACTOR PRESSURE VESSEL INTERMEDIATE SHELL PLATE B8605-1 (LONGITUDINAL ORIENTATION)





FIGURE 3-6. PREIRRADIATION TENSILE PROPERTIES FOR THE CATAWBA UNIT NO. 2 REACTOR PRESSURE VESSEL INTERMEDIATE SHELL PLATE B8605-1 (TRANSVERSE ORIENTATION)





FIGURE 3-7. PREIRRADIATION TENSILE PROPERTIES FOR THE CATAWBA UNIT NO. 2 REACTOR PRESSURE VESSEL CORE REGION WELD METAL




Figure 3-8. Typical Stress-Strain Curve for Tensile Test

SECTION 4

POSTIRRADIATION TESTING

4-1. CAPSULE REMOVAL

The first capsule (Capsule U) should be removed at the end of the first core cycle (1st refueling) as shown in Table 4-1. Subsequent capsules should be removed at 6, 9, and 15 EFPY (Effective Full Power Years) as indicated. Each specimen capsule, removed after exposure, will be transferred to a postirradiation test facility for disassembly and testing of all the specimens.

TABLE 4-1
SURVEILLANCE CAPSULE REMOVAL SCHEDULE

Capsule Identification	Orientation of Capsules ^(a)	Lead Factor ^(b)	Removal Time	Expected Capsule Fluence (n/cm ²)
U	58.5°	4.00	1st Refueling	3.28×10^{18}
Y	241 °	3.69	6 EFPY	$1.45 \times 10^{19(c)}$
V	61	3.69	9 EFPY	$2.18 \times 10^{19(d)}$
X	238.5°	4.00	15 EFPY	3.94×10^{19}
W	121.5°	4.00	Stand-By	—————
Z	301.5°	4.00	Stand-By	—————

a. Reference Irradiation Capsule Assembly Drawing, Figure 2-4.

b. The factor by which the capsule fluence leads the vessels maximum inner wall fluence.

c. Approximate Fluence at ¼-wall thickness at End-of-Life.

d. Approximate Fluence at vessel inner wall at End-of-Life.

4-2. CHARPY V-NOTCH IMPACT TESTS

The testing of the Charpy impact specimens from the intermediate shell plate B8605-1 weld metal, and HAZ metal in each capsule can be done singly at approximately ten different temperatures. The extra specimens should be used to run duplicate tests at temperatures of interest to develop the complete Charpy impact energy transition curve.

The initial Charpy specimen from the first capsule removed should be tested at room temperature. The test value at this temperature should be compared with preirradiation test data. The test temperature for the remaining specimens should then be adjusted higher or lower so as to develop a complete transition curve. For succeeding tests after longer irradiation periods, the test temperature in each case should be chosen in the light of results from the previous capsule.

4.3 TENSILE TESTS

A tensile test specimen from each of the selected irradiated materials shall be tested at a temperature representative of the upper end of the Charpy energy transition region. The remaining tensile specimens from each material shall be tested at the service temperature (550°F) and the midtransition temperature.

4.4 FRACTURE TOUGHNESS TESTS ON 1/2 COMPACT SPECIMENS

In light of current requirements of 10CFR, Part 50, Appendix G and applications of ASME Section III, Appendix G and Section XI, Appendix A, the 1/2-inch thick compact specimens should be tested in such a manner as to determine both static, crack initiation, and propagation parameters throughout the temperature range of interest with emphasis on the sharp fracture toughness transition and upper shelf regions consistent with specimen availability. The specimens should thus be statically tested in accordance with ASTM E399-81 procedures modified to account for the size of the specimens available.^[1] Specific test procedures should include unloading compliance and data interpretation should utilize the Equivalent Energy and J-Integral concepts.^[2,3,4]

1. Witt, F. J., "Fracture Toughness Parameters Obtained from Single Small Specimen Tests", WCAP-9397, October 1978.

2. Buchalet, C. and Mager, T. R., "Experimental Verification of Lower Bound K_{Ic} Values Utilizing the Equivalent Energy Concept," in *Progress in Flaw Growth and Fracture Toughness Testing*, ASTM-STP-536, pp. 281-296. American Society for Testing and Materials, Philadelphia, 1973.

3. Landes, J. D. and Begley, J. A., "Recent Developments in J_{Ic} Testing", in *Developments in Fracture Mechanics Test Methods Standardization*, ASTM-STP-632, pp. 57-81, American Society for Testing and Materials, Philadelphia, 1977.

4. McCabe, D. E., "Determination of R-Curves for Structural Materials Using Nonlinear Mechanics Methods," in *Flaw Growth and Fracture*, ASTM-STP-631, pp. 245-226, American Society for Testing and Materials, Philadelphia, 1977.

Fracture toughness data so obtained will be K_{Ic} , J_{Ic} and dJ/da or engineering estimates thereof. Advantages should be taken of the Charpy impact and tensile data in the selection of initial test temperatures. Test procedures actually performed on the specimens will reflect state-of-the-art at the time of testing.

4.5 POSTIRRADIATION TEST EQUIPMENT

Required minimum equipment for the postirradiation testing operations is as follows:

- Milling machine or special cutoff wheel for opening capsules, dosimeter blocks and spacers.
- Hot cell tensile testing machine with pin-type adapter for testing tensile specimens.
- Hot cell static CT testing machine with clevis and appropriate measuring equipment modified to account for the size of the specimens.
- Hot cell Charpy impact testing machine.
- Sodium iodide scintillation detector and pulse height analyzer for gamma counting of the specific activities of the dosimeters.

APPENDIX A DESCRIPTION AND CHARACTERIZATION OF THE CATAWBA UNIT NO. 2 REACTOR VESSEL BELTLINE AND SURVEILLANCE MATERIALS

Based on the initial RT_{NDT} , chemical composition (copper and phosphorus) and the end-of-life neutron fluence, the reactor vessel intermediate shell plate B8605-1 is expected to have the highest end-of-life ΔRT_{NDT} using the prediction methods of Regulatory Guide 1.99 Revision 1 and latest ASTM revisions. This material is therefore considered to be the limiting vessel beltline region material and has been used in the reactor vessel surveillance program.

For the surveillance program Combustion Engineering, Inc., supplied Westinghouse with sections of the A533 Grade B Class 1 Steel plate produced by Lukens Steel Company. This steel was used in the fabrication of the Catawba Unit No. 2 reactor pressure vessel, specifically, from the 9 $\frac{5}{8}$ -inch intermediate shell plate B8605-1. Also supplied was a submerged arc weldment made from sections of intermediate shell plate B8605-2^(a) and adjacent lower shell plate B8806-1. This test weldment was fabricated using $\frac{3}{16}$ inch Mil B-4 weld filler wire, heat number 83648 and Linde 0091 flux, lot number 3536 and is identical to that used by Combustion Engineering, Inc. in the Catawba Unit No. 2 reactor vessel fabrication process specifically the closing girth seam between the intermediate and lower shell plates, and all longitudinal weld seams of both the intermediate and lower shell plates.

The chemical analyses, T_{NDT} , RT_{NDT} , upper shelf energy and heat treatment history of all the core region pressure vessel shell plates used in the fabrication of the Catawba Unit No. 2 reactor pressure vessel are summarized in Tables A-1 thru A-5 respectively. This data is as reported in the vessel fabricators (Combustion Engineering, Inc.) certification reports or from subsequent Westinghouse analyses of similar materials used for the Catawba Unit No. 2 surveillance program. Weld material identical to that used in the fabrication of the core region beltline welds^(b) have been correlated with the Westinghouse surveillance program test weldment and available Combustion Engineering, Inc. weld certification reports and their surveillance program test weldment. This data is also reported in Tables A-3 thru A-5 of this Appendix.

- a. The limiting plate material selected in 1978 was intermediate shell plate B8605-2. This selection was based at the time on the highest initial RT_{NDT} . Therefore weld test plate "D" furnished to Westinghouse at that time was made up of plates B8605-2 and B8806-1.
- b. The beltline welds are considered to include the intermediate and lower shell plate longitudinal seams and the closing intermediate to lower shell girth seam.

TABLE A-1
CHEMICAL ANALYSIS OF THE INTERMEDIATE SHELL PLATES
USED IN THE CORE REGION OF THE CATAWBA
UNIT NO. 2 REACTOR PRESSURE VESSEL

Element	Chemical Composition (weight %)			
	Plate ^(a)		Plate ^(b)	Plate ^(b)
	B8605-1 ^(b)	B8605-1 ^(c)	B8605-2	B8616-1
C	.25	.22	.24	.24
Mn	1.40	1.37	1.35	1.39
P	.011	.012	.009	.010
S	.013	.013	.013	.021
Si	.28	.29	.26	.27
Ni	.63	.59	.61	.59
Mo	.57	.57	.57	.54
Cr	_____	.085	.05	_____
Cu	.09	.071	.07	.05
Al	_____	.042	.043	_____
Co	_____	.007	.006	_____
Pb	_____	.001	< .001	_____
W	_____	< .01	< .01	_____
Ti	_____	.004	< .01	_____
Zr	_____	< .002	.001	_____
V	not detected	.002	.003	not detected
Sn	_____	.007	.003	_____
As	_____	.008	.005	_____
Cb	_____	< .002	< .01	_____
N ₂	_____	.008	< .01	_____
B	_____	< .001	< .001	_____

a. Surveillance program test plate.

b. Chemical Analysis by Combustion Engineering, Inc.

c. Chemical Analysis by Westinghouse.

TABLE A-2
CHEMICAL ANALYSIS OF THE LOWER SHELL PLATES
USED IN THE CORE REGION OF THE CATABWA
UNIT NO. 2 REACTOR PRESSURE VESSEL

Element	Chemical Composition ^(a) (weight %)		
	Plate B8806-1	Plate B8806-2	Plate B8806-3
C	.23	.19	.20
Mn	1.40	1.33	1.35
P	.009	.007	.006
S	.016	.013	.013
Si	.22	.23	.23
Ni	.56	.59	.59
Mo	.57	.55	.55
Cr	.12	.03	.03
Cu	.05	.05	.05
Al	.021	.027	.027
Co	.006	.006	.005
Pb	< .001	< .001	< .001
W	< .01	< .01	< .01
Ti	< .01	< .01	< .01
Zr	.002	.001	.001
V	.004	.003	.002
Sn	.001	.002	.001
As	.003	.004	.002
Cb	< .01	< .01	< .01
N ₂	.007	.006	.006
B	< .001	< .001	< .001

a. Chemical Analysis by Combustion Engineering, Inc.

TABLE A-3
CHEMICAL ANALYSIS OF THE WELD METAL USED
IN THE CORE REGION WELD SEAMS OF THE
CATAWBA UNIT NO. 2 REACTOR PRESSURE VESSEL

NOTE: The core region (beltline) welds are considered to include the intermediate and lower shell plate longitudinal seams and the joining intermediate to lower shell girth seam. All core region (beltline) welds were fabricated using Weld Wire Heat No. 83648, Linde 0091 Flux, Lot No. 3536.

Element	Chemical Composition (weight %)		
	Wire Flux Test Weld Sample ^(a)	Actual Production Weld (Lower Shell Longitudinal Seam 101-142A) ^(a)	Westinghouse Surveillance Program Test Weldment D ^(b)
C	.13	.14	.15
Mn	1.23	.88	1.20
P	.005	.008	.010
S	.009	.012	.010
Si	.13	.12	.15
Ni	-----	.14	.14
Mo	.59	.44	.60
Cr	-----	.03	.052
Cu	.14	.04	.036
Al	-----	.001	.002
Co	-----	.017	.009
Pb	-----	Not detected	.001
W	-----	.01	< .01
Ti	-----	< .01	.005
Zr	-----	.002	< .002
V	.006	.004	.004
Sn	-----	.008	.005
As	-----	.013	.002
Cb	-----	.017	< .002
N ₂	-----	.007	.004
B	-----	< .001	< .001

- a. Chemical Analysis of Wire-Flux Weld Sample, Test Number D32255 and Chemistry Data Sheet 101-142A by Combustion Engineering, Inc.
- b. Chemical Analysis by Westinghouse of Test Sample Supplied by Combustion Engineering, Inc. Representative of the Closing Girth Seam Weld, Weld Wire Heat No. 83648, 0091 Flux, Lot No. 3536.

TABLE A-4

**T_{NDT}, RT_{NDT} AND UPPER SHELF ENERGY FOR
THE CATAWBA UNIT NO. 2 REACTOR
PRESSURE VESSEL CORE REGION SHELL PLATES
AND WELD METAL**

Material	T _{NDT} ^{[a] [b]}		RT _{NDT}		Average Upper Shelf ^[c] Energy	
	(°C)	(°F)	(°C)	(°F)	(J)	(ft lb)
Intermediate Shell Plates:						
B8605-1	-23	-10	-9	15	121	89
B8605-2	-29	-20	1	33	111	82
B8616-1	-18	0	-11	12	125	92
Lower Shell Plates:						
B8806-1	-51	-60	-14	6	113	83
B8806-2	-40	-40	-23	-10	138	102
B8806-3	-40	-40	-13	8	142	105

- a. Data obtained from Combustion Engineering, Inc. Reactor Vessel Material Certification Reports.
- b. Drop weight data obtained from the transverse material properties (normal to the major working direction).
- c. From impact data obtained from the transverse material properties (normal to the major working direction).

Material	T _{NDT} ^[d]		RT _{NDT}		Upper Shelf ^[d] Energy	
	(°C)	(°F)	(°C)	(°F)	(J)	(ft lb)
Intermediate and Lower Shell Longitudinal Weld Seams and Closing Girth Weld Seam (Weld Wire Heat No. 83648, Linde 0091 Flux, Lot No. 3536)	-62	-80	-62	-80	176	130

- d. Data obtained from Combustion Engineering, Inc. Wire/Flux Weld Deposit Material Certification Test No. 1332.

**TABLE A-5
HEAT TREATMENT HISTORY OF THE CATAWBA
UNIT NO. 2 REACTOR PRESSURE VESSEL
CORE REGION SHELL PLATES AND WELD SEAMS**

Material	Temperature (°F)	Time ^[a] (hr)	Cooling
Intermediate Shell Plates B8605-1 B8605-2 B8616-1	Austenitizing: 1600 ± 25 (871°C)	4	Water-quenched
	Tempered: 1225 ± 25 (663°C)	4	Air-cooled
	Stress Relief: 1150 ± 50 (621°C)	20 ^[b]	Furnace-cooled
Lower Shell Plates B8806-1 B8806-2 B8806-3	Austenitizing: 1600 ± 25 (871°C)	4	Water-quenched
	Tempered: 1225 ± 25 (663°C)	4	Air-cooled
	Stress Relief: 1150 ± 50 (621°C)	17 ^[b]	Furnace-cooled
Intermediate Shell Longitudinal Seam Welds	Stress Relief: 1150 ± 50 (621°C)	20 ^[b]	Furnace-cooled
Lower Shell Longitudinal Seam Welds		17 ^[b]	Furnace-cooled
Intermediate to Lower Shell Girth Seam Weld	Local Stress Relief: 1150 ± 50 (621°C)	11	Furnace-cooled
Surveillance Program Test Material			
Surveillance Program Weldment Test Plate "D" (Representative of closing Girth Seam)	Post Weld Stress Relief: 1150 ± 50 (621°C)	11 ^[c]	Furnace-cooled

a. Lukens Steel Company, Combustion Engineering, Inc. Certification Reports.
b. Stress Relief includes 8-2 Intermediate to Lower Shell Closing Girth Seam Post Weld Heat Treatment.
c. The Stress Relief Heat Treatment received by the Surveillance Test Weldment has been simulated.