

September 24, 1997

LICENSEE: Union Electric Company

FACILITY: Callaway Plant, Unit 1

SUBJECT: MEETING WITH UNION ELECTRIC COMPANY AND FRAMATOME TECHNOLOGIES  
REGARDING THE INSTALLATION OF FRAMATOME ELECTROSLEEVES IN THE  
CALLAWAY, UNIT 1 STEAM GENERATORS

On Wednesday, August 13, 1997, a meeting was held with Framatome Technologies, Inc. (FTI), Union Electric Company (UE), and the Nuclear Regulatory Commission (NRC) staff to discuss the electrosleeving process in support of a UE-proposed technical specification amendment that would allow electrosleeving of the steam generator tubes at the Callaway Plant. The meeting was held at the NRC offices in Rockville, Maryland. A notice of this meeting was issued by the staff on August 1, 1997. Attachment 1 is a list of meeting attendees. Attachment 2 is a non-proprietary version of the handout material that the NRC presented at the meeting.

The purpose of the meeting was to allow the NRC staff to present technical issues that will need to be satisfactorily resolved in order to complete action on the technical specification amendment request. The NRC staff requested that UE and FTI provide further information related to topics discussed at the meeting.

ORIGINAL SIGNED BY

Barry C. Westreich, Project Manager  
Project Directorate IV-2  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Docket No. 50-483

Attachments: 1. List of Meeting Attendees  
2. Meeting Handout material (Non-Proprietary)

cc w/atts: See next page

DISTRIBUTION: See next page

DF011/

Document Name: CALMEET.SUM

OFC	PM/PD4-2	LA/PD4-2	
NAME	Barry C. Westreich	E. Peyton	
DATE	9/25/97	9/24/97	
COPY	YES/NO	YES/NO	YES/NO

OFFICIAL RECORD COPY

9710060264 970924  
PDR ADOCK 05000483  
P PDR

NRC FILE CENTER COPY



DISTRIBUTION: Meeting Summary with Union Electric Company

E-MAIL

SJCollins/FJMiraglia (SJC1, FJM)  
RZimmerman (RPZ)  
EAdensam (EGA1)  
WBateman (WHB)  
TMartin (SLM3)  
EPeyton (ESP)  
JStrosnider (JRS2)  
GHornseth (GPH)  
DBrinkman (DSB1)  
TSullivan (TCS)  
CBeardslee (CDB)  
HConrad (HFC)  
THiltz (TGH)  
TGwynn (TPG)

HARD COPY

Docket File  
PUBLIC  
PDIV-2 r/f  
OGC  
ACRS  
BWestreich



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

September 24, 1997

LICENSEE: Union Electric Company  
FACILITY: Callaway Plant, Unit 1  
SUBJECT: MEETING WITH UNION ELECTRIC COMPANY AND FRAMATOME TECHNOLOGIES  
REGARDING THE INSTALLATION OF FRAMATOME ELECTROSLEEVES IN THE  
CALLAWAY, UNIT 1 STEAM GENERATORS

On Wednesday, August 13, 1997, a meeting was held with Framatome Technologies, Inc. (FTI), Union Electric Company (UE), and the Nuclear Regulatory Commission (NRC) staff to discuss the electrosleeving process in support of a UE-proposed technical specification amendment that would allow electrosleeving of the steam generator tubes at the Callaway Plant. The meeting was held at the NRC offices in Rockville, Maryland. A notice of this meeting was issued by the staff on August 1, 1997. Attachment 1 is a list of meeting attendees. Attachment 2 is a non-proprietary version of the handout material that the NRC presented at the meeting.

The purpose of the meeting was to allow the NRC staff to present technical issues that will need to be satisfactorily resolved in order to complete action on the technical specification amendment request. The NRC staff requested that UE and FTI provide further information related to topics discussed at the meeting.

A handwritten signature in black ink, appearing to read "Barry C. Westreich", is positioned above the typed name.

Barry C. Westreich, Project Manager  
Project Directorate IV-2  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Docket No. 50-483

Attachments: 1. List of Meeting Attendees  
2. Meeting Handout Material (Non-Proprietary)

cc w/atts: See next page

cc w/encls:

Professional Nuclear  
Consulting, Inc.  
19041 Raines Drive  
Derwood, Maryland 20855

Gerald Charnoff, Esq.  
Thomas A. Baxter, Esq.  
Shaw, Pittman, Potts & Trowbridge  
2300 N. Street, N.W.  
Washington, D.C. 20037

Mr. H. D. Bono  
Supervising Engineer,  
Site Licensing  
Union Electric Company  
Post Office Box 620  
Fulton, Missouri 65251

U.S. Nuclear Regulatory Commission  
Resident Inspector Office  
8201 NRC Road  
Steelman, Missouri 65077-1302

Mr. J. V. Laux, Manager  
Quality Assurance  
Union Electric Company  
Post Office Box 620  
Fulton, Missouri 65251

Manager - Electric Department  
Missouri Public Service Commission  
301 W. High  
Post Office Box 360  
Jefferson City, Missouri 65102

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
Harris Tower & Pavilion  
611 Ryan Plaza Drive, Suite 400  
Arlington, Texas 76011-8064

Mr. Ronald A. Kucera, Deputy Director  
Department of Natural Resources  
P.O. Box 176  
Jefferson City, Missouri 65102

Mr. Otto L. Maynard  
President and Chief Executive Officer  
Wolf Creek Nuclear Operating Corporation  
P.O. Box 411  
Burlington, Kansas 66839

Mr. Dan I. Bolef, President  
Kay Drey, Representative  
Board of Directors Coalition  
for the Environment  
6267 Delmar Boulevard  
University City, Missouri 63130

Mr. Lee Fritz  
Presiding Commissioner  
Callaway County Court House  
10 East Fifth Street  
Fulton, Missouri 65151

Mr. Alan C. Passwater, Manager  
Licensing and Fuels  
Union Electric Company  
Post Office Box 66149  
St. Louis, Missouri 63166-6149

Mr. Gary L. Randolph  
Vice President and Chief Nuclear Officer  
Union Electric Company  
Post Office Box 620  
Fulton, Missouri 65251

MEETING WITH UNION ELECTRIC COMPANY

LIST OF MEETING ATTENDEES

August 13, 1997

Union Electric Company

Ed Kahl  
Tim Herrmann

Framatome Technologies, Inc.

James E. Galford  
John Helmey  
Charles England  
Joseph R. Wyatt

Baltimore Gas & Electric Company

E. S. Broczkowski  
Getachen Tesfaye

Duquesne Light

Greg Kammerdener

NRC

Barry Westreich  
Jack Strosnider  
Geoff Hornseth  
Donald S. Brinkman  
Ted Sullivan  
Cherryl Beardslee  
H. F. Conrad



**ELECTROSLEEVE - LICENSE AMENDMENT REVIEW**

**OUTSTANDING ISSUES**

**(CALLAWAY DOCKET REVIEW)**

**CHERYL BEARDSLEE**

**AUGUST 13, 1997**

**U.S. NUCLEAR REGULATORY COMMISSION**

G:\BEARDSLEE\ELEC\_MTG.897

## **ISSUE #1 - QUALIFICATION FOR DEPTH SIZING CRACKS**

**JUNE 9, 1997 SUBMITTAL**

**Union Electric approach- Structural requirements can be met, assuming a RMSE, and measurement uncertainties are acceptable based on RMSE value.**

### **NRC CONCERNS**

**Flaws - Lab Grown Axial/Circumferential ODSCC Data Set**

---

### **CONCLUSIONS:**

- **Composition of the data set is inadequate**
- **Root Mean Square Error (RMSE), by itself, is not meaningful/sufficient for concluding that this NDE method is qualified**

## **ISSUE #2 - BASIS FOR FLAW SPECIFIC STRUCTURAL LIMITS**

**JUNE 9, 1997 SUBMITTAL**

Utilizes different structural limits than those previously submitted to the NRC. The new structural limits are flaw specific and less conservative.

### **ISSUE**

More detailed information must be submitted for the NRC staff to review and understand the basis for the revised limits.

## **ISSUE #3 - QUALIFICATION FOR DEPTH SIZING PITS**

**QUALIFICATION DATA SET - Consists of:**

- samples did not have Electrosleeves installed

**WHAT IS THE BASIS FOR THIS, CONSIDERING:**

- Potential NDE variability due to different thickness
- Potential NDE variability due to different materials
- Other potential NDE variabilities



#### **ISSUE #4 - IDENTIFICATION OF STRUCTURALLY SIGNIFICANT FLAWS IN PARENT TUBE**

Within the Electrosleeved area, there are sections where the parent tube is the pressure boundary and the sleeve condition is inconsequential.

Actual flaw data is not available that proves that structurally significant flaws can be identified with reasonable confidence.

- EDM Notch Data Set - does not contain real flaws
- Field SCC samples - do not contain structurally significant flaws
- Lab grown SCC samples - do not contain a range of flaw depths

#### **ISSUE #5 - APPLICABILITY OF EXPANSION/TRANSITION DATA SET TO OTHER REGIONS IN A STEAM GENERATOR TUBE**

Data set used to qualify depth sizing of cracks contained cracks in the expansion transition region.

What is the applicability of this data set to other tube locations or tube conditions? (i.e., dented tube support plate intersections, OD deposits, etc.)

## OVERALL CONCLUSIONS

- Significant NDE questions remain unanswered
- Answers to above issues are considered essential for the staff to conclude its review

# ELECTROSLEEVE

