



Point Beach Nuclear Plant
6610 Nuclear Rd., Two Rivers, WI 54241

(920) 755-2321

NPL 98-0187

March 16, 1998

Document Control Desk
U.S. NUCLEAR REGULATORY COMMISSION
Mail Station P1-137
Washington, D. C. 20555

Ladies/Gentlemen:

DOCKETS 50-266 AND 50-301
LICENSEE EVENT REPORT 98-010-00
INADEQUATE TECHNICAL SPECIFICATIONS
SURVEILLANCE OF CONTAINMENT SPRAY LOGIC
POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

Enclosed is Licensee Event Report 98-010-00 for Point Beach Nuclear Plant, Units 1 and 2. This report is provided in accordance with 10 CFR 50.73(a)(2)(i)(B), "Any operation or condition prohibited by the plant's Technical Specifications." This report describes the discovery that Technical Specification surveillance of the containment spray logic was not adequate.

New commitments within the report are indicated in italics.

If you require additional information, please contact us.

Sincerely,

A handwritten signature in black ink, appearing to read 'Douglas F. Johnson'.

Douglas F. Johnson
Manager,
Regulatory Services & Licensing

Attachment

cc: NRC Resident Inspector
NRC Regional Administrator
NRC Project Manager
INPO Support Services

9803300421 980316
PDR ADOCK 05000266
S PDR

IF22/1

000033