



UPPD

Omaha Public Power District
444 South 16th Street Mall
Omaha NE 68102-2247

October 3, 1997
LIC-97-0156

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station Pi-137
Washington, DC 20555

Reference: Docket No. 50-285

SUBJECT: Application for Amendment of Operating License

Enclosed please find Omaha Public Power District's (OPPD) "Application for Amendment of Operating License" which seeks to amend the Fort Calhoun Station Unit No. 1 Technical Specifications (TS). The changes requested will revise the TS surveillance 3.9, "Auxiliary Feedwater System," to clarify what flow paths are required to be tested. Additionally, OPPD proposes to revise the Auxiliary Feedwater pumps' surveillance requirements to delete the specific discharge pressure. OPPD respectfully requests 30 days after approval to implement the proposed specifications.

Attachment A contains a markup reflecting the requested changes of the Technical Specifications. Attachment B provides the "Discussion, Justification and No Significant Hazards Consideration."

1/1

ADD 1

9710100210 971003
PDR ADOCK 05000285
P PDR



U. S. Nuclear Regulatory Commission
LIC-97-C155
Page 2

If you have additional questions, or require further information, please do not hesitate to contact me or members of my staff.

Sincerely,

W. G. Gates

W. G. Gates
Vice President

WGG/mle

Attachments

c: Winston & Strawn
E. W. Merschoff, NRC Regional Administrator, Region IV
L. R. Wharton, NRC Project Manager
W. C. Walker, NRC Senior Resident Inspector
B. E. Casari, Director - Environmental Health Division,
State of Nebraska

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)
)
Omaha Public Power District) Docket No. 50-285
(Fort Calhoun Station)
Unit No. 1))

AFFIDAVIT

W. G. Gates, being duly sworn, hereby deposes and says that he is the Vice President in charge of all nuclear activities of the Omaha Public Power District; that as such he is duly authorized to sign and file with the Nuclear Regulatory Commission the attached information concerning the Application for Amendment dated September 25, 1997 concerning revisions to Technical Specification 3.9, "Auxiliary Feedwater System," to clarify what flow paths are required to be tested, and delete the specific discharge pressure; that he is familiar with the content thereof; and that the matters set forth therein are true and correct to the best of his knowledge, information, and belief.

W. G. Gates

W. G. Gates
Vice President

STATE OF NEBRASKA)

) ss

COUNTY OF DOUGLAS)

Subscribed and sworn to before me, a Notary Public in and for the State of Nebraska on this 3rd day of October, 1997.

Julie B. Kuhr
Notary Public

