

WOLF CREEK

NUCLEAR OPERATING CORPORATION

Clay C. Warren
Chief Operating Officer

August 6, 1997

WO 97-0058

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, D. C. 20555

Subject: Docket No. 50-482: Proposed Revision to Wolf
Creek Generating Station Radiological Emergency
Response Plan


Gentlemen:

This letter transmits a proposed revision to the Wolf Creek Generating Station Radiological Emergency Response Plan (RERP). This revision is a comprehensive rewrite of the RERP and a conversion to the standard Wolf Creek Nuclear Operating Corporation (WCNOC) procedure format. WCNOC has evaluated the proposed change, pursuant to 10 CFR 50.54(q), and determined that certain items included in the proposed change may constitute a reduction in effectiveness of the plan. WCNOC requests NRC approval of this proposed change by December 19, 1997, to support our current implementation schedule.

Enclosure 1 identifies changes, based on our evaluation, that require NRC approval prior to implementation. Enclosure 2 provides an evaluation of the proposed changes in accordance with 10 CFR 50.54(q) and a summary of those changes. Enclosure 3 provides the change summary for this revision. Enclosure 4 provides the full text of the proposed revision to the RERP.

If you have any questions regarding this proposed change please contact me at (316) 364-8831, extension 4485, or Mr. Richard D. Flannigan at extension 4500.

Very truly yours,



Clay C. Warren

CCW/jad

120036

- Enclosure 1: Changes for NRC Review
- Enclosure 2: Evaluation and Disposition of Proposed Changes
- Enclosure 3: Change Summary for RERP Change to AP 06-002, "Radiological Emergency Response Plan"
- Enclosure 4: Proposed Radiological Emergency Response Plan

cc: W. D. Johnson (NRC), w/e
E. W. Merschoff (NRC), w/e
J. F. Ringwald (NRC), w/e
J. C. Stone (NRC), w/e



Adams

9708130210 970806
PDR ADOCK 05000482
F PDR

Burlington, KS 66839 / Phone: (316) 364-8831
Equal Opportunity Employer M/F/H/V

ENCLOSURE 1

TO WCNOC LETTER

WO 97-0058

CHANGES FOR NRC REVIEW

The Wolf Creek Generating Station (WCGS) Radiological Emergency Response Plan (RERP) has been upgraded to the new procedure format. The RERP will be an Administrative Procedure (AP) and will meet the format requirements of the WCGS procedure writer's guide. Redundant information located in two or more sections of the RERP has been entered in only one location in the new AP. Some items were changed and should be reviewed by the NRC for approval. The following is a list of the items WCGS is requesting to be reviewed and approved by the NRC.

1. In section 1.0, Normal Operating Organization, of the old plan, positions not required by NUREG-065, Table B-1, have been removed from the plan. These support roles are still used as needed to enhance facility performance. These positions, if not staffed, will not affect the activation of an emergency facility. The following is a list of the positions removed:

- Step 1.2.2.1, Operations Assessment Coordinator.
- Step 1.2.2.1.1, Operations Status Board Recorder.
- Step 1.2.3.1.1, Field Team Communicator.
- Step 1.2.3.2.2, Radiological Status Board Recorder.
- Step 1.2.4.2, Accountability Clerk.
- Step 1.2.6, TSC Clerk.
- Step 1.2.9.4, Warehouse Support.
- Step 1.3.1.1, Technical Logkeeper.
- Step 1.3.3.1.1, EOF Field Team Communicator.
- Step EOF Operations Status Board Recorder.
- Step 1.3.5.2, EOF Administrative Assistant.
- Step 1.3.6.1.2, Media Center Registrar.
- Step 1.3.6.1.3, Audio/Visual Support.
- Step 1.3.6.2.1, Information Clearinghouse Administrative Assistant.
- Step 1.3.6.3.1, Phone Team.
- Step 1.3.6.4.1, Media Monitoring Team.

Positions required for Emergency Facility activation, as suggested by NUREG-0654, Table B-1, are covered in the new AP in the following steps:

- Step 6.5, Control Room Organization.
- Step 6.6, Technical Support Center Organization.
- Step 6.7, Operations Support Center Organization.
- Step 6.8, Emergency Operations Facility Organization.
- Step 6.9, Public Information Organization.

2. In Section 2.0, the facility activation times have changed. The TSC has changed from activation in 30 minutes during normal working hours and 60 minutes during off normal working hours to a goal of 75 minutes for all times to activate the TSC. The EOF has changed to a goal of 90 minutes. These activation times were covered in the following:
 - Old step 4.1.1.2 for the TSC to new step 6.6.1.
 - Old step 4.1.1.3 for the EOF to new step 6.8.1.
3. Positions in RERP Table 1.1-1 were eliminated when to make required positions consistent with those recommended in NUREG-0654. The number of Health Physics personnel required at various times was also change to more accurately reflect requirements of NUREG-0654. The table was changed to Attachment D.

ENCLOSURE 2

TO WCNOC LETTER

WO 97-0058

EVALUATION AND DISPOSITION
OF PROPOSED CHANGE

EVALUATION AND DISPOSITION OF PROPOSED CHANGE

Page 1 of 2

The Radiological Emergency Response Plan (RERP) has been completely restructured, putting this document into the format of an Administrative Procedure, which conforms to the format of the WCGS procedure writer's guide. The major changes to the content of the RERP are as follows:

- A. The positions required to activate the Technical Support Center (TSC) were modified to allow activation when the TSC becomes capable of assuming the major functions from the Control Room. The TSC becomes fully functional when all positions have been staffed. This will allow for a timely transition of major functions from the Control Room, allowing the Control Room to focus on plant conditions requiring immediate attention.
- B. The activation time for the TSC has been modified to a goal of 75 minutes from the declaration of an ALERT.
- C. The activation time for the Emergency Operations Facility (EOF) has been modified to a goal of 90 minutes from the declaration of a Site Area Emergency or General Emergency.
- D. Moved the Emergency Action Levels (EALs) from a table within the body of the RERP to a form controlled by the RERP. This change also includes a commitment to ensure that a Unreviewed Safety Question Determination (USQD) is performed on the EALs, as is currently required.

The following areas of the RERP have been effected:

This change effects the primary responsibilities described in the Emergency Plan in that positions which cover the functional areas of the emergency as listed in Table B-1 of NUREG-0654 are covered. However, those positions which have a minor support role and do not affect the activation of the emergency facilities have been removed. The plan will more accurately reflect the positions required to activate emergency facilities. Steps have been placed in the plan to allow for positions not recommended by Table B.1 to be used to enhance performance in the emergency facilities. This change should not reduce the overall effectiveness of the plan because it does not affect the key functions of the emergency facility and allows for changes within the Emergency Response Organization (ERO) as better methods and means are available for conducting these minor support roles without having to make a change. However, NRC approval should be received before implementation. Positions in RERP Table 1.1-1 were eliminated to make required positions consistent with those recommended in NUREG-0654. The number of Health Physics personnel required at various times was also changed to more accurately reflect requirements of NUREG-0654. The table was changed to Attachment D. This item should be reviewed by the NRC.

The Emergency Action Level (EAL) flow charts have not been changed. However, to be consistent with the format of the WCGS procedure writer's guide, they have been made into a form. A commitment was added to the RERP to ensure that a USQD is performed for all EAL changes. This is not a reduction in the effectiveness of the plan since the same review and approval process is retained and no changes were made to the EALs themselves.

The immediate notification form was not changed. A description of the general information which must be provided was moved and is described in the actions for the Shift Supervisor, Duty Emergency Director, and Duty Emergency Manager. This form can not be changed without concurrence of the State and County. This is not a reduction in the effectiveness of the plan.

Several tables were removed from the supplements which describe Hotel and School locations and capacities and information describing how evacuation time estimates are calculated. This change does not affect protective action recommendations. Coffey County is responsible for this information and it is contained in the county emergency plan. This is not a reduction in the effectiveness of the plan.

The current revision of the RERP states that a Health Physics Technician (HP) will travel in the ambulance. It is also stated that if a HP does not travel in the ambulance, personnel qualified in contamination control will accompany the victim and an HP will arrive at the hospital. To clarify this inconsistency, the initial statement indicating an HP would travel with the ambulance, is removed. This is not a reduction in the effectiveness of the plan.

The description of the exercise cycle was changed from 5 years to 6 years. However, this change is being made to be consistent with the NRC inspection cycle and therefore this is not a reduction in the effectiveness of the plan.

This activation times for the TSC and EOF described in the RERP have changed. The activation times for the TSC have been changed from 30 minutes during normal working hours and 60 minutes during off normal hours to a goal of 75 minutes during all times, and the activation time for the EOF has been changed to a goal of 90 minutes. The times have been changed to give personnel responding to an emergency a more realistic time to respond after normal working hours or if responding from the Learning Center to the site during normal working hours. The major population areas for people responding to emergency facilities include Emporia, Kansas and Ottawa, Kansas. The driving distance to the WCGS site from Emporia, Kansas is approximately 45 miles and the driving distance to the WCGS site from Ottawa, Kansas is approximately 50 miles. The establishment of the activation times as goals allows for the consideration of adverse weather or other conditions which may affect response times. Present requirements may lead personnel to respond in an unsafe manner to meet the requirements for activation. Due to changing requirements for the time to activate an emergency facility, the requirement for having an offsite team deployed within one hour from the declaration of an ALERT has been modified. Under the responsibility of the Dose Assessment Coordinator (DAC) and the Radiological Assessment Supervisor (RAS) a statement was added to have it be a priority in getting the off-site monitoring teams dispatched. The changes in activation times are considered a reduction in the effectiveness of the plan. Therefore, NRC approval is necessary before implementation.

The enclosed change summary provides a detailed description of all changes.

ENCLOSURE 3

TO WCNOC LETTER

WO 97-0058

CHANGE SUMMARY FOR RERP CHANGE TO AP 06-002
"RADIOLOGICAL EMERGENCY RESPONSE PLAN"

CHANGE SUMMARY FOR RERP CHANGE TO
 AP 06-002, "RADIOLOGICAL EMERGENCY RESPONSE PLAN"

The RERP has been changed to an Administrative Procedure (AP) to be consistent with procedures used at Wolf Creek Generating Station (WCGS). The format of the AP makes the procedure easier to use because of the layout of information. During the change to the AP format the same information is being conveyed, but some of the wording was changed to make the directions easier and to meet WCGS writer's guide format. Information which was contained in several sections of the old plan was placed in one section of the new AP. This should eliminate contradicting statements due to making changes to information in one section but not to other sections containing the same information. When information contained in several sections was placed in one location, some of the old RERP paragraphs containing the same information were deleted. Information in the new AP is easier to find since it is better identified in the Table Of Contents. The table shown below is a cross-reference of the changes made from the RERP to the new AP. Some of the reasons for changes are listed as being editorial enhancement to make the section/step easier to read and understand due to the above mentioned reasons. Several positions were removed from the text of the RERP, but not from the Emergency Plan Organization. This was done to make the PERP more closely aligned with statutory requirements and guidance.

| Step | Description | Reason for Change |
|--------------------------|--|--|
| ALL | Changed RERP into new Administrative Procedure (AP) format. Made wording changes to improve readability. | The new format is easier to use and information should be in only one location, thus decreasing the chance to miss changing all the information during a revision. |
| Section 0.0 | Deleted all of the section. | This is a summary and the new AP does not have a summary section. The information in this section is covered in the body of the new AP. |
| Section 1.0, step 1.1 | Paragraph 1 captured in step 2.5 of AP. | Step 2.5 is under the scope section and covers the organization and its functions. |
| | Paragraph 2 captured in step 6.5.1-1. | The Figure is now Figure 2 and covered under the Control Room organization. |
| | Paragraph 3 captured in step 2.5. Vice-President Plant Operations has been changed to Plant Manager. | Step 2.5 is under the scope section and covers the organization and its functions. Changed VP Plant Ops due to title change. |
| | Paragraph 4 captured in step 6.5. | Step 6.5 is Control Room organization. Minor changes to wording to read better. |
| | Paragraph 5 captured in step 6.5.1-1. | Wording format changed to read better. |
| | Paragraph 6 captured in step 6.5.1-1 and 6.5.5. | Both steps together contain the subject matter of this paragraph. |
| | Paragraph 7 captured in step 6.6. Changed time to respond to "a goal to activate the TSC within 75 minutes of an Alert." | Step 6.6 is TSC organization. Minor changes to wording to improve readability. Time changed to a goal to allow for a more realistic time for personnel to respond from home. The major population areas, for people responding to this facility include Emporia and Ottawa. Increasing the amount of time to a goal of 75 minutes provides a more realistic amount of time for personnel to safely report from home. |

CHANGE SUMMARY FOR RERP CHANGE TO
 AP 06-002, "RADIOLOGICAL EMERGENCY RESPONSE PLAN"

| Step | Description | Reason for Change |
|-----------|--|--|
| 1.2 | Paragraph 1 deleted. | This paragraph was deleted since other steps involving the organization covers it. |
| | Paragraph 2 captured in step 6.6.5. Removed the VP Plant Operations. | Step 2.5 discusses the management organization and step 6.6.5 covers the DED position. |
| | Paragraph 3 captured in step 6.6.5-2. | Step 6.6.5-2 covers the transfer of duties from the SS to the DED. |
| 1.2.1 | Paragraph 1 captured in steps 6.6, 6.5, 6.8, & 6.5.2. | This paragraph is covered by several steps under each position or subject. |
| | Paragraph 2 captured in step 6.5.2 and substeps. | Step 6.5.2 covers the position of the SS. |
| | Paragraph 3 captured in step 6.6.5 and substeps. | Step 6.6.5 covers the position of the DED. |
| 1.2.1 | Paragraph 4 captured in step 6.6.5-4. | Step 6.6.5-4 lists the non-transferable duties of the DED. |
| 1.2.2 | Captured in step 6.6.6. | Step 6.6.6 covers the position of the OEC. |
| 1.2.2.1 | The OAC title was deleted. | This position is not addressed by NUREG-0654, Table B-1. Failure to staff this position will not prevent the activation of the facility. RERP step 6.6.18 allows for additional personnel if needed. The responsibilities for this function are described in the EPPs. |
| 1.2.2.1.1 | The Operations Status Board Recorded title was deleted. | This position is not addressed by NUREG-0654, Table B-1. Failure to staff this position will not prevent the activation of the facility. RERP step 6.6.18 allows for additional personnel if needed. The responsibilities for this function are described in the EPPs. |
| 1.2.2.2 | Captured in step 6.6.7. | Step 6.6.7 covers this position. |
| 1.2.2.2.1 | Captured in step 6.6.8. | Step 6.6.8 covers this position. |
| 1.2.2.3 | Captured in step 6.6.9. | Step 6.6.9 covers this position. |
| 1.2.3 | Captured in step 6.6.10. | Step 6.6.10 covers this position. |
| 1.2.3.1 | Captured in step 6.6.15. | Step 6.6.15 covers this position. |
| 1.2.3.1.1 | The Field Team Communicator title was deleted. | This position is not addressed by NUREG-0654, Table B-1. Failure to staff this position will not prevent the activation of the facility. RERP step 6.6.18 allows for additional personnel if needed. The responsibilities for this function are described in the EPPs. |
| 1.2.3.2 | Captured in step 6.6.11. | Step 6.6.11 covers this position. |
| 1.2.3.2.1 | Captured in step 6.6.13. | Step 6.6.13 covers this position. |
| 1.2.3.2.2 | The Radiological Status Board Recorder title was deleted. | This position is not addressed by NUREG-0654, Table B-1. Failure to staff this position will not prevent the activation of the facility. RERP step 6.6.18 allows for additional personnel if needed. The responsibilities for this function are described in the EPPs. |
| 1.2.3.3 | Captured in step 6.6.12. | Step 6.6.12 covers this position. |
| 1.2.4 | Captured in step 6.6.14. | Step 6.6.14 covers this position. |
| 1.2.4.1 | Captured in step 6.6.16. | Step 6.6.16 covers this position. |

CHANGE SUMMARY FOR RERP CHANGE TO
 AP 06-002, "RADIOLOGICAL EMERGENCY RESPONSE PLAN"

| Step | Description | Reason for Change |
|---------|---|---|
| 1.2.4.2 | The Accountability Clerk title was deleted. | This position is not addressed by NUREG-0654, Table B-1. Failure to staff this position will not prevent the activation of the facility. RERP step 6.6.18 allows for additional personnel if needed. The responsibilities for this function are described in the EPPs. |
| 1.2.5 | Captured in step 6.6.17. | Step 6.6.17 covers this position. |
| 1.2.6 | The TSC Clerk title was deleted. | This position is not addressed by NUREG-0654, Table B-1. Failure to staff this position will not prevent the activation of the facility. RERP step 6.6.18 allows for additional personnel if needed. The responsibilities for this function are described in the EPPs. |
| 1.2.7 | Captured in step 6.9.2. | Step 6.9.2 covers this position. |
| 1.2.8 | Deleted step. | This position has been deleted. |
| 1.2.9 | Captured in step 6.7.1. | Step 6.7.1 covers this position. |
| 1.2.9.1 | Captured in step 6.7.2. | Step 6.7.2 covers this position. |
| 1.2.9.2 | Captured in step 6.7.2. | Step 6.7.2 covers this position. |
| 1.2.9.3 | Captured in step 6.7.2. | Step 6.7.2 covers this position. |
| 1.2.9.4 | The Warehouse Support title was deleted. | This position is not addressed by NUREG-0654, Table B-1. Failure to staff this position will not prevent the activation of the facility. RERP step 6.6.18 allows for additional personnel if needed. The responsibilities for this function are described in the EPPs. |
| 1.2.10 | Deleted. | Deleted due to the Table being deleted. |
| 1.3 | Deleted. | This step provided general information. Details of positions called for in the plan are covered in sections 6.5 through 6.9 |
| 1.3.1 | Captured in step 6.8.1, 6.8.2-2, & 6.8.2-3. Changed the activation time to "a goal to be activated within 90 minutes of a declaration of an SAE or GE". | Step 6.8.1 and 6.8.2 covers the DEM position and duties. Time changed to a goal to allow for times when severe weather may not allow for normal response times, for personnel responding from home. The major population areas, for people responding to this facility include Topeka and Olathe. Changing the response time to a goal of 90 minutes provides an allowance when conditions prevent personnel from reporting safely from home in ninety minutes. |
| 1.3.1.1 | The Technical Logkeeper title was deleted. | This position is not addressed by NUREG-0654, Table B-1. Failure to staff this position will not prevent the activation of the facility. RERP step 6.8.14 allows for additional personnel if needed. The responsibilities for this function are described in the EPPs. |
| 1.3.2 | Captured in step 6.9.3. | Step 6.9.3 covers this position. |
| 1.3.3 | Captured in steps 6.8.3 & 6.8.3-1. | Step 6.8.3 covers this position. |

CHANGE SUMMARY FOR RERP CHANGE TO
 AP 06-002, "RADIOLOGICAL EMERGENCY RESPONSE PLAN"

| Step | Description | Reason for Change |
|-----------|---|--|
| 1.3.3.1 | Captured in step 6.8.4. | Step 6.8.4 covers this position. |
| 1.3.3.1.1 | The EOF Field Team Communicator title was deleted. | This position is not addressed by NUREG-0654, Table B-1. Failure to staff this position will not prevent the activation of the facility. RERP step 6.8.14 allows for additional personnel if needed. The responsibilities for this function are described in the EPPs. |
| 1.3.3.1.2 | Captured in step 6.8.5. | Step 6.8.5 covers this position. |
| 1.3.3.2 | Captured in step 6.8.6. | Step 6.8.6 covers this position. |
| 1.3.3.2.1 | Captured in step 6.8.7. | Step 6.8.7 covers this position. |
| 1.3.3.3 | Captured in step 6.8.8. | Step 6.8.8 covers this position. |
| 1.3.4 | Captured in step 6.8.9. | Step 6.8.9 covers this position. |
| 1.3.4.1 | The EOF Ops Status Recorder title was deleted. | This position is not addressed by NUREG-0654, Table B-1. Failure to staff this position will not prevent the activation of the facility. RERP step 6.8.14 allows for additional personnel if needed. The responsibilities for this function are described in the EPPs. |
| 1.3.4.2 | Captured in step 6.8.10. | Step 6.8.10 covers this position. |
| 1.3.5 | Captured in step 6.8.11. | Step 6.8.11 covers this position. |
| 1.3.5.1 | Captured in step 6.8.13. | Step 6.8.13 covers this position. |
| 1.3.5.2 | The EOF Administrative Assistant title was deleted. | This position is not addressed by NUREG-0654, Table B-1. Failure to staff this position will not prevent the activation of the facility. RERP step 6.8.14 allows for additional personnel if needed. The responsibilities for this function are described in the EPPs. |
| 1.3.5.3 | Captured in step 6.8.12. | Step 6.8.12 covers this position. |
| 1.3.6 | Captured in step 6.9.1. | Step 6.9.1 covers this position. |
| 1.3.6.1 | Captured in step 6.9.4. | Step 6.9.4 covers this position. |
| 1.3.6.1.1 | Captured in step 6.9.5. | Step 6.9.5 covers this position. |
| 1.3.6.1.2 | The Media Center Registrar title was deleted. | This position is not addressed by NUREG-0654, Table B-1. Failure to staff this position will not prevent the activation of the facility. RERP step 6.9.11 allows for additional personnel if needed. The responsibilities for this function are described in the EPPs. |
| 1.3.6.1.3 | The Audio/Visual Support title was deleted. | This position is not addressed by NUREG-0654, Table B-1. Failure to staff this position will not prevent the activation of the facility. RERP step 6.9.11 allows for additional personnel if needed. The responsibilities for this function are described in the EPPs. |
| 1.3.6.2 | Captured in step 6.9.6. | Step 6.9.6 covers this position. |
| 1.3.6.2.1 | The Information Clearinghouse Administrative Assistant title was deleted. | This position is not addressed by NUREG-0654, Table B-1. Failure to staff this position will not prevent the activation of the facility. RERP step 6.9.11 allows for additional personnel if needed. The responsibilities for this function are described in the EPPs. |

CHANGE SUMMARY FOR RERP CHANGE TO
 AP 06-002, "RADIOLOGICAL EMERGENCY RESPONSE PLAN"

| Step | Description | Reason for Change |
|-----------|--|---|
| 1.3.6.3 | Captured in step 6.9.7. | Step 6.9.7 covers this position. |
| 1.3.6.3.1 | The Phone Team title was deleted. | This position is not addressed by NUREG-0654, Table B-1. Failure to staff this position will not prevent the activation of the facility. RERP step 6.9.11 allows for additional personnel if needed. The responsibilities for this function are described in the EPPs. |
| 1.3.6.4 | Captured in step 6.9.8. | Step 6.9.8 covers this position. |
| 1.3.6.4.1 | The Media Monitoring Team title was deleted. | This position is not addressed by NUREG-0654, Table B-1. Failure to staff this position will not prevent the activation of the facility. RERP step 6.9.11 allows for additional personnel if needed. The responsibilities for this function are described in the EPPs. |
| 1.3.6.5 | Captured in step 6.9.9. | Step 6.9.9 covers this position. |
| 1.3.6.6 | Captured in step 6.9.10. | Step 6.9.10 covers this position. |
| 1.3.7 | Captured in step 6.5.3-1a. | Step 6.5.3-1a covers this position. |
| 1.4.1 | Paragraph 1 captured in step 6.10.1 & 6.10.2. Paragraph 2 captured in step 6.11.1 & 6.4.7-2. Paragraph 3 captured in step 6.3.3. Paragraph 4 captured in step 6.5.2, 6.6.5, & 6.8.2. Paragraph 5 captured in step 6.5.2. | Paragraphs captured as stated with minor word changes for better readability. |
| 1.4.1.1 | Paragraph 1 captured in step 6.10.1. Paragraph 2 captured in step 4.19, 6.5.2, 6.6.5-3, & 6.8.2-2g. Paragraph 3 deleted. | The County Plan is covered by this step. Added immediate notification to definition Section (4.19) and the covered the subject in the SS, DED, & DEM position steps. Paragraph does not fit the format of the AP and duties are covered in other steps of the AP. |
| 1.4.1.1.1 | Paragraph 1 captured in step 6.10.2. Paragraph 2 captured in step 6.10.2 & 6.10.3. Paragraph 3 captured in step 6.10.2 & 6.10.3-3. | Step 6.10.2 covers this position. Steps 6.10.2 & 6.10.3 covers this position. Steps 6.10.2 & 6.10.3-3 covers this position. |
| 1.4.1.1.2 | Captured in step 6.10.3. | Step 6.10.3 covers this position. |
| 1.4.1.1.3 | Captured in 6.10.4, deleted substeps. | Step 6.10.4 covers this position. |
| 1.4.1.2 | Captured in step 6.11.2. | Step 6.11.2 covers this position. |
| 1.4.1.2.1 | Captured in step 6.11.3. | Step 6.11.3 covers this position. |
| 1.4.1.2.2 | Captured in step 6.11.4. | Step 6.11.4 covers this position. |
| 1.4.1.2.3 | Captured in step 6.11.5. | Step 6.11.5 covers this position. |
| 1.4.1.2.4 | Captured in step 6.11.6. | Step 6.11.6 covers this position. |
| 1.4.1.2.5 | Captured in step 6.11.7. | Step 6.11.7 covers this position. |
| 1.4.1.3 | Paragraph 1 captured in step 6.12.1. Paragraph 2 captured in step 6.12.2. Paragraph 3 captured in step 6.12.5. | Step 6.12.1 covers this position. Step 6.12.2 covers this position. Step 6.12.5 covers this position. |
| 1.4.1.3.1 | Captured in step 6.12.3. | Step 6.12.3 covers this position. |
| 1.4.1.3.2 | Captured in step 6.12.4. | Step 6.12.4 covers this position. |
| 1.4.2.1 | Captured in step 6.10.5-2. | Step 6.10.5-2 covers this position. |

CHANGE SUMMARY FOR RERP CHANGE TO
AP 06-002, "RADIOLOGICAL EMERGENCY RESPONSE PLAN"

| Step | Description | Reason for Change |
|-----------------------|---|---|
| 1.4.2.2 | Captured in step 6.10.5-3. | Step 6.10.5-3 covers this position. |
| 1.4.2.3 | Captured in step 6.10.5-7. | Step 6.10.5-7 cover* this position. |
| 1.4.2.4 | Captured in step 6.10.5-6. | Step 6.10.5-6 covers this position. |
| 1.4.3.1 | Paragraph 1 captured in step 6.13.1. | Step 6.13.1 covers this position. |
| | Paragraph 2 deleted. | Step 6.8.2-2 covers this subject. |
| | Paragraph 3 captured in step 6.8.2-2. | Step 6.8.2-2 covers this position. |
| 1.4.3.2 | Captured in step 6.13.2. | Step 6.13.2 covers this position. |
| 1.4.3.3 | Captured in step 6.13.3. | Step 6.13.3 covers this position. |
| 1.4.3.4 | Captured in step 6.13.4. | Step 6.13.4 covers this position. |
| Table 1.1-1 | Captured in Attachment D | Table change to an Attachment in the AP. |
| Table 1.2-1 | Deleted | Responsibilities are covered in the steps for each position. |
| Table 1.2-2 | Deleted | Responsibilities are covered in the steps for each position. |
| Table 1.2-3 | Deleted | Responsibilities are covered in the steps for each position. |
| Table 1.4-1 | Captured in Attachment H | Table change to an Attachment in the AP. |
| Figure 1.1-2 | Captured in Figure 2 | Table change to a Figure in the AP. |
| Figure 1.2-2 | Captured in Figure 3 | Table change to a Figure in the AP. |
| Figure 1.2-4 | Captured in Figure 4 | Table change to a Figure in the AP. |
| Figure 1.2-5 | Captured in Figure 5 | Table change to a Figure in the AP. |
| Figure 1.3-2 | Captured in Figure 6 | Table change to a Figure in the AP. |
| Section 2.0, step 2.1 | Captured in steps 6.2.2 & 6.2.3. | Steps cover the subject. Extra wording deleted as an editorial enhancement to make the section/step easier to read and understand. |
| 2.2 | Paragraph 1 captured in step 6.2.4. Substeps and rest deleted. | Step 6.2.4 covers the subject. The substeps were deleted as an editorial enhancement to make the section/step easier to read and understand. |
| 2.2.1 | Title and paragraph 1 captured in step 4.23 & 4.23.1. Paragraph 2 deleted. | This step was moved to the definition section. The Explanations/Bases for the EALs contain the reasons and methods for declaring an emergency, so the last paragraph was deleted. |
| 2.2.2 | Title and paragraph 1 captured in step 4.3 & 4.3.1. Paragraph 2 deleted. | This step was moved to the definition section. The Explanations/Bases for the EALs contain the reasons and methods for declaring an emergency, so the last paragraph was deleted. |
| 2.2.3 | Title and paragraph 1 captured in step 4.31 & 4.31.1. Paragraph 2 deleted. | This step was moved to the definition section. The Explanations/Bases for the EALs contain the reasons and methods for declaring an emergency, so the last paragraph was deleted. |
| 2.2.4 | Title and paragraph 1 captured in step 4.18 & 4.18.1. Paragraph 2 deleted. | This step was moved to the definition section. The Explanations/Bases for the EALs contain the reasons and methods for declaring an emergency, so the last paragraph was deleted. |

CHANGE SUMMARY FOR RERP CHANGE TO
 AP 06-002, "RADIOLOGICAL EMERGENCY RESPONSE PLAN"

| Step | Description | Reason for Change |
|-------------|--|--|
| 2.3 | Captured in step 2.6. | Step 2.6 covers the subject. Made minor changes to wording for better readability. |
| 2.4.1 | Captured in step 6.2.1. | Step 6.2.1 covers the subject. Made minor changes to wording for better readability. |
| 2.4.2 | Deleted. | Discussion of the Symptom, Event And Barrier Based Event Classification is covered in NUMARC/NESP 007 and is not needed in the plan. |
| 2.4.3 | Deleted. | Deleted due to being a Summary of the section which does not fit the Writer's Guide format. |
| Table 2.2-1 | Captured in Attachment F. | Table was changed to an Attachment. |
| Table 2.2-2 | Captured in APF 06-002-01, EMERGENCY ACTION LEVELS | Table was placed in a form covered by the new AP. |
| Section 3.0 | Paragraph 1 captured in step 6.3.1. | Subject covered in indicated step with wording changed for better readability. |
| | Paragraph 2 captured in steps 6.3.2 & 6.3.3-1. | |
| 3.1.1 | Deleted. | Deleted as an editorial enhancement to make the section/step easier to read and understand. |
| 3.1.2 | Paragraph 1, major points captured in step 6.3.6. | Subject covered in indicated step with wording changed for better readability. |
| | Paragraph 2 captured in step 6.3.7. | |
| | Paragraph 3 captured in step 6.3.5. | |
| | Paragraph 4 captured in step 6.14.1-4. | NPIS covered by step 6.14. |
| | Paragraph 5 captured in step 6.3.6. | Subject covered in indicated step with wording changed for better readability. |
| | Paragraph 6 captured in step 6.3.7. | |
| | Paragraph 7 captured in step 6.3.7. | |
| 3.1.3 | Paragraph 1 captured in steps 6.3.7 & 6.14.1. | Subject covered in indicated steps with wording changed for better readability. |
| | Paragraph 2 captured in step 6.3.7. | |
| | Paragraph 3 captured in step 6.14.2. | |
| | Paragraph 4 captured in steps 6.1.7, 6.3.11, & 6.3.21. | |
| | Paragraph 5 covered in step 6.3.8. | |
| 3.1.4 | Paragraph 1 captured in step 6.3.19. | Subject covered in indicated step with wording changed for better readability. |
| | Paragraph 2 captured in step 6.3.19. | |
| 3.2 | Captured in section 2.0. | Subject covered in section 2.0 with wording changed for better readability. |
| 3.3 | Captured in step 6.3.1. | Subject covered in step 6.3.1 with wording changed for better readability. |
| 3.3.1 | Captured in step 6.3.1, 6.3.10 & 6.3.11. | Subject covered in steps indicated with wording changed for better readability. |

CHANGE SUMMARY FOR RERP CHANGE TO
 AP 06-002, "RADIOLOGICAL EMERGENCY RESPONSE PLAN"

| Step | Description | Reason for Change |
|-------------------------|---|--|
| 3.3.1.1 | Captured in step 6.3.9, 6.3.10 & 6.3.11 | Subject covered in steps indicated with wording changed for better readability. |
| 3.3.1.2 | Captured in steps 6.3.12 & 6.3.13. | Subject covered in steps indicated with wording changed for better readability. |
| 3.3.1.3 | Captured in steps 6.3.14, 6.3.15, 6.3.16, 6.3.17, 6.3.18, & 6.3.19. | Subject covered in steps indicated with wording changed for better readability. |
| 3.3.1.4 | Captured in steps 6.3.20, 6.3.21, 6.3.22, & 6.6.10. | Subject covered in steps indicated with wording changed for better readability. |
| 3.3.1.5 | Captured in step 6.4.6. | Subject covered in step indicated with wording changed for better readability. |
| 3.3.1.5.1 | Captured in step 6.4.6. | Subject covered in step indicated with wording changed for better readability. |
| 3.3.1.5.2 | Captured in step 6.4.6-4 & 6.4.6-5. | Subject covered in steps indicated with wording changed for better readability. |
| 3.3.1.5.3 | Captured in step 6.10.6. | Subject covered in step indicated with wording changed for better readability. |
| 3.3.1.5.4 | Captured in step 6.10.5. | Subject covered in step indicated with wording changed for better readability. Deleted non-essential wording as an editorial enhancement to make the section/step easier to read and understand to make the section/step easier to read and understand. |
| 3.3.2 | Captured in steps 6.3.3 & 6.16.2-4. | Subject covered in steps indicated with wording changed for better readability. Deleted non-essential wording as an editorial enhancement to make the section/step easier to read and understand to make the section/step easier to read and understand. |
| Table 3.0-1 | Captured in Attachment E, page 1 | Table changed to an Attachment. |
| Table 3.0-2 | Captured in Attachment E, page 2 | Table changed to an Attachment. |
| Table 3.0-3 | Captured in Attachment E, page 2 | Table changed to an Attachment. |
| Table 3.0-4 | Captured in Attachment E, page 3 | Table changed to an Attachment. |
| Table 3.0-5 | Captured in Attachment E, page 4 | Table changed to an Attachment. |
| Section 4.0, step 4.1.1 | Deleted. | These items are covered in steps 6.4. |
| 4.1.1.1 | Captured in step 6.4.1. | Covered by step 6.4. |
| 4.1.1.2 | Captured in steps 6.4.2, 6.4.3, 6.6.1, 6.6.3, & 6.16. | Items covered by indicated steps with wording changed for better readability. |
| 4.1.1.3 | Captured in steps 6.4.4, 6.4.5, 6.8.1, 6.8.2, & 6.16. | Items covered by indicated steps with wording changed for better readability. |
| 4.1.2 | Deleted. | Items covered by other steps under facilities. |
| 4.1.2.1 | Captured in step 6.4.5-1. | Item covered by indicated step with wording changed for better readability. |

CHANGE SUMMARY FOR RERP CHANGE TO
 AP 06-002, "RADIOLOGICAL EMERGENCY RESPONSE PLAN"

| Step | Description | Reason for Change |
|-----------|--|--|
| 4.1.2.2 | Captured in step 6.4.5-3. | Item covered by indicated step with wording changed for better readability. |
| 4.1.2.3 | Captured in step 6.4.5-4. | Item covered by indicated step with wording changed for better readability. |
| 4.1.3.1 | Captured in step 6.4.7. | Item covered by indicated step with wording changed for better readability. |
| 4.1.3.2 | Captured in step 6.4.7. | Item covered by indicated step with wording changed for better readability. |
| 4.2 | Captured in step 6.16. | Items covered by indicated steps with wording changed for better readability. Deleted non-essential wording as an editorial enhancement to make the section/step easier to read and understand. Exact number of PBX circuits is not necessary information. |
| 4.2.1.1 | Captured in step 6.16.1. | |
| 4.2.1.2 | Deleted. | |
| 4.2.1.3 | Captured in step 6.16.2. | |
| 4.2.1.3.2 | Captured in step 6.16.1. | |
| 4.2.1.3.3 | Captured in step 6.16.1. | Covered by step 6.16.1. |
| 4.2.1.3.4 | Captured in step 6.16.1. | Covered by step 6.16.1. |
| 4.2.2 | 1st paragraph deleted. | Figure was deleted from earlier revision. |
| | 2nd paragraph captured in step 4.19. | Covered by step 4.19. |
| 4.2.3 | Deleted. | Does not meet writer's guide format. |
| 4.3 | Captured in step 6.4.1. | Item covered by indicated step with wording changed for better readability. |
| 4.3.1 | Paragraph 1 captured in step 6.14.1. | Items covered by indicated steps with wording changed for better readability. |
| | Paragraph 2 captured in step 6.14.1. | |
| | Paragraph 3 captured in step 6.14.1-4. | |
| | Paragraph 4 captured in step 6.14.1-5. | |
| | Paragraph 5 captured in step 6.14.1-4. | |
| 4.3.2.1 | Deleted. | Subject covered by step 2.6. |
| 4.3.2.1.1 | Captured in step 6.14.2. | Item covered by indicated step with wording changed for better readability. |
| 4.3.2.1.2 | Captured in step 6.14.2. | Item covered by indicated step with wording changed for better readability. |
| 4.3.2.1.3 | Captured in steps 6.14.2-3 & 6.3.6. | Item covered by indicated step with wording changed for better readability. |
| 4.3.2.1.4 | Captured in step 6.3.7. | Item covered by indicated step with wording changed for better readability. |

CHANGE SUMMARY FOR RERP CHANGE TO
 AP 06-002, "RADIOLOGICAL EMERGENCY RESPONSE PLAN"

| Step | Description | Reason for Change |
|---------|--|--|
| 4.3.2.2 | Paragraph 1 captured in step 6.8.3. | Item covered by indicated step with wording changed for better readability. |
| | Paragraph 2 changed due to change in notification time of TSC. Covered in step 6.6.11. | |
| | Paragraph 3 major elements covered in steps 6.3.6, 6.3.7, & 6.3.8. | |
| | Paragraph 4 captured in step 6.3.9. | |
| 4.3.3.1 | Paragraph 1 captured in step 6.14.3-1. | Items covered by indicated steps with wording changed for better readability. |
| | Paragraph 2 captured in step 6.14.3-2. | |
| | Paragraph 3 captured in step 6.14.3-3. | |
| | Paragraph 4 captured in step 6.14.3-4. | |
| | Paragraph 5 captured in step 6.14.3-5. | |
| 4.3.3.2 | Paragraph 1 covered in step 2.6. | Items covered by indicated step with wording changed for better readability. Deleted non-essential wording as an editorial enhancement to make the section/step easier to read and understand. |
| | Paragraph 2 covered in step 2.6. | |
| | Paragraph 3 covered in step 2.6. | |
| | Paragraph 4 captured in step 6.14.4. | |
| | Paragraph 5 covered in step 2.6. | |
| | Paragraph 6 covered in step 2.6. | |
| 4.3.3.3 | Captured in step 6.14.5. | Item covered by indicated step with wording changed for better readability. |
| 4.3.4 | Paragraph 1 captured in step 6.14.6-1. | Items covered by indicated step with wording changed for better readability. Deleted non-essential an wording as editorial enhancement to make the section/step easier to read and understand. |
| | Paragraph 2 covered in step 2.6. | |
| | Paragraph 3 covered in step 2.6. | |
| | Paragraph 4 captured in step 6.14.6-2. | |
| 4.3.5 | Paragraph 1 captured in step 6.14.7-1. | Items covered by indicated step with wording changed for better readability. Deleted non-essential wording as an editorial enhancement to make the section/step easier to read and understand. |
| | Paragraph 2 covered in step 2.6. | |
| | Paragraph 3 covered in step 2.6. | |
| | Paragraph 4 covered in step 2.6. | |
| | Paragraph 5 captured in step 6.14.7-2. | |
| | Paragraph 6 captured in step 6.14.7-3. | |
| 4.3.6 | Paragraph 1 captured in step 6.4.6-1, 6.4.6-2, & 6.4.6-3. | Items covered by indicated steps with wording changed for better readability. |
| | Paragraph 2 captured in step 6.4.6-4. | |

CHANGE SUMMARY FOR RERP CHANGE TO
 AP 06-002, "RADIOLOGICAL EMERGENCY RESPONSE PLAN"

| Step | Description | Reason for Change |
|--------------------------|---|--|
| 4.3.7 | Paragraph 1 captured in step 6.15.1. | Items covered by indicated steps with wording changed for better readability. |
| | Paragraph 2 captured in step 6.15.2. | |
| | Paragraph 3 captured in step 6.15.3. | |
| Table 4.1-1 | Deleted. | Facilities are discussed in Section 6.4. |
| Table 4.2-2 | Deleted. | Person in command in each facility is discussed in Organization Sections. |
| Table 4.3-1 | Deleted. | Deleted non-essential wording as an editorial enhancement to make the section/step easier to read and understand. Inventory is controlled in EPPs. |
| Figure 4.1-1 | Captured in Figure 1 & 7. | Figures placed in new AP as Figures 1 & 7 |
| Figure 4.1-2 | Captured in Figure 7. | Figures placed in new AP as Figure 7 |
| Figure 4.1-3 | Captured in Figure 8. | Figures placed in new AP as Figure 8 |
| Figure 4.1-4 | Captured in Figure 9. | Figures placed in new AP as Figure 9. |
| Figure 4.1-5 | Deleted. | Response facilities are discussed in Section 6.4 and the old figure does not show a good location for these facilities. |
| Section 5.0, step 5.1 | Paragraph 1 captured in step 6.17.1. | Items covered by indicated steps with wording changed for better readability. |
| | Paragraph 2 captured in step 6.17.2. | |
| | Paragraph 3 captured in step 6.17.6. | |
| | Paragraph 4 captured in step 6.17.3. | |
| | Paragraph 5 captured in step 6.17.4 & 6.17.5. | |
| | Paragraph 6 captured in step 6.17.4. | |
| | Paragraph 7 captured in step 6.17.2. | |
| 5.2 | Paragraph 1 captured in step 6.19.1. | Items covered by indicated step with wording changed for better readability. Deleted non-essential wording as an editorial enhancement to make the section/step easier to read and understand. |
| | Paragraph 2 deleted. | |
| | Paragraph 3 deleted. | |
| | Paragraph 4 captured in step 6.19.3. | |
| | Paragraph 5 captured in step 6.19.3. | |
| | Paragraph 6 captured in step 6.17.6. | |

CHANGE SUMMARY FOR RERP CHANGE TO
 AP 06-002, "RADIOLOGICAL EMERGENCY RESPONSE PLAN"

| Step | Description | Reason for Change |
|-------------|---|---|
| 5.2.1.1 | Captured in step 6.18.1. | Items covered by indicated steps with wording changed for better readability. |
| 5.2.1.2 | Captured in step 6.18.1. | Items covered by indicated steps with wording changed for better readability. |
| 5.2.1.3 | Captured in step 6.18.1. | Items covered by indicated steps with wording changed for better readability. |
| 5.2.1.4 | Deleted. | Deleted as an editorial enhancement to make the section/step easier to read and understand. |
| 5.2.2 | Captured in step 6.18.2. | Items covered by indicated steps with wording changed for better readability. |
| 5.2.3 | Captured in step 6.18.3. | Items covered by indicated steps with wording changed for better readability. |
| 5.2.4 | Captured in step 6.18.4 & 6.18.5. | Item covered by indicated steps with wording changed for better readability. |
| 5.2.5 | Captured in step 6.18.6. | Items covered by indicated steps with wording changed for better readability. |
| 5.2.6 | Captured in step 6.19.5. | Item covered by indicated step with wording changed for better readability. |
| 5.2.7 | Captured in step 6.19.4. | Item covered by indicated step with wording changed for better readability. |
| 5.3 | Paragraph 1 captured in step 6.20.1. | Items covered by indicated step with wording changed for better readability. Deleted non-essential wording as an editorial enhancement to make the section/step easier to read and understand |
| | Paragraph 2 captured in step 6.20.2. | |
| | Paragraph 3 deleted. | |
| 5.4.1 | Paragraph 1 captured in step 6.16.2-2. | Items covered by indicated steps with wording changed for better readability. |
| | Paragraph 2 captured in step 6.16.2-3. | |
| 5.4.2 | Paragraph 1 captured in step 6.16.2-5. | Items covered by indicated steps with wording changed for better readability. |
| | Paragraph 2 captured in step 6.16.2-6. | |
| | Paragraph 3 captured in step 6.16.2-4. | |
| | Paragraph 4 captured in step 6.3.4. | |
| 5.4.3 | Captured in step 6.16.2-1. | Item covered by indicated step with wording changed for better readability. |
| Table 5.4-1 | Deleted. | Information covered by the State and County Plans. |
| 6.1 | Captured in step 4.30. | Step 4.30 is in the definition section. |
| 6.2 | Paragraph 1 captured in steps 6.21.1, 6.21.2, & 6.21.3. | Items covered by indicated steps with wording changed for better readability. |
| | Paragraph 2 captured in step 6.21.3-3. | |
| | Paragraph 3 captured in steps 6.21.5 & 6.21.4. | |

CHANGE SUMMARY FOR RERP CHANGE TO
 AP 06-002, "RADIOLOGICAL EMERGENCY RESPONSE PLAN"

| Step | Description | Reason for Change |
|--------------------|--|---|
| 6.3 | Captured in step 6.21.1. | Item covered by indicated step with wording changed for better readability. |
| 6.3.1 | Captured in step 6.8.2 & 6.21. | Item covered by indicated step with wording changed for better readability. |
| 6.3.2 | Captured in step 6.6.5 & 6.21. | Item covered by indicated step with wording changed for better readability. |
| 6.3.3 | Captured in step 6.6.7 & 6.21. | Item covered by indicated step with wording changed for better readability. |
| 6.3.4 | Captured in step 6.8.3 & 6.21. | Item covered by indicated step with wording changed for better readability. |
| 6.3.5 | Captured in step 6.9.1 & 6.21. | Item covered by indicated step with wording changed for better readability. |
| 6.3.6 | Captured in step 6.8.11 & 6.21. | Item covered by indicated step with wording changed for better readability. |
| 6.3.7 | Captured in step 6.13.1 & 6.21. | Item covered by indicated step with wording changed for better readability. |
| 6.3.8 | Captured in step 6.13.2 & 6.21. | Item covered by indicated step with wording changed for better readability. |
| 6.4 | Captured in step 6.4.4. | Item covered by indicated step with wording changed for better readability. |
| 6.4.1 | Captured in step 6.4.2. | Item covered by indicated step with wording changed for better readability. |
| Figure 6.3-1 | Deleted. | Organization is determined by the DED or DEM for the emergency in progress. |
| Supplement AA | Captured in section 4.0. | The new AP has a definitions section. Deleted unnecessary definitions and added new ones. |
| Supplement BB | Captured in Attachment C. | Supplement changed to an Attachment. |
| Supplement CC | Captured in Attachment G. | Supplement changed to an Attachment. |
| Supplement DD, 1.1 | Deleted. | Deleted as an editorial enhancement to make the section/step easier to read and understand. |
| 1.2 | Captured in step 6.1.2. | Item covered by indicated step with wording changed for better readability. |
| 1.3 | Paragraph 1 captured in steps 6.1.3 & 6.1.6. | Items covered by indicated steps with wording changed for better readability. |
| | Paragraph 2 captured in step 6.1.6. | |
| 1.4 | Paragraph 1 captured in step 6.1.7. | Items covered by indicated steps with wording changed for better readability. |
| | Paragraph 2 captured in Figure 1. | |
| 2.0 | Captured in steps 6.1.7 & 6.3.3-1. | Items covered by indicated steps with wording changed for better readability and is covered by the County Plan. |
| 3.0 | Captured in step 6.3.3-1. | |
| 4.0 | Captured in step 6.3.3-1. | |

| Step | Description | Reason for Change |
|-------------------------|--|--|
| Table DD-1 | Captured in Attachment b, page 1. | Tables changed to Attachments. Some tables were deleted as an editorial enhancement to make the section/step easier to read and understand since the items are covered in the County Plan. |
| Table DD-2 | Deleted. | |
| Table DD-3 | Captured in Attachment B, page 2. | |
| Table DD-4 | Deleted. | |
| Table DD-5 | Deleted. | |
| Table DD-6 | Captured in Attachment B, pages 3 & 4. | |
| Table DD-7 | Captured in Attachment B, page 5. | |
| Figure DD-1 | Captured in Figure 1 | Figures placed in new AP as indicated due to requirement in Writer's Guide. |
| Figure DD-3 | Captured in Figure 1 | Figures placed in new AP as indicated due to requirement in Writer's Guide. |
| Supplement EE, step 1.1 | Deleted. | Deleted as an editorial enhancement to make the section/step easier to read and understand. |
| 1.2 | Captured in step 6.1.2. | Item covered by indicated step with wording changed for better readability. |
| 1.3 | Captured in step 6.1. | Item covered by indicated step with wording changed for better readability. |
| 1.4 | Captured in step 6.1. | Item covered by indicated step with wording changed for better readability. |
| 1.5 | Captured in step 6.1. | Item covered by indicated step with wording changed for better readability. |
| 1.6 | Captured in step 6.1.8. | Item covered by indicated step with wording changed for better readability. |
| 1.7 | Captured in step 6.1.5. | Item covered by indicated step with wording changed for better readability. |
| 2.0 | Captured in step 6.12.2. | Item covered by indicated step with wording changed for better readability. |
| 2.1 | Captured in step 6.12.2. | Item covered by indicated step with wording changed for better readability. |
| 2.2 | Captured in step 6.1 & Figure 10. | Item covered by indicated step and Figure with wording changed for better readability. |
| 2.3 | Captured in step 6.1. | Items covered by indicated steps with wording changed for better readability. |
| 3.0 | Captured in step 6.1. | Items covered by indicated steps with wording changed for better readability. |
| 4.0 | Captured in step 6.10.3. | Items covered by indicated steps with wording changed for better readability. |
| 4.1 | Deleted. | Deleted as an editorial enhancement to make the section/step easier to read and understand. |
| 4.2 | Captured in step 6.10.3. | Items covered by indicated steps with wording changed for better readability. |
| 5.0 | Deleted. | Deleted as an editorial enhancement to make the section/step easier to read and understand. |

CHANGE SUMMARY FOR RERP CHANGE TO
 AP 06-002, "RADIOLOGICAL EMERGENCY RESPONSE PLAN"

| Step | Description | Reason for Change |
|------------------|---------------------------|---|
| Figure EE-1 | Captured in Figure 1. | Figures placed in new AP as indicated due to requirement in Writer's Guide. |
| Figure EE-2 | Captured in Figure 10. | Figures placed in new AP as indicated due to requirement in Writer's Guide. |
| Supplement FF | Captured in Attachment C. | Supplement changed to an Attachment. |
| Supplement GG | Captured in Attachment C. | Supplement changed to an Attachment. |
| Supplement HH | Deleted. | Supplement contained no information of use. |

ENCLOSURE 4

TO WCNOC LETTER

WO 97-0058

PROPOSED
RADIOLOGICAL EMERGENCY RESPONSE PLAN

ENCLOSURE 4

TO WCNOC LETTER

WO 97-0058

PROPOSED
RADIOLOGICAL EMERGENCY RESPONSE PLAN