Westinghouse Non-Proprietary Class 3

Revision S

Westinghouse Setpoint Methodology for Protection Systems

Millstone Nuclear Power Station Unit 3

24 Month Full Cycle Evaluation

9710200071 971015 PDR ADOCK 05000423 WCAP-10992 Rev. 5

## WESTINGHOUSE SETPOINT METHODOLOGY FOR PROTECTION SYSTEMS

## MILLSTONE NUCLEAR POWER STATION UNIT 3

24 MONTH FUEL CYCLE EVALUATION

August 1997

T. P. Williams J. R. Reagan C. R. Tuley

WESTINGHOUSE ELECTRIC CORPORATION
Nuclear Services Division
P. O. Box 355
Pittsburgh, Pennsylvania 15230-0355

© 1997 Westinghouse Electric Corporation All Rights Reserved

## **ACKNOWLEDGEMENTS**

The authors of this report wish to acknowledge N. Bhatt, D. Asay, S. V. Andre' and M. T. Bowler for their cooperation and technical assistance throughout the Millstone Unit 3 Extended Surveillance Interval Program.

Section		Title	Page	
1.0	INTI	RODUCTION	. 1	
	1.1	References / Standards		
2.0	CON	MEINATION OF UNCERTAINTY COMPONENTS	. 3	
	2.1	Methodology		
	2.2	Sensor Allowances	. 5	
	2.3	ck Allowances	7	
	2.4	Process Allowances	. 8	
	2.5	Measurement and Test Equipment Accuracy	9	
	2.6	References / Standards	10	
3.0	PRO	TECTION SYSTEM SETPOINT METHODOLOGY	11	
	3.1	argin Calculation		
	3.2	Definitions For Protection System Setpoint Tolerances	12	
	3.3	Cross Reference - SAMA PMC 20.1-1973 and ANSI/ISA-S51.1-1979	21	
	3.4	References / Standards	22	
4.0	APP	LICATION OF THE SETPOINT METHODOLOGY	64	
	4.1	Uncertainty Calculation Basic Assumptions/Premises	64	
	4.2	Sensor/Transmitter Operability Determination Program and Criteria	66	
	4.3	Process Rack Operability Determination Program and Criteria	68	
	4.4	Application to the Plant Technical Specifications	70	
	4.5	References/Standards	72	
APPE	ENDIX	A		
	SAN	IPLE MILLSTONE UNIT 3 SETPOINT TECHNICAL SPECIFICATIONS	A-1	

Section	Title	Page
TABLE 3-1	POWER RANGE, NEUTRON FLUX - LOW & MIGH	. 23
TABLE 3-2	POWER RANGE, NEUTRON FLUX - HIGH	
	N-1 LOOP OPERATION	. 24
TABLE 3-3	POWER RANGE, NEUTRON FLUX HIGH POSITIVE	
	AND NEGATIVE RATE	. 25
TABLE 3-4	INTERMEDIATE RANGE NEUTRON FLUX	. 26
TABLE 3-5	SOURCE RANGE NEUTRON FLUX	. 27
TABLE 3-6	OVERTEMPERATURE AT (CORE BURNDOWN	
	EFFECTS) (N LOOP)	. 28
TABLE 3-7	OVERPOWER ΔT (CORE BURNDOWN EFFECTS)	
	(N LOOP)	. 30
TABLE 3-8	OVERTEMPERATURE ΔT (CORE BURNDOWN	
	EFFECTS) (N-1 LOOP)	. 32
TABLE 3-9	OVERPOWER AT (CORE BURNDOWN EFFECTS)	
	(N-1 LOOP)	. 34
TABLE 3-10	PRESSURIZER PRESSURE - LOW & HIGH	
	(ROSEMOUNT 1154GP9 TRANSMITTER)	. 36
TABLE 3-11	PRE3SURIZER PRESSURE - SI	
	(ROSEMOUNT 1154GPO TRANSMITTER)	. 37
TABLE 3-12	PRESSURIZER WATER LEVEL - HIGH	
	(VERITRAK 76DP1 TRANSMITTER)	. 38
TABLE 3-13	PRESSURIZER WATER LEVEL - HIGH	
	(ROSEMOUNT 1153HD5 TRANSMITTER)	. 39

Title	Page
STEAM GENERATOR WATER LEVEL - LOW-LOW	
	40
	. 40
	42
	42
	44
CONTAINMENT PRESSURE - HIGH 1, HIGH 2,	
HIGH 3 (ROSEMOUNT 1153AB6 TRANSMITTER)	47
STEAMLINE PRESSURE - LOW SI	
(ROSEMOUNT 1153GB9 TRANSMITTER)	. 48
NEGATIVE STEAM PRESSURE RATE - HIGH	. 49
RCS LOW FLOW (N LOOP)	
(ROSEMOUNT 1153HD5 TRANSMITTER)	. 50
RCS LOW FLOW (N-1 LOOP)	
(ROSEMOUNT 1153HD5 TRANSMITTER)	. 51
REACTOR PROTECTION SYSTEM/ENGINEERED	
SAFETY FEATURES ACTUATION SYSTEM	
CHANNEL UNCERTAINTY ALLOWANCES	54
	STEAM GENERATOR WATER LEVEL - LOW-LOW (FLB) (ROSEMOUNT 1154DH4 TRANSMITTER) STEAM GENERATOR WATER LEVEL - LOW-LOW (LONF) (ROSEMOUNT 1154DH4 TRANSMITTER) STEAM GENERATOR WATER LEVEL - HIGH-HIGH (ROSEMOUNT 1154DH4 TRANSMITTER) REACTOR COOLANT PUMP UNDERSPEED CONTAINMENT PRESSURE - HIGH 1, HIGH 2, HIGH 3 (ROSEMOUNT 1153AB6 TRANSMITTER) STEAMLINE PRESSURE - LOW SI (ROSEMOUNT 1153GB9 TRANSMITTER) NEGATIVE STEAM PRESSURE RATE - HIGH RCS LOW FLOW (N LOOP) (ROSEMOUNT 1153HD5 TRANSMITTER) RCS LOW FLOW (N-1 LOOP) (ROSEMOUNT 1153HD5 TRANSMITTER) TAVG, LOW AND LOW-LOW REACTOR PROTECTION SYSTEM/ENGINEERED SAFETY FEATURES ACTUATION SYSTEM CHANNEL UNCERTAINTY ALLOWANCES

Section	Title	Page
TABLE 3-27	ΔP MEASUREMENTS EXPRESSED IN FLOW UNITS	. 61
TABLE 4-1	WESTINGHOUSE PROTECTION SYSTEM STS SETPOINT INPUTS	. 73
APPENDIX A	SAMPLE MILLSTONE UNIT 3 SETPOINT TECHNICAL SPECIFICATIONS	A-1

#### 1.0 INTRODUCTION

In Generic Letter 91-04,<sup>[1]</sup> the NRC has noted that uncertainty calculations should be performed in a manner which results in values at a high probability and a high confidence level. The implication being a requirement for a more statistically rigorous calculation. In addition, Generic Letter 91-18<sup>[2]</sup> clarifies the NRC's definition of operability. In response to these documents, Westinghouse has modified the basic uncertainty algorith 1. To address the requirements for a definitive basis for drift, explicit calculations were made to determine appropriate values for the transmitters and process racks.

The basic Westinghouse approach to an uncertainty calculation is to achieve an understanding of the plant instrumentation calibration and operability verification processes. The uncertainty algorithm resulting from this understanding can be function specific, i.e., is very likely different for two functions if their calibration or operability determination processes are different. Effort is expended in determination of what parameters are dependent statistically or functionally. Those parameters that are determined to be independent are treated accordingly. This allows the use of a Square-Root-Sum-Of-The-Squares (SRSS) summation of the various components. A direct benefit of the use of this technique is increased margin in the total allowance. For those parameters determined to be dependent, appropriation (conservative) summation techniques are utilized. An explanation of the overall approach is provided in Section 2.0.

Section 3.0 provides a description, or definition, of each of the various components, to allow a clear understanding of the methodology. Also provided is a detailed example of each setpoint margin calculation demonstrating the methodology and noting how each parameter value is utilized. In all cases, margin exists between the summation and the total allowance.

Section 4.0 provides a description of the methodology utilized in the determination of the Millstone Unit 3 Technical Specifications and an explanation of the relationship between a trip setpoint and an operability verification. An Appendix is provided noting a recommended set of Technical Specifications using the plant specific data and the revised Westinghouse approach that reflects the plant specific operability verification process.

#### 1.1 References / Standards

- [1] Generic Letter 91-04, 1991, "Changes in Technical Specification Surveillance Intervals to Accommodate a 24 Month Fuel Cycle."
- [2] Generic Letter 91-18, 1991, "Information to Licensees Regarding Two NRC Inspection Manual Sections on Resolution of Degraded and Nonconforming Conditions and on Operability."

## 2.0 COMBINATION OF UNCERTAINTY COMPONENTS

#### 2.1 Methodology

The methodology used to combine the uncertainty components for a channel is an appropriate combination of those groups which are statistically and functionally independent. Those uncertainties which are not independent are appropriately treated (or conservatively treated by arithmetic summation) and then systematically combined with the independent terms.

The basic methodology used is the SRSS technique which has been utilized in other Westinghouse reports. This technique, or others of a similar nature, has been used in WCAP-10395<sup>[1]</sup> and WCAP-8567<sup>[2]</sup>. WCAP-8567 is approved by the NRC noting acceptability of statistical techniques for the application requested. Also, various ANSI, American Nuclear Society, and Instrument Society of America (ISA) standards approve the use of probabilistic and statistical techniques in determining safety-related setpoints<sup>[3,4]</sup>. The basic methodology used in this report is essentially the same as that noted in an ISA paper presented in 1992<sup>[5]</sup>.

The relationship between the uncertainty components and the calculated uncertainty for a channel is noted in Eq. 2.1,

$$CSA = \{ (PMA)^2 + (PEA)^2 + (SMTE + SD)^2 + (SMTE + SCA)^2 + (SPE)^2 + (STE)^2 + (SRA)^2 + (RMTE + RD)^2 + (RMTE + RCA)^2 +$$

where:

CSA =Channel Statistical Allowance PMA =Process Measurement Accuracy PEA =Primary Element Accuracy =Sensor Measurement and Test Equipment Accuracy SMTE SD =Sensor Drift SCA =Sensor Calibration Accuracy SPE -Sensor Pressure Effects STE =Sensor Temperature Effects SRA =Sensor Reference Accuracy =Rack Measurement and Test Equipment Accuracy RMTE RD =Rack Drift RCA =Rack Calibration Accuracy RCSA =Rack Comparator Setting Accuracy RTE =Rack Temperature Effects EA =Environmental Allowance BIAS =One directional, known magnitude

As can be seen in the equation, drift and calibration accuracy allowances are treated as dependent parameters with the measurement and test equipment uncertainties. The environmental allowance is not necessarily considered dependent with all other parameters, but as an additional degree of conservatism is added to the statistical sum. Bias terms are one directional with a known magnitude and are added to the statistical sum. The calibration terms are treated in the same radical based on the Generic Letter 91-04<sup>[6]</sup> requirement for general trending. Millstone Unit 3 has identified that trending will be performed. This results in a net reduction of the CSA magnitude (over that which would be determined if trending was not performed).

#### 2.2 Sensor Allowances

(th)

Six parameters are considered to be sensor allowances: SCA, SRA, SMTE, SD, STE, and SPE (see Table 3-24). Of these parameters, three are considered to be independent (SRA, STE and SPE), and three are considered dependent with at least one other term (SCA, SMTE and SD). SRA is the manufacturer's reference accuracy that is achievable by the device. This term is introduced to address repeatability and hysteresis concerns when only performing a single pass calibration, i.e., one up and one down. [5] STE and SPE are considered to be independent due to the manner in which the instrumentation is checked; i.e., the instrumentation is calibrated and drift determined under conditions in which pressure and temperature are sumed constant. An example of this would be as follows. Assume a sensor is placed in some position in the containment during a refueling outage. After placement, an instrument technician calibrates the sensor. This calibration is performed at ambient pressure and temperature conditions. Some time later with the plant shutdown, an instrument technician checks for sensor drift. Using the same technique as for calibrating the sensor, the technician determines if the sensor has drifted. The conditions under which this determination is made are again ambient pressure and temperature. The temperature and pressure should be essentially the same at both measurements and thus should have no significant impact on the drift determination and are, therefore, independent of the drift allowance. For this evaluation, transmitter "as left / as found" data was evaluated to project a 30 month drift and process rack "as left / as found" data was evaluated for a 3 month drift for all channels noted in this document.

SCA, SMTE and SD are considered to be dependent for the same reason that STE and SPE are considered independent; i.e., due to the manner in which the instrumentation is checked. Instrumentation calibration techniques use the same process as determining instrument drift. That is, the end result of the two is the same. When calibrating a sensor, the sensor output is checked to determine if it is accurately representing the input. The same is performed for a determination of the sensor drift. The "as left / as found" data are recorded to determine whether the sensor has performed its intended function in the past and will it continue to perform this function for future cycles as specified by the manufacturer's specifications.

The transmitter "as left / as found" data was evaluated for population normality and outliers and a 30 month uncertainty determined at a 95% probability and a 95% confidence level. A similar evaluation was performed for the process racks for a 3 month uncertainty. The statistically derived calibration accuracy and drift values (for 30 months or 3 months, as appropriate) were combined with the measurement and test equipment accuracy term to form the dependent relationships. A hypothetical example of the impact of this treatment for a level transmitter is (sensor parameters only):

excerpting the sensor portion of Equation 2.1 results in;

$$\{(SMTE + SCA)^2 + (SMTE + SD)^2 + (SPE)^2 + (STE)^2 + (SRA)^2\}^{1/2}$$
  
- or -  $I^{+a.c} = 2.0\%$ 

Assuming no dependencies for any of the parameters results in the following:

$$\{(SCA)^2 + (SMTE)^2 + (SD)^2 + (SPE)^2 + (STE)^2 + (SRA)^2\}^{1/2}$$

$$- \text{ or } -$$

$$I^{+a.c} = 1.5\%$$
(Eq. 2.2)

Thus it can be seen that the approach represented by Equation 2.1, which accounts for dependent parameters, results in a more conservative summation of the allowances.

#### 2.3 Rack Allowances

Five parameters, as noted by Table 3-24, are considered to be rack allowances: RCA, RMTE, RCSA, RTE, and RD. Three of these parameters (RCA, RMTE, and RD) are considered to be dependent for much the same reason as outlined for sensors in Section 2.2. When calibrating or determining drift in the racks for a specific channel, the processes are performed at essentially constant temperature; i.e., ambient temperature (which is reasonably controlled). Because of this, the RTE parameter is considered to be independent of any factors for calibration or drift. However, the same cannot be said for the other rack parameters. As noted in Section 2.2, when calibrating or determining drift for a channel, the same end result is desired; that is, the point at which the bistable changes state. For this evaluation, "as left / as found" data was evaluated to project a calibration uncertainty, rack drift and a comparator setting accuracy based on the 3 month surveillance interval requirement for each channel. Based on this logic, these factors have been conservatively summed to form several independent groupings (see Equation 2.1). The impact of this approach (formation of independent groups based on dependent components) is significant. For the hypothetical example of a level transmitter channel, using the same approach outlined in Equations 2.1 and 2.2 results in the following:

excerpting the rack portion of Equation 2.1 results in;

$$\{(RMTE + RCA)^2 + (RMTE + RCSA)^2 + (RMTE + RD)^2 + (RTE)^2\}^{1/2}$$
  
- or -  $I^{*ax} = 1.5\%$ 

Assuming no dependencies for any of the parameters yields the following less conservative results;

$$\{(RCA)^{2} + (RMTE)^{2} + (RCSA)^{2} + (RD)^{2} + (RTE)^{2}\}^{1/2}$$

$$= \text{or} +$$

$$\int_{-\infty}^{+\infty} = 1.3\%$$
(Eq. 2.3)

Thus, the use of Equation 2.1 is conservative for rack effects and for sensor effects. Therefore, accounting for dependencies in the treatment of these allowances provides a conservative result.

#### 2.4 Process Allowances

Finally, the PMA and PEA parameters are considered to be independent of both sensor and rack parameters. PMA provides allowances for the non-instrument related effects; e.g., neutron flux, calorimetric power uncertainty assumptions, fluid density changes, and temperature stratification assumptions. PMA may consist of more than one independent uncertainty allowance. PEA accounts for uncertainties due to metering devices, such as elbows, venturis, and orifice plates. Thus, these parameters have been factored into Equation 2.1 as independent quantities. It should be noted that treatment as an independent parameter does not preclude determination that a PMA or PEA term should be treated as a bias. If that is determined appropriate, Equation 2.1 would be modified such that the affected term would be treated by arithmetic summation as deemed necessary.

## 2.5 Measurement and Test Equipment Accuracy

Based on information from Northeast Nuclear Energy Company (NNECO), it was concluded that the equipment used for calibration and functional testing of the transmitters and racks does not meet SAMA Standard PMC 20.1-1973<sup>[7]</sup> with regards to allowed exclusion from the calculation. This implies that test equipment without an accuracy of 10% or less of the calibration accuracy is required to be included in the uncertainty calculations of Equations 2.1, and 3.1. NNECO procedures were reviewed to determine the appropriate uncertainty for each function evaluated. These M&TE uncertainties were included in the calculations, as seen on the tables included in this report.

#### 2.6 References / Standards

- [1] Grigsby, J. M., Spier, E. M., Tuley, C. R., "Statistical Evaluation of LOCA Heat Source Uncertainty," WCAP-10395 (Proprietary), WCAP-10396 (Non-Proprietary), November 1983.
- [2] Chelemer, H., Boman, L. H., and Sharp, D. R., "Improved Thermal Design Procedure," WCAP-8567 (Proprietary), WCAP-8568 (Non-Proprietary), July, 1975.
- [3] ANSI/ANS Standard 58.4-1979, "Criteria for Technical Specifications for Nuclear Power Stations."
- [4] ISA Standard S67.04, 1994, "Setpoints for Nuclear Safety-Related Instrumentation Used in Nuclear Power Plants."
- [5] Tuley, C. R., Williams, T. P., "The Significance of Verifying the SAMA PMC 20.1-1973 Defined Reference Accuracy for the Westinghouse Setpoint Methodology," Instrumentation, Controls and Automation in the Power Industry, Vol. 35, Proceedings of the Thirty-Fifth Power Instrumentation Symposium (2nd Annual ISA/EPRI Joint Controls and Automation Conference), Kansas City, Mo., June, 1992, p. 497.
- [6] Generic Letter 91-04, 1991, "Changes in Technical Specification Surveillance Intervals to Accommodate a 24 Month Fuel Cycle."
- [7] Scientific Apparatus Manufacturers Association, Standard PMC 20.1-1973. "Process Measurement and Control Terminology."

## 3.0 PROTECTION SYSTEM SETPOINT METHODOLOGY

#### 3.1 Margin Calculation

As noted in Section 2.0, Westinghouse utilizes the square root of the sum of the squares for summation of the various components of the channel uncertainty. This approach is valid where no dependency is present. Arithmetic summation is a conservative treatment when a dependency between two or more parameters exists. The equation used to determine the margin, and thus the acceptability of the parameter values used, is:

$$Margin = TA - \{(PMA)^2 + (PEA)^2 + (SMTE + SCA)^2 + (SMTE + SD)^2 + (SPE)^2 + (STE)^2 + (SRA)^2 + (RMTE + RCA)^2 + (RMTE + RCSA)^2 + (RMTE + RD)^2 + (RTE)^2\}^{1/2} - EA - BIAS$$
 (Eq. 3.1)

where:

TA = Total Allowance (which is defined as) Safety Analysis Limit - Nominal Trip Setpoint, and all other parameters are as defined for Equation 2.1.

This equation is appropriate when trending of transmitter calibration and drift and process rack calibration and drift values is taking place. Using Equation 2.1, Equation 3.1 may be simplified to:

$$Margin = TA - CSA (Eq. 3.2)$$

Tables 3-1 through 3-23 provide individual component uncertainties and CSA calculations for the protection functions noted in Tables 2.2-1 and 3.3-4 of the Millstone Unit 3 Technical Specifications. Table 3-24 provides a summary of the Reactor Protection System / Engineered Safety Features Actuation System Channel Uncertainty Allowances for Millstone Unit 3 and includes Safety Analysis and Technical Specification values, Total Allowance and

Margin. Westinghouse typically reports values in these tables to the decimal place using the conventional technique of rounding down values less than 0.05 and rounding up values greater than or equal to 0.05. Parameters reported in Tables 3-1 through 3-24 as "0.0" have been identified as having a value of  $\leq 0.04$ . Parameters reported as "0" or "---" in the tables are not applicable (i.e., have no value) for that channel.

## 3.2 Definitions For Protection System Setpoint Tolerances

To insure a clear understanding of the channel uncertainty values used in this report, the following definitions are noted:

#### As Found

The condition in which a transmitter, process rack module or process instrument loop is found after a period of operation. For example, after a period of operation, a transmitter was found to deviate from the ideal condition by -0.5% span. This would be the "as found" condition.

#### M As Left

The condition in which a transmitter, process rack module or process instrument loop is left after calibration or bistable trip setpoint verification. This condition is typically better than the calibration accuracy for that piece of equipment. For example, the permitted calibration accuracy for a transmitter is  $\pm 0.5\%$  of span, while the worst measured deviation from the ideal condition after calibration is  $\pm 0.1\%$  span. In this instance, if the calibration was stopped at this point (i.e., no additional efforts were made to decrease the deviation) the "as left" error would be  $\pm 0.1\%$  span.

#### · Channel

The sensing and process equipment, i.e., transmitter to bistable, for one input to the voting logic of a protection function. Westinghouse designs protection functions with voting logic made up of multiple channels, e.g. 2/4 Steam Generator Level - Low-Low channels must have two bistables in the tripped condition for a Reactor Trip to be initiated.

#### Channel Statistical Allowance (CSA)

The combination of the various channel uncertainties via SRSS. It includes both instrument (sensor and process rack) uncertainties and non-instrument related effects (Process Measurement Accuracy). This parameter is compared with the Total Allowance for determination of instrument channel margin.

#### ■ Environmental Allowance (EA)

The change in a process signal (transmitter or process rack output) due to adverse environmental conditions from a limiting accident condition. Typically this value is determined from a conservative set of enveloping conditions and may represent the following:

- a) temperature effects on a transmitter,
- b) radiation effects on a transmitter,
- c) seismic effects on a transmitter,
- d) temperature effects on a level transmitter reference leg,
- e) temperature effects on signal cable insulation, and
- f) seismic effects on process racks.

#### Margin

The calculated difference (in % instrument span) between the Total Allowance and the Channel Statistical Allowance.

#### Nominal Trip Setpoint (NTS)

A bistable trip setpoint in plant Technical Specifications or plant administrative procedures. This value is the nominal value to which the bistable is set, as accurately as reasonably achievable.

#### ■ Normalization

The process of establishing a relationship, or link, between a process parameter and an instrument channel. This is in contrast with a calibration process. A calibration process is performed with independent known values, i.e., a bistable is calibrated to change state when a specific voltage is reached. This voltage corresponds to a process parameter magnitude with the relationship established through the scaling process. A normalization process typically involves an indirect measurement, e.g., determination of Steam Flow via the Δp drop across a flow restrictor. The flow coefficient is not known for this condition, effectivel, an orifice, therefore a mass balance between Feedwater Flow and Steam Flow can be made. With the Feedwater Flow known through measurement via the venturi, the Steam Flow is normalized.

## ■ Process Loop (Instrument Process Loop)

The process equipment for a single channel of a protection function.

## ■ Process Measurement Accuracy (PMA)

Allowance for non-instrument related effects which have a direct bearing on the accuracy of an instrument channel's reading, e.g., temperature stratification in a large diameter pipe, fluid density in a pipe or vessel.

## Primary Element Accuracy (PEA)

Uncertainty due to the use of a metering device, e.g., venturi, orifice, or elbow. Typically, this is a calculated or measured accuracy for the device.

#### ■ Process Racks

The analog modules downstream of the transmitter or sensing device, which condition a signal and act upon it prior to input to a voting logic system. For Westinghouse process systems, this includes all the equipment contained in the process equipment cabinets, e.g., conversion resistor, transmitter power supply, R/E, lead/lag, rate, lag functions, function generator, summator, control/protection isolator, and bistable for analog functions. The go/no go signal generated by the bistable is the output of the last module in the analog process rack instrument loop and is the input to the voting logic.

#### · R/E

Resistance (R) to voltage (E) conversion module. The RTD output (change in resistance as a function of temperature) is converted to a process loop working parameter (voltage) by this analog module.

## Rack Calibration Accuracy (RCA)

The reference (calibration) accuracy, as defined by SAMA Standard PMC 20.1-1973<sup>[1]</sup> for a process loop string. Inherent in this definition is the verification of the following under a reference set of conditions; 1) conformity<sup>[2]</sup>, 2) hysteresis<sup>[3]</sup> and 3) repeatability<sup>[4]</sup>. The Westinghouse definition of a process loop includes all modules in a specific channel. Also it is assumed that the individual modules are calibrated to a particular tolerance and that the process loop as a string is verified to be calibrated to a specific tolerance. The tolerance for the string is typically less than the arithmetic sum or SRSS of the individual module tolerances. This forces calibration of the process loop without a systematic bias in the individual module calibrations, i.e., as left values for individual modules must be compensating in sign and magnitude.

For an analog channel, an individual module is typically calibrated to within [ ]+ac, with the entire process loop typically calibrated to within [ ]+ac.

## Rack Comparator Setting Accuracy (RCSA)

The reference (calibration) accuracy, as defined by SAMA Standard PMC 20.1-1973<sup>[11]</sup>, of the instrument loop comparator (bistable). Inherent in this definition is the verification of repeatability<sup>[4]</sup> under a reference set of conditions. For a single input bistable (fixed setpoint) the typical calibration tolerance is [ ]<sup>+ac</sup>. This assumes that comparator nonlinearities are compensated by the setpoint. For a dual input bistable (floating setpoint) the typical calibration tolerance is [ ]<sup>+ac</sup>. This allows for nonlinearities between the two inputs. In many plants calibration of the bistable is included as an integral part of the rack calibration, i.e., string calibration.

#### Rack Drift (RD)

The change in input-output relationship over a period of time at reference conditions, e.g., at constant temperature. A typical allowance value assumed for this parameter is  $\pm 1.0\%$  span for analog channels. An example of RD is: for an "as found" value of -0.5% span and an "as left" value of +0.1% span, the magnitude of the drift would be  $\{(-0.5) - (+0.1) = -0.6\%$  span) in the negative direction. For this evaluation, a maximum surveillance interval of 3 months was assumed when projecting drift allowance, as noted in the uncertainty tables.

## Rack Measurement & Test Equipment Accuracy (RMTE)

The accuracy of the test equipment (typically a transmitter simulator, voltage or current power supply, and DVM) used to calibrate a process loop in the racks. When the magnitude of RMTE meets the requirements of SAMA PMC 20.1-1973<sup>[5]</sup> it is considered an integral part of RCA. Magnitudes in excess of the 10:1 limit are explicitly included in Westinghouse calculations.

## Rack Temperature Effects (RTE)

Change in input-output relationship for the process rack module string due to a change in the ambient environmental conditions (temperature, humidity, voltage and frequency) from the reference calibration conditions. It has been determined that temperature is the most significant, with the other parameters being second order effects. For process instrumentation, a value of [ ]  $^{+a.c}$  is used for analog channel temperature effects. It is assumed that calibration is performed at a nominal ambient temperature of +70 °F with an upper extreme of +120 °F (+50 °F  $\Delta$ T) and a lower extreme of +40 °F.

#### Range

The upper and lower limits of the operating region for a device, e.g., for a Pressurizer Pressure transmitter, 1700 to 2500 psig, for Steam Generator Level, approximately 120.8 to 31.5 inches of water column. This is not necessarily the calibrated span of the device, although quite often the two are close. For further information see SAMA PMC 20.1-1973<sup>(6)</sup>.

### ■ Safety Analysis Limit (SAL)

The parameter value assumed in a transient analysis or other plant operating limit at which a reactor trip or actuation function is initiated.

## ■ Sen: \_ Calibration Accuracy (SCA)

The calibration accuracy for a Sensor or transmitter as defined by the Millstone Unit 3 calibration procedures. For transmitters, this accuracy is typically [

]\*\*ac as defined by NNECO Procedures. Utilizing Westinghouse

recommendations for RTD cross-calibration, this accuracy is typically [ ]\*\*\* for the Hot and Cold Leg RTDs.

### Sensor Drift (SD)

The change in input-output relationship over a period of time at reference calibration conditions, e.g., at constant temperature. An example of SD is: for an "as found" value of +0.5% span and an "as left" value of +0.1% span, the magnitude of the drift would be  $\{(+0.5) - (+0.1) = +0.4\%$  span $\}$  in the positive direction. For this evaluation, a maximum surveillance interval of 30 months was assumed when projecting drift allowance with exceptions as noted in the uncertainty tables.

## Sensor Measurement & Test Equipment Accuracy (SMTE)

The accuracy of the test equipment (typically a high accuracy local readout gauge and DVM) used to calibrate a sensor or transmitter in the field or in a calibration laboratory. When the magnitude of SMTE meets the requirements of SAMA PMC 20.1-1973<sup>[5]</sup> it is considered an integral part of SCA. Magnitudes in excess of the 10:1 limit are explicitly included in Westinghouse calculations.

#### Sensor Pressure Effects (SPE)

The change in input-output relationship due to a change in the static head pressure from the calibration conditions or the accuracy to which a correction factor is introduced for the difference between calibration and operating conditions for a  $\Delta p$  transmitter.

## ■ Sensor Temperature Effects (STE)

The change in input-output relationship due to a change in the ambient environmental conditions (temperature, humidity, voltage and frequency) from the reference calibration conditions. It has been determined that temperature is the most significant, with the other parameters being second order effects. It is assumed that calibration is performed at a nominal ambient temperature of +70 °F with an upper extreme of +120 °F and a lower extreme of +40 °F.

## ■ Sensor Reference Accuracy

The reference accuracy that is achievable by the device as specified in the manufacturers specification sheets. Reference (calibration) accuracy for a sensor or transmitter as defined by SAMA Standard PMC 20.1-1973<sup>[1]</sup>. Inherent in this

definition is the verification of the following under a reference set of conditions; 1) conformity<sup>[2]</sup>, 2) hysteresis<sup>[3]</sup> and 3) repeatability<sup>[4]</sup>. This term is introduced into the uncertainty calculation to address repeatability concerns when only performing a calibration, i.e., one up and one down or repeatability and hysteresis when performing a single pass calibration in only one direction.

#### ■ Span

The region for which a device is calibrated and verified to be operable, e.g., for a Pressurizer Pressure transmitter, 800 psi, for Steam Generator Level, approximately 89.3 inches of water column. For Pressurizer Pressure, considerable suppression of the zero is exhibited.

#### SRSS

Square root of the sum of the squares, i.e.,

$$\epsilon = \sqrt{(a)^2 + (b)^2 + (c)^2}$$

as approved for use in setpoint calculations by ISA Standard S67.04-1994[7].

## Total Allowance (TA)

The calculated difference between the Safety Analysis Limit and the Nominal Trip Setpoint (SAL - NTS) in % instrument span. Two examples of the calculation of TA are:

■ Steam Generator Level - Low-Low

If the instrument span= 100% LVL, then

■ Pressurizer Pressure - Low Trip

If the instrument span = 800 psi, then

$$TA = \frac{(40 \text{ psia}) * (100\% \text{ span})}{(800 \text{ psia})} = 5.0\% \text{ span}$$

## 3.3 Cross Reference - SAMA PMC 20.1-1973 and ANSI/ISA-S51.1-1979

SAMA Standard PMC 20.1-1973, "Process Measurement & Control Terminology" is no longer in print and thus is unavailable from SAMA. It has been replaced by ANSI/ISA S51.1-1979, "Process Instrumentation Terminology" and is available from the Instrument Society of America. Noted below is a cross reference listing of equivalent definitions between the two standards for terms used in this document. Even though the SAMA standard is no longer available, Westinghouse prefers and continues to use the SAMA definitions.

#### SAMA

Reference Accuracy(1)

Conformity<sup>[2]</sup>

Hysteresis<sup>[3]</sup>

Repeatability<sup>[4]</sup>

Test Cycle<sup>[5]</sup>

Test Procedures[5]

Range<sup>[6]</sup>

#### ISA

Accuracy Rating[8]

Conformity, independent[9]

Hysteresis[10]

Repeatability[11]

Calibration Cycle<sup>[12]</sup>

Test Procedures[12]

Range[13]

#### 3.4 References / Standards

- Scientific Apparatus Makers Association Standard PMC 20.1-1973, "Process Measurement & Control Terminology", p 4, 1973.
- [2] Ibid, p 5.
- [3] Ibid, p 19.
- [4] Ibid, p 28.
- [5] Ibid, p 36.
- [6] Ibid, p 27.
- [7] Instrument Society of America Standard S67.04-1994, "Setpoints for Nuclear Safety-Related Instrumentation", p 18, 1994.
- [8] Instrument Society of America Standard S51.1-1979, "Process Instrumentation Terminology", p 6, 1979.
- [9] Ibid, p 8.
- [10] Ibid, p 20.
- [11] Ibid, p 27.
- [12] Ibid, p 33.
- [13] Ibid, p 25.

TABLE 3-1
POWER RANGE, NEUTRON FLUX - LOW & HIGH

Parameter		Allowa	nce*
Process Measurement Accuracy	<b>y*a.c</b>		1***
i	1*44		
Primary Element Accuracy			
Sensor Calibration Accuracy			
	J.re		
Measurement & Test Equipment Accuracy [	1,44		
Sensor Pressure Effects			
Sensor Temperature Effects	J***		
Sensor Drift	Jean		
Environmental Allowance			
Bias		r de l'	
Rack Calibration Rack Accuracy Measurement & Test Equipment Accuracy	ey .		
Comparator			
Rack Temperature Effect			
Rack Drift			
Tag No.'s - N41, N42, N43, N44			
In percent span (120% RTP)			
Channel Statistical Allowance =			
r			
			]"

TABLE 3-2
POWER RANGE, NEUTRON FLUX - HIGH N-1 LOOP OPERATION

	Allowance'
J.ve	
J***	
Jean	
J*sc	
J-ec	
J***	
	Jave Jave Jave

## TABLE 3-3 POWER RANGE, NEUTRON FLUX HIGH POSITIVE AND NEGATIVE RATE

Parameter	Al	llowance*	
Process Measurement Accuracy			46,0
1*4.6			H
Primary Element Accuracy			
Sensor Calibration Accuracy			
1			
Measurement & Test Equipment Accuracy			H
Sensor Pressure Effects			
Sensor Temperature Effects			
1***			
Sensor Drift			
1440			
Environmental Allowance			
Bias			
Rack Calibration Rack Accuracy			
Measurement & Test Equipment Accuracy			
Comparator  Rack Temperature Effect			
Rack Drift		4	
Tag No.'s - N41, N42, N43, N44			
* In percent span (120% RTP)			
Channel Statistical Allowance =			+4,0

## TABLE 3-4 INTERMEDIATE PLANGE NEUTRON FLUX

Parameter	Allowance*
Process Measurement Accuracy	1"
J*s.c	
Primary Element Accuracy	
Sensor Calibration Accuracy	
Measurement & Test Equipment Accuracy	
Sensor Pressure Effects	
Sensor Temperature Effects	
Sensor Drift	
Environmental Allowance	
Bias	
Rack Calibration Rack Accuracy Measurement & Test Equipment Accuracy	
Comparator	
Rack Temperature Effect	
Rack Drift	
Tag No.'s - N35, N36	
* In percent span (120% RTP) Channel Statistical Allowance =	

#### TABLE 3-5 SOURCE RANGE NEUTRON FLUX

Parameter		Allowance'
Decours Management &		r 7"
Process Measurement Accuracy		
J.erc		
Primary Flement Accuracy		
Sensor Calibration Accuracy		
	1.44	
Measurement & Test Equipment Accuracy		
Sensor Pressure Effects		
Sensor Temperature Effects		
	J.v.	
Sensor Drift	1***	
Paris and Allert and A		
Environmental Allowance		
Bias		
Rack Calibration		
Rack Accuracy Measurement & Test Equipment Accuracy		
Comparator		
Rack Temperature Effect		
Rack Drift		
1 ag No k - J21 N22		

1ag No.'s - 1431, N32

<sup>\*</sup> In percent span (10<sup>6</sup> cps) Channel Statistical Allowance =

#### TABLE 3-6

# OVERTEMPERATURE $\Delta T$ (CORE BURNDOWN EFFECTS) (N LOOP) (Rosemount Model 1154GP9 Transmitter for Pressurizer Pressure) Assumes re-normalization of $\Delta T_o$ , T'', and T'

Process Measurement Accuracy	Parameter				Allowa	ince*
Primary Element Accuracy  Sensor Calibration Accuracy  Sensor Reference Accuracy  [	Process Measurement Accuracy					7***
Primary Element Accuracy  Sensor Calibration Accuracy  [		1"	Jeac			
Primary Element Accuracy  Sensor Calibration Accuracy  [						
Sensor Calibration Accuracy  [	1	]***	1,***			
Sensor Reference Accuracy  [	Primary Element Accuracy					
Measurement & Test Equipment Accuracy  [	Sensor Calibration Accuracy [					
Sensor Pressure Effects  Sensor Temperature Effects  [	Sensor Reference Accuracy			1***		
Sensor Temperature Effects  [	Measurement & Test Equipmen	nt Accurac	у			
Sensor Drift  [	Sensor Pressure Effects					
Environmental Allowance						
Environmental Allowance	Sensor Drift					
]***						
	Environmental Allowance [			4		
Rack Calibration Accuracy  [	Rack Calibration Accuracy [ [ [ [ [ [ [ [ [ [ [ [ [ [ [ [ [ [ [	J.re				

# TABLE 3-6 (continued) OVERTEMPERATURE ΔT (CORL BURNDOWN EFFECTS) (N L OP) (Rosemount Model 1154GP9 Transmitter for Pressurizer Pressure) Assumes re-normalization of ΔT<sub>o</sub>, T", and T'

Parameter		Allowance*
Measurement & Test I	Equipment Accuracy	
i	]***	
Comparator (Included in string co	alibration)	
Rack Temperature Effe	ct	
Rack Drift [ [ [ [	]***c ]***c	
	A. TE411B, PT455, N41 E421B, PT456, N42	

Channel Statistical Allowance =

<sup>\*</sup> In percent ΔT span (ΔT - 90.3°F; Tavg - 100°F; Pressure - 800 psi; Power - 150% RTP; ΔI - ±60% ΔI; 90.3°F span = 150% power)

TABLE 3-7 OVERPOWER  $\Delta T$  (CORE BURNDOWN EFFECTS) (N LOOP) Assumes re-normalization of  $\Delta T_{\rm e}$ , T'', and T'

Parameter		Allowance*
Process Measurement Accuracy		1 1"
l Jean	J***	
i	J***	
	lare lare	
[ ]*ac		
Primary Element Accuracy		
Sensor Calibration Accuracy		
1	J.m	
Measurement & Test Equipment Accuracy		
Sensor Pressure Effects		
Sensor Temperature Effects		
Sensor Drift		
ī	Jan.	
Environmental Allowance		
Rack Calibration Accuracy		
]*4.0		
[ ]-ec		
]***	J.r.s	
Measurement & Test Equipment Accuracy		
3***		
I Jere		
Comparator (Included in string calibration)		
Rack Temperature Effect		
Rack Drift		
Lare Dill		
J. L.		

Tag Numbers - TE411A, TE411B, TE431A, TE431B, TE421A, TE421B, TE441A, TE441B • In percent  $\Delta T$  span ( $\Delta T$  - 90.3°F; Tavg - 100°F; Power - 150% RTP; 90.3°F span = 150% power)

# $\begin{array}{c} \textbf{TABLE 3-7 (continued)} \\ \textbf{OVERPOWER } \Delta T \text{ (CORE BURNDOWN EFFECTS) (N LOOP)} \\ \textbf{Assumes re-normalization of } \Delta T_o, \, T^*, \, \text{and } T^* \end{array}$

# TABLE 3-8 OVERTEMPERATURE $\Delta T$ (CORE BURNDOWN EFFECTS) (N-1 LOOP) (Rosemcunt Model 1154GP9 Transmitter for Pressurizer Pressure) Assumes re-normalization of $\Delta T_o$ , $T^n$ , and $T^n$

Parameter		Allowance*
Process Measurement Accuracy		[ ]
	J.r.c	
]***		
i i		
	1+vc 1+vc	
7*44		
	*6.0	
į Juri		
Primary Element Accuracy		
Sensor Calibration Accuracy		
	1-00	
	1***	
Sanaar Bafarana A.		
Sensor Reference Accuracy	1+AC	
Measurement & Test Equipment Accura	cy	
Sensor Pressure Effects		
Sensor Temperature Effects		
Sensor Drift		
	]***	
	]**,c	
Parties and the		
Environmental Allowance	1*4.4	and the same of
	1+4.0	
Pack Calibration Accuracy		
1940		
- Paul		
Jess Jess		
	*AC	
	7*4.0	

#### TABLE 3-8 (continued)

# OVERTEMPF \*ATURE $\Delta T$ (CORE BURNFOWN EFFECTS) (N-1 LOOP) (Rosemount Model 11\*4GP9 Transmitter for Pressurizer Pressure) Assumes re-normalization of $\Delta T_{\rm e}$ , T'', and T'

Parameter		Allowance*
M		
Measurement &	Test Equipment Accuracy	현기 나는 그 사람들이 좀 되었다.
i	1*40	
i	Jaro	
- (	Jean	
	J.v.	
Comparator (Included in st	ring calibration)	
Rack Temperatur	e Effect	
Rack Prift	1*60	
	1*44	
	) tac	
i	7***	
* In percent ΔT r Power - 150%	span (ΔT - 87.0°F; Tavg - 100°F; Pressure - 800 p RTP; ΔI - ±60% ΔI; 87.0°F span = 150% power)	psi;
Channel Statistica	al Allowance =	
r		
1. 1.44		
		The second secon

TABLE 3-9
OVERPOWER ΔT (CORE BURNDOWN EFFECTS) (N-1 LOOP)
Assumes re-normalization of ΔT<sub>ot</sub> T", and T'

Parameter	Allowance'
Process Measurement Accuracy	1"
1 1+40	
	7*86
į.	Jeac Jeac
Jere Jere	
Primary Element Accuracy	
Sensor Calibration Accuracy	
1	
Measurement & Test Equipment Accuracy	
Sensor Pressure Effects	
Sensor Temperature Effects	
Sensor Drift	
J.erc	
Environmental Allowance	
Rack Calibration Accuracy	
]*Ac	
[ ]***	
1 Jare	
Measurement & Test Equipment Accuracy	
1 7****	
I.ere	
Comparator (Included in string calibration)	
Rack Temperature Effect	
Rack Drift	
[ ].ere	
]+4.6	

Tag Numbers - TE411A, TE411B, TE431A, TE431B, TE421A, TE421B, TE441A, TE441B

\* In percent ΔT span (ΔT - 87.0°F; Tavg - 100°F; Power - 150% RTP; 87.0°F span = 150% power)

## $\begin{array}{c} \textbf{TABLE 3-9 (continued)} \\ \textbf{OVERPOWER } \Delta T \text{ (Core Burndown Effects) (N-1 LOOP)} \\ \textbf{Assumes re-normalization of } \Delta T_o \ T'', \ \textbf{and} \ T' \end{array}$

## TABLE 3-10 PRESSURIZER PRESSURE - LOW & HIGH (ROSEMOUNT 1154GP9 TRANSMITTER)

Parameter	Allowance*
Process Measurement Accuracy	[ ]**
Primary Element Accuracy	
Sensor Calibration Accuracy Sensor Reference Accuracy	
Measurement & Test Equipment Accuracy	
Sensor Pressure Effects	
Sensor Temperature Effects	
Sensor Drift (30 months)	
Environmental Allowance	
Bias [ ]*a,c	
Rack Calibration Rack Accuracy Measurement & Test Equipment Accuracy	
Comparator String Calibrated	
Rack Temperature Effect	
Rack Drift	
Tag No.'s - PT457, PT458	
* In percent span (800 psia)	
Channel Statistical Allowance =	

## TABLE 3-11 PRESSURIZER PRESSURE - SI (ROSEMOUNT 1154GP9 TRANSMITTER)

rarameter	Allowance*
Process Measurement Accuracy	[ ]**·
Primary Element Accuracy	
Sensor Calibration Accuracy Sensor Reference Accuracy	
Measurement & Test Equipment Accuracy	
Sensor Pressure Effects	
Sensor Temperature Effects Included in E.A term	
Sensor Drift (30 months)	
Environmental Allowance  [	
Bias [ ]****	
Rack Calibration Rack Accuracy Measurement & Test Equipment Accuracy	
Comparator String Calibrated	
Rack Temperature Effect	
Rack Drift	
Tag No.'s - PT457, PT458	4
* In percent span (800 psia) Channel Statistical Allowance =	7***

### TABLE 3-12 PRESSURIZER WATER LEVEL - HIGH (VERITRAK 76DP1 TRANSMITTER)

r ar ameter	Allowance
Process Measurement Accuracy	r 7**
1 1+ac	
j**.c	
Primary Element Accuracy	
Sensor Calibration Accuracy	
Sensor Reference Accuracy	
Measurement & Test Equip.nent Accuracy	
Sensor Pressure Effects	
Sensor Temperature Effects	
Sensor Drift (30 months)	
Environmental Allowance	
Bias	
[ ]+a.c	
Rack Calibration	
Rack Accuracy Measurement & Test Equipment Accuracy	
Comparator	
String Calibrated	
Rack Temperature Effect	
Rack Drift	
Tag No.'s - LT-459	
* In percent span (100%)	
Channel Statistical Allowance =	
f	7***

TABLE 3-13
PRESSURIZER WATER LEVEL - HIGH (ROSEMOUNT 1153HD5 TRANSMITTER)

r at ameter		Allowanc	e'
Province Management Academic			7 *4.0
Process Measurement Accuracy	7*65		
i	1+4.0		
Primary Element Accuracy			
Sensor Calibration Accuracy Sensor Reference Accuracy			
Measurement & Test Equipment Accuracy			
Sensor Pressure Effects			
Sensor Temperature Effects			
Sensor Drift (30 months)			
Environmental Allowance			
Bias			1
[ ]***c			
Rack Calibration Rack Accuracy Measurement & Test Equipment Accuracy			
Comparator String Calibrated			
Rack Temperature Effect			
Rack Drift			
Tag No.'s - LT-460, LT-461			7
* In percent span (100%)			
Channel Statistical Allowance =			
			+4,0

## TABLE 3-14 STEAM GENERATOR WATER LEVEL - LOW-LOW (FLB) (ROSEMOUNT 1154DH4 TRANSMITTER)

rarameter	Allowance'
Process Measurement Accuracy	ſ 1"
1+6.0	
1***	
]+4.0	
[ ]-wc	
Primary Element Accuracy	
Sensor Calibration Accuracy	
Sensor Reference Accuracy	
Measurement & Test Equipment Accuracy	
Canada Danisa Differen	
Sensor Pressure Effects	
Sensor Temperature Effects	
Included in EA term	
Sensor Drift (30 months)	
Faultonian and Allows	
Environmental Allowance	
Jeac	
j jan	
Bias	
]*Ac	
R .ck Calibration	
Rack Accuracy	
Measurement & Test Equipment Accuracy	병에 없는데 하여 말이 되게 되었다.
Comparator	
String Calicrated	
Rack Temperature Effect	[1] : 14명하는 [1] : 1명 [1] : 1명 [1]
Rack Drift	
Tag No.'s - LT517, LT518, LT519	
LT527, LT528, LT529 LT537, LT538, LT539	
LT547, LT548, LT549	
LT551, LT552, LT553	
LT554	

\* In percent span (100%)

# TABLE 3-14 (continued) STEAM GENERATOR WATER LEVEL LOW-LOW (FLB) (ROSEMOUNT 1154DH4 TRANSMITTER)

#### TABLE 3-15 STEAM GENERATOR WATER LEVEL - LOW-LOW (LONF) (ROSEMOUNT 1154DH4 TRANSMITTER)

Parameter		Allowance*
Process Measurement Acc	uracy	[ ]"
	]**.0	
	l.v.	
	]*A.C	
Primary Element Accuracy		
Sensor Calibration Accura	cy	
Sensor Reference Accurac		
M	[[[[[[]]]]]] [[[]] [[]] [[]] [[]]	
Measurement & Test Equi	pment Accuracy	
Sensor Pressure Effects		
Sensor Temperature Effec	ts	
Sensor Drift (30 months)		
Environmental Allowance		
Bias	1+4.0	
Rack Calibration		
Rack Accuracy		
Measurement & Test Eq	uipment Accuracy	
Comparator		
String Calibrated		
		마르게 나타 보기를 다 먹지 않다.
Rack Temperature Effect		
Rack Drift		
NACK DIII		

Tag No.'s - LT517, LT518, LT519 LT527, LT528, LT529 LT537, LT538, LT539 LT547, LT548, LT549 LT551, LT552, LT553 LT554

<sup>\*</sup> In percent span (100%)

## TABLE 3-15 (continued) STEAM GENERATOR WATER LEVEL LOW-LOW (LONF) (ROSEMOUNT 1154DH4 TRANSMITTER)

#### TABLE 3-16 STEAM GENERATOR WATER LEVEL - HIGH-HIGH (ROSEMOUNT 1154DH4 TRANSMITTER)

Parameter		Allowance*
Process Measurement Accuracy		1
	J*4.0	
	]+a.c	
i	]+4.0	
Primary Element Accuracy		
Sensor Calibration Accuracy Sensor Reference Accuracy		
Measurement & Test Equipment Accura	всу	
Sensor Pressure Effects		
Sensor Temperature Effects		
Sensor Drift (30 months)		
Environmental Allowance		
Bias		
	J.re	
Rack Calibration		
Rack Accuracy		
Measurement & Test Equipment Accu	ıracy	
Comparator		
String Calibrated		
Rack Temperature Effect		
Rack Drift		
Tag No.'s - LT517, LT518, LT519		
LT527, LT528, LT529		
LT537, LT538, LT539		
LT547, LT548, LT549		
LT551, LT552, LT553		
LT554		

<sup>\*</sup> In percent span (100%)

### TABLE 3-16 (continued) STEAM GENERATOR WATER LEVEL HIGH-HIGH (ROSEMOUNT 1154DH4 TRANSMITTER)

### TABLE 3-17 REACTOR COOLANT PUMP UNDERSPEED

Parameter	Allowance*
Process Measurement Accuracy	ſ 7**
Primary Element Accuracy	
Sensor Calibration Accuracy Sensor Reference Accuracy	
Measurement & Test Equipment Accuracy	
Sensor Pressure Effects	
Sensor Temperature Effects	
Sensor Drift (30 months)	
Environmental Allowance	
Bias	
Rack Calibration Rack Accuracy Measurement & Test Equipment Accuracy	
Comparator String Calibraed	
Rack Temperature Effect	
Rack Drift	
Tag No.'s - SE495, SE496, SE497, SE498	
* In percent span (81.013 - 106.329% RNS)	
Channel Statistical Allowance =	
	*A.C

### TABLE 3-18 CONTAINMENT PRESSURE - HIGH 1, HIGH 2, HIGH 3 (ROSEMOUNT 1153AB6 TRANSMITTER)

rarameter	Allowan	ce*
Process Measurement Accuracy	r	7***
Primary Element Accuracy		
Sensor Calibration Accuracy Sensor Reference Accuracy		
Measurement & Test Equipment Accuracy		
Sensor Pressure Effects		
Sensor Temperature Effects		
Sensor Drift (30 months)		
Environmental Allowance		
Bias [ ]+a.e		
Rack Calibration Rack Accuracy Measurement & Test Equipment Accuracy		
Comparator String Calibrated		
Rack Temperature Effect		
Rack Drift		
Tag No.'s - PT934, PT935, PT936, PT937	L	j

<sup>\*</sup> In percent span (60 psia)

TABLE 3-19
STEAMLINE PRESSURE - LOW SI (ROSEMOUNT 1153GB9 TRANSMITTER)

Parameter	Allowatce*
Process Measurement Accuracy	ſ 1"
Primary Element Accuracy	
Sensor Calibration Accuracy Sensor Reference Accuracy	
Measurement & Test Equipment Accuracy	
Sensor Pressure Effects	
Sensor Temperature Effects	
Sensor Drift (30 months)	
Environmental Allowance	
Bias [ ]***,c	
Rack Calibration Rack Accuracy Measurement & Test Equipment Accuracy	
Comparator String Calibrated	
Rack Temperature Effect	
Rack Drift	
Tag No.'s - PT514, PT515, PT516 PT524, PT525, PT526 PT534, PT535, PT536 PT544, PT545, PT546	
* In percent span (1300 psig)	
Channel Statistical Allowence =	]*

#### TABLE 3-20 NEGATIVE STEAM PRESSURE RATE - HIGH

Parameter	Allowance*
Process Measurement Accuracy	[ ]**
Primary Element Accuracy	
Sensor Calibration Accuracy	
J***	
Measurement & Test Equipment Accuracy	
Sensor Pressure Effects	
Sensor Temperature Effects	
1***	
Sensor Drift [ ]*4.5	
Environmental Allowance	
Rack Calibration Rack Accuracy Measurement & Test Equipment Accuracy	
Comparator	
Rack Temperature Effect	
Rack Drift	
Tag No.'s - PT514, PT515, PT516 PT524, PT525, PT526 PT534, PT535, PT536 PT544, PT545, PT546	
* In percent span (1300 PSIG) Channel Statistical Allowance =	
	****

TABLE 3-21
RCS LOW FLOW (N LOOP) (ROSEMOUNT 1153HD5 TRANSMITTER)

Parameter				Allowance'
Process Measurement Accuracy				[ ]"
1	]*4,0			
1		]*4.0		
Primary Element Accuracy				
	]*a,c			
Sensor Calibration Accuracy				
Censor Deference Accurrent	7*4.6	]*4,0		
Sensor Reference Accuracy [				
Measurement & Test Equipment	Accuracy			
			I.rr.	
Sensor Pressure Effects				
1			]*4,0	
Consor Tomporotus y Effects				
Sensor Temperature Effects			1+4.0	
Sensor Drift (30 months)[	]****c			
Environmental Allowance				
Bias [		J*	4,6	
Rack Calibration				
Rack Accuracy [	1*4.0			
Measurement & Test Equipment	Accuracy [		]+xc	
Comparator				
Comparator String Calibrated				
Rack Temperature Effect [		]*a,c		
Rack Drift [	]*4,0			
				L d
rag No.'s - FT414, FT415, FT416 FT434, FT435, FT436, F				
***************************************	1 , 1 1	2,11440		
In percent span (120% flow)				
Channel Statistical Allowance =				- **
				]"

RCS LOW FLOW (N-1 LOOP) (ROSEMOUNT 1153HD5 TRANSMITTER)

Parameter		Allowance*
Process Measurement Accuracy		7 7***
	]+a.c	
	]*4.0	
Primary Element Accuracy		
1	]*a,c	
Sensor Calibration Accuracy		
	J*Ac	
Sensor Reference Accuracy [	]***	
Measurement & Test Equipment Ac	curacy	
	1.00	
Sensor Pressure Effects		
	J***c	
Sensor Temperature Effects		
[	J.evc	
Sensor Drift (30 months)[	7*4.0	
Environmental Allowance		
Bias [	J***	
Rack Calibration		
Rack Accuracy [	]***	
Measurement & Test Equipment A	Accuracy [ ]*a,c	경기보석의 교육학
Comparator		
String Calibrated		
Rack Temperature Effect [	1+xc	
Rack Drift [ ]+ac		
Tag No.'s - FT414, FT415, FT416, F		
FT434, FT435, FT436, FT	444, FT445, FT446	
* In percent span (120% flow)		
Channel Statistical Allowance =		
T		7 ***

#### **TABLE 3-23** TAVG, LOW AND LOW-LOW

Parameter	Allowance*
Process Measurement Accuracy (hot leg streaming)(pmaTh) Beta (hot leg streaming stability-introduced on the loss of a hot leg RTD)	
Primary Element Accuracy	
Sensor Calibration Accuracy (scartd) Sensor Reference Accuracy (srartd)	
Measurement & Test Equipment Accuracy (smte)	
Sensor Pressure Effects	
Sensor Temperature Effects	
Sensor Drift (30 months) (sdrtd)	
Environmental Allowance	
Bias [ ]***.*	
Rack Calibration Accuracy Tavg (tcal) R/E (recal) Alpha (accuracy of hot leg streaming bias on the loss of a hot leg RTD)	
Measurement & Test Equipment Accuracy Tavg (tmte) R/E (remte)	
Comparator String Calibrated	
Rack Temperature Effect (trte)	
Rack Drift (trd)	
Tag No.'s - TE411, TE421, TE431, TE441	

Parameter

<sup>\*</sup> In percent span (100 °F)
+ Number of hot leg RTDs used
++ Number of cold leg RTDs used

#### TABLE 3-23 (continued) TAVG, LOW AND LOW-LOW

$$srtd = (smtertd + sdrtd)^{2} + (scartd + smtertd)^{2} + srartd^{2} = 0.9$$

$$re = (remte + rerd)^{2} + (recal + remte)^{2} = 0.2$$

$$track = (tmte + trd)^{2} + trte^{2} + (tcal + tmte)^{2} + alpha^{2} = 1.2$$

#### REACTOR PROTECTION SYS ACTUATION SYSTEM C

							SENSOR	-
		1	2	3	4	,- ,-	6	,
	PROTECTION CHANNEL	PROCESS MEASUREMENT ACCURACY (1)	PRIMARY ELEMENT ACCURACY (1)	CALBERA TON ACCURACY (1)	REFERENCE ACCURACY (1)	MEASUREMENT & TEST EQUIPMENT ADQURACY (1)	PRESSURE EFFECTS (1)	TEMPERATURE EFFECTS (1)
1	POWER RANGE, NEUTRON FLUX - HIGH SETPOINT							
2	POWER RANGE, NEUTRON FLUX - LOW SETPOINT							
3	POWER RANGE, MEUTHON FLUX - HIGH SETPOINT (N-1 LOOP)	+						
4	POWER RANGE, NEUTRON PLUX - HIGH POSITIVE & NEGATIVE RATE	+	-					-
5	INTERMEDIATE RANGE, NEUTRON FLUX	+						
6	SOURCE RANGE, NEUTRON FLUX	H		-				-
7	OMERTEMPERATURE AT AT CHANNEL (N-LOOP)  TAYG CHANNEL PRESSURIZER PRESSURIZE CHANNEL	11 1						
_	I(AI) CHANNEL							
6	OVERPOWER AT AT CHANNEL (HLOOP)  Tang CHANNEL							
9	OVERTEMPERATURE AT (N-1 LOOP)							
10	OVERPOWER AT (N-1 LOOP)							
11	PRESSURIZER PRESSURE - LOW, REACTOR THIP (ROSEMOUNT 1154GP9 XMITTER)	1				— Т		
12	PRESSURIZER PRESSURE - HIGH, REACTOR TRIP (ROSEMOUNT 1154GP9 XMITTER)							
13	PRESSURIZER WATER LEVEL - HIGH (VERITRAX 760P1 XMITTER)	-	-					
14	PRESSURGER WATER LEVEL - HIGH (ROSEMOUNT 1153HDS XMITTER)	-	-					
15	LOSS OF FLOW (N LOOP) (ROSEMOUNT 1153HDS XMITTER)							-
16	LOSS OF FLOW (N-1 LOOP) (RICSEMOUNT 1153HDS XMITTER)			-		+		
17	STEAM GENE VATOR WATER LEVEL - LOW-LOW for FLB (ROSEMOUNT 1154DH4 XMITTER)	-	-					
18	STEAM GENERATOR WATER LEVEL - LOW-LOW for LONF (ROSEMOUNT 1154DH4 XMITTER)	-				-		
19	REACTOR COOLANT PLANP LINDERSPEED		-					-
30	PRESSURIZER PRESSURE LOW - SI (ROSEMOUNT 1154GP9 XMITTER)			-				
21	STEAMLINE PRESSURE - LOW (ROSEMOUNT 11SIGBS XMITTER)		-					-
22	CONTAINMENT PRESSURE HIGH 1 (ROSEMOUNT 11STABLE XMITTER)	-		-				-
23	CONTAINMENT PRESSURE HIGH 2 PROSEMOUNT 11SUABS XMITTER)	-			-		***	
24	CONTAINMENT PRESSURE HIGH 1 (ROSEMOUNT 1153AB6 XMITTER)							***************************************
25	MEGATIVE STEAM PRESSURE RATE - HIGH	-	-					
26	STEAM GENERATOR WATER LEVEL - HIGH-HIGH (ROSEMOUNT 11540H4 XMITTER)						-	
v	TAVG LOW & LOW-LOW							
2 3 4 5 6 7.	ALL VALUES IN PERCENT OF SPAIL AS NOTED IN TABLE 15,04 OF THE FT "?. AS NOTED IN TABLES 2.2-1 AND 3.3-4 OF THE PLANT TECHNICAL SPECIFICATIONS.  NOT USED IN SAFETY ANALYSIS. AS NOTED IN FIGURE 15.0-1 & 15.0-1 & 0.5 THE PSAIR AS NOTED IN TABLE 2.2-1, NOTES 1 AND 2 OF THE PLANT TECHNICAL SPECIFICATIONS. AS NOTED IN TABLE 2.2-1, NOTES 3 AND 4 OF THE PLANT TECHNICAL SPECIFICATIONS.	9. [ 10. [ 11. [ 12. [ 13. [ 14. ] 16. INDURE / EXC SPECIFICATION		In Inc. Inc. Inc. Inc. Inc. Inc. Inc. Inc.	)*** I IN TABLE 4.3-1 (	OF THE PLANT TECH	#NCAL	17. [ 18. [ 19. [ 20. [ 21. [ 22. [

A CONTRACTOR

ME 3-24
MENGINEERED SAFETY FEATURES
ANNEL TOTAL ALLOWANCES
ONE UNIT 3

PAGE 54 & PAGE 55

-			OTDI MONT DATE	·			-		-			
-			STRUMENT RACI	-							·	
	10	11	12	13	14	15	16	17	16	19	20	
ENVISION- MENTAL ALLOW NOE (1)	CALIBRATION ACCUPACY (1)	MEASUREMY - T  & TEST  EQUIPMENT  ACCURACY  (1)	COMPARATOR SETTING ACCURACY (1)	TEMPERATURE EFFECTS (1)	DRIFT (1)	SAFETY ANALYSIS LIMIT G)	NOMBNAL TRIP SETPOINT (3)	ALLOWABLE VALUE (3)	TOTAL ALLOWANCE (1)	CHANNEL STATISTICAL ALLOWANCE (1)	MARGIN (1)	
					7					_	7-	
-	-					118% RTP	109% RTP	\$109.6% RTP	7.5		-	1
-	-	-				35%, RTP	25% RTP	\$25.8% RTP	8.3			2
						abs. RTP	. BUNL RTP	SELEN RTP	7.5			3
						(3)	S.ON, RTP	SS.0% RTP				4
					-	(5)	25% RTP	S25.6% RTP		-		5
	-	Charles and the same of the sa				(5)	1.0E+05 CPS	\$1.06E+05 CPS		2 2 2 2 2	-	6
						FUNCTION(6)	FUNCTION(7)	PUNCTION (7)	10.0		TURE	7
						PUNCTION(6)	FUNCTION(8)	FUNCTION (8)	44	Also Ave Apertu	turle of re Card	•
						FUNCTION(6)	FUNCTION(7)	FUNCTION (7)	10.0			9
						FUNCTION(6)	FUNCTION(8)	FUNCTION (8)	4.8			10
			-		-	1860 PSIA	1900 PSIA	≥1897.6 PSIA	5.0	-	-	-
-	1					2425 PSIA	2065 PSIA	\$2387.4 PSIA	5.0			11
						(5)	89% SPAN	589.3% SPAN			-	13
						(5)	89% SPAN	SBEJN SPAN		-	-	14
						85% DESIGN	90% DESIGN	289.8% DESIGN	4.2	1		15
			A			85% DESIGN	90% DESIGN	269.8% DESIGN	42	H	-	16
						0% SPAN	18.1% SPAN	217.8% SPAN	18.1	<del>                                     </del>	-	17
THE RESERVE THE PERSON NAMED IN						10% (PAN	18.1% SPAN	≥17.8% SPAN	8.1			18
						92% RMS	92.4% RNS	290.2% RNS	1.7			19
						1700 PSIA	1892 PSIA	≥1689.6 PSIA	24.0			20
						420 PSIG	658.6 PSIG	2654.7 PSIG	18.4			21
			THE RESERVE OF THE PERSON NAMED IN COLUMN 1			10.7 PSIA	17.7 PSIA	£17.9 PSIA	3.3			22
						19.7 PSIA	17.7 PSIA	\$17.9 PSIA	3.3			23
						24.7 PSIA	22.7 PS/A	\$22.9 PSIA	3.3			24
						(5)	100 PSVS	≤KD.9 PSVS	-			25
						98% SPAN	80.5% SPAN	580.8% SPAN	15.5			28
						(5)	564" F / 553" F	2963.6 °F 269.2.6 °F	-			Z

9710200071-01

### REACTOR PROTECTION SYS

MILI

				SENSOR					
-		1	2	3	4	5	6	7	Γ
	PROTECTION CHANNEL	PROCESS MEASUREMENT ACCURACY (1)	PRIMARY ELEMENT ACCURACY (1)	CALBRATION ACCURACY (1)	REFERENCE ACCURACY (1)	MEASUREMENT & TEST EQUIPMENT //OCURACY (1)	PPESSURE EFFECTS (1)	TEMPERATURE EFFECTS (1)	
1	POWER RANGE, NEUTRON FLUX - HIGH SETPOINT						18.111		-
2	POWER RANGE, NEUTRICH FLUX - LOW SETPOINT	-						-	-
3	POWER RANGE, NEUTRON FLUX - HIGH SETPOINT (N. 1 LOOP)	-			-		-	-	-
4	POWER RANGE, NEUTRON PLUX - HIGH POSITIVE & NEGATIVE RATE	-							-
5	INTERMEDIATE RANGE, NEUTRON FLUX	-							-
6	SOURCE RANGE, NEUTRON FLUX	1				-		-	-
7	OVERTEMPERATURE AT AT CHANNEL	-							-
	(N-LOOP)  TAVG CHANNEL  PRESSUREZER PRESSURE CHANNEL  ((A)) CHANNEL								
	OVERPOWER AT AT CHANNEL (N-LOOP)								
9	Tang CHANNEL  OVERTEMPERATURE AT	-				1			
10	(N-1 LOOP)  OVERPOWER AT (N-1 LOOP)	-	-				-		
11	PRESSURIZER PRESSURE - LOW, REACTOR TRIP (ROSEMOUNT 1154-3P9 XMITTER)	-							
12		+							-
13		-							-
14		-							
15								-	
16									_
.7		-						-	
18									_
19	STEAM GENERATOR WATER LEVEL - LOW-LOW for LONG (PICSEMOUNT 1154DH4 XMITTER) REACTOR COCULANT PUMP UNDERSPEED	-							_
20									_
21								-	
22	(Autoritation of the Control of the	-							es in i
23	Parameter 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1								encom.
24	CONTAINMENT PRESSURE HIGH 2 (ROSEMOUNT 11SABS XMITTER)	-				-			_
	CONTAINMENT PRESSURE HIGH 3 (ROSEMOUNT 11SSAB6 XMITTER)								_
25	NEGATIVE STEAM PRESSURE RATE - HIGH	-							-
26	STEAM GENERATOR WATER LEVEL - HIGH HIGH (ROSEMOUNT 11540H4 XMITTER)	-							
27	TAVG LOW & LOW-LOW								
1.234567	ALL VALUES IN PERCENT OF SPAIN. AS NOTED IN TABLE 15.0-4 OF THE PSAIR. AS NOTED IN TABLES 2.2-1 AND 3.3-4 OF THE PLANT TECHNICAL SPECIFICATIONS.  [ NOT USED IN SAFETY ANALYSIS. AS NOTED IN PRILIPE 15.0-1 & 15.0-10 OF THE PSAIR AS NOTED IN TABLE 2.2-1, NOTES 1 AND 2 OF THE PLANT TECHNICAL SPECIFICATIONS. AS NOTED IN TABLE 2.2-1, NOTES 3 AND 4 OF THE PLANT TECHNICAL SPECIFICATIONS.	9. [ 10. [ 11. [ 12. [ 13. [ 14. [ 15. ] 16. INCORE / EXC SPECIFICATIO		Jee Jee PARISON AS NOTEI	IMA IN TABLE 4.3-1	OF THE PLANT TEO	HNICAL	17. [ 18. [ 19. [ 20. [ 21. [ 22. [	

	9	10	- 11	12	43	44	4.0					THE R. P. LEWIS CO., LANSING, MICH.	-
+			-	12	13	14	15	16	17	18	19	20	
FT	ENVIRON- MENTAL ALLOWANCE (1)	CALBRATION ACCURACY (1)	MEASUPEMENT A TEST EQUIPMENT ACCURACY (1)	COMPARATOR SETTING ACCURACY (1)	TEMPERATURE EFFECTS (1)	DRIFT (1)	SAFETY ANALYSIS LIMIT Ø)	NOMBHAL TRIP SETPOINT (3)	ALLOMABLE VALUE (3)	TOTAL ALLOWANCE (1)	CHANNEL STATISTICAL ALLOWANCE (1)	MARGIN	
T						7				14	Press. (1)	(1)	
+						-	118% RTP	100% RTP	S109.8% A1.9	7.5			1
+	-				-		36% RTP	25% RTP	525.6% RTP	8.3			2
+							89% RTP	80% RYP	580.6% RTP	7.5			3
+							(5)	5.0% RTP	SS. SY. RTP	in			4
+	-						(5)	25% RTP	SELEN RIT	-			5
+							(5)	1.0E+05 CPS	\$1.06E+05 CPS				- 6
							FUNCTION(6)	FUNCTION(7)	FUNCTION (7)	90.0	ANS	TURE	7
-											CA		
+							FUNCTION(6)	PUNCTION(8)	FUNCTION (6)	4.8	Aleo Ava Apertu	ra Card	
1					1		PUNCTION(6)	FUNCTION(7)	FUNCTION (7)	10.0			1
	***************************************						FUNCTION(6)	FUNCTION(8)	FUNCTION (8)	4.6			10
T							1860 PS/4	1900 PSIA	21897.6 PSIA				
T						-	2NS PSIA	2385 PSIA	S2987.4 PSIA	5.0			11
T		-					(6)	89% SPAN	SELIN SPAN	8.0			12
T							(8)	80% SPAN	589.7% SPAN	-			13
T							85% DESIGN	90% DESIGN	389.8% DESIGN	4.2	-		14
T							85% DESIGN	90% DESIGN	260.9% DESIGN	42	-	-	15
T							Ms SPAN	18.1% SPAN	≥17.8% SPAN	18.1	-	-	16
T							K/N SPAN	18.1% SPAN	217.8% SPAN	6.1	-	-	17
T							92% RNS	92.4% HMS	26L2% RNS	1.7	-	-	10
I							1700 PSIA	1892 PSIA	≥1889.6 PSJA	24.0	-	-	19
I							420 PSAG	658.6 PSIG	2864.7 PSIG	18.4	-	-	21
I							15.7 PSIA	17.7 PSIA	\$17.9 PSIA	3.3	1		22
I							19.7 ≥SIA	17.7 PSIA	≤17.9 PSIA	1.3	+	-	23
T							24.7 PSIA	22.7 PSIA	520.9 PSIA	3.3	1	+	24
I							(5)	100 PSI/S	≤100.9 PSVS	_	+	-	-
J							90% SPAN	90.5% SPAN	SBC.8% SPAN	15.5	1	-	25
1							(5)	564" F / 583" F	≥563.6 °F	-		-	26
_	7				23. (		<u></u>		2652.6 °F				
	per .	)**  **			25. [	RESISTANCE I	DEGRADATKIN - TRE	ATED AS A BIAS					

#### TABLE 3-25

### OVERTEMPERATURE AT CALCULATIONS (Rosemount 1154GP9 Transmitter for Pressurizer Pressure)

■ The equation for Overtemperature  $\Delta T$ :

$$\frac{\Delta T}{\Delta T_0} \, \frac{(1 \, + \, \tau_1 S)}{(1 \, + \, \tau_2 S)} \, \leq \, \left( K_1 \, - \, K_2 \frac{(1 \, + \, \tau_4 S)}{(1 \, + \, \tau_2 S)} \, \left( T \, - \, T' \right) \, + \, K_S \, \left( F \, - \, P' \right) \, - \, f_1 \, \left( \Delta I \right) \, \right)$$

K<sub>1</sub> (nominal) = 1.20 Technical Specification value

K<sub>1</sub> (max) = [ ]\*\*\*.

 $K_2 = 0.02456/^{\circ}F$ 

 $K_3 = 0.001311/psi$ 

Vessel  $\Delta T$  = 60.2 °  $\Gamma$  (N Loop)

Vessel  $\Delta T$  = 58.0 °F (N-1 Loop)

 $\Delta I$  gain = 1.98% RTP/%  $\Delta I$ 

■ Full power ∆T calculation:

 $\Delta T \text{ span} = [$ 

 $\Delta T \text{ span} = [$ 

]\*4,0

■ Process Measurement Accuracy Calculations:

[ ].re

\* Presumes normalization of  $\Delta T_0$  and T to as found full power indicated values.

## TABLE 3-25 (continued) OVERTEMPERATURE AT CALCULATIONS (Rosemount 1154GP9 Transmitter for Pressurizer Pressure)

	ΔI - Incore / Excore Mismatch	7***
	ΔI - Incore Map Delta-I	7***
■ Pressi	ure Channel Uncertainties	. *4.0
Gair		] +4.0
SCA	[[[대대][[[대대][[[[[[[[[[[[[[[[[[[[[[[[[[	
SMT		
SD	[경하다] 교육하다 하는 사람들은 사람들이 되었다.	
RCA RMT		1***
RD	*	

## TABLE 3-25 (continued) OVERTEMPERATURE AT CALCULATIONS (Rosemount 1154GP9 Transmitter for Pressurizer Pressure)

#### ■ △I Channel Uncertainties

#### ■ Total Allowance



Same result for N-1 Loop

### TABLE 3-26 OVERPOWER AT CALCULATIONS

■ The equation for Overpower  $\Delta T$ :

$$\frac{\Delta T}{\Delta T_0} \frac{(1 + \tau_1 S)}{(1 + \tau_2 S)} \leq \{K_4 - K_5(\frac{\tau_7 S}{(1 + \tau_7 S)}) T - K_6 [T - T']\}$$

K<sub>4</sub> (nominal) = 1.09 Technical Specification value

 $K_4$  (max) = [  $\gamma^*$ a.c

K<sub>4</sub> = 0.0 for decreasing average temperature

K<sub>5</sub> = 0.02 for increasing average temperature (sec/°F)

 $K_6 = 0.0018/^{\circ}F$ 

Vessel ΔT = 60.2 °F (N Loop)

Vessel  $\Delta T$  = 58.0 °F (N-1 Loop)

■ Full power ∆T calculation:

$$\Delta T \text{ span} = [$$

 $\Delta T \text{ span} = [$ 

]\*\*\*\*

■ Process Measurement Accuracy Calculations:

]\*\*\*\*

1

]+4,0

Presumes normalization of  $\Delta T_0$  and T'' to as found full power indicated values.

### TABLE 3-26 (Continued) OVERPOWER AT CALCULATIONS

Total Allowance

\*\* Same results for N-1 Loop

### TABLE 3-27 AP MEAST REMENTS EXPRESSED IN FLOW UNITS

The  $\Delta P$  accuracy expressed as percent of span of the transmitter applies throughout the measured span, i.e.,  $\pm 1.5\%$  of 100 inches  $\Delta P = \pm 1.5$  inches anywhere in the span. Because  $P^2 = f(\Delta P)$  the same cannot be said for flow accuracies. When it is more convenient to express the accuracy of a transmitter in flow terms, the following method is used:

$$(F_N)^2 = \Delta P_N$$
 where N = Nominal Flow

thus 
$$\partial F_{N} = \frac{\partial \Delta P_{N}}{2F_{N}}$$
 Eq. 3-27.1

For at a point (not in percent) is:

$$\frac{\partial F_N}{F_N} = \frac{\partial \Delta P_N}{2(F_N)^2} = \frac{\partial \Delta P_N}{2\Delta P_N}$$
 Eq. 3-27.2

and

$$\frac{\Delta P_{N}}{\Delta P_{max}} = \frac{(F_{N})^{2}}{(F_{max})^{2}}$$
 Eq. 3-27.3

where max = maximum flow and the transmitter  $\Delta P$  error is:

$$\frac{\partial \Delta P_{N}}{\Delta P_{max}}$$
 (100) = percent error in Full Scale ΔP (% ε FS ΔP)

Eq. 3-27.4

therefore:

$$\frac{\partial F_{N}}{F_{N}} = \frac{\Delta P_{\text{max}} \left[ \frac{\% \in FS \Delta P}{100} \right]}{2 \Delta P_{\text{max}} \left[ \frac{F_{N}}{F_{\text{max}}} \right]^{2}} = \left[ \frac{\% \in FS \Delta P}{(2)(100)} \right] \left[ \frac{F_{\text{max}}}{F_{N}} \right]^{2}$$

Eq. 3-27.5

Error in flow units is:

$$\partial F_{N} = F_{N} \left[ \frac{\% e FS \Delta P}{(2)(100)} \right] \left[ \frac{F_{max}}{F_{N}} \right]^{2}$$

Eq. 3-27.6

Error in percent nominal flow is:

$$\frac{\partial F_{N}}{F_{N}}(100) = \left[\frac{\% \in FS \Delta P}{2}\right] \left[\frac{F_{max}}{F_{N}}\right]^{2}$$

Eq. 3-27.7

Error in percent full span is:

$$\frac{\partial F_{N}}{F_{max}}(100) = \left[\frac{F_{N}}{F_{max}}\right] \left[\frac{\% \in FS \Delta P}{(2?(100))}\right] \left[\frac{F_{max}}{F_{N}}\right]^{2} (100)$$
$$= \left[\frac{\% \in FS \Delta P}{2}\right] \left[\frac{F_{max}}{F_{N}}\right]$$

Eq. 3-27.8

Equation 3-27.8 is used to express errors in percent full span in this document.

This page intentionally left blank

## 4.0 APPLICATION OF THE SETPOINT METHODOLOGY

## 4.1 Uncertainty Calculation Basic Assumptions/Premises

.

The equations noted in Sections 2 and 3 have several basic premises which were determined by a systematic review of the calibration and drift determination procedures utilized at Millstone Unit 3 and statistical evaluations of "as left" and "as found" data for the RPS/ESFAS functions noted in Tables 3-1 through 3-24 of this document:

- 1) the instrument technicians make reasonable attempts to achieve the Nominal Trip Setpoint as an "as left" condition at the start of each process rack's surveillance interval,
- 2) the instrument technicians make reasonable attempts to achieve a nominal "as left" condition at the start of each sensor/transmitter's surveillance interval.
- 3) the process rack drift is evaluated (probability distribution function characteristics and drift magnitude) over multiple surveillance intervals,
- 4) the sensor/transmitter drift is trended over the fuel cycle and evaluated (probability distribution function characteristics and drift magnitude) over multiple fuel cycles,
- 5) the process rack calibration accuracy is evaluated (probability distribution function characteristics and calibration magnitude) over multiple surveillance intervals,
- 6) the sensor/transmitter calibration accuracy is evaluated (probability distribution function characteristics and calibration magnitude) over multiple surveillance intervals,

- 7) the process racks (with the exception of the bistables) are calibrated using a one up (or one down) pass utilizing multiple calibration points (minimum 4 points and for many functions 5 points, as recommended by ISA51.1<sup>[1]</sup>).
- 8) the sensor/transmitters are calibrated using a one up (or one down) pass utilizing multiple calibration points (minimum 4 points and for many functions 5 points, as recommended by ISA51.1<sup>[2]</sup>)

It should be riced for (1) and (2) that it is not necessary for the instrument technician to recalibrate a device or channel if the "as left" condition is not exactly at the nominal condition but is within the plus or minus of nominal "as left" procedural tolerance. As noted above, the uncertainty calculations assume that the "as left" tolerance (conservative and non-conservative direction) is satisfied on a reasonable, statistical basis, not that the nominal condition is satisfied exactly. Westinghouse has statistically evaluated the "as left" condition for the RPS/ESFAS process rack channels and sensor/transmitters for Millstone Unit 3 over multiple calibration cycles. This evaluation determined that the SCA and RCA parameter values noted in Tables 3-1 through 3-24 were satisfied on at least a 95% probability / 95% confidence level basis. For those instances where non-conservative biases in calibration were noted, the biases were factored into the uncertainty calculations. Calibration biases for sensor/transmitters were considered as non-conservative since sensor/transmitter signals are used for both control and protection and could be considered significant for control purposes. It is therefore necessary for the plant to periodically reverify the continued validity of these results. This prevents the institution of nonconservative biases due to a procedural basis without the plant staffs knowledge and appropriate treatment.

In summary, a sensor/transmitter or a process rack channel is considered to be "calibrated" when the two-sided "as left" calibration procedural tolerance is satisfied. An instrument technician may determine to recalibrate if near "he extremes of the "as left" procedural tolerance, but it is not required. "ecalibration is explicitly required any time the "as found" condition of the device or channel is outside of the "as left" procedural tolerance. A device or channel may not be left outside the "as left"

tolerance without declaring the channel "inoperable" and appropriate action taken. Thus an "as left" tolerance may be considered as an outer limit for the purposes of calibration and instrument uncertainty calculations

As part of this effort, drift data ("as found" - "as left") for the sensor/transmitters and the process evaluated. Multiple surveillance intervals were evaluated to determine the appropriate value. See first for a surveillance interval of 30 months (for sensor/transmitters) and 3 months (for analog process rack modules). This evaluation determined that the SD and RD parameter values noted in Tables 3-1 through 3-24 were satisfied on a 95% probability / 95% confidence level basis for the projected surveillance intervals. Generic Letter 91-04<sup>[3]</sup> requires that drift be tracked or trended on a periodic basis. The equations used in Sections 2 and 3, assume that drift data is evaluated for continuation of the validity of the basic characteristics determined by the Westinghouse evaluation. This assumption has a significant beneficial effect on the basic uncertainty equations utilized, i.e., it results in a reduction in the CSA magnitude.

## 4.2 Sensor/Transmitter Operability Determination Program and Criteria

As a result of the review of the plant procedures, the equations noted in Sections 2 and 3 are significantly different from those used in previous Westinghouse uncertainty calculations. One aspect of the equations easily noted is the significance of the calibration process, i.e., it is treated as statistically independent of the drift determination. Another aspect is that if drift and calibration are independent processes, then the determination of equipment operability is changed, i.e., it is not the arithmetic sum of the two uncertainties. Millstone Unit? and Westinghouse have agreed upon a set of criteria that may be used for equipment operability determination which are controlled by plant procedures and processes, as opposed to the plant Technical Specifications. The principle criterion for sensor/transmitter operability, as a first pass parameter, is drift ("as found" - "as left") determined to be within SD, where SD is the 95/95 drift value determined for that specific device, e.g., a Pressurizer Pressure transmitter. This would require the instrument technician to record both the "as left" and "as

found" conditions and perform a calculation in the field. This field calculation has been determined to be impracticable at this time since it would require having the "as left" value for that device at the time of drift determination and becomes a records availability/control problem. An alternative is the use of a fixed magnitude, two-sided "as found" tolerance about the nominal value. It was agreed that a reasonable value for this tolerance is SMTE + SD, where SD is again the 95/95 drift value and SMTE is as defined in the uncertainty calculations and identified in the Milistone Unit 3 procedures reviewed by Westinghouse. The value of this sum is explicitly noted for each RPS/ESFAS function in Table 4-1 of this document. This criterion can then be incorporated into plant function specific calibration and drift procedures as the defined "as found" tolerance about the desired, nominal value.

A second criterion is the ability to calibrate the sensor/transmitter within the two-sided "as left" tolerance. If the device drift is found outside the SMTE + SD (or "as found") criterion, the drift characteristics may be evaluated incorporating the previous experience for that specific device. The response time characteristics may also be evaluated on a qualitative and if necessary, a quantitative basis. It has also been agreed by Millstone Unit 3 and Westinghouse that monitoring the sensor/transmitter response with the average of its peer devices, utilizing data available online, periodically over the entire cycle is an additional check on operability. This additional check provides a reasonable substitute for the use of a relative SD term (as recommended in the Westinghouse paper presented at the ISA/EPRI conference of June, 1994<sup>[4]</sup>). When an appropriate acceptance criterion is utilized, it then allows the use of SMTE + SD as a first pass operability criterion. The acceptance criterion agreed upon between Millstone Unit 3 and Westinghouse is a relative deviation of ±0.5 % span from the beginning of cycle difference value. A relative shift of this magnitude has been determined to be an appropriate indication of device drift warranting further investigation.

It is believed that the Millstone Unit 3 systematic sensor/transmitter program of drift and calibration review is acceptable as a set of first pass criteria. More elaborate evaluation and more frequent online monitoring may be included, as necessary, if the drift is found to be excessive or the device is found difficult to calibrate. To provide additional confidence in the evaluation process, Millstone Unit 3 has agreed to utilize a function indication match criterion at the beginning of each cycle to determine the

acceptability of the calibration process for the transmitter and that portion of the channel encompassed through the indicator. Based on the above, it is believed that the total program proposed for Millstone Unit 3 will provide a more comprehensive evaluation of operability than a simple determination of an acceptable "as found".

#### 4.3 Process Rack Operability Determination Program and Criteria

A similar program to that described for sensor/transmitters has been determined for the process racks. However, since the surveillance interval for the process racks is significantly shorter than the sensor/transmitter (3 months vs 30 months) and the process racks are accessible at power, the program does not have to be as comprehensive. The parameter of most interest as a first pass operability criterion is drift ("as found" - "as left") found to be within RD where RD is the 95/95 drift value determined for that channel. However, this has the same difficulties as the drift determination for a sensor/transmitter, i.e., records of the "as left" condition must be available for field use in a calculation with the same records availability/control problems. A similar alternative may be used for the process racks as was agreed upon for the sensor/transmitter, a fixed magnitude, two-sided "as found" tolerance about the nominal trip setpoint. Presuming similarity with the transmitter program, it would be reasonable for this "as found" tolerance to be RMTE + RD, where RD is the 95/95 drift value and RMTE is as defined in the uncertainty calculations and identified in the Millstone Unit 3 procedures reviewed by Westinghouse. This value is explicitly noted for each RPS/ESFAS function in Table 4-1 as the Rack Operability column. However, comparison of this value with the "as left" tolerance utilized in the plant procedures and the Westinghouse uncertainty calculations will note that this "as found" tolerance is less than the "as left" tolerance. This is due to the fact that RD is a relative drift magnitude as opposed to an absolute drift magnitude and that the process racks are very stable, i.e., do not drift much. Thus it is not reasonable to use this criterion as an "as found" tolerance in an absolute sense as it conflicts with the second criterion for operability determination. That is, a channel could be left near zero, found outside the absolute drift criterion yet be inside the calibration criterion and not actually have exceeded the relative drift criterion. Therefore, a more reasonable approach for the plant staff was determined. The "as found" criterion based on absolute magnitude is the same as the

"as left" criterion, i.e., the allowed deviation from the Nominal Trip Setpoint on an absolute indication basis is plus or minus the "as left" tolerance. A process loop found inside the "as left" tolerance on an indicated basis is considered to be operable. A channel found outside the "as left" tolerance is evaluated and recalibrated. If the channel can be returned to within the "as left" tolerance, the channel is considered to be operable. This criterion can then be incorporated into plant, function specific calibration and drift procedures as the defined "as found" tolerance about the Nominal Trip Setpoint. At a later date, once the "as found" data is compiled, the relative drift ("as found" - "as left") can be calculated and compared against the Rack Operability column of Table 4-1. This comparison can then be utilized to ensure consistency with the assumptions of the uncertainty calculations documented in Tables 3-1 through 3-24. Since the channel was left within the calibration tolerance, any determination that Table 4-1 criteria were exceeded would result in a conclusion that the affected hardware should be watched more closely. A channel found to exceed the criteria of Table 4-1 multiple times should trigger a more comprehensive evaluation of the operability of the channel.

The second criterion used for operability determination is the ability to calibrate the process rack channel within the two-sided "as left" tolerance. If the channel relative drift is determined to be outside the RMTE + RD (or operability) criterion, the drift characteristics may be evaluated incorporating the previous experience for that specific channel. The response time characteristics for the channel (or individual process rack module) may also be evaluated on a qualitative and if necessary, a quantitative basis. There is not as much information to be gained by evaluating channel to average of peer channels utilizing control board or process computer indication due to the difference in uncertainty significance, i.e., the uncertainty associated with a control board indicator is significantly larger than the uncertainty associated with a trip bistable. Therefore channel to channel or average of channels comparison is not expected to provide significant indication of operability of the process racks in any way other than in a gross manner. Thus no recommendations have been made in performing this process for the racks. (It should be noted that this type of comparison is considered beneficial for transmitters and is included for that purpose in Section 4.2 by Millstone Unit 3 and Westinghouse).

It is believed that the Millstone Unit 3 systematic program of drift and calibration review proposed for the process racks is acceptable as a set of first pass criteria. More elaborate evaluation and monitoring may be included, as necessary, if the drift is found to be excessive or the channel is found difficult to calibrate. Based on the above, it is believed that the total process rack program proposed for Millstone Unit 3 will provide a more comprehensive evaluation of operability than a simple determination of an acceptable "as found".

#### 4.4 Application to the Plant Technical Specifications

The drift operability criteria noted for the process racks in Section 4.3 are based on a statistical evaluation of the performance of the installed hardware. Thus the values can change if the Measurement and Test Equipment is changed, or the procedures used in the surveillance process are changed significantly and particularly if the process rack modules themselves are changed, e.g., from pure analog to a mixture of analog and ASIC (Application Specific Integrated Circuit) modules. Therefore, the operability criteria are not expected to be static. In fact they are expected to change as the characteristics of the equipment change. This does not imply that the criteria can increase due to increasingly poor performance of the equipment over time. But rather just the opposite. As new and better equipment and processes are instituted, the operability criteria magnitudes would be expected to decrease to reflect the increased capabilities of the replacement equipment. For example, if the plant purchased some form of equipment that allowed the determination of relative drift in the field, it would be expected that the Rack Operability column values of Table 4-1 would then be used as the "as found" acceptance criteria in the plant procedures.

Sections 4.2 and 4.3 are basically consistent with the recommendations of the Westinghouse paper presented at the June 1994, ISA/EPRI conference in Orlando Fl<sup>[5]</sup>. Therefore, consistent with this paper, Westinghouse recommends revision of Specification 2.2.1, "Limiting Safety System Settings - Reactor Trip System Instrumentation Setpoints", Specification 3.3.2, "Engineered Safety Features Actuation System Instrumentation - Limiting Condition for Operation", Table 2.2-1 "Reactor Trip

Instrumentation Setpoints" and Table 3.3-4, "Engineered Safety Features Actuation System Instrumentation Trip Setpoints". Appendix A provides the Westinghouse recommendations for revision of these two specifications and tables. Table 3-24 (Column 16) and Table 4-1 of this document provide the recommended Nominal Trip Setpoint for each RPS/ESFAS protection function, which was utilized in the Westinghouse uncertainty calculations and deter ained to be acceptable for use. Table 4-1 also notes the Westinghouse recommended operability critical for each RPS/ESFAS protection function sensor/transmitter and process rack channel. These recommended in the plant procedures and maintained under plant administrative control. This is consistent with the bases sections for the two specifications provided in Appendix A. In addition, the plant operability determination processes described in Sections 4.2 and 4.3 are consistent with the basic intent of the ISA paper and the bases sections for the two specifications provided in Appendix A.

## 4.5 References/Standards

- Instrument Society of America Standard S51.1 1979, "Process instrumentation Terminology", p 33, 1979.
- [2] Ibid
- [3] Generic Letter 91-04, 1991, "Changes in Technical Specification Surveillance Intervals to Accommodate a 24 month Fuel Cycle."
- [4] Tuley, C. R., Williams, T. P., "The Allowable Value in the Westinghouse Setpoint Methodology - Fact or Fiction?" presented at the Thirty-Seventh Power Instrumentation Symposium (4th Annual ISA/EPRI Joint Controls and Automation Conference), Orlando Fl., June, 1994.
- [5] Ibid
- [6] Ibid

TABLE 4-1
WESTINGHOUSE PROTECTION SYSTEM STS SETPOINT INPUTS
MILLSTONE UNIT 3

		MILECOTOTE OF	*** 5			
	PROTECTION CHANNEL	SENSOR OPERABILITY (1.8)	RACK OPERABILITY (1.9)	INSTRUMENT SPAN	NOMINAL TRIP SETPOINT	-
*	POWER RANGE, NEUTRON FLUX - HIGH SETPOINT	-	0.4% SPAN	120% RTP	109% RTP	,
2	POWER RANGE, NEUTRON FLUX - LOW SETPOINT		0.4% SPAN	28% RTP	25% RTP	2
3	POWER RANGE, NEUTRON FLUX - HIGH SETPOINT (N-1 LOOP)	-	0.4% SPAN	120% RSP	80% RIP	3
4	POWER RANGE, NEUTRON FLUX - HIGH POSITIVE & NEGATIVE RATE	gas.	0.4% SPAN	120% RTP	5 0% RTP	4
5	INTERMEDIATE RANGE, N. GTRON FLUX	-	0.4% SPAN	120% RTP	25% RTP	5
6	SOURCE RANGE, NEUTRON FLUX	14.	0.3% SPAN	10E+66 CPS	1.6E+65 CPS	6
7	OVERTEMPERATURE AT AT CHANNEL (N-LOOP)	- (11)	0.6% SPAN	Ø	FUNCTION(6)	1
	TAYG CHANNEL	— (11)	0.4% SPAN			
	PRESSURIZER PRESSURE CHANNEL (ROSEMOUNT 1/54GP9)	1.3% SPAN (10)	0.2% SPAN		le de la companya de	
	N(ΔI) CHANNEL		0.4% SPAN			
8	OVERPOWER AT AT CHANNEL (#160P)	- (tt)	0.4% SPAN	0	FUNCTION(7)	
	Tavg CHANNEL	- (t1)	0.4% SPAN			
9	OVERTEMPERATURE AT AT CHANNEL (N-1 LOOP)	-(11)	0.4% SVAN		FUNCTION(6)	9
	TAVG CHANNEL	-(11)	0.4% SPAN			
	PRESSURIZER PRESSURE CHANNEL (ROSEMOUNT 1154GP9)	1 3% SPAN (10)	0.2% SPAN			
	f(AI) CHANNEL		0.4% SPAN			
0	OVERPOWER AT AT CHANNEL (N.1 LOOP)	-(11)	G4% SPAN	6)	FUNCTION(7)	10
	Tavg CHANNEL	(11)	6 ML SPAN	TELF		
1	PRESSURIZER PRESSURE - LOW, REACTOR TRUP (ROSEMOUNT 1154GPB XMITTER)	1.9% SPAN	0.2% SPAN	890 PSI	1900 PSIA	11
2	PRESSURIZER PRESSURE - HIGH REACTOL TRIP (ROSEMOUNT 1154GP9 XMITTER)	13% SPAN	0.2% SPAN	800 PSI	2985 PSIA	12
3	PRESSURIZER WATER LEVEL HIGH (VERITRAK 780P1 XMITTER)	1.4% SPAN	0.2% SPAN	100% SPAN	89% SPAN	13
	PRESSURIZER WATER LEVEL - Y'H (ROSEMOUNT 1153HDS XMITTER)	12% SPAN	0.2% SPAN	100% SPAN	80% SPAN	14

""STINGHOUSE PROTECTION SYSTEM STS SETPOINT INPUTS
MILLSTONE UNIT 3 TABLE 4-1

			The second secon		the same of the sa	the second named in column 2 is not a se	-
	PROTECTION CHANNEL	ANNEL	SENSOR OPERABILITY (1.8)	RACK OPERABILITY (1.9)	INSTRIMENT SPAN	NOMINAL TRIP SETPOINT	
8	PCS LOW FLOW (N LOOP)	(ROSEMOUNT 1153HDS XMITTER)	0 PPL SPAN	2.7% SPAN	126%, DESIGN FLOW	RPS, DESIGN	\$
PC.	RCS LOW FLOW (N.1.100P)	GROSEWOURT HISHOS XMITTER)	DEM, SPARI	0.3%, SPAN	120%, DESIGN FLOW	90%, DESIGN	2
315	STEAN ANTON WATER LEVEL - LOW LOW	PATOR WATER LEVEL - LOW-LOW PROSEMOUNT TISATHA XMETTER;	1.2% SPAN	報の記号	100%, SPAN	IN PLE SPAR	22
98	REACT 4 COCHANT PUMP UNDERSPEED			D. etc. SPARC	HIDEL SPAN	45 PS, SPAN	12
PR	PRESSURIZER PRESSURE LOW - SI	PROSEMOUNT 1154GP9 XMITTER)	1.7% SPAN	0.2% SPAN	800 PSs	1892.3 PSA	2
STE	STEAMUNE PRESSIGE . LOW	(ROSEMOUNT HISIGBS XMITTER);	0.9% SPAN	0.2% SPAN	1300 PSI	SIS 4 8 859	22
90	CONTAINMENT PRESSINE HIGH 1	PROSEMOUNT INSIABLE XMITTER)	D BY, SPAK	0.2% SPAR	60 PSI	17.7 PSIA	12
60	CONTARMENT PRESSURE HIGH 2	(ROSEMOUNT 1153AB6 XMITTER)	OBN. SPAN	0.2% SPAN	80 PSI	17.7 PSIA	8
800	CONTAMMENT PRESSURE HIGH 3	(ROSEMOUNT 1153AB6 XMITTER)	0 8%, SPAN	9.2% SPAN	80 PSI	22.7 PSIA	2
MEG	NEGATIVE STEAM PRESSURE RATE - HIGH		DIPLE SPAN	8.2% SPAN	1300 PSI	100 PSIS	38
STE	STEAM GENERATOR WATER LEVEL - HIGH-HIGH - \$100EAROUNT 1150DHA MATTER)	(ROSEMOUNT 11SADHA XMITTER)	1.2% SPAN	0.2% SPAN	100%, SPAN	80.5% SPAN	16
TAVE	TAVG LOW & LOW LOW		-(11)	Der SPAN	100° F	SAFF. 552°F	16
NOTES:	NOTES: (1) ALL VALUES IN PERCENT SPAN		(5) T <sub>ree</sub> - 150° F P - 800 PSS \$ - 120%, RTP 5] - 87° F				

(2) T<sub>A122</sub> 100° F P : 800 PSI • : 200° F A1 : 90.3° F A1 : 160° A

IS AS NOTED IN TABLE 221, NOTE 1:0F THE PLANT TECHNICAL SPECIFICATIONS (7) AS NOTED IN TABLE 221, NU. IE 2 OF THE PLANT TECHNICAL SPECIFICATIONS

(3) T<sub>4-3</sub> - 100° F P - 800 PSS + - 129% RTP 51 - 90.3° F

100° F - 800 PSI - 120% RTP - 87° F - 160% Al

(10) PRESSURE SPAN - 800 PSI

(11) NARROW HANGE (, AND T, RTDs, 0,e' F

## APPENDIX A

SAMPLE MILLSTONE UNIT 3
SETPOINT TECHNICAL SPECIFICATIONS

### SAFETY LIMITS AND LIMITING SAFETY SYSTEM SETTINGS

## 2.2 LIMITING SAFETY SYSTEM SETTINGS

## REACTOR TRIP SYSTEM INSTRUMENTATION SETPOINTS

2.2.1 The Reactor Trip System Instrumentation Channel and Interlock Channel shall be OPERABLE.

APPLICABILITY: As shown for each channel in Table 3.3-1.

#### ACTION:

- a. With a Reactor Trip System Instrumentation Channel or Interlock Channel Nominal Trip Setpoint inconsistent with the value shown in the Nominal Trip Setpoint column of Table 2.2-1, adjust the Setpoint consistent with the Nominal Trip Setpoint value.
- b. With a Reactor Trip System Instrumentation Channel or Interlock Channel found to be inoperable, declare the channel inoperable and apply the applicable ACTION statement requirement of Specification 3.3.1 until the channel is restored to OPERABLE status.

# TABLE 2.2-1 REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

1.		Nominal Trip Setpoint	Allowable Value
	Manual Reactor Trip	N.A.	N.A.
2.	Power Range, Neutron Flux,		
	High Setpoint		
	Four Loops Operating     Three Loops Operating	109% of RTP* 80% of RTP*	≤ 109.6% RTP* ≤ 80.6% RTP*
	Low Setpoint	25% of RTP*	≤ 25.6% RTP*
3.	Power Range, Neutron Flux, High Positive Rate	5% of RTP* with a time constant ≥ 2 seconds	$\leq$ 5.6% RTP* with a time constant $\geq$ 2 seconds
4.	Deleted		
5.	Intermediate Range, Neutron Flux	25% of RTP*	≤ 25.6% RTP*
6.	Source Range, Neutron Flux	10*5 cps	≤ 1.06 x 10 <sup>+8</sup> cps
7.	Overtemperature ΔT		
	a. Four Loops Operating		
	1) Channels I, II 2) Channels III, IV	See note 1 See note 1	See note 2 See note 2
	b. Three Loops Operating		
	1) Channels I, II 2) Channels III, IV	See note 1 See note 1	See note 2 See note 2
8.	Overpower $\Delta T$	See note 3	See note 4
9.	Pressurizer Pressure - Low	1900 psia	≥ 1897.6 psia
10.	Pressurizer Pressure - High	2385 psia	≤ 2387.4 psia
11.	Pressurizer Water Level - High	89% of instrument span	≤ 89.3% of instrument span
12.	Reactor Coolant Flow - Low	90% of loop design flow**	≥ 89.8% of loop design flow

<sup>\*</sup> RTP - Rated Thermal Power

<sup>\*\*</sup> Minimum Measured Flow Per Loop = 1/4 of the RCS flow rate limit as listed in Section 3.2.3.1.a (four loops operating): 1/3 of the RCS flow rate limit as listed in Section 3.2.3.2.a (three loops operating).

# TABLE 2.2-1 (Continued) REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

Eun	actional Unit	Nominal Trip Setpoint	Allowable Value
13.	Steam Generator Water Level - Low-Low	18.1% of narrow range instrument span	≥ 17.8% of narrow range instrument span
14.	General Warning Alarm	N.A.	N.A.
15.	Low Shaft Speed - Reactor Coolant Pumps	92.4% of RNS	≥ 92.2% RN\$
16.	Turbine Trip		
	a. Low Fluid Oil Pressure b. Turbine Stop Valve Closure	500 psig 1% open	Provided by plant
17.	Safety Injection Input from ESF	N.A.	N.A.
18.	Reactor Trip System Interlocks		
	a. Intermediate Range Neutron Flux, P-6	1 x 10 <sup>-10</sup> amps	≥ 9.1 x 10 <sup>-11</sup> Amps
	b. Low Power Reactor Trips Block, P-7		
	1. P-10 input (Note 5) 2. P-13 input	11% of RTP* 10% RTP* Turbine Impulse Pressure Equivalent	≤ 11.6% RTP* ≤ 10.6% RTP*
	c. Power Range Neutron Flux, P-8		
	Four Loops Operating     Three Loops Operating	37.5% of RTP* 37.5% of RTP*	≤ 38.1% RTP* ≤ 38.1% RTP*
	d. Power Range Neutron Flux, P-9	51% of RTP*	≤ 51.6% RTP*
	e. Power Range Neutron Flux, P-10 (Note 6)	9% of RTP	≥ 8.4% RTP*
19.	Reactor Trip Breakers	N.A.	N.A.
20.	Automatic Trip and Interlock Logic	N.A.	N.A.
21.	Three Loop Operation Bypass Circuitry	N.A.	N.A.
	DTD Date of The country		

<sup>\*</sup> RTP - Rated Thermal Power

# TABLE 2.2-1 (Continued) TABLE NOTATION

NOTE 1: OVERTEMPERATURE AT

$$\frac{\Delta T}{\Delta T_0} \frac{(1 + \tau_1 S)}{(1 + \tau_2 S)} \leq \{K_1 - K_2 \frac{(1 + \tau_4 S)}{(1 + \tau_5 S)} (T - T') + K_3 (P - P') - f_1 (\Delta I)\}$$

Where:  $\Delta T$  is measured Reactor Coolant System  $\Delta T$ , °F;

ΔT, is loop specific indicated ΔT at RATED THERMAL POWER, °F;

 $\frac{1+\tau_1 S}{1+\tau_2 S} \quad \text{is the function generated by the Lead-lag compensator on measured $\Delta T$;}$ 

 $\tau_1$ , and  $\tau_2$  are the time constants utilized in the lead-lag compensator for  $\Delta T$ ,  $\tau_1 \ge 8$  secs.,  $\tau_2 \le 3$  secs.

K<sub>1</sub> ≤ 1.20 (Four Loops Operating), ≤ 1.20 (Three Loops Operating);

 $K_2 \ge 0.02456/^{\circ}F$ ;

 $\frac{1+\tau_4~S}{1+\tau_\kappa~S}~~is~the~function~generated~by~the~lead-lag~compensator~for~T_{avg};$ 

 $\tau_4$ , and  $\tau_5$  are the time constants utilized in the lead-lag compensator for  $T_{avg}$ ,  $\tau_4 \ge 20$  secs.,  $\tau_5 \le 4$  secs.

T is measured Reactor Coolant System average temperature, °F;

T' is loop specific indicated T<sub>avo</sub> at RATED THERMAL POWER, ≤ 587.1°F;

K<sub>3</sub> ≥ 0.001311/psi

P is measured pressurizer pressure, psia;

# TABLE 2.2-1 (Continued) TABLE NOTATION (Continued)

NOTE 1: (continued)

P' is nominal pressurizer pressure, ≥ 2250 psia;

S is the Laplace transform operator, sec<sup>-1</sup>;

and  $f_1(\Delta I)$  is a function of the indicated difference between top and bottom detectors of the power range neutron ion chambers; with nominal gains to be selected based on measured instrument response during plant startup tests calibrations such that:

- (1) for q<sub>i</sub> q<sub>b</sub> between -26 percent and +3 percent, f<sub>i</sub>(ΔI) ≥ 0 (where q<sub>i</sub> and q<sub>b</sub> are percent RATED THERMAL POWER in the upper and lower halves of the core, respectively, and q<sub>i</sub> + q<sub>b</sub> is the total THER<sup>f</sup> AL POWER in percent RATED THERMAL POWER;
- (2) for each percent that the magnitude of (q, q<sub>b</sub>) exceeds -26 percent, the ΔT trip setpoint shall be automatically reduced by ≥ 3.55 percent of its value at RATED THERMAL POWER.
- (3) for each percent that the magnitude of (q<sub>t</sub> q<sub>b</sub>) exceeds +3 percent, the ΔT Trip Setpoint shall be automatically reduced by ≥ 1.98 percent of its value at RATED THERMAL POWER.

#### NOTE 2:

The channel's maximum as left trip setpoint shall not exceed its computed Trip Setpoint by more than the following;  $0.4\% \Delta T$  span for the  $\Delta T$  channel,  $0.4\% \Delta T$  span for the Tavg channel,  $0.4\% \Delta T$  span for the Pressurizer Pressure channel and  $0.8\% \Delta T$  span for the f( $\Delta T$ ) channel.

# TABLE 2.2-1 (Continued) TABLE NOTATION (Continued)

NOTE 3: OVERPOWER AT

$$\frac{\Delta T}{\Delta T_0} \frac{(1 + \tau_1 S)}{(1 + \tau_2 S)} \leq \{K_4 - K_5 (\frac{\tau_7 S}{(1 + \tau_7 S)}) T - K_6 [T - T'']\}$$

Where:  $\Delta T$  is measured Reactor Coolant System  $\Delta T$ ,  ${}^{\circ}F$ ;

 $\Delta T_o$  is loop specific indicated  $\Delta T$  at RATED THERMAL POWER, °F;

$$1 + \tau_1 S$$
 is the function generated by the lead-lag compensator on measured  $\Delta T$ ;  $1 + \tau_2 S$ 

 $\tau_1$  and  $\tau_2$  —are the time constants utilized in the lead-lag compensator for  $\Delta T,$   $\tau_1 \geq 8$  sec,  $\tau_2 \leq 3$  sec;

 $K_4 \le 1.09$ ;

 $\rm K_5 \geq 0.02/^{\circ}F$  for increasing  $\rm T_{avg}$  and  $\rm K_5 \leq~0$  for decreasing  $\rm T_{avg};$ 

 $\tau_7$  S is the function generated by the rate-lag compensator for  $T_{avg}$ ;  $1+\tau_7$  S

 $\tau_7$  is the time constant utilized in the rate-lag co. ansator for  $T_{avg}$  ,  $\tau_7 \ge 10$  sec;

T is measured average Reactor Coolant System temperature; °F;

# TABLE 2.2-1 (Continued) TABLE NOTATION (Continued)

#### NOTE 3: (continued)

T" is loop specific indicated T<sub>avg</sub> at RATED THERMAL POWER, ≤ 587.1°F;

 $K_s \ge 0.00180$ /°F when T > T" and  $K_s \le 0$ /°F when T  $\le$  T";

S is the Laplace transform operator, sec1.

NOTE 4: The channel's maximum as left trip setpoint shall not exceed its computed Trip Setpoint by more than 0.4% ΔT span the ΔT channel and 0.4% ΔT span for the Tavg channel.

NOTE 5: Setpoint is for increasing power.

NOTE 6: Setpoint is for decreasing power.

#### BASES

### 2.2.1 REACTOR TRIP SYSTEM INSTRUMENTATION SETPOINTS

The Nominal Trip Setpoints specified in Table 2.2-1 are the nominal values at which the reactor trips are set for each functional unit. The Allowable Values (Nominal Trip Setpoints ± the calibration tolerance) are considered the Limiting Safety System Settings as identified in 10CFR50.36 and have been selected to ensure that the core and Reactor Coolant System are prevented from exceeding their safety limits during normal operation and design basis anticipated operational occurrences and to assist the Engineered Safety Features Actualian System in mitigating the consequences of accidents. The Setpoint for a Reactor Trip System or interlock function is considered to be consistent with the nominal value when the measured "as left" Setpoint is within the administratively controlled (±) calibration tolerance identified in plant procedures (which specifies the difference between the Allowable Value and Nominal Trip Setpoint). Additionally, the Nominal Trip Setpoints may be adjusted in the conservative direction provided the delta between the Nominal Trip Setpoint and the Allowable Value remains unchanged.

Maintenance and Test Equipment accuracy is administratively controlled by plant procedures and is included in the plant uncertainty calculations as defined in WCAP-10991. Operability determinations are based on the use of Maintenance and Test Equipment that conforms with the accuracy used in the plant uncertainty calculation. Maintenance and Test Equipment should be consistent with the requirements of ANSI / ISA 51.1-1979 or the most accurate practicable.

The Allowable Value specified in Table 2.2-1 is the initial value for consideration of channel operability. If the process rack bistable setting is measured within the "as left" calibration tolerance, which specifies the difference between the Allowable Value and Nominal trip Setpoint, then the channel is considered to be operable. Additionally, an administratively controlled limit for operability of a device is determined by device drift being less than the value required for the surveillance interval. In the event the device exceeds the administratively controlled limit, operability of the device may be evaluated by other device performance characteristics, e.g., comparison to historical device drift data, calibration characteristics, response characteristics and short term drift characteristics. A device (RTD, relay, transmitter, process rack module, etc.), whose "as found" value is in excess of the calibration tolerance, but within the operability criteria (administratively controlled limit), is considered operable but must be recalibrated such that the "as left" value is within the two sided (±) calibration tolerance. Plant procedures set administrative limits ("as left" and "as found" criteria) to control the determination of operability by setting minimum standards based on the methodology in WCAP-10991 and the uncertainty values included in the determination of the Nominal Trip Setpoint, and allow the use of other device characteristics to evaluate operability. REPORTABLE EVENTS are identified when the minimum number of channels required to be operable are not met.

#### LIMITING SAFETY SYSTEM SETTINGS

BASES

## 2.2.1 REACTOR TRIP SYSTEM INSTRUMENTATION SETPOINTS (Continued)

The methodology, as defined in WCAP-10991 to derive the Nominal Trip Setpoints, is based upon combining all of the uncertainties in the channels. Inherent in the determination of the Nominal Trip Setpoints are the magnitudes of these channel uncertainties. Sensors and other instrumentation utilized in these channels should be capable of operating within the allowances of these uncertainty magnitudes. Occasional drift in excess of the allowance may be determined to be acceptable based on the other device performance characteristics. Device drift in excess of the allowance that is more than occasional, may be indicative of more serious problems and would warrant further investigation.

The various reactor trip circuits automatically open the reactor trip breakers whenever a condition monitored by the Reactor Trip System reaches a preset or calculated level. In addition to redundant channels and trains, the design approach provides Reactor Trip System functional diversity. The functional capability at the specified trip setting is required for those anticipatory or diverse reactor trips for which no direct credit was assumed in the safety analysis to enhance the overall reliability of the Reactor Trip System. The Reactor Trip System initiates a turbine trip signal whenever reactor trip is initiated. This prevents the reactivity insertion that would otherwise result from excessive Reactor Coolant System cooldown and thus avoids unnecessary actuation of the Engineered Safety Features Actuation System.

#### INSTRUMENTATION

# 3/4.3.2 ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION

#### LIMITING CONDITION FOR OPERATION

3.3.2 The Engineered Safety Features Actuation System (ESFAS) instrumentation channels and interlocks shown in Table 3.3-3 shall be OPERABLE.

APPLICABILITY: As shown in Table 3.3-3.

#### ACTION:

- a. With an ESFAS Instrumentation Channel or Interlock Channel Nominal Trip Setpoint inconsistent with the value shown in the Nominal Trip Setpoint column of Table 3.3-4, adjust the Setpoint consistent with the Nominal Trip Setpoint value.
- b. With an ESFAS Instrumentation Channel or Interlock Channel found to be inoperable declare the channel inoperable and apply the applicable ACTION statement requirements of Table 3.3-3 until the channel is restored to OPERABLE status.

#### INSTRUMENTATION

#### SURVEILLANCE REQUIREMENTS

- 4.3.2.1 Each ESFAS instrumentation channel and interlock and the automatic actuation logic and relays shall be demonstrated OPERARLE by the performance of the ESFAS Instrumentation Surveillance Requirements specified in Table 4.3-2.
- 4.3.2.2 The ENGINEERED SAFETY FEATURES RESPONSE TIME\* of each ESFAS function shall be demonstrated to be within the limit at least once per 24 months. Each test shall include at least one train such that both trains are tested at least once per 48 months and one channel (to include input relays to both trains) per function such that all channels are tested at least once per N times 24 months where N is the total number of redundant channels in a specific ESFAS function as shown in the "Total No. of Channels" column of Table 3.3-3.

# TABLE 3.3-4 ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS

1	Func	tions	al Uni		Nominal Trip Se. oint	Allowable Value
	1.	(Re Isoli Isoli On	acto ation ation by), \$1	njection r Trip, Feedwater , Control Building (Manual Initiation tart Diesel tors, and Service Water)		
		a.	Mai	nual Initiation	N.A.	N.A.
		þ.	Aut	omatic Actuation Logic	N.A.	N.A.
		9.	Cor	ntainment Pressure - High-1	17.7 psia	≤ 17.9 psia
		d.	Pres	ssurizer Pressure - Low		
			1)	Channels I and II Channels III and IV	1892 psia 1892 psia	≥ 1889.6 psia ≥ 1889.6 psia
		е.	Sted	amline Pressure - Low	658.6 psig*	≥ 654.7 psig*
	2.	Co	ntain	ment Spray (CDA)		
		a.	Mai	nual Initiation	N.A.	N.A.
		b.		omatic Actuation Logic Actuation Relays	N.A.	N.A.
		c.	Cor	ntainment Pressure - High-3	22.7 psia	≤ 22.9 psia
3.	3. Containment Isolation					
		a.	Pho	ise "A" Isolation		
			1)	Manual Initiation	N.A.	N.A.
			2)	Automatic Actuation Logic and Actuation Relays	N.A.	N.A.
			3)	Safety Injection	See Item 1 above for all Safety in Setpoints.	njection Trip
		b.	Pho	use "B" Isolation		
			1)	Manual Initiation	N.A.	N.A.
			2)	Automatic Actuation Logic and Actuation Relays	N.A.	N.A.
			3)	Containment Pressure - High-3	22.7 psia	≤ 22.9 psia

# TABLE 3.3-4 (Continued) ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS

Eun	ction	al Unit	Nominal Trip Setpoint	Allowable Value
4.	Ste	am Line Isolation		
	a.	Manual Initiation	N.A.	N.A.
	b.	Automatic Actuation Logic and Actuation Relays	N.A.	N.A.
	c.	Containment Pressure - High-2	17.7 psia	≤ 17.9 psia
	d.	Steamline Pressure - Low	658.6 psig*	≥ 654.7 psig*
	е.	Steam Line Pressure - Negative Rate - High	100 psi/s**	≤ 103.9 psi/s**
5.		oine Trip and Feedwater ation		
	a.	Automatic Actuation Logic Actuation Relays	N.A.	N.A.
	b.	Steam Generator Water Level—High-High (P-14)	80.5 % of narrow range instrument span	≤ 80.8% of narrow range instrument span
	C.	Safety Injection Actuation Logic	See Item 1 above for all Safety Ir Setpoints.	njection Trip
	d.	Tavg Low Coincident with Reactor Trip (P-4)		
		1) Four Loops Operating	564°F	≥ 563.6°F
		2) Three Loops Operating	554°F	≥ 563.6°F
6.	Au	kiliary Feedwater		
	a.	Manual Initiation	N.A.	N.A.
	b.	Automatic Actuation Logic and Actuation Relays	N.A.	N.A.
	c.	Steam Generator Water Level-Low-Low		
		Start Motor-     Driven Pumps	18.1 % of narrow range instrument span	≥ 17.8% of narrow range instrument span

# TABLE 3.3-4 (Continued) ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS

Eun	ction	al Unit	Nominal Trip Setpoint	Allowable Value
6. 1	Auxlie	ary Feedwater (continued)		Alleriable value
	N SAME			
		2) Start Turbine- Driven Pumps	18.1 % of narrow /ange instrument span	≥17.8% of narrow range instrument span
	d.	Safety Injection	See Item 1 above for all Safe Setpoints.	ty Injection Trip
	е.	Loss of Offsite Power Start Motor-Driven Pumps	2800∨	***
	f.	Containment Depressurization Actuation (CDA) Start Motor-Driven Pumps	See Item 2 above for all CDA	Trip Setpoints.
7.	Co	ntrol Building Isolation		
	a. b.	Manual Actuation Manual Safety Injection Actuation	N.A. N.A.	N.A. N.A.
	C.		N.A.	N.A.
	d.	Containment Pressure — High-1	17.7 psia	≤ 17.9 psia
	e.	Control Building Inlet Ventilation Radiation	1.5 x 10 <sup>-5</sup> µci/cc	***
8.	Los	s of Power		
	a.	4 kV Bus Undervoltage (Loss of Voltage)	***	***
	b.	4 kV Bus Undervoltuge (Grid Degraded Voltage)	***	***
9.	Eng	gineured Safety Features tuation System Interlocks		
		Pressurizer Pressure, P-11 Low-Low Tavg, P-12 Reactor Trip, P-4	1999.7 psia 553°F N.A.	≤ 2002.1 psia ≥ 552.6°F N.A.
10.		ergency Generator Load quencer	N.A.	N.A.

#### TABLE 3.3-4 (Continued)

#### TOTAL NOTATIONS

- \* Time constants utilized in the lead-lag controller for Steam Line Pressure-Low are  $\tau_1 \geq 50$  seconds and  $\tau_2 \leq 5$  seconds. CHANNEL CALIBRATION shall ensure that these time constants are adjusted to these values.
- \*\* The time constant utilized in the rate-lag controller for Steam Line Pressure Negative Rate High is greater than or equal to 50 seconds. CHANNEL CALIBRATION shall ensure that this time constant is adjusted to this value.
- To be provided by plant.

BASES

# 3/4.3.1 and 3/4.3.2 REACTOR TRIP SYSTEM INSTRUMENTATION AND ENGINEERED SAFETY FEATURES ACTUATION 3YSTEM INSTRUMENTATION

The OPERABILITY of the Reactor Trip System and the Engineered Safety Features Actuation System instrumentation and interlocks ensures that: (1) the associated action and/or Reactor trip will be initiated when the parameter monitored by each channel or combination thereof reaches its setpoint, (2) the specified coincidence logic is maintained, (3) sufficient redundancy is maintained to permit a channel to be out of service for testing or maintenance, and (4) sufficient system functional capability is available from diverse parameters.

The OPERABILITY of these systems is required to provide the overall reliability, redundancy, and diversity assumed available in the facility design for the protection and mitigation of accident and transient conditions. The integrated operation of each of these systems is consistent with the assumptions used in the safety analyses. The Surveillance Pequirements specified for these systems ensure that the overall system functional capability is maintained comparable to the original design standards. The periodic surveillance tests performed at the minimum frequencies are sufficient to demonstrate this capability.

The Engineered Safety Features Actuation System Nominal Trip Setpoints specified in Table 3.3-4 are the nominal values at which the bistables are set for each functional unit. The Allowable Values (Nominal Trip Setpoints ± the calibration tolerance) are considered the Limiting Safety System Settings as identified in 10CFR50.36 and have been selected to mitigate the consequences of accidents. A Setpoint is considered to be consistent with the nominal value when the measured "as left" Setpoint is within the administratively controlled (±) calibration tolerance identified in plant procedures (which specifies the difference between the Allowable Value and Nominal Trip Setpoint). Additionally, the Nominal Trip Setpoints may be adjusted in the conservative direction provided the delta between the Nominal Trip Setpoint and the Allowable Value remains unchanged.

Maintenance and Test Equipment accuracy is administratively controlled by plant procedures and is included in the plant uncertainty calculations as defined in WCAP-10991. Operability determinations are based on the use of Maintenance and Test Equipment that conforms with the accuracy used in the plant uncertainty calculation. Maintenance and Test Equipment should be consistent with the requirements of ANSI / ISA 51.1-1979 or the most accurate practicable.

The Allowable Value specified in Table 3.3-4 is the initial value for consideration of channel operability. If the process rack bistable setting is measured within the "as left" calibration tolerance, which specifies the difference between the Allowable Value and Nominal Trip Setpoint, then the channel is considered to be operable. Additionally, an administratively controlled limit for operability of a device is

BASES

3/4.3.1 and 3/4.3.2 REACTOR TRIP SYSTEM INSTRUMENTATION AND ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION (continued)

determined by device drift being less than the value required for the surveillance interval. In the event the device exceeds the administratively controlled limit, operability of the device may be evaluated by other device performance characteristics, e.g., comparison to historical device drift data, calibration characteristics, response characteristics and short term drift characteristics. A device (RTD, relay, transmitter, process rack module, etc.), whose "as found" value is in excess of the calibration tolerance, but within the operability criteria (administratively controlled limit), is considered operable but must be recalibrated such that the "as left" value is within the two sided (±) calibration tolerance. Plant procedures set administrative limits ("as left" and "as found" criteria) to control the determination of operability by setting minimum standards based on the methodology in WCAP-10991 and the uncertainty values included in the determination of the Nominal Trip Setpoint, and allow the use of other device characteristics to evaluate operability. REPORTABLE EVENTS are identified when the minimum number of channels required to be operable are not met.

The methodology, as defined in WCAP-10991 to derive the Nominal Trip Setpoints, is based upon combining all of the uncertainties in the channels. Inherent in the determination of the Nominal Trip Setpoints are the magnitudes of these channel uncertainties. Sensors and other instrumentation utilized in these channels should be capable of operating within the allowances of these uncertainty magnitudes. Occasional drift in excess of the allowance may be determined to be acceptable based on the other device performance characteristics. Device drift in excess of the allowance that is more than occasional, may be indicative of more serious problems and would warrant further investigation.