

CORRECTED PAGE
UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-295
UNIT NAME Zion Unit 1
DATE 8/14/97
COMPLETED BY J. CYGAN
TELEPHONE (847) 746-2084 x3169

REPORT MONTH March 1996

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down ³ Reactor	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
1	3/1/96	S	383.3	B	1				Unit 1 Went Off-Line On 2/19/96 At 0212 For Loose Parts Indication In The 1B S/G (ZIM05). Unit 1 Went Back On Line 3/16/96 At 2215.
2	3/16/96	F	137.3	A	3	*LER#96-010	FW	XCV	Unit 1 Auto Tripped On 1C S/G Level Hi Hi At 2256 on 3/16/96. (1F19) Rx Power Was At Approximately 20%.

*On the original page the LER was reported as LER#96-009. The number was changed subsequent to issuance of report.

1

F: Forced
S: Scheduled

2

Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & Licensee Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3

Method
1-Manual
2-Manual Trip
3-Auto Trip
4-Continued
5-Reduced Load

4

Exhibit G - Instructions
for Preparation of Data
Entry Sheets for Licensee
Event Report (LER) File
(NUREG-0161)

5

Exhibit 1 - Same Source

9708220182 970814
PDR ADOCK 05000295
R PDR