

April 29, 1998

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Section P1-137
Washington, D.C. 20555-0001

Gentlemen:

ULNRC - 03823



DOCKET NUMBER 50-483
UNION ELECTRIC COMPANY
CALLAWAY PLANT
AMENDMENT NUMBER 124

This is to inform the Commission of the implementation of Amendment 124 to the Callaway Facility Operating License NPF-30. Amendment 124 modifies the plant heatup and cooldown curves and the maximum allowable power operated relief valve setpoints for cold overpressure protection. The Commission had previously approved an exemption from the requirements of 10 CFR 50.60 that allowed the application of ASME Code Case N-514 in developing the cold overpressure mitigation system setpoints.

The changes have been issued to controlled Technical Specification holders and became effective April 2, 1998.

Very truly yours,

A handwritten signature in cursive script, reading "Alan C. Passwater".

Alan C. Passwater
Manager, Licensing & Fuels

DES/mlo

9805050279 980429
PDR ADOCK 05000483
P PDR

1/0
A001

cc: M. H. Fletcher
Professional Nuclear Consulting, Inc.
19041 Raines Drive
Derwood, MD 20855-2432

Regional Administrator
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive
Suite 400
Arlington, TX 76011-8064

Senior Resident Inspector
Callaway Resident Office
U.S. Nuclear Regulatory Commission
8201 NRC Road
Steedman, MO 65077

Kristine M. Thomas (2)
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
1 White Flint, North, Mail Stop 13E16
11555 Rockville Pike
Rockville, MD 20852-2738

Manager, Electric Department
Missouri Public Service Commission
P.O. Box 360
Jefferson City, MO 65102

Ron Kucera
Department of Natural Resources
P.O. Box 176
Jefferson City, MO 65102

Denny Buschbaum
TU Electric
P.O. Box 1002
Glen Rose, TX 76043

Pat Nugent
Pacific Gas & Electric
Regulatory Services
P.O. Box 56
Avila Beach, CA 93424