

FNP Unit 1
Technical Specifications
Power Uprate Implementation

Changed Page

Unit 1

Page 6-19a

Revision

New Page
(Replace TS Page 6-19a
In February 12, 1998 Submittal)

ADMINISTRATIVE CONTROLS

2. WCAP-10216-P-A, Rev. 1A, "Relaxation Of Constant Axial Offset Control / F_Q Surveillance Technical Specification," February 1994 (W Proprietary).

(Methodology for Specifications 3.2.1 - Axial Flux Difference and 3.2.2 - Heat Flux Hot Channel Factor.)

- 3a. WCAP-12945-P-A, Volume 1, Revision 2, and Volumes 2 through 5, Revision 1, "Code Qualification Document for Best Estimate LOCA Analysis," March 1998 (W Proprietary).

- 3b. WCAP-12610-P-A, "VANTAGE+ Fuel Assembly Reference Core Report," April 1995 (W Proprietary).

(Methodology for Specification 3.2.2 - Heat Flux Hot Channel Factor.)

The core operating limits shall be determined so that all applicable limits (e.g., fuel thermal-mechanical limits, core thermal-hydraulic limits, ECCS limits, nuclear limits such as shutdown margin, and transient and accident analysis limits) of the safety analysis are met.

The CORE OPERATING LIMITS REPORT, including any mid-cycle revisions or supplements thereto, shall be provided upon issuance, for each reload cycle, to the NRC Document Control Desk with copies to the Regional Administrator and Resident Inspector.

ANNUAL DIESEL GENERATOR RELIABILITY DATA REPORT

6.9.1.12 The number of tests (valid or invalid) and the number of failures to start on demand for each diesel generator shall be submitted to the NRC annually. This report shall contain the information identified in Regulatory Position C.3.b of NRC Regulatory Guide 1.108, Revision 1, 1977.

ADMINISTRATIVE CONTROLS

2. WCAP-10216-P-A, Rev. 1A, "Relaxation Of Constant Axial Offset Control / P_Q Surveillance Technical Specification," February 1994 (W Proprietary).

(Methodology for Specifications 3.2.1 - Axial Flux Difference and 3.2.2 - Heat Flux Hot Channel Factor.)

3. ~~WCAP-10266-P-A, Rev. 2, "The 1981 Version Of Westinghouse Evaluation Model Using BASH Code," March 1987 (W Proprietary).~~

(Methodology for Specification 3.2.2 - Heat Flux Hot Channel Factor.)

The core operating limits shall be determined so that all applicable limits (e.g., fuel thermal-mechanical limits, core thermal-hydraulic limits, ECCS limits, nuclear limits such as shutdown margin, and transient and accident analysis limits) of the safety analysis are met.

The CORE OPERATING LIMITS REPORT, including any mid-cycle revisions or supplements thereto, shall be provided upon issuance, for each reload cycle, to the NRC Document Control Desk with copies to the Regional Administrator and Resident Inspector.

ANNUAL DIESEL GENERATOR RELIABILITY DATA REPORT

6.9.1.12 The number of tests (valid or invalid) and the number of failures to start on demand for each diesel generator shall be submitted to the NRC annually. This report shall contain the information identified in Regulatory Position C.3.b of NRC Regulatory Guide 1.108, Revision 1, 1977.

, Volume 1, Revision 2, and Volumes 2 through 5, Revision 1,

Insert A to pg 6.19a

- 3a. ~~WCAP-12945-P, Vol. I-II, 1992-1993, "Code Qualification Document for Best Estimate LOCA Analysis," (W Proprietary)@~~ March 1998

- 3b. ~~Letter, N. J. Liparulo, (W) to R. C. Jones, (USNRC), "Revision to Westinghouse Uncertainty Methodology", NTD-NRC-95-4575, Oct. 15, 1995.~~ March 1998

- 3c. ~~Letter, R. C. Jones (USNRC) to N. J. Liparulo (W), "Acceptance for Referencing of the Topical Report, WCAP-12945(P), Westinghouse Code Qualification Document for Best Estimate Loss of Coolant Analysis", June 28, 1996.~~ March 1998

- 3d. WCAP-12610-P-A, "VANTAGE+ Fuel Assembly Reference Core Report," April 1995 (W Proprietary).

March 1998

FNP Unit 2
Technical Specifications
Power Uprate Implementation

Changed Page

Unit 2

Page 6-19a

Revision

New Page
(Replace TS Page 6-19a
In February 12, 1998 Submittal)

ADMINISTRATIVE CONTROLS

2. WCAP-10216-P-A, Rev. 1A, "Relaxation Of Constant Axial Offset Control / FQ Surveillance Technical Specification," February 1994 (W Proprietary).
(Methodology for Specifications 3.2.1 - Axial Flux Difference and 3.2.2 - Heat Flux Hot Channel Factor.)

3. ~~WCAP-10266-P-A, Rev. 2, "The 1991 Version Of Westinghouse Evaluation Model Using BASH Code," March 1987 (W Proprietary).~~

(Methodology for Specification 3.2.2 - Heat Flux Hot Channel Factor.)

The core operating limits shall be determined so that all applicable limits (e.g., fuel thermal-mechanical limits, core thermal-hydraulic limits, ECCS limits, nuclear limits such as shutdown margin, and transient and accident analysis limits) of the safety analysis are met.

The CORE OPERATING LIMITS REPORT, including any mid-cycle revisions or supplements thereto, shall be provided upon issuance, for each reload cycle, to the NRC Document Control Desk with copies to the Regional Administrator and Resident Inspector.

ANNUAL DIESEL GENERATOR RELIABILITY DATA REPORT

6.9.1.12 The number of tests (valid or invalid) and the number of failures to start on demand for each diesel generator shall be submitted to the NRC annually. This report shall contain the information identified in Regulatory Position C.3.b of NRC Regulatory Guide 1.108, Revision 1, 1977.

Insert A to pg 6.19a

~~Volume 1, Revision 2, and Volumes 2 through 5, Revision 1,~~

March 1998

- 3a. WCAP-12945-P, ~~Vol. I-B, 1992-1993, "Code Qualification Document for Best Estimate LOCA Analysis,"~~ (W Proprietary) ~~March 1998~~

- 3b. ~~Letter, N. J. Liparulo, (W) to R. C. Jones, (USNRC), "Revision to Westinghouse Uncertainty Methodology", NTD NRC 95-4575, Oct. 15, 1995.~~

March 1998

- 3c. ~~Letter, R. C. Jones (USNRC) to N. J. Liparulo (W), "Acceptance for Referencing of the Topical Report, WCAP-12945(P), Westinghouse Code Qualification Document for Best Estimate Loss of Coolant Analysis", June 28, 1996.~~

March 1998

- 3d. WCAP-12610-P-A, "VANTAGE+ Fuel Assembly Reference Core Report," April 1995 (W Proprietary).

March 1998

ADMINISTRATIVE CONTROLS

2. WCAP-10216-P-A, Rev. 1A, "Relaxation Of Constant Axial Offset Control / FQ Surveillance Technical Specification," February 1994 (W Proprietary).

(Methodology for Specifications 3.2.1 - Axial Flux Difference and 3.2.2 - Heat Flux Hot Channel Factor.)

- 3a. WCAP-12945-P-A, Volume 1, Revision 2, and Volumes 2 through 5, Revision 1, "Code Qualification Document for Best Estimate LOCA Analysis," March 1998 (W Proprietary).

- 3b. WCAP-12610-P-A, "VANTAGE+ Fuel Assembly Reference Core Report," April 1995 (W Proprietary).

(Methodology for Specification 3.2.2 - Heat Flux Hot Channel Factor.)

The core operating limits shall be determined so that all applicable limits (e.g., fuel thermal-mechanical limits, core thermal-hydraulic limits, ECCS limits, nuclear limits such as shutdown margin, and transient and accident analysis limits) of the safety analysis are met.

The CORE OPERATING LIMITS REPORT, including any mid-cycle revisions or supplements thereto, shall be provided upon issuance, for each reload cycle, to the NRC Document Control Desk with copies to the Regional Administrator and Resident Inspector.

ANNUAL DIESEL GENERATOR RELIABILITY DATA REPORT

6.9.1.12 The number of tests (valid or invalid) and the number of failures to start on demand for each diesel generator shall be submitted to the NRC annually. This report shall contain the information identified in Regulatory Position C.3.b of NRC Regulatory Guide 1.108, Revision 1, 1977.