



Post-It™ brand fax transmittal memo 7671 # of pages = 7

To	NRC Operations Center	From	R.S. Frantz
Co.		Co.	Illinois Power Co.
Dept.		Phone	217-935-8881
Fax	301-816-5151	Fax	

Illinois Power Company
 Clinton Power Station
 P.O. Box 678
 Clinton, IL 61727
 Tel 217 935-6220
 Fax 217 935-4632

Wayne D. Romberg
 Assistant Vice President - Nuclear

U-602818

2C.220

4F.190

August 25, 1997

32815

Docket No. 50-461

10CFR50.73

10CFR21.21

Document Control Desk
 Nuclear Regulatory Commission
 Washington, D.C. 20555

Subject: Clinton Power Station - Unit 1
 Licensee Event Report No. 97-021-00
 and 10CFR Part 21 Report No. 21-97-040

Dear Madam or Sir:

Enclosed is Licensee Event Report (LER) No. 97-021-00 and 10CFR, Part 21 Report No. 21-97-040: Control Circuit for Division 1 Emergency Diesel Generator Feed Breaker Does Not Meet Design Basis Due to Design Error and Could Prevent Power for Division 1 Safe Shutdown Equipment During a Main Control Room Fire with Loss of Offsite Power. This report is being submitted in accordance with the requirements of 10CFR50.73 and 10CFR21.21.

Sincerely yours,

Wayne D. Romberg
 Assistant Vice President

9709040301 970825
 PDR ADOCK 05000461
 S PDR

IE2811

RSF/krk

Enclosure

000098

cc: NRC Clinton Licensing Project Manager
 NRC Resident Office, V-690
 Regional Administrator, Region III, USNRC
 G. C. Wright, Region III, USNRC
 Illinois Department of Nuclear Safety
 INPO Records Center
 Sargent & Lundy

